

APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** OSP - 0478 - 10 **APPLICATION #: OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** Manufacturer: Russell Sigler Inc. Manufacturer's Technical Representative: Raul Mangiliman Mailing Address: 229 Littlefield Avenue, Suite 4, South San Francisco, CA 94080 Email: rmangiliman@siglers.com Telephone: 415.330.6624 **Product Information** Product Name: 16TJ Absorption Chiller Product Type: Chiller Product Model Number: TSA-16TJ-12E-SF (List all unique product identification numbers and/or part numbers) General Description: Single-effect steam-fired absorption chiller. Mounting Description: Base mounted – neoprene pads **Applicant Information** Applicant Company Name: TRU Compliance, LLC Contact Person: Derek J. Manwill, S.E. Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702 Email: dmanwill@trucompliance.com Telephone: 844.878.0200 I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 09/07/2016 Company Name: TRU Compliance, LLC Title: Vice President

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





OFFICE USE ONLY



Page 2 of 5

09/14/2016 OSP-0478-10



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters								
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No								
Design Basis of Equipment or Components (F _p /W _p) = 0.78								
S _{DS} (Design spectral response acceleration at short period, g) = 1.3								
a _p (In-structure equipment or component amplification factor) = 2.5								
R _p (Equipment or component response modification factor) =2.5								
Ω_0 (System overstrength factor) = 2								
I _p (Importance factor) = 1.5								
z/h (Height factor ratio) =0								
Equipment or Component Natural Frequencies (Hz) = See UUT1 Summary Sheet in Attachment								
Overall dimensions and weight (or range thereof) = See Attachments								
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No								
Design Basis of Equipment or Components (V/W) =								
S _{DS} (Design spectral response acceleration at short period, g) =								
S _{D1} (Design spectral response acceleration at 1 second period, g) =								
R (Response modification coefficient) =								
Ω_0 (System overstrength factor) =								
C _d (Deflection amplification factor) =								
I _p (Importance factor) = 1.5								
Height to Center of Gravity above base =								
Equipment or Component Natural Frequencies (Hz) =								
Overall dimensions and weight (or range thereof) =								
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No								
List of Attachments Supporting Special Seismic Certification								
☐ Test Report(s) ☐ Drawings ☐ Calculations ☐ Manufacturer's Catalog								
Other(s) (Please Specify): Attachment A								
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022								
Signature: Date: 9/14/2016								
Signature: Date: 9/14/2016 Print Name: M. R. Karim Title: SHFR								
Special Seismic Certification Valid Up to : $S_{DS}(g) = 1.3$ $z/h = 0.0$								
Condition of Approval (if applicable):								

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"



OSHPD

Page 3 of 3

Page 3 of 5

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX





Manufacturer: Model Line:	Russell Sigler Inc. 16TJ						TABLE 1				
Certified Product Construction Summary: Carbon steel construction.											
Certified Options Summary: No certified options or accessories. Single configuration only.											
Mounting Configuration Base mounted - isolate Note: Installed mounting cor	d (neoprene pads)	configuration	n and equiva	lent strength	and stiffness t	to those test	red.				
Building Code: CBC 2016		Seismic C	ertificatio	on Limits:	$S_{DS} = 1.3 g$ $z/h=0.0$ $I_P = 1.5$						
Model Line	Model	Dir Depth	mensions (Width	(in) Height	Weight (lb)		Notes	UUT	Γ		
16TJ	TSA-16TJ-12E-SF	102	51	86	8880			1			

TRU Compliance, LLC - A Tobolski Watkins Affiliate 844.TRU.0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHFFT

TRU PROJECT NO. 16030



UUT 1

Manufacturer: Russell Sigler Inc.

Model Line: 16TJ

Model Number: TSA-16TJ-12E-SF Serial Number: 81787797

Product Construction Summary:

Carbon steel construction.


Options/Subcomponent Summary:

No certified options or accessories other than specific unit configuration.

UUT Properties											
Weight	Dimension (in)				Lowest Natural Frequency (Hz)						
(lb)	Depth	Width	Height		Front-Back		Side	e-Side Ver		tical	
8880	102	51	86		5.8		9.6		6.2		
UUT Highest Passed Seismic Run Information											
Building Code		Test Criteria		S _{DS} (g)	z/h	Ι _Ρ	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016		ICC-ES AC156		1.3	0.0	1.5	1.30	0.52	0.87	0.35	

Test Mounting Details:







Base mounted on (4) 12x16x3/8" A36 steel plates with 22" of 3/16" fillet weld each. Base plates and channel are fully supported by Vibrex ISOCUBE 3/4" thick neoprene pads. Base plates are anchored using (4) 3/4" Grade 8 bolts each.

Unit maintained structural integrity and remained functional per manufacturer requirement.

Contents were included in testing per operating conditions.