



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: **OSP – 0485 – 10**

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Purcell Systems, Inc.

Manufacturer's Technical Representative: Marcel Vezeau

Mailing Address: 16125 E. Euclid Avenue, Spokane, WA 99216

Telephone: 509.720.5510 Email: mvezeau@purcellsystems.com

**Product Information**

Product Name: VaultFlex Outdoor UPS Battery Enclosure

Product Type: UPS Battery Enclosure

Product Model Number: See Attachment

(List all unique product identification numbers and/or part numbers)

General Description: Outdoor UPS Battery Enclosure

Mounting Description: Rigid floor mounted with and without optional carbon steel plinth.

**Applicant Information**

Applicant Company Name: TRU Compliance, LLC

Contact Person: Matthew J Tobolski, PhD, S.E.

Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702


Telephone: 844.878.0200 Email: mtobolski@trucompliance.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 10/13/2016

Title: President Company Name: TRU Compliance, LLC

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: TRU Compliance, LLC  
Name: Matthew J Tobolski, PhD, S.E. California License Number: S5648  
Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702  
Telephone: 844.878.0200 Email: mtobolski@trucompliance.com

**Supports and Attachments Preapproval**


- Supports and attachments are preapproved under OPM-  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: Environmental Testing Laboratory (ETL)  
Contact Name: Paul E. Little  
Mailing Address: 11034 Indian Trail, Dallas, TX 75229  
Telephone: 972.247.9657 Email: paul@etldallas.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.44 ( $S_{DS} = 2.0g$ ); 1.44 ( $S_{DS} = 3.2g$ )

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.0g ( $z/h = 1.0$ ); 3.2g ( $z/h = 0.0$ )

$a_p$  (In-structure equipment or component amplification factor) = 1.0

$R_p$  (Equipment or component response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0 ( $S_{DS} = 2.0g$ ); 0.0 ( $S_{DS} = 3.2g$ )

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

R (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2015:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): Attachment

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**


Signature:  Date: January 26, 2017

Print Name: ALI SUMER Title: DSE

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = See Above  $z/h$  = See Above

Condition of Approval (if applicable): \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_





SPECIAL SEISMIC CERTIFICATION  
 MODEL LINE NUMBERING - FOR REFERENCE ONLY

TRU PROJECT NO. 16007



<i>Manufacturer:</i> Purcell Systems, Inc.		TABLE 1
<i>Model Line:</i> VaultFlex Outdoor UPS Battery Enclosure		
Options: The options below follow the Base Model Number "VFX42-6534-UPS-".		
Columns 1 - 3	Bus Voltage	480 = 480 VDC
		384 = 384 VDC
Column 4	Battery Model	0 = 12XE1010F-FR
		1 = 12XE1110F-FR
		2 = 12XE1150F-FR
Column 5	Center Tap Option	N = No Center Tap
		C = Center Tap
Columns 6 - 8	Breaker Size	600 = 600 Amp
		500 = 500 Amp
		400 = 400 Amp
Column 9	Aux Contacts	A = No option installed
		B = Dual Aux
		C = Alarm
		D = Dual Aux + Alarm
Column 10	Breaker Option	A = No option installed
		B = 24 VDC Shunt
		C = 48 VDC Shunt
		D = 24 UVR
		E = 48 UVR
		F = 250 VDC Shunt
Column 11	Plinth Option	0 = No Plinth
		1 = Galvanized steel plinth
Column 12	Thermal Option	A = 48 VDC ACU & Heater

SPECIAL SEISMIC CERTIFICATION  
 CERTIFIED SUBCOMPONENT MATRIX



TRU PROJECT NO. 16007

<i>Manufacturer:</i>	Purcell Systems, Inc.	<i>Table Description:</i>	Batteries	TABLE 2
<i>Model Line:</i>	VaultFlex Outdoor UPS Battery Enclosure			

<i>Building Code:</i> CBC 2016	<i>Seismic Certification Limits:</i>	$S_{DS} = 2.0g$ $z/h = 1.0$ $S_{DS} = 3.2g$ $z/h = 0.0$	$I_P = 1.5$
--------------------------------	--------------------------------------	--	-------------

Model Line (Manufacturer)	Model	Dimension (in)			Weight (lb)	Material	Notes	UUT
		Depth	Width	Height				
DataSafe (EnerSys)	12XE1010F-FR	22.1	4.9	11.1	107.3	Lead-acid	<i>UUT: quantity (32) installed</i>	1
	12XE1110F-FR	22.1	4.9	11.1	114.0	Lead-acid		Interp.
	12XE1150F-FR	22.1	4.9	12.4	129.2	Lead-acid	<i>UUT: quantity (40) installed</i>	2



# UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 16007



<b>Manufacturer:</b> Purcell Systems, Inc.	<b>UUT 1</b>
<b>Model Line:</b> VaultFlex Outdoor UPS Battery Enclosure	
<b>Model Number:</b> VFX42-6534-UPS-3840N400AB0A <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
Cabinet: 0.080" aluminum with 1.5" foil backed insulation; Battery Rack: 0.120" carbon steel.

**Options/Subcomponent Summary:**  
(32) 12XE1010F-FR batteries; 550W, 60VDC Heating assembly; 3.8A, R 134A Active Cooling Assembly; 400A, 600 VDC breaker; 450A, 600 VDC breaker; 54 V Power supply; corrosion inhibiting pad gasket

### UUT Properties

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
4567	34	65	75	9	10	24.7

### UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S <sub>DS</sub>	z/h	I <sub>P</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
CBC 2016	ICC-ES AC156	2.0g	1.0	1.5	3.2	2.4	2.13	0.85
		3.2g	0.0					

### Test Mounting Details:



The UUT was rigid floor mounted to the table using eight (8) 5/8" Grade 8 Bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement.  
Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 16007



<i>Manufacturer:</i> Purcell Systems, Inc.	<b>UUT 2</b>
<i>Model Line:</i> VaultFlex Outdoor UPS Battery Enclosure	
<i>Model Number:</i> VFX42-6534-UPS-4802C600DF1A <i>Serial Number:</i> N/A	

*Product Construction Summary:*  
Cabinet: 0.080" aluminum with 1.5" foil backed insulation; Battery Rack: 0.120" carbon steel.

*Options/Subcomponent Summary:*  
(40) 12XE1150F-FR batteries; 550W, 60VDC Heating assembly; 3.8A, R 134A Active Cooling Assembly; 600A, 600 VDC Shunt trip breaker; 54 V Power supply; carbon steel plinth

*UUT Properties*

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
6452	34	65	75	6.7	8.3	22.4

*UUT Highest Passed Seismic Run Information*

Building Code	Test Criteria	S <sub>DS</sub>	z/h	I <sub>P</sub>	A <sub>FLX-H</sub>	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	A <sub>RIG-V</sub>
CBC 2016	ICC-ES AC156	2.0g	1.0	1.5	3.2	2.4	2.13	0.85
		3.2g	0.0					

*Test Mounting Details:*



The UUT was rigid mounded to the plinth using eight (8) 5/8" Grade 8 Bolts. The plinth was rigid floor mounted to the table using eight (8) 5/8" Grade 8 Bolts.  
Unit maintained structural integrity and remained functional per manufacturer requirement.  
Contents were included in testing per operating conditions.