



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0486**

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Eaton Corporation

Manufacturer's Technical Representative: Mario Perciballi

Mailing Address: 3301 Spring Forest Rd, Raleigh, NC 27616

Telephone: (919) 878-1071

Email: MarioAPerciballi@Eaton.com

**Product Information**

Product Name: UPS and Batteries

Product Type: UPS

Product Model Number: 9155 UPS, 9355 UPS, 9355 Options Cabinet, 9X55 Battery Cabinet

General Description: Backup power systems constructed of formed carbon steel framing and cabinets with capacity Ranging from 8 – 30 kVA. UL924 option.

Mounting Description: Rigid, Floor Mounted

Tested Seismic Enhancements: None

**Applicant Information**

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.


Contact Person: Galen Reid

Mailing Address: 233 SW Wilson Ave., Suite 101, Bend, OR 97702

Telephone: (541) 604-7225

Email: greid@structint.com

Title: Director, TRU Compliance





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**


Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.  
Name: Andrew Coughlin California License Number: S6082  
Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 95138-1025  
Telephone: (415) 635-8461 Email: acoughlin@structint.com

**Certification Method**

GR-63-Core       ICC-ES AC156       IEEE 344       IEEE 693       NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: NATIONAL TECHNICAL SYSTEMS (NTS)  
Contact Person: Robert Bridges  
Mailing Address: 7800 Highway 20 West, Huntsville AL 35806  
Telephone: (256) 837-4411 Email: Robert.Bridges@nts.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.33

SDS (Design spectral response acceleration at short period, g) = 1.85 (z/h = 1); 2.96 (z/h = 0)

$a_p$  (Amplification factor) = 1.0

$R_p$  (Response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment


**HCAI Approval (For Office Use Only) - Approval Expires on 11/22/2028**

Date: 11/22/2022

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = See Above z/h = See Above

Condition of Approval (if applicable): DATE: 11/22/2022



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>TABLE 1</b>
<b>Model Line:</b> 9X55 UPS and Accessories	

**Certified Product Construction Summary:**  
Formed carbon steel internal framing with carbon steep panelized walls, base and roof.

**Certified Options Summary:**  
See Certified Subcomponent Matrices

**Mounting Configuration:**  
Base mounted - rigid  
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code: CBC 2022**      **Seismic Certification Limits:**       $S_{DS} = 1.85 g$      $z/h = 1.0$        $I_p = 1.5$   
 $S_{DS} = 2.96 g$      $z/h = 0.0$

Model Line	Model <sup>1</sup>	Dimensions (in) <sup>2</sup>			Weight (lb) <sup>2</sup>	Notes	UUT
		Depth	Width	Height			
9155 (2-HIGH) UPS w/ 32 Battery	K408X1X0XXX0X0	33.7	12.0	32.2	459	8 kVA	Extrap.
	K410X1X0XXX0X0	33.7	12.0	32.2	459	10 kVA	Extrap.
	K421X1X0XXX0X0	33.7	12.0	32.2	459	12 kVA	Interp.
	G410110000	33.7	12.0	32.2	459	12 kVA (9155-10GE)	16
	K415X1X0XXX0X0	33.7	12.0	32.2	459	15 kVA	Interp.
9155 (3-HIGH) UPS w/ 64 Battery	K408X2X0XXX0X0	33.7	12.0	47.8	736	8 kVA	Interp.
	K410X2X0XXX0X0	33.7	12.0	47.8	736	10 kVA	Interp.
	K412X2X0XXX0X0	33.7	12.0	47.8	736	12 kVA	Interp.
	K415X2X0XXX0X0	33.7	12.0	47.8	736	15 kVA	Interp.
9155 (3-HIGH) UPS w/ 32 Battery w/ Trans. Mod.	K408X3X0XXX0X0	33.7	12.0	47.8	736	8 kVA	Interp.
	K410X3X0XXX0X0	33.7	12.0	47.8	736	10kVA	Interp.
	K412X3X0XXX0X0	33.7	12.0	47.8	736	12 kVA	Interp.
	K415X3X0XXX0X0	33.7	12.0	47.8	736	15 kVA	Interp.
9155 (3-HIGH) UL 924 1PH UPS	BH-08KEL277-100	33.7	12.0	47.8	736	7.2 kVA	Interp.
	BH-10KEL277-10	33.7	12.0	47.8	736	9 kVA	Interp.

**Notes:**  
1. "X" Indicates selection digit not critical to seismic performance; see nomenclature description  
2. Maximum dimensions without seismic mounting kit, maximum weight includes seismic mounting kit.

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>TABLE 2</b>
<b>Model Line:</b> 9X55 UPS and Accessories	

**Certified Product Construction Summary:**  
Formed carbon steel internal framing with carbon steep panelized walls, base and roof.

**Certified Options Summary:**  
See Certified Subcomponent Matrices

**Mounting Configuration:**  
Base mounted - rigid  
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code: CBC 2022**      **Seismic Certification Limits:**       $S_{DS} = 1.85 g$      $z/h = 1.0$        $I_p = 1.5$   
 $S_{DS} = 2.96 g$      $z/h = 0.0$

Model Line	Model <sup>1</sup>	Dimensions (in) <sup>2</sup>			Weight (lb) <sup>2</sup>	Notes	UUT
		Depth	Width	Height			
9355 (2-HIGH) UPS w/ 32 Battery	KA10X1X0XXXXX0X0	33.7	12.0	32.2	480	10 kVA	Extrap.
	KA15X1X0XXXXX0X0	33.7	12.0	32.2	480	15 kVA	Interp.
	KA1511100000010	33.7	12.0	32.2	480	15 kVA	1
9355 (3-HIGH) UPS w/ 64 Battery	KA10X2X0XXXXX0X0	33.7	12.0	47.8	755	10 kVA	Extrap.
	KA15X2X0XXXXX0X0	33.7	12.0	47.8	755	15 kVA	Interp.
	P-103000337	33.7	12.0	47.8	755	15 kVA	Interp.
	103006185	33.7	12.0	47.8	755	15 kVA (9355-15-14GE)	17
9355 (3-HIGH) UL 924 3PH UPS	BH-10KEL2083P-100	33.7	12.0	47.8	755	8.5 kVA 208V	Extrap.
	BH-15KEL2083P-100	33.7	12.0	47.8	755	13.1 kVA 208V	Interp.
9355 (3-HIGH) UPS w/ 32 Battery w/ Trans. Mod.	KA10X3X0XXXXX0X0	33.7	12.0	47.8	755	10 kVA	Extrap.
	KA15X3X0XXXXX0X0	33.7	12.0	47.8	755	15 kVA	Interp.
	KA1513400000010	33.7	12.0	47.8	755	15 kVA	2
9355 (20-30 kVA)	KB20XXX0XXXXXXX	34.1	20.0	67.0	1,155	20 kVA	Interp.
	KB30XXX0XXXXXXX	34.1	20.0	67.0	1,155	30 kVA	Interp.
	KB3013100000010	34.1	20.0	67.0	1,155	30 kVA	4
9355 (20-30 kVA) Options Cabinet	KBT0X0XXXXXXX	34.1	20.0	67.0	222	MBS Only	Interp.
	KBT0X1XXXXXXX	34.1	20.0	67.0	490	MBS + Input Xfrmr	Interp.
	KBT0X2XXXXXXX	34.1	20.0	67.0	490	Input Xfrmr Only	Interp.
	KBT0X3XXXXXXX	34.1	20.0	67.0	490	Output Xfrmr Only	Interp.
	KBT001100000010	34.1	20.0	67.0	490	MBS + Input Xfrmr	5

**Notes:**  
1. "X" Indicates selection digit not critical to seismic performance; see nomenclature description  
2. Maximum dimensions without seismic mounting kit, maximum weight includes seismic mounting kit.



# SPECIAL SEISMIC CERTIFICATION PRODUCT NOMENCLATURE

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation <b>Model Line:</b> 9X55 8-15 kVA Nomenclature			<b>TABLE 4</b>
Digit	Item	Description	UUT
1	Model Line	K = 9X55	1, 2, 16, 17
2	Base Model	4 = 9155 (8-15 kVA)	16
		A = 9355 (10-15 kVA)	1, 2, 17
3-4	kVA Rating	08 = 8 kVA	
		10 = 10 kVA	
		12 = 12 kVA	16
		15 = 15 kVA	1, 2, 17
5	System Type	1 = Reverse Transfer (not critical to seismic, programming)	1, 2, 16, 17
		2 = Parallel (not critical to seismic, programming)	
		A = Reverse Transfer, FAA (not critical to seismic, programming)	
6	Battery Configuration	1 = 1 Battery Module	1, 16
		2 = 2 Battery Modules	17
		3 = 1 Battery Module + Transformer Module	2
		4 = 1 Battery Module w/o Batteries	
		5 = 2 Battery Modules w/o Batteries	
		6 = 1 Battery Module w/o Batteries + Transformer Module	
7	Voltage Configuration	0 = N/A (only 9155)	16
		1 = 120/208V in/out, 50/60 Hz Autodetect (only 9355)	1
		2 = 127/220V in/out, 50/60 Hz Autodetect (only 9355)	
		4 = 480V in, 120/208V out (only 9355)	2, 17
		6 = 600V in, 120/208V out (only 9355)	
8	Communications Options	0 = None	1, 2, 16, 17
		3 = ConnectUPS WE/SNMP with EMP	
		4 = Modbus Communications Card	
		5 = Standard Relay Interface Card	
		6 = Industrial Relay Interface Card	
		7 = Internal Modem Card	
9-12	Power Distribution	0-4, A-N, P, S, X - Plug Configurations (not critical to seismic)	1, 2, 16, 17
13	Unused	0 = None	1, 2, 16, 17
14	Start-up Options	1-4 - Warranty and Service Options (not critical to seismic)	1, 2, 16, 17
15	Unused	0 = None	1, 2, 16, 17





# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX


2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>Table Description:</b> Frames	<b>TABLE 6</b>
<b>Model Line:</b> 9X55 UPS and Accessories		

<b>Building Code:</b> CBC 2022	<b>Seismic Certification Limits:</b>	$S_{DS} = 1.85 g$ $z/h = 1.0$ $S_{DS} = 2.96 g$ $z/h = 0.0$	$I_p = 1.5$
--------------------------------	--------------------------------------	--	-------------

Model Line (Manufacturer)	Model	Dimension (in)			Weight (lb)	Material	Notes	UUT
		Depth	Width	Height				
9X55 Frame (Eaton)	8-15 kVA (2-HIGH)	33.7	12.0	32.2	86	16 GA CRS		1, 6
	8-15 kVA (3-HIGH)	33.7	12.0	47.8	122	16 GA CRS		2, 3, 17
	20-30 kVA	34.1	20.0	67.0	245	16 GA CRS		4, 5
9X55 Seismic Kit (Eaton)	103004194-5501					CRS	8-15 kVA	1-3, 16, 17
	103004896					CRS	20-30 kVA	4, 5



# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation <b>Model Line:</b> 9X55 UPS and Accessories		<b>Table Description:</b> Electrical Components			<b>TABLE 7</b>	
<b>Building Code:</b> CBC 2022		<b>Seismic Certification Limits:</b>			$S_{DS} = 1.85 g \quad z/h = 1.0$ $S_{DS} = 2.96 g \quad z/h = 0.0$	
					$I_p = 1.5$	
Component Type	Manufacturer	Model	Description	Notes	UUT	
Electronics Module	Eaton	1024064	9155 module, 15 kVA and under		16	
		744-A0421	9355 module, 15 kVA and under		1, 2, 17	
Battery	CSB	PWHR1234W2FR	12V, 34 WATT (9 AH), VRLA		1-4, 16, 17	
Static Switch	Eaton	103004889	30 kVA -0486		4	
Contractor	Eaton	E111D85X3N	Output contactor, 115A		4	
		E111D10X3N	Bypass and input contactor, 130A		1,2,4,16,17	
Transformer	Eaton	V29M28E35M-50C	35 kVA, 208/208 (Al)		5	
	Trafotek	149502093	600-208/208 (Cu)		2	
Breaker	Airpax	209-2-34218-1-V	1A, 2 Pole		Extrap.	
		209-3-34218-2-V	2A, 2 Pole		2	
		229-2-IREC5-33735-100	100A, 2 Pole		1,2,16,17	
	Eaton (E-Frame)	EGS3070FFG	70A, 3 Pole, Thermal Trip		Extrap.	
		EGK3125KSG	125A, 3 Pole, Thermal Trip		Extrap.	
		EGS3125FFG	125A, 3 Pole, Thermal Trip		4	
	Eaton (F-Frame)	HFDDC3150LA1301U3801	150A, 3 Pole		Interp.	
		FD2200S18	200A, 2 Pole, Shunt Trip		4	
		FD3225KLA06	225A, 3 Pole		Extrap.	
	Eaton (G-Frame)	GHC3020	20A, 3 Pole		4	
		GHC3030	30A, 3 Pole		Interp.	
GHC3060		60A, 3 Pole		Interp.		
Power Module	Eaton	103004894	30 kVA power module		4	
		103004889	30 kVA power module/static switch		4	


# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



**Manufacturer:** Eaton Corporation  
**Model Line:** 9X55 UPS and Accessories

UUT	Unit Description	Report Number	Testing Lab	Year Tested	ISO 17025 Accredited?	S <sub>Ds</sub>	z/h	I <sub>p</sub>
1	KA1511100000010	55906R08-9 (EUT27)	Wyle Lab (NTS - Hunstville)	2008	Yes	1.85 2.96	1.0 0.0	1.5
2	KA1513400000010	55906R08-13 (EUT21)	Wyle Lab (NTS - Hunstville)	2008	Yes	1.93 3.09	1.0 0.0	1.5
3	103004193-5501	55906R08-12 (EUT19)	Wyle Lab (NTS - Hunstville)	2008	Yes	2.03 3.25	1.0 0.0	1.5
4	KB3013100000010	55906R08-9 (EUT13)	Wyle Lab (NTS - Hunstville)	2008	Yes	1.85 2.96	1.0 0.0	1.5
5	KBT001100000010	55906R08-8 (EUT5)	Wyle Lab (NTS - Hunstville)	2008	Yes	2.03 3.25	1.0 0.0	1.5
16	G410110000	70961R13 (UUT6)	Wyle Lab (NTS - Hunstville)	2013	Yes	2.73 4.37	1.0 0.0	1.5
17	103006185	70961R13 (UUT7)	Wyle Lab (NTS - Hunstville)	2013	Yes	2.73 4.37	1.0 0.0	1.5



**Notes:**

# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>UUT 1</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> KA1511100000010 <b>Serial Number:</b> FB336JBA45	

**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frames:** Eaton (8-15 kVA (2-HIGH)); **Seismic Kit:** Eaton (103004194-5501); **Electric Module:** Eaton (744-A0421);  
**Battery:** CBS (PWHR1234W2FR); **Contactor:** Eaton (E111D10X3N); **Breaker:** Airpax (229-2-IREC5-33735-100)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
480	32.0	18.0	34.0	27.0	15.0	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.97	0.79
		2.96	0.0					

**Test Mounting Details:** (Test Report: 55906R08-9 (EUT27))



UUT1 was base mounted - rigid using twelve (12) Class 8.8 M10 bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET



2200643-CR-001-R0

<b>Manufacturer:</b> Eaton Corporation	<b>UUT 2</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> KA1513400000010 <b>Serial Number:</b> FB336JBA37	


**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frames:** Eaton (8-15 kVA (3-HIGH)); **Seismic Kit:** Eaton (103004194-5501); **Electronics Module:** Eaton (744-A0421);  
**Battery:** CBS (PWHR1234W2FR); **Contactor:** Eaton (E111D10X3N); **Transformer:** Trafotek (149502093);  
**Breaker:** Airpax (209-3-34218-2-V, 229-2-IREC5-33735-100)

<i>UUT Properties</i>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
755	32.5	14.5	49.5	17.0	8.8	>33.3

<i>UUT Highest Passed Seismic Run Information</i>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022	ICC-ES AC156	1.93	1.0	1.5	1.93	2.32	2.06	0.82	
		3.09	0.0						

**Test Mounting Details:** (Test Report: 55906R08-13 (EUT21))



UUT2 was base mounted - rigid using twelve (12) Class 8.8 M10 Bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>UUT 3</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> 103004193-5501 <b>Serial Number:</b> N/A	


**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frames:** Eaton (8-15 kVA (3-HIGH)); **Seismic Kit:** Eaton (103004194-5501); **Battery:** CBS (PWHR1234W2FR);

<i>UUT Properties</i>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
855	28.5	14.5	50.0	17.0	6.0	>33.3

<i>UUT Highest Passed Seismic Run Information</i>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022	ICC-ES AC156	2.03	1.0	1.5	3.25	2.44	2.06	0.82	
		3.25	0.0						

**Test Mounting Details:** (Test Report: 55906R08-12 (EUT19))



UUT3 was base mounted - rigid using twelve (12) Class 8.8 M10 Bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>UUT 4</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> KB301310000010 <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frame:** Eaton (20-30 kVA); **Seismic Kit:** Eaton (103004896); **Battery:** CSB (PWHR1234W2FR);  
**Static Switch:** Eaton (103004889); **Contactors:** Eaton (E111D85X3N, E111D10X3N);  
**Breaker:** Eaton (E-Frame, EGS3125FFG) (F-Frame, FD2200S18) (G-Frame, GHC3020);  
**Power Module:** Eaton (103004894, 103004889)

<b>UUT Properties</b>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,155	44.0	24.0	65.0	6.4	6.4	>33.3

<b>UUT Highest Passed Seismic Run Information</b>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.97	0.79	
		2.96	0.0						

**Test Mounting Details:** (Test Report: 55906R08-9 (EUT13))



UUT4 was base mounted - rigid using ten (10) Class 8.8 M10 bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>UUT 5</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> KBT001100000010 <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frame:** Eaton (20-30 kVA); **Seismic Kit:** Eaton (103004896); **Transformer:** Eaton (V29M28E35M-50C)

<i>UUT Properties</i>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
490	44.0	24.0	66.0	7.5	7.2	>33.3

<i>UUT Highest Passed Seismic Run Information</i>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2022	ICC-ES AC156	2.03	1.0	1.5	3.25	2.44	2.06	0.82	
		3.25	0.0						

**Test Mounting Details:** (Test Report: 55906R08-8 (EUT5))



UUT5 was base mounted - rigid using ten (10) Class 8.8 M10 bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

2200643-CR-001-R0



<b>Manufacturer:</b> Eaton Corporation	<b>UUT 16</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> G410110000	
<b>Serial Number:</b> BG095FBB06	

**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frame:** Eaton (8-15 kVA (2-HIGH)); **Seismic Kit:** Eaton (103004914-5501); **Electronics Module:** Eaton (1024064);  
**Battery:** CSB (PWHR1234W2FR); **Contactor:** Eaton (E111D10X3N); **Breaker:** Airpax (229-2-IREC5-33735-100)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
452	32.0	18.0	34.0	>33.3	24.0	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.73	1.0	1.5	4.37	3.28	2.91	1.17
		4.37	0.0					

**Test Mounting Details:** (Test Report: 70961R13 (UUT6))



UUT16 was base mounted - rigid using twelve (12) Class 8.8 M10 bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET



2200643-CR-001-R0

<b>Manufacturer:</b> Eaton Corporation	<b>UUT 17</b>
<b>Model Line:</b> 9X55 UPS and Accessories	
<b>Model Number:</b> 103006185 <b>Serial Number:</b> BG111JBA01	

**Product Construction Summary:**  
Formed carbon steel internal framing with carbon steel panelized walls, base and roof.

**Options/Subcomponent Summary:**  
**Frame:** Eaton (8-15 kVA (3-HIGH)); **Seismic Kit:** Eaton (103004914-5501); **Electronics Module:** Eaton (744-A0421);  
**Battery:** CSB (PWHR1234W2FR); **Contactor:** Eaton (E111D10X3N); **Breaker:** Airpax (229-2-IREC5-33735-100)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
750	32.0	18.0	49.5	18.0	12.0	>33.3

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	2.73	1.0	1.5	4.37	3.28	2.91	1.17
		4.37	0.0					

**Test Mounting Details:** (Test Report: 70961R13 (UUT7))



UUT17 was base mounted - rigid using twelve (12) Class 8.8 M10 bolts torqued to 31 ft-lbs. and washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.