

OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0492 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** Manufacturer: Fuji Electric Manufacturer's Technical Representative: Gareth Davis Mailing Address: 50 Northfield Avenue, Edison, NJ 08837 Telephone: 732.564.5145 Email: gdavis@fecoa.fujielectric.com **Product Information** Product Name: UPS7300WX-T3U Product Type: Uninterruptible Power Supply Product Model Number: UPS7300WX-T3U/ 225kVA, 300kVA, 333kVA (List all unique product identification numbers and/or part numbers) General Description: 225kVA - 333kVA UPS Mounting Description: Rigid base mounted. **Applicant Information** Applicant Company Name: TRU Compliance LLC Contact Person: Derek J. Manwill, S.E. Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702 Email: dmanwill@trucompliance.com Telephone: 844.878.0200 I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 12/1/2016 Company Name: TRU Compliance LLC Title: Vice President

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





Page 1 of 3



Page 2 of 5

12/02/2016



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters								
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No								
Design Basis of Equipment or Components $(F_p/W_p) = 1.5 (S_{DS} = 2.0g)$; 1.44 $(S_{DS} = 3.2g)$								
S _{DS} (Design spectral response acceleration at short period, g) = 2.0 (z/h = 1.0); 3.2 (z/h = 0.0)								
a _p (In-structure equipment or component amplification factor) =								
R _p (Equipment or component response modification factor) = 6.0								
Ω_0 (System overstrength factor) = 2.0								
I _p (Importance factor) = 1.5								
z/h (Height factor ratio) = $1.0 (S_{DS} = 2.0g)$; $0.0 (S_{DS} = 3.2g)$								
Equipment or Component Natural Frequencies (Hz) = See Attachment								
Overall dimensions and weight (or range thereof) = See Attachment								
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No								
Design Basis of Equipment or Components (V/W) =								
S _{DS} (Design spectral response acceleration at short period, g) =								
S _{D1} (Design spectral response acceleration at 1 second period, g) =								
R (Response modification coefficient) =								
Ω_0 (System overstrength factor) =								
C _d (Deflection amplification factor) =								
I _p (Importance factor) = 1.5								
Height to Center of Gravity above base =								
Equipment or Component Natural Frequencies (Hz) =								
Overall dimensions and weight (or range thereof) =								
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No								
List of Attachments Supporting Special Seismic Certification								
□ Test Report(s) □ Drawings □ Calculations □ Manufacturer's Catalog								
Other(s) (Please Specify): Attachment A								
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022								
Signature: Date: 12/2/2016								
Print Name: M. R. Karim Title: SHFR								
Special Seismic Certification Valid Up to : S _{DS} (g) = See Above z/h = See Above								
Condition of Approval (if applicable):								

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

Page 3 of 5

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 16044



Manufacturer: Fuji Electric
Model Line: UPS7300WX-T3U

TABLE 1

Certified Product Construction Summary:

Carbon steel cabinet, carbon steel frame, carbon steel base channel.

Certified Options Summary:

None. Subcomponents are identical between models and uniquely identified by model number. All models are identical other than software.

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016	Seismic Certification Limits:	$S_{DS} = 2.0g$	z/h=1.0	1 _P = 1.5
Banaring code. CDC 2010	Seisinic dei tineation Ennits.	$S_{DS} = 3.2g$	z/h=0.0	τρ 1.5

Modelline	Model	Dimensions (in)			Weight	Notes	
Model Line		Depth	Width	Height	(lb)	Notes	UUT
	225 kVA	31.5	59.1	78.7	2450	Identical to 333 - software	
USP730WX-T3U	300 kVA	31.5	59.1	78.7	2450	Identical to 333 - software	
	333 kVA	31.5	59.1	78.7	2450		1

UNIT UNDER TEST (UUT) SUMMARY SHFFT

TRU PROJECT NO. 16044



UUT 1

Manufacturer:Fuji ElectricModel Line:UPS7300WX-T3U

Serial Number: N/A

Product Construction Summary:

Model Number:

Carbon steel cabinet, carbon steel frame, carbon steel base channel.

UPS7300WX-T3U/333kVA

Options/Subcomponent Summary:

Single subcomponent configuration (all subcomponents are uniquely identified by model number).

	UUT Properties										
	Weight	Dimension (in)				Lowest Natural Frequency (Hz)					
	(lb)	Depth	Width	Hei	ight	Front	-Back	Side	-Side	Vert	tical
	2450	31.5	59.1	78	3.7	7.7		6.7		25.0	
	UUT Highest Passed Seismic Run Information										
	Building Code		Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016		ICC-ES AC156		2.0	1.0	1.5	3.2	2.4			
		6 2010	100-L3 AC 100		3.2	0.0	1.5			2.13	0.85

Test Mounting Details:



Rigid base mounted with (10) 3/4" Grade 8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.