



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0513

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Broad USA, Inc.

Manufacturer's Technical Representative: Kevin Fu

Mailing Address: 401 Hackensack Ave. Suite 503, Hackensack, NJ 07601

Telephone: (201) 678-3010

Email: kevin@broadusa.com

Product Information

Product Name: BS Steam Absorption Chillers

Product Model Number(s): BS20 – BS300

Product Category: Chillers

Product Sub-Category: Chillers - Absorption

General Description: BS Series steam absorption chillers.

Mounting Description: Base Mounted Rigid

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: Pre Compliance

Contact Person: Andy Coughlin

Mailing Address: 324 NW Hill St., Bend, OR 97703

Telephone: (541) 241-2310

Email: andy@go-pre.com

Title: Principal Engineer



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: PRE COMPLIANCE

Name: Andrew Coughlin

California License Number: S6082

Mailing Address: 324 NW Hill St, Bend, OR 97703

Telephone: (415) 635-8461

Email: Andy@go-pre.com

**Certification Method**

☐ GR-63-Core

☒ ICC-ES AC156

☐ IEEE 344

☐ IEEE 693

☐ NEBS 3

☐ Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)

Contact Person: Amarnath Kasalanati

Mailing Address: 325 Davis Hall, Berkeley CA 94720-1729

Telephone: (510) 642-3437

Email: amarnath1@berkeley.edu

BY: Timothy J. Piland

DATE: 09/24/2025



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Certified Response Spectral Acceleration Factors:(F<sub>p</sub>/W<sub>p</sub>)

Horizontal (A Flx-H), g= 3.15 (A Rig-H), g= 2.12

Vertical (A Flx-V), g= 2.11 (A Rig-V), g= 0.84

SDS (Design spectral response acceleration at short period, g) = 1.97; z/h = 1; 3.16; z/h = 0

H<sub>f</sub> (Force amplification height factor) = 1 @ z/h = 0; 3.5 @ z/h = 1

R<sub>u</sub> (Structure ductility reduction factor) = 1 @ z/h = 0; 1.3 @ z/h = 1

I<sub>p</sub> (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

HCAI Approval (For Office Use Only) - Approval Expires on 09/24/2031

Date: 9/24/2025

Name: Timothy Piland

Title: Senior Structural Engineer

Condition of Approval (if applicable): \_\_\_\_\_

OSP-0513

BY: Timothy J. Piland

DATE: 09/24/2025



**PRE**  
COMPLIANCE

## Pre No. 251712-01-R0

**Manufacturer:**

Broad USA, Inc.

**Product Type:**

## Chillers – Absorption

**Model Line:**

## BS Steam Absorption Chillers

## Seismic Parameters

**$S_{DS} = 1.97g$  for  $R_u=1.3, H_f=3.5$**

**$S_{DS} = 3.16g$  for  $R_u=1.0, H_f=1.0$**

## Building Codes

**CBC 2025**

## TABLE 1

**Mounting Configuration: Base Mounted - Rigid**

## Construction Summary

Heavy gauge carbon steel construction.

## Options Summary

[illegible]

Notes:

<sup>1</sup>Includes seismic bracing upgrades between main shell and HTG shell. Weight listed includes solution weight.



## COMPLIANCE

## SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENTS

Pre No. 251712-01-R0

**Manufacturer:** Broad USA, Inc.  
**Product Type:** Chillers – Absorption  
**Model Line:** BS Steam Absorption Chillers

## Seismic Parameters

$S_{DS} = 1.97g$  for  $R_\mu=1.3, H_f=3.5$   
 $S_{DS} = 3.16g$  for  $R_\mu=1.0, H_f=1.0$

## Building Codes

**CBC 2025**

## TABLE 2

### Table Description: Control Devices

[illegible]



# PRE COMPLIANCE

Pre No. 251712-01-R0

## SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENTS

**Manufacturer:** Broad USA, Inc.  
**Product Type:** Chillers – Absorption  
**Model Line:** BS Steam Absorption Chillers

## Seismic Parameters

$S_{DS} = 1.97g$  for  $R_\mu=1.3, H_f=3.5$   
 $S_{DS} = 3.16g$  for  $R_\mu=1.0, H_f=1.0$

## Building Codes

**CBC 2025**

## TABLE 3

### Table Description: Control Devices

[illegible]



# SPECIAL SEISMIC CERTIFICATION TESTING SUMMARY

Chiller  
- Rigid)

TR251712-01-R0  
(UUT 1)

Pacific Earthquake  
Engineering Research  
Center (PEER)

**HCAi**

OSP-0513

BY: Timothy J. Piland

DATE: 09/24/2025

CALIFORNIA BUILDING CODE, 2025

Page 7 of 10



# SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

## UUT 1

Test Report# 16059-TR-001, rev01

**Manufacturer:** Broad USA, Inc.  
**Model Line:** BS Steam Absorption Chillers  
**Model Number:** BS136X10.79-35/27.8-5.6/13.3-150  
**Serial Number:** 16120021

### Highest Passed Test Level

$S_{DS}$	$R_{\mu}$	$H_f$	$I_p$	$A_{flx-h}$	$A_{rig-h}$	$A_{flx-v}$	$A_{rig-v}$
2.00	1.3	3.5	1.5	3.20	2.15	2.13	0.85
3.20	1.0	1.0					

### Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
257.0	91.5	118.0	45,820

### Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
13.63	9.74	19.72

### Building Codes

CBC 2025

### Test Criteria

ICC-ES AC156

### Construction/Option Summary

Heavy gauge carbon steel construction.  
 Includes seismic bracing upgrades between main shell and HTG shell.

### UUT Mounting Details:



UUT was base mounted - rigid using 2" long 1/4" fillet welds every 12" along four (4) base channels. Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

### List of Included Subcomponents

**Inverter:** INVT (GD310-004G-4-UL, GD20-1R5G-4-UL); **Touch Screen:** Siemens (6AV2124-0MC01-0AX0);  
**Controller:** Siemens (S1500); **Fan:** Sunon (A2175-HBL); **Valves:** Broad (DN10, DN15, DN20, DN25, DN50, DN150);  
**Pumps:** Teikoku (NP70-40D/321H2/4-F, NP65-40C/122H2/4-B, NP40-20A2/121H2/4-B, LY-015H4-0103R-A);  
**Gauge:** Beijing Brighty (01~0.3MPA); **Flow Switch:** Broad (LKB-01BbYD); **Pressure Control:** Danfoss (KP135);  
**Temperature Sensor:** Therncway (ST02-145E3L100-60, ST02-145E3L100-100, ST02-145E3M100A-60); **Probes:**  
 Broad (BROADKY1, BROADKY2, BROADKY4, BROADKY5, BROADKY6)



# SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

## UUT 2

Test Report# 16059-TR-001, rev01

**Manufacturer:** Broad USA, Inc.  
**Model Line:** BS Steam Absorption Chillers  
**Model Number:** BS20x10.8-36.4/29.4-6.7/13.7-Fa-Ma  
**Serial Number:** 6120022

### Highest Passed Test Level

$S_{DS}$	$R_{\mu}$	$H_f$	$I_p$	$A_{flx-h}$	$A_{rig-h}$	$A_{flx-v}$	$A_{rig-v}$
2.00	1.3	3.5	1.5	3.20	2.15	2.13	0.85
3.20	1.0	1.0					

### Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
117.0	79.5	95.0	15,565

### Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
6.76	7.02	17.70

### Building Codes

CBC 2025

### Test Criteria

ICC-ES AC156

### Construction/Option Summary

Heavy gauge carbon steel construction.  
Includes seismic bracing upgrades between main shell and HTG shell.

### UUT Mounting Details:



UUT was base mounted - rigid using 2" long 1/4" fillet welds every 12" along two (2) base channels. Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

### List of Included Subcomponents

**Inverter:** INVT (GD20-1R5G-4-UL, GD20-0R7G-4-UL); **Touch Screen:** Siemens (6AV2124-0MC01-0AX0);  
**Controller:** Siemens (S1500); **Fan:** Sunon (A2175-HBL); **Valves:** Broad (DN10, DN15, DN20, DN25, DN100);  
**Pumps:** Teikoku (NP70-40D/321H2/4-F, NP65-40C/122H2/4-B, NP40-20A2/121H2/4-B, LY-015H4-0103R-A);  
**Gauge:** Beijing Brighty (01~0.3MPA); **Flow Switch:** Broad (LKB-01BbYD); **Pressure Control:** Danfoss (KP135);  
**Temperature Sensor:** Therncway (ST02-145E3L100-60, ST02-145E3M100A-60);  
**Probes:** Broad (BROADKY1, BROADKY2, BROADKY4, BROADKY5, BROADKY6)

# SPECIAL SEISMIC CERTIFICATION UUT SUMMARY

## UUT 3

Test Report# TR251712-01-R0

**Manufacturer:** Broad USA, Inc.  
**Model Line:** BS Steam Absorption Chillers  
**Model Number:** BS300  
**Serial Number:** 25041801

### Highest Passed Test Level

$S_{DS}$	$R_{\mu}$	$H_f$	$I_p$	$A_{flx-h}$	$A_{rig-h}$	$A_{flx-v}$	$A_{rig-v}$
1.97	1.3	3.5	1.5	3.16	2.12	2.11	0.85
3.16	1.0	1.0					

### Dimensions/Weights

Depth (in)	Width (in)	Height (in)	Weight (lbs.)
303.0	127.0	132.0	79,200

### Lowest Natural Frequency (Hz)

Front-Back	Side-Side	Vertical
6.7	6.7	25.7

### Building Codes

CBC 2025

### Test Criteria

ICC-ES AC156

### Construction/Option Summary

Heavy gauge carbon steel construction.  
Includes seismic bracing upgrades between main shell and HTG shell.

### UUT Mounting Details:



UUT was base mounted - rigid using 5" long 1/4" fillet welds every 3' along four (4) base channels. Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

### List of Included Subcomponents

**Inverter:** INVT (GD310-004G-4-UL, GD20-1R5G-4-UL); **Touch Screen:** Siemens (6AV2124-0MC01-0AX0); **Controller:** Siemens (S1500); **Fan:** Sunon (A2175-HBL); **Valves:** Broad (DN10, DN15, DN20, DN25, DN50, DN150); **Pumps:** Teikoku (NP70-40D/321H2/4-F, NP65-40C/122H2/4-B, NP40-20A2/121H2/4-B, LY-015H4-0103R-A); **Gauge:** Beijing Brighty (01~0.3MPA); **Flow Switch:** Broad (LKB-01BbYD); **Pressure Control:** Danfoss (KP135); **Temperature Sensor:** Therncway (ST02-145E3L100-60, ST02-145E3L100-100, ST02-145E3M100A-60); **Probes:** Broad (BROADKY1, BROADKY2, BROADKY4, BROADKY5, BROADKY6)