



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR HCAI SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP-0528

HCAI Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Toshiba International Corporation

Manufacturer's Technical Representative: Tiffany Tye

Mailing Address: 13131 West Little York Road, Houston, TX 77041

Telephone: (855) 803-7087

Email: tiffany.tye@toshiba.com

Product Information

Product Name: UPS and Batteries

Product Type: UPS

Product Model Number: G9000 and G2020 Uninterruptible Power Systems

General Description: UPS with carbon steel enclosures and Si & SiC power modules.

Mounting Description: Rigid, Floor Mounted

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: Manwill Engineering LLC


Contact Person: Derek Manwill

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: (541) 241-2102

Email: derek@manwillSE.com

Title: President





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)


Company Name: MANWILL ENGINEERING LLC
Name: Derek Manwill California License Number: S6266
Mailing Address: PO Box 1194, Bend, OR 97709
Telephone: (541) 241-2102 Email: derek@manwillse.com

Certification Method

GR-63-Core ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
 Other (Please Specify): _____

Testing Laboratory

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Jeremy Lange
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: Jeremy@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) = 1.16 (SDS=1.54, z/h=1), 0.90 (SDS=2.00, z/h=0)

SDS (Design spectral response acceleration at short period, g) = 1.54 (z/h=1), 2.00 (z/h=0)

a_p (Amplification factor) = 2.5

R_p (Response modification factor) = 6.0

Ω_0 (System overstrength factor) = 2.0


I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 04/06/2028			
Date:	<u>4/6/2022</u>	OSP-0528	
Name:	<u>Mohammad Karim</u>	BY: Mohammad Karim	Title: <u>Supervisor, Health Facilities</u>
Special Seismic Certification Valid Up to:	SDS (g) = <u>See Above</u>		z/h = <u>See Above</u>
Condition of Approval (if applicable):	<u>DATE: 04/06/2022</u>		



ATTACHMENT 1: CERTIFIED COMPONENTS

SPECIAL SEISMIC CERTIFICATION

TABLE 1

DOCUMENT NO.: 17011CR2.0

MANUFACTURER: TOSHIBA INTERNATIONAL CORPORATION						
PRODUCT FAMILY: G9000 AND G2020 UNINTERRUPTIBLE POWER SYSTEMS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
G9000 Uninterruptible Power Systems						
T9XS3S10KS6XSN2 (100kVA)	32.7	27.6	78.7	772		EXTRAP
T9XS3S10KS6XSN (100kVA)	32.8	27.6	78.7	866	Si power modules	UUT 1
T9XS3S16KS6XSN2 (160kVA)	32.7	27.6	78.7	860		INTERP
T9XS3S16KS6XSN (160kVA)	32.7	35.4	78.7	1200		INTERP
T9XS3S22KS6XSN2 (225kVA)	32.7	35.4	78.7	1080		INTERP
T9XS3S22KS6XSN (225kVA)	32.7	35.4	78.7	1250		INTERP
T9XS3S30KS6XSN (300kVA)	32.8	51.2	78.7	2260		INTERP
T9XS3S50KS6XSN (500kVA)	32.8	70.9	78.7	3300		INTERP
T9XS3S65KS6XSN (650kVA)	32.8	90.6	78.7	4062		INTERP
T9XS3S75KS6XSN (750kVA)	32.8	90.6	78.7	4062	Si power modules	UUT 2
G2020 Uninterruptible Power Systems						
T200H0500KWWW (500kVA)	33.5	59.1	78.7	2756		INTERP
T200H0750KWWW (750kVA)	33.5	81.6	78.7	3565	SiC power module	UUT 3
MOUNTING:	Rigid floor mounted.			SEISMIC LEVELS:	$S_{DS} = 1.54g$ for $z/h = 1$ $S_{DS} = 2.00g$ for $z/h = 0$ $I_p = 1.5$	
NOTES:	<p>Product Construction: Carbon steel cabinet. The G9000 and G2020 have similar construction, configuration, and mounting.</p> <p>Options/Subcomponents: The G9000 and G2020 have the same configuration, manufacturers, and materials of subcomponents, except for the material of the power modules. The G9000 uses silicon (Si) for the power modules, while the G2020 uses silicon carbide (SiC); the configuration is similar and the manufacturers are the same for the power modules.</p> <p>Note 1. X in 3rd digit of G9000 model number denotes main controller generation: 0 for Generation 1, 1 for Generation 2. Generation 1 tested in UUT 1 and UUT 2; Generation 2 tested in UUT 3.</p>					

ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SPECIAL SEISMIC CERTIFICATION

UUT 1 - G9000 100kVA

DOCUMENT NO.: 17011CR2.0

MANUFACTURER:	TOSHIBA INTERNATIONAL CORPORATION
MODEL NUMBER:	T90S3S10KS6XSN (100kVA)
UNIT FUNCTION:	UNINTERRUPTIBLE POWER SYSTEM
SERIAL NUMBER:	08-7E445120012

DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
32.8	27.6	78.7	866	7.9	5.0	18.9

CODE & CRITERIA:	2019 CBC	ICC-ES AC156
-----------------------------	----------	--------------

TEST LABORATORY:	ENVIRONMENTAL TESTING LABORATORY
-------------------------	----------------------------------

REPORT & DATE:	SQ37-1010-1	September 28, 2010
---------------------------	-------------	--------------------

S _{DS} (g)	z/h	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
1.54	1	2.46	1.85	1.34	0.54
2.00	0				

IMPORTANCE FACTOR, I_p = 1.5
 Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

MOUNTING:	Rigid floor mounted using (4) 1/2" ASTM A307 bolts.
------------------	---

CONSTRUCTION:	NEMA 1 carbon steel enclosure, Si power modules.
----------------------	--

SUBCOMPONENTS:	Subcomponents uniquely identified by model number.
-----------------------	--

TESTING NOTES:	No 45-degree performed on uniaxial. Therefore, values have been adjusted down by a factor of 1.3 for orthogonality.
-----------------------	---



UUT 2 - G9000 750kVA

BY: Mohammad Karim

MANUFACTURER:	TOSHIBA INTERNATIONAL CORPORATION
MODEL NUMBER:	T90S3S75KS6XSN (750kVA)
UNIT FUNCTION:	UNINTERRUPTIBLE POWER SYSTEM
SERIAL NUMBER:	09-7E415710081

DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
32.8	90.6	78.7	4062	5.8	5.4	5.7

CODE & CRITERIA:	2019 CBC	ICC-ES AC156
-----------------------------	----------	--------------

TEST LABORATORY:	ENVIRONMENTAL TESTING LABORATORY
-------------------------	----------------------------------

REPORT & DATE:	SQ37-1010-1	September 29, 2010
---------------------------	-------------	--------------------

S _{DS} (g)	z/h	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
1.54	1	2.46	1.85	1.34	0.54
2.00	0				

IMPORTANCE FACTOR, I_p = 1.5
 Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

MOUNTING:	Rigid floor mounted using (10) 5/8" ASTM A307 bolts.
------------------	--

CONSTRUCTION:	NEMA 1 carbon steel enclosure, Si power modules.
----------------------	--

SUBCOMPONENTS:	Subcomponents uniquely identified by model number.
-----------------------	--

TESTING NOTES:	No 45-degree performed on uniaxial. Therefore, values have been adjusted down by a factor of 1.3 for orthogonality. LCD display will be secured with screws instead of friction clip to ensure separation of display parts does not occur. Enhancements will be incorporated into production units.
-----------------------	---



ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SPECIAL SEISMIC CERTIFICATION

UUT 3 - G2020 750kVA

DOCUMENT NO.: 17011CR2.0

MANUFACTURER:		TOSHIBA INTERNATIONAL CORPORATION				
MODEL NUMBER:		T200H0750KWWW (750kVA)				
UNIT FUNCTION:		UNINTERRUPTIBLE POWER SYSTEM				
SERIAL NUMBER:		17530069				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
33.5	81.6	78.7	3565	5.6	9.1	17.3
CODE & CRITERIA:		2019 CBC		ICC-ES AC156		
TEST LABORATORY:		ENVIRONMENTAL TESTING LABORATORY				
REPORT & DATE:		17011TR1.1		May 31, 2017		
S_{DS} (g)	z/h	A_{FLX-H} (g)	A_{RIG-H} (g)	A_{FLX-V} (g)	A_{RIG-V} (g)	
2.00	1	3.20	2.40	1.34	0.54	
2.00	0					
IMPORTANCE FACTOR, I_p = 1.5						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
MOUNTING:		Rigid floor mounted using (6) 5/8" Grade 8 bolts.				
CONSTRUCTION:		NEMA 1 carbon steel enclosure, SiC power modules.				
SUBCOMPONENTS:		Subcomponents uniquely identified by model number.				
TESTING NOTES:		Upper latch assembly modified to ensure door closure. Enhancements will be incorporated into production units.				

