## OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP - 0560 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** Schneider Electric Manufacturer: Manufacturer's Technical Representative: Jeff Gatscher Mailing Address: 6700 Tower Circle Franklin, TN 37067 USA Telephone: (615) 459-8466 Email: jeff.gatscher@schneider-electric.com **Product Information** Product Name: Premset Switchgear Product Type: MV Metal Enclosed Switchgear Product Model Number: ESB, D01N, D02N, G06, D06H, D06N, G12, D12H (List all unique product identification numbers and/or part numbers) 15 kV Metal Enclosed Switchgear, Compact Vacuum Circuit Breaker Switchgear with Shielded General Description: Solid Insulation (2SIS) System, 600A and 1200A with front and rear connection. Rigid Base Mounted Mounting Description: **Applicant Information** Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc. Contact Person: Andy Coughlin, SE Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138 Telephone: (844) 878-0200 Email: acoughlin@structint.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 5/3/2018 Title: Director, TRU Compliance Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 1 of 3

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: _TRU Compliance, by Structural Integrity Associates, Inc.
Name: Andrew M. Coughlin SE California License Number: S6082
Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138
Telephone: (844) 878-0200 Email: acoughlin@structint.com
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved
Certification Method
<ul> <li>☐ Other (Please Specify):</li> <li>☐ Osp-0560-10</li> </ul>
BY:Ali Sumer
Testing Laboratory  DATE: 02/26/2019
Company Name: National Technical Systems
Contact Name: Mike Noblitt
Mailing Address: 7800 Highway 20 WEST, Huntsville, AL 35806
Telephone: _(844) 467-6414





# OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = 1.63 (S <sub>DS</sub> = 2.17, z/h = 1.0); 1.08 (S <sub>DS</sub> = 2.39, z/h = 0.0)
S <sub>DS</sub> (Design spectral response acceleration at short period, g) = 2.17 (z/h = 1.0); 2.39 (z/h =0.0)
a <sub>p</sub> (In-structure equipment or component amplification factor) =
R <sub>p</sub> (Equipment or component response modification factor) = 6.0
$\Omega_0$ (System overstrength factor) =2
I <sub>P</sub> (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0 (S <sub>DS</sub> = 2.17); 0.0 (S <sub>DS</sub> = 2.39)
Equipment or Component Natural Frequencies (Hz) = See Attachment
Overall dimensions and weight (or range thereof) = See Attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes  No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient ) = OSP-0560-10
$\Omega_0$ (System overstrength factor) =
C <sub>d</sub> (Deflection amplification factor) = BY:Ali Sumer
I <sub>p</sub> (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No
List of Attachments Supporting Special Seismic Certification
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
Signature: Date: February 26, 2019
Print Name: Ali Sumer Title: DSE
Special Seismic Certification Valid Up to : $S_{DS}(g) = \underline{See \ Above}$ $z/h = \underline{See \ Above}$
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX



## 1700706-CR-001 R0

**Manufacturer:** Schneider Electric

Model Line: Premset

Certified Product Construction Summary:

14 Ga. Painted Carbon Steel Enclosure.

### **Certified Options Summary:**

600A - 1200A Copper or Aluminum main busbars, Copper or Aluminum riser busbars, Front or rear connection with top or bottom cable entry, Front access only or Rear access options, Rear cable assembly, 17.7" to 27.75" tall low voltage compartment, 10.2" base plinth, standard or additional depth doors. Ganged configuration only.

#### Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016

Seismic Certification Limits:

 $S_{DS} = 2.17g$  z/h=1.0  $S_{DS} = 2.39g$  z/h=0.0

 $I_{P} = 1.5$ 

**TABLE 1** 

Model Line	Model	Dimensions (in)			Weight	UUT	
Model Line	Model	Depth	Width	Height	(lb)	Notes	001
	ESB	60	14.75	96.75	973		Extrap.
	D01N	B <sub>60</sub> : A	14.75 <sup>S</sup>	96.75	973	0	Extrap.
	D02N	60	14.75	96.75	973	10	Extrap.
Premset	G06	D60TE	: 014.752 6	/ 96.759	973	UUT: Al main/riser busbars	3
Fielliset	D06H	60	14.75	96.75	973		Interp.
	D06N	60	14.75	96.75	887	UUT: Al main/riser busbars	3
	G12	60	14.75	96.75	1066	UUT: Cu main/riser busbars	1
	D12H	58	29.5	96.75	1520	UUT: Cu main/riser busbars	1
			$_{3}$ UILL	ING			

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

# Schneider TRU COMPLIANCE

## 1700706-CR-001 R0

Manufacturer: Schneider Electric Table Description: Main Components

Model Line: Premset

TABLE 2

Building Code: CBC 2016 Seismic Certification Limits:  $S_{DS} = 2.17 g \quad z/h = 1.0$  $S_{DS} = 2.17 g \quad z/h = 0.0$ 

$S_{DS} = 2.39  \text{g} \cdot \text{z/n} = 0.0$									
Component Type	Manufacturer	Model	Description R CODR	Notes	UUT				
Breakers	Schneider Electric	AAV91761	Vacuum circuit breaker	UUT 1: Qty (2) for 1200 A	1,3				
	Zaliako	03816686NO	12/28/75 kV		3				
Low-Power Voltage	Zelisko	0381669 <mark>5NO</mark>	24/50/125 kV		1				
Transformers (LPVT)	Cabracidas Flactuia	P7MSULPVT01	Cable side voltage sensing for 600 A Unit		3				
	Schneider Electric	P7MS <mark>ULPV</mark> T02	Cable side voltage sensing for 1200 A Unit		1				
		CIT	Manual close/open		Extrap.				
Mechanism	Schneider Electric	CII BY:	Closing with Hand Lever or motor & Opening with Push Button or trip coils		3				
		oco DAT	Stored energy type with Closing & Opening with Push Button or trip coils		1				
		P7M12001	24-30V DC		Extrap.				
Matau Maalaau isus	Calamaidan Elaatnia	P7M12002	48-60V AC/DC		Extrap.				
Motor Mechanism	Schneider Electric	P7M12003	100-130V AC/DC		1,3				
Schneider Elece		P7M12004	200-250V AC/DC		3				
		ESB- P7MESBC10	Breaker/switch enclosure		Extrap.				
		D01N- P7MD0XNC10	Breaker/switch enclosure		Extrap.				
Taul	Calamaidan Elaatnia	D02N- P7MD0XNC10	Breaker/switch enclosure		Extrap.				
Tank	Schneider Electric	D06H- P7MD06HC10	Breaker/switch enclosure		Extrap.				
		D06N- P7MD0XNC10	Breaker/switch enclosure		3				
		D12H- P7MD06HC10	Breaker/switch enclosure		1				
Tank Camera	Schneider Electric	NHA64038	Tank camera to confirm switch position		1,3				
Cable Test Daviss	Cabaaiday Flaatii -	P7MCTESTID	600A		3				
Cable Test Device	Schneider Electric	P7MCTESTID1250A	1200A		1				

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

# Schneider TRU COMPLIANCE

## 1700706-CR-001 R0

Manufacturer: Schneider Electric Table Description: Low Voltage Components

Model Line: Premset

TABLE 3

Building Code: CBC 2016 Seismic Certification Limits:  $S_{DS} = 2.17 g \quad z/h = 1.0$   $S_{DS} = 2.17 g \quad z/h = 0.0$ 

			$S_{DS} = 2.39  g  z/h = 0.0$		
Component Type	Manufacturer	Model	R CODE Description	Notes	UUT
		VIP Protection Relay	Protection Relay		3
Dolove	Schneider Electric	MiCOM	24-220 VDC, 110-230 VAC Protection Relay		3
Relays	Schneider Electric	VD23	Voltage Detector Relay		3
		Sepam	24-250 VDC, 110/240 VAC Protection Relay		1,3
Ammeter	Schneider Electric	AMP 21D	Ammeter, 3-630 A		1
Fault Passage Indicator	Schneider Electric	Easergy Flair	Fault passage indicator, 2-4 digit display		3
Cantuallana	Calara i dan Ela atria	SC100 BY: A	Intelligent Controller, 24-60 VDC		1,3
Controllers	Schneider Electric	SC-MI	Local control device, on/off, remote local		1
Transfer Systems	Schneider Electric	AT\$100 DATE	Automatic transfer system		3
		PM5000	Power Meter		3
Power Meters	Schneider Electric	PM8000	Power Meter		Interp.
		ION7650	Power Meter		1
		P7MARU2	ARU2 type, For protection	mounted at bottom tank	1
Current Transformers	Schneider Electric	P7MARU1	ARU2 type, For metering	mounted at bushings	1,3
		ARC6	ARU6 type, For metering	mounted at cables	3
		VPI62403	Voltage presence indicator (3kV)		3
Voltage Presence	Schneider Electric	VPI62404	Voltage presence indicator(6.6kV)		Interp.
Indicator		VPI62406	Voltage presence indicator (15kV)		1
		P7MLCIMEXX	Locking Assy VAC/VDC		1,3
Live Cable Interlock	Schneider Electric	P7M12020	Electronic Device ESL100A 24-48 VDC		3
		P7M12021	Electronic Device ESL100E 110-250 VAC/DC		1
Sensor	Schneider Electric	Easergy TH110/CL110	Wireless thermal and humidity sensor		1
Power Supply	Schneider Electric	PS100	Power Supply		1

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

# Schneider TRU COMPLIANCE

## 1700706-CR-001 R0

Manufacturer: Schneider Electric Table Description: Extension boxes **TABLE 4** Model Line: Premset  $S_{DS} = 2.17g$  z/h = 1.0Seismic Certification Limits: Building Code: CBC 2016  $I_{P} = 1.5$  $S_{DS} = 2.39 g z/h = 0.0$ Description **Component Type** Manufacturer Model UUT **Notes** 290mm deep Door extension box Extrap. Cable Compartment Schneider Electric 450mm deep Door extension box 1 Box Door extension box 500mm deep 17.72" Low Voltage Box LV Box C Extrap. 20.12" Low Voltage Box LV Box C with top control cable duct Extrap. Low Voltage Box Schneider Electric 25.35" Low Voltage Box LV Box Cmax 1 27.75" Low Voltage Box LV Box Cmax with top control cable duct 3 Rear Cable Extension Schneider Electric Rear cable extension Rear cable extension box 1,3 Single wide DATE 14.75" wide plinth 1, 3 Plinth Schneider Electric 29.5" wide plinth Double wide 1

# UNIT UNDER TEST (UUT) SUMMARY SHEET



## 1700706-CR-001 R0

Manufact						
Model Lin	Premset					1
UUT	Unit Description	Report Number	Testing Laboratory	S <sub>DS (g)</sub>	z/h	I <sub>P</sub>
1	Premset 15kV MV Switchgear Model Configuration: D12H & G12	PR061026-TR-17 (UUT1), and Premset RRS vs TRS Plots.pdf	NTS-Huntsville	2.19 2.46	1 0	1.5
3	Premset 15kV MV Switchgear Model Configuration: D06N & G06	PR069325-TR-17 (UUT1), and Premset RRS vs TRS Plots.pdf	NTS-Huntsville	2.25 2.39	1 0	1.5
		ED EOR CODE	COMP			
	EI EI	OSP-0560-10	T T T T T T T T T T T T T T T T T T T			
	0	BY:Ali Sume	E O			
	CAL	DATE: 02/26/201				
	The state of the s	Park Till	₩ N			
		BUILDING	CO			
Notes:						

TRU Compliance, by Structural Integrity Associates, Inc. 844.TRU.0200 | info@trucompliance.com

# UNIT UNDER TEST (UUT) SUMMARY SHEET



**UUT 1** 

## 1700706-CR-001 R0

*Manufacturer:* Schneider Electric

**Model Line:** Premset

Model Number: D12H & G12 Serial Number: ICFA41200LPHB/LDI/PS

**Product Construction Summary:** 

14 Ga. Painted Carbon Steel Enclosure.

#### Options/Subcomponent Summary:

Breakers (AAV91761), Low-Power Voltage Transformers (Zelisko 03816686No and Schneider Electric P7MSULPVT02), Mechanism(OCO), Motor Mechanism(PZM12003), Tank(D12H-P7MD06HC10), Tank Camera(NHA64038), Cable Test Device (P7MCTESTID1250A), Relays(Sepam), Ammeter(AMP 21D), Controllers(SC100 and SC-MI), Power Meters(ION7650), Current Transformers(P7MARU2 and PMARU1), Voltage Presence Indicator(VP162404 and VP162406), Live Cable Interlock(P7M12020 and P7M12021), Sensor(Easergy TH110/CL110), Power Supply(PS100), Cable Compartment Box(450MM), Low Voltage Box(25.35"), Rear Cable Extension, Plinth(14.75" and 29.5")

	UUT Properties											
Weight		Di <mark>mensi</mark> on (in)	UD11FL	Lowest	Natural Frequen	tural Frequency (Hz)						
(lb)	Depth	Width	Height	Front-Back	Side-Side	Vertical						
2586	60	44.25	99.5	13.5	7.2	13.0						
	<u> </u>	UUT Highest	Passed Seismic Ru	ın Information		<u> </u>						

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)		
CBC 2016	ICC-ES AC156	2.19	1.0	1.5	2.5	2.63 1.64	0.66			
	DATE: 02/2	6 2.46 1	9 0.0	1.5	3.5		1.04	0.66		

### Test Mounting Details:







Twelve (12) 1/2"-13 Grade 5 Bolts were used to mount the UUT to the test frame.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

02/26/2019 OSP-0560-10 Page 9 of 10

# UNIT UNDER TEST (UUT) SUMMARY SHEET



UUT3

## 1700706-CR-001 R0

**Manufacturer:** Schneider Electric

**Model Line:** Premset

Model Number: D06N and G06 Serial Number: 39555468-001

**Product Construction Summary:** 

14 Ga. Painted Carbon Steel Enclosure.

### Options/Subcomponent Summary:

Breaker(AAV91761), Low-Power Voltage Transformer(Schneider Electric P7MSULPVT01 and Zelisko 03816686NO), Mechanism(CI1), Motor Mechanism(P7M12003 and P7M12004), Tank(D06N-P7MD0XNC10), Tank Camera(NHA64038), Cable Test Device(P7MCTESTID), Relays(VIP Protection Relay, MiCOM, VD23, and Sepam), Fault Passage Indicator(Easergy Flair), Controllers(Sc100), Transfer System(ATS100), Power Meter(PM5000), Current Transformer(P7MARU1 and ARC6), Voltage Presence Indicator(VPI62403), Live Cable Interlock(P7MLCIMEXX and P7M12020), Cable Compartment Box(500mm), Low Voltage Box(27.75"), Rear Cable Extrension, Plinth(14.75")

	UUT Properties										
Weight		Di <mark>mensi</mark> on (in)	ension (in) Lowest Natural Freq			uency (Hz)					
(lb)	Depth	Width	Height	Front-Back	Side-Side	Vertical					
1860	62.54	A 29.5	99.5	14.0	6.5	>33.3					
		111711:1	D	XMANANA XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX							

**UUT Highest Passed Seismic Run Information** 

Building Code		Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2016		ICC-ES AC156 02/2	2.25	1.0	1.5	3.6	2.7	1.6	0.64
	W.		6 2.39) 1	9 0.0	1.5/				

Test Mounting Details:







Nine (9) 1/2"-13 Grade 5 Bolts were used to mount the UUT to the test frame.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.