



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0569 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Berg Electric

Manufacturer's Technical Representative: Brock Knowles

Mailing Address: 1935 Deere Avenue, Irvine, CA 92606

Telephone: (310) 912-7082

Email: bknowles@bergelectric.com

Product Information

Product Name: C & D Technologies 4-Tier Battery Rack and Micro ARE-M Series Ferroresonant Charger

Product Type: Backup Battery System

Product Model Number: Varies, see Attachment A

(List all unique product identification numbers and/or part numbers)

General Description: 4-Tier Battery rack with (20) Lead Acid Batteries and Ferroresonant Charger.

Seismic enhancements made to the test units to address anomalies observed during the tests shall be incorporated into the production units.

Mounting Description: Charger: Rigid wall mounted.

Battery rack: Rigid Base Mounted. **Battery Rack must be CD Technologies Rack Model #RDO1266.**

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

Contact Person: Andrew M. Coughlin, SE

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: 844-878-0200

Email: acoughlin@structint.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.


Signature of Applicant: _____

Date: 5/31/2018

Title: Director, TRU Compliance

Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

Name: Andrew M. Coughlin California License Number: S6082

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: 844-878-0200 Email: acoughlin@structint.com

Supports and Attachments Preapproval


Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)

Supports and attachments are not preapproved

Certification Method

Testing in accordance with: ICC-ES AC156

Other (Please Specify): _____




Testing Laboratory

Company Name: National Technical Systems (NTS)

Contact Name: Ratish Rao

Mailing Address: 1536 East Valencia Drive, Fullerton, CA 92831

Telephone: (714) 879-6110 Email: ratish.rao@nts.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 0.76

S_{DS} (Design spectral response acceleration at short period, g) = 1.681

a_p (In-structure equipment or component amplification factor) = 1

R_p (Equipment or component response modification factor) = 2.5

Ω_0 (System overstrength factor) = 2

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 0

Equipment or Component Natural Frequencies (Hz) = See Attachment A

Overall dimensions and weight (or range thereof) = See Attachment A

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = BY: Timothy J. Piland

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Attachment A


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: October 5, 2018

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to : S_{DS} (g) = 1.681 z/h = 0

Condition of Approval (if applicable): Battery Rack must be CD Technologies Rack Model #RDO1266



SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 1800053



Manufacturer: Berg Electric	TABLE 1
Model Line: Modular Battery Rack and Charger	

Certified Product Construction Summary:
Battery rack is constructed of painted carbon steel. The NEMA 1 enclosure for the battery charger is powder coated carbon steel.

Certified Options Summary:

Mounting Configuration:
Battery Rack - Rigid Base Mounted; Charger - Rigid Wall Mounted
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016 **Seismic Certification Limits:** $S_{DS} = 1.681 g$ $z/h = 0.0$ $I_p = 1.5$

Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
Modular Battery Rack	RD01266	20.25	43.5	60.44	2220	Qty: 20 Lead Acid Batteries	1
Micro ARE Charger	M13035A	19	20.5	30	460		2

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX


TRU PROJECT NO. 1800053



Manufacturer: Berg Electric	TABLE 2
Model Line: Modular Battery Rack and Charger	

Building Code: CBC 2016 **Seismic Certification Limits:** $S_{DS} = 1.681 g$ $z/h = 0.0$ $I_p = 1.5$

Model Line (Manufacturer)	Model	Dimension (in)			Weight (lb)	Material	Notes	UUT
		Depth	Width	Height				
Battery (Liberty)	LS6-200	6.84	16.58	8.95	95	6V lead-acid (VRLA), 200 Ah		1



UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1800053



Manufacturer: Berg Electric	UUT 1
Model Line: Modular Battery Rack and Charger	
Model Number: RD01266	
Serial Number: NTS1	

Product Construction Summary:
Steel rack with acid-resistant, scratch-resistant, and chip proof paint.

Options/Subcomponent Summary:
Twenty (20) Liberty LS6-200 batteries


UUT Properties

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2220	20.25	43.5	60.44	8.25	7.72	>33.3

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC156 10/05	1.68	1.8	0.0	1.5	1.68	0.67	1.12	0.45

Test Mounting Details:



Hold-Down

Unistrut

Rigid base mounted with four (4) 1/2" Grade 8 bolts with lock washer and flat washer. Unistrut was fastened on each tier at end of battery row to retain batteries in the side-to-side direction. Manufacturer provided RD01371 hold downs were installed at the top of the long sides of each tier to restrain the batteries in the vertical direction.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1800053



Manufacturer: Berg Electric	UUT 2
Model Line: Modular Battery Rack and Charger	
Model Number: ARE-M13035A Serial Number: BPS1876633	

Product Construction Summary:
NEMA 1, steel with baked powder coat finish

Options/Subcomponent Summary:
Input 240V /Output 130V

UUT Properties

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
460	19	20.5	30	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC156 10/05	1.68	1.8	0.0	1.5	1.68	0.67	1.12	0.45

Test Mounting Details:



Rigid wall mounted with four (4) 3/8" Grade 8 bolts with lock washer and flat washer.
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.
Contents were included in testing per operating conditions.



MODULAR BATTERY RACKS

FOR LIBERTY SERIES 1000®

C&D Technologies modular battery racks are designed to be flexible, durable, and easy to install. Engineered for use with C&D's Liberty Series 1000® batteries, these modular racks fit virtually any requirements.



APPLICATIONS

- Telecommunications
 - Private Branch Exchange (PBX)
 - Fiber Optic & Microwave sites
 - Outside Plant Facilities
- UPS
 - Data Centers
 - Industrial Process Control Facilities
 - Emergency 911 Response Centers
 - Air Traffic Control Centers
- Switchgear & Control
 - Portable Battery Trainers for Substation Battery Testing
 - Monitoring & Control Systems

FEATURES & BENEFITS

FLEXIBLE

- Stackable modules easily accommodate system expansion.
- Optional panels are available to completely enclose rack, providing a cabinet like appearance.
- Rack modules can be arranged end-to-end, back-to-back, and in tiered configurations.

DURABLE

- High-quality construction guarantees longer life.
- Acid-resistant paint is scratch-resistant and chip proof.

EASY TO INSTALL

- Rack can be ordered to ship fully assembled, requiring only onsite battery installation.
- Rack can ship unassembled as lower cost option.
- Racks are free standing, however floor-anchoring holes are provided (anchor bolts not supplied).

ACCESSIBLE

- Open rack allows easy maintenance and service.
- Optional panels remove easily to provide four-side access.

SEISMIC ZONE 4

- Standard modules vertically stacked and properly anchored meet 1994 UBC Zone 4 requirements (0.9g) up to four tiers.
- Five-tier modular rack with panels available for lower seismic applications (Zone 3, 0.675g).
- Special five-tier rack with bolt-on bracing is available that meets UBC Zone 4 requirements (panels not available).




RACK SPECIFICATIONS

Model	Seismic Zone	Number of Tiers	Width in (mm)	Depth in (mm)	Height in (mm)	Weight* lbs (kgs)	Optional panels lbs (kgs)	
29.00-in Racks								
RD01615	4	1	29.00 (736)	20.25 (514)	15.44 (392)	65 (30)	50 (23)	
RD01616	4	2			30.44 (773)	130 (59)	80 (36)	
RD01617	4	3			45.44 (1154)	195 (89)	112 (51)	
RD01618	4	4			60.44 (1535)	260 (118)	144 (65)	
RD01678**	4	5			25.25 (641)	75.44 (1916)	400 (181)	N/A
RD01623	3	5			20.25 (514)	75.44 (1916)	325 (148)	176 (80)
43.50-in Racks								
RD01263	4	1	43.50 (1105)	20.25 (514)	15.44 (392)	80 (36)	62 (28)	
RD01264	4	2			30.44 (773)	160 (72)	102 (46)	
RD01265	4	3			45.44 (1154)	240 (109)	142 (64)	
RD01266	4	4			60.44 (1535)	320 (145)	182 (83)	
RD01670**	4	5			25.25 (641)	75.44 (1916)	475 (216)	N/A
RD01262	3	5			20.25 (514)	75.44 (1916)	400 (181)	222 (101)

*Does not include the weight of the batteries, strictly empty rack weight

**Panels not available for this model

For racks with panels, use suffix "WP" with model number
(Example: RD01263WP specifies single tier rack with panels.)
Add 2.50 inches for each end panel, 0.75 inches for each front or rear panel, and 0.81 inches for the top panel.



Isometric Rack View

MAXIMUM RACK LOADING (NUMBER OF UNITS)

Model	LS12-100 (J) thru LS2-600 (J)
29.00-in Racks	
RD01615	4
RD01616	8
RD01617	12
RD01618	16
RD01678**	20
RD01623	20
43.50-in Racks	
RD01263	6
RD01264	12
RD01265	18
RD01266	24
RD01670**	30
RD01262	30


Note: Will fit LS12-100 through LS2-600 standard batteries and those with jackets.

For information on the Liberty Series 1000 batteries, please refer to brochure 12-373.


DATE: 10/05/2018
SCALE: 1/8" = 1'-0"
DRAWN BY: J. COOPER
CHECKED BY: J. COOPER
APPROVED BY: J. BEHMER

ZONE	REV	DESCRIPTION	DATE	CHKD	APPROVED
	15	REMOVED HOLD DOWN BOLTS, UPDATED FOOTING	10/05/2018	JTC	JTC


- NOTES:
- FLOOR MOUNTING HOLES ARE 0.594" SQUARE.
 - FLOOR MOUNTING BOLTS ARE NOT FURNISHED BY C&D.
 - STANDARD COLOR OF RACK IS DRIFTWOOD JPO0539.
 - ANCHOR BOLT SIZE & TYPE SHALL BE DETERMINED BY INSTALLER TO COMPLY WITH BUILDING CODES.
 - FOR SAFETY & STABILITY, THE MANUFACTURER RECOMMENDS THAT RACKS BE ANCHORED TO THE FLOOR.
 - TORQUE ALL BOLTS (RACK ONLY) TO 300 IN.-LBS.
 - REFER TO RS-990 FOR RECEIVING, HANDLING & INSTALLATION INSTRUCTIONS.
 - RACK WELDMENT (ITEM 1), SIDE RAILS (ITEM 2) & BUMPERS (ITEM 3) ARE ASSEMBLED FOR SHIPMENT. BRACES AND REMAINING HARDWARE SHIP LOOSE. SEE DWG. M09326 FOR SHIPPING SPECIFICATIONS.
 - ONE THRU FIVE TIER RACK ASSEMBLIES ARE DESIGNED FOR USE IN 1994 UBC ZONE 4 INSTALLATIONS.
 - OVERALL DIMENSIONS OF RACKS WITH PANELS ARE 48.50" x 22.00".




~~THREE TIER RD01265~~



~~SECTION "C-C"~~



~~FOUR TIER RD01266~~




~~SECTION "C-C"~~

BILL OF MATERIAL FOR RACKS ONLY


QUANTITIES	NAME	DESCRIPTION	PART NUMBER	ITEM
4	RD01265	FRAME	RD01263	1
8	RD01264	RAIL	RD01297	2
40	RD01264	BUMPER	RD01370	3
4	RD01264	BRACE	JH01797	4
12	RD01264	BOLT	REC0292	5
12	RD01264	NUT	PH01982P	6
24	RD01264	WASHER	PH01984P	7
20	RD01264	BOLT	JH00284	8
16	RD01264	NUT	PH01482P	9
12	RD01264	WASHER	JH01597	10
24	RD01264	WASHER	PH00798P	11
4	RD01264	NUT	PH00797P	12

BILL OF MATERIAL FOR RACK WITH PANELS


QUANTITIES	NAME	DESCRIPTION	PART NUMBER	ITEM
1	RD01266WP	1 TIER RACK	RD01263	14
1	RD01266WP	2 TIER RACK	RD01264	15
1	RD01266WP	3 TIER RACK	RD01265	16
6	RD01266WP	4 TIER RACK	RD01266	17
6	RD01266WP	PANEL FRONT AND REAR	RD01307	18
2	RD01266WP	PANEL END	RD01310	19
2	RD01266WP	PANEL TOP (END)	RD01312	20
1	RD01266WP	PANEL TOP (CENTER)	RD01311	21
16	RD01266WP	BOLT	PH00798P	22
4	RD01266WP	SCREW	JH00230	23
20	RD01266WP	NUT	PH01985	24
1	RD01266WP	LABEL C&D LOGO	PH01538	25
16	RD01266WP	WASHER	PH01538	26



~~TWO TIER RD01264~~



~~SECTION "C-C"~~



~~SECTION "C-C"~~

ALL SHEETS ARE THE SAME REVISION STATUS

C&D TECHNOLOGIES, INC.
1400 UNION MEETING ROAD, BLUE BELL, PA 19062-0688
www.candtechnologies.com

DATE: 11/27/00
CHECKED BY: J. COOPER
APPROVED BY: J. BEHMER

DATE: 11/27/00
CHECKED BY: J. COOPER
APPROVED BY: J. BEHMER

DATE: 11/29/06
CHECKED BY: J. BEHMER
APPROVED BY: J. BEHMER



FILE: M09251A
SCALE: NTS
SHEET 1 OF 3

ASSY: 43.5" MODULAR RACK
1 - 5 TIER, EP, LIBERTY 1000


DATE: 11/27/00

THE DRAWING AND THE MANUFACTURE THEREOF ARE THE PROPERTY OF THE COMPANY AND ARE NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF A QUALIFIED REPRESENTATIVE OF THE COMPANY.


REVISION HISTORY					
ZONE	REV	DESCRIPTION	DATE	BY	APPROVED
	15	REMOVED HOLD DOWN BRACES UPDATED FORMAT	10/09/18	SPK	SPK




SECTION "B-B"
SIDE RAIL ASSEMBLY




BRACE INSTALLATION
FOR BACK TO BACK ASSEMBLY
DISCARD BRACES ON ONE RACK
AND USE BRACES FROM ONE
RACK ONLY.




BRACE INSTALLATION
USE TWO LOCK WASHERS
FOR BRIDGE CONNECTIONS
WITH HEX NUT




DETAIL "A-A"
TYPICAL OF BOLTING OF TIERS
TOGETHER TO MAKE ONE UNIT



TYPICAL RACK (2 TIER SHOWN)
WITH BATTERIES IN PLACE



SECTION "C-C"
VIEW WITH BATTERIES
REMOVED



FOR LS 100/200/300/600
THIS BRACKET IS TO BE INSTALLED ON TOP TIER 10.59" FROM
LEFT HAND EDGE OR OF RAIL TO CL OF BRACKET. THE TWO
BUMPER WILL BE OMITTED WHEN BRACKET IS INSTALLED.
TERMINAL BLOCK & SUPPORT BRACKET ASSY RT00202

DRAWN C.H. HOUSTON		DATE 11/27/09
CHECKED S. J. JONES		DATE 11/27/09
APPROVED D. J. JONES		DATE 11/27/09
THIRD ANGLE PROJECTION		
UNION		
ALL SHEETS ARE THE SAME REVISION STATUS		
CD TECHNOLOGIES, INC.		
1400 UNION MEETING ROAD, BLUE BELL, PA 19422-0858		
TITLE ASSY: 43.5" MODULAR RACK 1 - 5 TIER, EP, LIBERTY 1000		
SIZE C	DATE CODE M09254	TOLERANCE 15
SCALE NTS	SHEET 2	OF 3