

| APPLICATION FOR OSHPD SPECIAL SEISMIC  | OFFICE USE ONLY  |
|--|--|
| CERTIFICATION PREAPPROVAL (OSP)  | APPLICATION #: OSP – 0574 – 10                         |
| OSHPD Special Seismic Certification Preapproval (OSP)  |  |
| Type: 🛛 New 🗌 Renewal  |  |
| Manufacturer Information   |  |
| Manufacturer: Power Technique North America LLC (Beacon Medaes)  | )  |
| Manufacturer's Technical Representative: <u>Tim Conner, Engineering M</u>  | lanager, Medical Gas Products                          |
| Mailing Address:1059 Paragon Way, Rock Hill, SC 29730  |  |
| Telephone: (803) 817-5600 Email: tim.cor   | nner@beaconmedaes.com                                  |
| Product Information  | 0.   |
| Product Name: MV Filter Modules  | 19 PL  |
| Product Type: Mechanical Equipment   | L'E  |
| Product Model Number: See attached   | CE   |
| (List all unique product identification numbers and/or part numbers)   |  |
|  | ain flasks, butterfly valves, and manifolds sitting on |
| manufacturer supplied frames   | 1 2  |
| Mounting Description: Units are rigid base mounted   |  |
|  | A.   |
| Applicant Information  | CODI   |
| Applicant Company Name: The VMC Group  |  |
| Contact Person: John Guiliano  |  |
| Mailing Address: 113 Main Street, Bloomingdale, NJ 07403   |  |
| Telephone: (973) 838-1780 Email: john.gi   | uliano@thevmcgroup.com                                 |
| I hereby agree to reimburse the Office of Statewide Health Pl<br>accordance with the California Administrative Code, 2016. | anning and Development review fees in                  |
| Signature of Applicant:  | Date: 8/16/18  |
| Title: President // Company Name: The VM   | MC Group   |
| "Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"                         | OSHPD  |
| 02/21/2019 OSP-0574-10   | Page 1 of 9  |



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)

Page 2 of 3

| California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)   |  |  |  |  |  |  |  |  |  |
|--|--|--|--|--|--|--|--|--|--|
| oanornia Licensed otractaral Engineer Responsible for the Engineering and rest Report(s)   |  |  |  |  |  |  |  |  |  |
| Company Name: The VMC Group  |  |  |  |  |  |  |  |  |  |
| Name: Kenneth Tarlow California License Number: SE-2851  |  |  |  |  |  |  |  |  |  |
| Mailing Address: 113 Main Street, Bloomingdale, NJ 07403   |  |  |  |  |  |  |  |  |  |
| Telephone: (973) 838-1780 Email: <u>ken.tarlow@thevmcgroup.com</u>   |  |  |  |  |  |  |  |  |  |
| Supports and Attachments Preapproval   |  |  |  |  |  |  |  |  |  |
| <ul> <li>Supports and attachments are preapproved under OPM-<br/>(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)</li> <li>Supports and attachments are not preapproved</li> </ul> |  |  |  |  |  |  |  |  |  |
| Certification Method OSHPD   |  |  |  |  |  |  |  |  |  |
| Testing in accordance with:       ICC-ES AC156 0574-10         Other (Please Specify):       BY:Ali Sumer  |  |  |  |  |  |  |  |  |  |
| C DATE: 02/21/2010   |  |  |  |  |  |  |  |  |  |
| Testing Laboratory   |  |  |  |  |  |  |  |  |  |
| Company Name: Dynamic Certification Labs   |  |  |  |  |  |  |  |  |  |
| Contact Name:Josh Sailer, Laboratory Manager   |  |  |  |  |  |  |  |  |  |
| Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431   |  |  |  |  |  |  |  |  |  |
| Telephone: _(775) 358-5085 Email: _josh@shaketest.com  |  |  |  |  |  |  |  |  |  |

OSHPD



Page 2 of 3

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)

| Seismic Parameters   |                             |
|--|-----------------------------|
| Design in accordance with ASCE 7-10 Chapter 13: 🛛 Yes 🗌 No   |                             |
| Design Basis of Equipment or Components $(F_p/W_p) = 3.00$   |                             |
| S <sub>DS</sub> (Design spectral response acceleration at short period, g) =                       | 2.50 g                      |
| a <sub>p</sub> (In-structure equipment or component amplification factor) =                        | 1.0                         |
| R <sub>p</sub> (Equipment or component response modification factor) =                             | 1.5                         |
| $\Omega_0$ (System overstrength factor) = 2.0  |                             |
| I <sub>p</sub> (Importance factor) = 1.5   |                             |
| z/h (Height factor ratio) =1.0   |                             |
| Equipment or Component Natural Frequencies (Hz) = ) See at   | tachment                    |
| Overall dimensions and weight (or range thereof) = <u>See att</u>                                  | achment                     |
| Equipment or Components @ grade designed in accordance with ASCE                                   | 7-10 Chapter 15: 🗌 Yes 🖾 No |
| Design Basis of Equipment or Components (V/W) =  |                             |
| S <sub>DS</sub> (Design spectral response acceleration at short period, g) =                       | ZC                          |
| $S_{D1}$ (Design spectral response acceleration at 1 second period, g                              | ) = (1)                     |
| R (Response modification coefficient ) =   |                             |
| $\Omega_0$ (System overstrength factor) =  | 0                           |
| $C_d$ (Deflection amplification factor) =  |                             |
| $I_p$ (Importance factor) = 1.5  | N N                         |
| Height to Center of Gravity above base =   | - AL                        |
| Equipment or Component Natural Frequencies (Hz) =  | 302                         |
| Overall dimensions and weight (or range thereof) = $D$   |                             |
|  | No                          |
| List of Attachments Supporting Special Seismic Certification                                       |                             |
| ☐ Test Report(s) ☐ Drawings ☐ Calculations ☑   | Manufacturer's Catalog      |
| Other(s) (Please Specify):   |                             |
| OSHPD Approval (For Office Use Only) – Approval Expires on D                                       | December 31, 2022           |
| Signature:   | Data: Eabruary 20, 2010     |
|  |                             |
| Print Name: <u>Ali Sumer</u>   |                             |
| Special Seismic Certification Valid Up to : $S_{DS}(g) = 2.5$                                      |                             |
| Condition of Approval (if applicable):   |                             |
|  |                             |
|  |                             |
| "Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs" | MAMA OSHPD                  |
| 02/21/2019 OSP-0574-10   | Page 3 of 9                 |

OSP-0574-10

<sup>&</sup>quot;Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

## **Table 1 - Certified Components**

 $(( \bullet))$  DCL <sub>Dynamic Certification Laboratories</sub>

Manufacturer: Power Technique North America LLC (Beacon Medaes)

Product Line: MV Filter Modules

### Product Construction: Powder-coated carbon steel frame Mounting Description · Rigid base mount

| wounting Description: Rigid base mount |                                    |     |                     |        |       |         |      |              |  |
|--|------------------------------------|-----|---------------------|--------|-------|---------|------|--------------|--|
| Model                                  | Description                        |     | Dimensions (inches) |        |       | Sds (g) | z/h  | Unit         |  |
| Number                                 |                                    |     | Width               | Height | (lb)  | 5us (g) | 2/11 | Offic        |  |
| MV80-2                                 | VACUUM FILTER ASM 45 SCFM 2" CONN  | 31  | 34                  | 63     | 220   |         |      | UUT1         |  |
| MV160-2                                | VACUUM FILTER ASM 90 SCFM 3" CONN  | 31  | 34                  | 65     | 273   |         |      | Interpolated |  |
| MV160-3                                | VACUUM FILTER ASM 180 SCFM 3" CONN | 45  | 34                  | 65     | 402   |         |      | Interpolated |  |
| MV160-4                                | VACUUM FILTER ASM 270 SCFM 4" CONN | 59  | 34                  | 66     | 536   | 2.5     | 1.0  | Interpolated |  |
| MV160-5                                | VACUUM FILTER ASM 360 SCFM 4" CONN | 73  | 34                  | 66     | 670   | 2.5     | 1.0  | Interpolated |  |
| MV160-6                                | VACUUM FILTER ASM 450 SCFM 4" CONN | 87  | 34                  | 66     | 787   |         |      | Interpolated |  |
| MV160-7                                | VACUUM FILTER ASM 540 SCFM 4" CONN | 101 | 34                  | 66     | 957   |         |      | Interpolated |  |
| MV160-8                                | VACUUM FILTER ASM 630 SCFM 4" CONN | 115 | 34                  | 66     | 1,110 |         |      | UUT2         |  |
|  | OK                                 | 001 | UM                  |        |       |         |      |              |  |



## **Table 2 - Nomenclature Chart**

```
((
)) DCL Dynamic Certification Laboratories
```

### Manufacturer: Power Technique North America LLC (Beacon Medaes) Product Line: MV Filter Modules В A Variable Definition Allowable Value Definition MV80 Medical Vacuum (MV) Size 80 Filter А Filter Size MV160 Medical (Acuum (NV) Size 160 Filter 2 filter assembly 2 3 filter assembly 3 4 filter assembly 4 5 5 filter assembly В Filter Quantity 6 filter assembly 6 7 7 filter assembly 9 8 filter assembly Example System: Medical Vacuum Filter Module, MV80, 2 filter assembly Example Model Numer: MV80-2 Example Description in BPCS: BY:A Line 1: MV80-2 Vacuum Filter ASM Line 2: 45 SCFM 2" Conn Example System: Medical Vacuum Filter Module, MV160, 2 filter assembly Example Model Numer: MV160-2 Example Description in BPCS: Line 1: MV160-2 Vacuum Filter ASM DING Line 2: 90 SCFM 3" Conn Example System: Medical Vacuum Filter Module, MV160, 5 filter assembly Example Model Numer: WV160-5 Example Description in BPCS: Line 1: MV160-5 Vacuum Filter ASM Line 2: 360 SCFM 4" Conn

## Table 3 - Certified Subcomponents

(( )) DCL Dynamic Certification Laboratories

### Manufacturer: Power Technique North America LLC (Beacon Medaes)

Product Line: MV Filter Modules

- -

#### Product Construction: Powder-coated carbon steel frame . . . ----

| wounting Descript | tion: Rigid base mou     | IIIL                             |                       | Approvimato           |                   |
|-------------------|--------------------------|----------------------------------|-----------------------|-----------------------|-------------------|
| Subcomponent      | Model Number             | Manufacturer                     | Notes                 | Approximate<br>Weight | Unit              |
| Bacterial filter  | 8102297952               | Walker Filtration Ltd.           | MV80                  | 20.7                  | UUT1              |
| Bacterial filter  | 8102297978               | Walker Filtration Ltd.           | MV160                 | 30.7                  | UUT2              |
| Drain flask       | 4107655895               | Walker Filtration Ltd.           | 100ML                 | 0.5                   | UUT1/UUT2         |
| Frame             | 4107655786               | Alloy Fabricators                | Welded, single filter | 43.1                  | UUT1/UUT2         |
|                   | 4107655746               | Marson International LLC         | 2X2"-2"               | 10.8                  | UUT1              |
|                   | 4107655747               | Marson International LLC         | 2X3"-3"               | 16.4                  | Interpolated      |
|                   | 4107655854               | Marson International LLC 2X3"-4" |                       | 18.8                  | Interpolated      |
| Manifold          | 4107655748               | Marson International LLC         | 3X3"-3"               | 23.0                  | Interpolated      |
|                   | 4107655852               | Marson International LLC         | 3X3"-4"               | 26.2                  | Interpolated      |
|                   | 4107655750               | Marson International LLC         | 4X3"-4"               | 33.5                  | UUT2              |
|                   | 4107655751               | Marson International LLC         | 5X3"-4"               | 40.9                  | Extrapolated      |
| Split manifold    | 4107655855               | Marson International LLC         | 4X3"-4"               | 39.4                  | UUT2 <sup>1</sup> |
| 00 dag albaw      | 4107655737               | Marson International LLC         | 2" FLG 2              | 4.8                   | UUT1              |
| 90 deg elbow      | 4107655739 🏷             | Marson International LLC         | 3" FLG                | 6.5                   | UUT2              |
| Puttorflyvalvo    | 410765578 <mark>4</mark> | Hajoca Corp.                     | 2" threaded           | 8.8                   | UUT1              |
| Butterfly valve   | 410765578 <mark>5</mark> | Hajoca Corp. Sume                | 3" threaded           | 12.6                  | UUT2              |

DING

Note:

1. Manufacturing process is ISO 9001 certified. PORNIA BUI

## Table 4 - Tested Components

*Manufacturer:* Power Technique North America LLC (Beacon Medaes)

Product Line: MV Filter Modules

### Product Construction: Powder-coated carbon steel frame

### *Mounting Description:* Rigid base mount

| Model   | Description                        | Dimensions (inches) |       |        | Weight | Sele (m) | z/h  | Unit |
|---------|------------------------------------|---------------------|-------|--------|--------|----------|------|------|
| Number  | er                                 |                     | Width | Height | (lb)   | Sds (g)  | 2/11 | Onit |
| MV80-2  | VACUUM FILTER ASM 45 SCFM 2" CONN  | 31                  | 34    | 63     | 220    | 2 5      | 1.0  | UUT1 |
| MV160-8 | VACUUM FILTER ASM 630 SCFM 4" CONN | 115                 | 34    | 66     | 1,110  | 2.5      | 1.0  | UUT2 |

((
)) DCL Dynamic Certification Laboratories



## UNIT UNDER TEST (UUT) Summary Sheet

Manufacturer: Power Technique North America LLC (Beacon Medaes)

Product Line: MV Filter Modules

Model Number: MV80-2

Product Construction Summary: Powder-coated carbon steel frame

Options / Component Summary: Bacterial Filter, Drain Flask, Butterfly Valve, 2" Manifold

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

| UUT Properties          |                         |         |                |  |            |            |            |            |  |  |
|-------------------------|-------------------------|---------|----------------|--|------------|------------|------------|------------|--|--|
| <b>Operating Weight</b> |                         | D       | imensions (in) | ensions (in) Lowest Natural Frequency (H |            |            |            | ency (Hz)  |  |  |
| (lb)                    |                         |         | Length         | Front-Back                               | Side-Side  | Vertical   |            |            |  |  |
| 220                     | UUT1 31.0 34.0 63.0     |         |                |  |            | 10.5       | 10.5       | >33.3      |  |  |
|                         | Seismic Test Parameters |         |                |  |            |            |            |            |  |  |
| Building Code           | Test Criteria           | Sds (g) | z/h            | lp                                       | Aflx-H (g) | Arig-H (g) | Aflx-V (g) | Arig-V (g) |  |  |
| CBC 2016                | ICC-ES AC156            | 2.50    | 1.0 P          |  | 4.00       | 3.00       | 1.67       | 0.67       |  |  |
| CBC 2010                | ICC-L3 AC150            | 2.50    | 0.0            | 1.5                                      | 4.00       | 5.00       | 1.07       | 0.07       |  |  |

((
)) DCL Dynamic Certification Laboratories

RECOMMENDED ANCHOR BOLT LOCATION SHOWN WITH 'X' (4 PLACES) 12MM X 1.50

Unit Mounting Description:



UUT 1 was rigid base mounted to the DCL interface fixture with (4) 1/2" diameter, Grade 5, bolts Bolts were spaced lengthwise at 14" and widthwise at 30.25" on center

SECTION A-A SCALE 1 / 6 **UNIT UNDER TEST (UUT) Summary Sheet** 

# (( )) DCL Dynamic Certification Laboratories

Manufacturer: Power Technique North America LLC (Beacon Medaes)

Product Line: MV Filter Modules

Model Number: MV160-8

Product Construction Summary: Powder-coated carbon steel frame

Options / Component Summary: Bacterial Filter, Drain Flask, Butterfly Valve, 4" Manifold

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

|                         |                         |         | UU             | T Properties |            |                               |            |            |  |  |
|-------------------------|-------------------------|---------|----------------|--------------|------------|-------------------------------|------------|------------|--|--|
| <b>Operating Weight</b> |                         | D       | imensions (in) |              |            | Lowest Natural Frequency (Hz) |            |            |  |  |
| (lb)                    |                         |         | Front-Back     | Side-Side    | Vertical   |                               |            |            |  |  |
| 1,110                   | UUT                     | 2       | 115.0          | 34.0         | 66.0       | 9.0                           | 10.0       | >33.3      |  |  |
|                         | Seismic Test Parameters |         |                |              |            |                               |            |            |  |  |
| Building Code           | Test Criteria           | Sds (g) | z/h            | lp           | Aflx-H (g) | Arig-H (g)                    | Aflx-V (g) | Arig-V (g) |  |  |
| CBC 2016                | ICC-ES AC156            | 2.50    | 1.00P          |              | 4.00       | 3.00                          | 1.67       | 0.67       |  |  |
| CBC 2010                | ICC-LS ACISO            | 2.50    | 0.0            | 1.5          | 4.00       | 3.00                          | 1.07       | 0.07       |  |  |

Unit Mounting Description:



UUT 2 was rigid base mounted to the DCL interface fixture with (16) 1/2" diameter, Grade 5, bolts Bolts were spaced lengthwise at 14" and widthwise at 30.25" on center