

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY			
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0580			
HCAI Special Seismic Certification Preapproval (OSP)				
Type: New X Renewal				
Manufacturer Information				
Manufacturer: Advanced Cooling Technologies, Inc.				
Manufacturer's Technical Representative: Cathy He				
Mailing Address: 3151 Independence Drive, Livermore, CA 94551				
Telephone: (925) 393-0780 Email: cathy.he@advanced	dcoolingtech.com			
Product Information				
Product Name: Chillers				
Product Model Number(s): See attached	E.			
Product Category: Chillers OSP-0580	1 CA			
Product Sub-Category: Chillers - Air Cooled				
General Description: Air cooled chiller containing condensers, evaporators,	pumps, compressors, and controller.			
Mounting Description: Rigid floor mounted and isolated floor mounted on nec	pprene pads			
Tested Seismic Enhancements: Seismic enhancements made to the test un anomalies during the tests shall be incorpor				
Applicant Information				
Applicant Company Name: Dynamic Certification Laboratories				
Contact Person: Kelly Laplace				
Mailing Address: 1315 Greg Street, Sparks, NV 894316098				
Telephone: (775) 358-5085 Email: kelly@shaketest.com	m			

Title: VP of Sales: Test and Measurement Division



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

"A healthier California where all receive equitable, affordable, and quality health care"

OSP-0580



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com
Certification Method
□ GR-63-Core
Other (Please Specify):
FOR CODE CON
Testing Laboratory
Company Name: DYNAMIC CERTIFICATION LABORATORY (DCL)
Contact Person: Josh Sailer
Mailing Address: 1315 Greg St., Ste 109, Sparks NV 89431
Telephone: (775) 358-5085
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Jeremy Lange Q DATE: 09/26/2024
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: jeremy@etldallas.com
BUILDING



"A healthier California where all receive equitable, affordable, and quality health care" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

OSP-0580



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Desig	n Basis of Equipment or Components	(Fp/Wp) =	Rigid:1.5, Iso.:3.6 (\$	SDS = 2.0g); Ri	gid:1.13, Iso.:1.5 (SDS = 2.5g)						
	SDS (Design spectral response accele	eration at sho	rt period, g) = 2.00	(z/h=1), 2.50 (z	:/h=0)						
	a_p (Amplification factor) = 2.5										
	Rp (Response modification factor) =	6.0 (rigid); 2.	5 (neoprene isolate	d)							
	Ω_0 (System overstrength factor) =	verstrength factor) = 2.0									
	Ip (Importance factor) =										
	z/h (Height ratio factor) =	1 and 0									
	Natural frequencies (Hz) =	See Attachm	nent								
	Overall dimensions and weight =	See Attachm	ent ODE CO	Mp,							
HCA	Approval (For Office Use Only) -	Approval E	xpires on 09/26/2	2030							
Date:	9/26/2024	C	SP-0580	G							
Name	e: Mohammad Karim			Title:	Supervisor, Health Facilities						
Speci	al Seismic Certification Valid Up to: SE	os (g) = 2.0	hammad Karin	z/h =	1						
Condi	tion of Approval (if applicable):	DATE:	09/26/2024								
		PRNIA B	UILDING C	005.00							



"A healthier California where all receive equitable, affordable, and quality health care" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

OSP-0580

Special Seismic Certification Table 1- Certified Components



DCL Project Number: 71124-2401

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Mounting: Base Mounted With and Without Nitrile Butadiene Rubber Isolator Pads

Certified Seismic Levels: Sds = 2.00g, z/h=1.0; Sds = 2.50g, z/h=0.0									
Model Number	Description		Dimensions [in.]		Weight	Unit			
Model Nulliber	Description	Depth	Width	Height	[lb.]	Onic			
CH10E1P4R407.M.GEH	10kw, R-410A Refrigerant	25.2	55.5	65.0	640	UUT-01			
CH10E1P4R513.M.GEH	10kw, R-513A Refrigerant	25.2	55.5	65.0	641	Interpolated			
CH.30E2P4.R410.M	30kw, R-410A Refrigerant	37.3	65.5	67.0	1,440	UUT-04			
CH.30E2P4.R513.M	30kw, R-513A Refrigerant	37.3	65.5	67.0	1,434	Interpolated			
CH55E4P4R513.M	55kw, R-513A Refrigerant	79.9	55.1	78.3	2,121	Interpolated			
CH55E4P4R410A.M	55kw, R-410A Refrigerant	79.9	55.1	78.3	2,130	UUT-02			
CH70E4P4R410.M	CH70E4P4R410.M 70kw, R-410A Refrigerant		40.9	75.2	2,920	UUT-03			

BY: Mohammad Karim

DATE: 09/26/2024

Special Seismic Certification Table 2 - Certified Subcomponents



DCL Project Number: 71124-2401

Model Number	Manufacturer	Description	Material	Weight [lb]	Unit
		Compressors			
ZR47KCE	Copland	Scroll Compressor, 4 kW	Iron, Copper	62	UUT-01
C-SBP205H38B	Panasonic	Scroll Compressor, 7.5 kW	Iron, Copper	85	UUT-03
C-SBP170H38B	Panasonic	Scroll Compressor, 5 kW	Iron, Copper	86	UUT-02, UUT-0
	1	Condensers			
8156513260	AIRSYS	Condenser; Copper Tube, 9.52 mm diameter	Copper, Aluminum	118	UUT-01, UUT-(
8156512900	AIRSYS	Condenser; Copper Tube, 7.0 mm diameter	Copper, Aluminum	198	UUT-02
8156512920	AIRSYS	Condenser; Copper Tube, 7.0 mm diameter	Copper, Aluminum	322	UUT-03
		Fan Units			
8251006340	Dunli	Fan Unit	Stainless Steel, Carbon Steel, Plastic, Aluminum	86	UUT-01
FN071-ZIQ.DG.V7P3	ZIEHL-ABEGG	Fan UnitOSP-058	Metal, Plastic	95	UUT-02
EC137-A500	Dunli	Fan Unit	Metal, Plastic	96	UUT-04
FN050	ZIEHL-ABEGG	O BY: Unitohammad	Karim Metal, Plastic	109	UUT-03
		Evaporators			
C62L-EZB-22	Danfoss	40-70 L/min, Plate-Type Evaporator	Stainless Steel	38	UUT-01, UUT-0
C62L-EZB-62	Danfoss	100-150 L/min, Plate-Type Evaporator	Stainless Steel	76	UUT-02
C62L-EZB-76	Danfoss	100-150 L/min, Plate-Type Evaporator	Stainless Steel	89	UUT-03
		Pumps			
MHI204	Wilo	40 mH ₂ O Pump, 1.5 kW	Iron, Copper, Aluminum, Stainless Steel	96	UUT-01, UUT-0
CM10-3	Grundfos	50 mH ₂ O Pump, 4 kW	Iron, Copper, Aluminum, Stainless Steel	219	UUT-02, UUT-0
		Expansion Valve	S		
TE20	Danfoss	Expansion Valve	Metal, Plastic	3	UUT-02, UUT-0
E2V24	Carel	Expansion Valve	Metal, Plastic	3	UUT-04
8155412270	Carel	Expansion Valve	Copper, Carbon Steel, Plastic	3	UUT-01
		Controller Units	;		
2040317370	AIRSYS	Controller Unit	Iron, Copper, Plastic	6	UUT-03
2040329530	AIRSYS	Controller Unit	Iron, Copper, Plastic	6	UUT-01, UUT-(
2040311800	AIRSYS	Controller Unit	Iron, Copper, Plastic	6	UUT-02

Special Seismic Certification Table 3- Tested Units



DCL Project Number: 71124-2401

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Mounting: Base Mounted With and Without Nitrile Butadiene Rubber Isolator Pads

5											
Certified Seismic Levels: Sds = 2.00g, z/h=1.0; Sds = 2.50g, z/h=0.0											
Mandal Number		Dimensions [in.]		Weight	Nitrile Butadiene	Test Report	11				
Model Number	Depth	Width	Height	[lb.]	Rubber Isolator Pads	[Lab]	Unit				
CH10E1P4R407.M.GEH	25.2	55.5	65.0	640	No	18042TR1.0 [Environmental Testing Lab]	UUT-01				
CH.30E2P4.R410.M	37.3	65.5	67.0	1,440	Yes	10322-2201 [DCL]	UUT-04				
CH55E4P4R410A.M	79.9	55.1	78.3	2,130	Yes	18042TR1.0 [Environmental Testing Lab]	UUT-02				
CH70E4P4R410.M	111.4	40.9	F 95.2	2,920	Yes	18042TR1.0 [Environmental Testing Lab]	UUT-03				
1											





UUT-01

Manwill Engineering Test Report Number: 18042TR1.0

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Model Number: CH10E1P4R407.M.GEH

Product Construction Summary: Painted Carbon Steel

Options / Component Summary: Compressors, evaporators, pumps, condensers and controller.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

			UUT	Properties				
Operating Weight		Din	nensions (in)			Lowest N	Natural Freque	ency (Hz)
(lb)	UUT		Depth	Width	Height	Front-Back	Side-Side	Vertical
640	UUT-01		25.2	55.5	65.0	8.9	10.0	>33.3
		NE	Seismic To	est Parameter	s			
Building Code	Test Criteria	Sds (g)	z/h	_ lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.00	1.0		3.20	2.40	N/A	N/A
CBC 2022		2.50	0.0SP	-0580	N/A	N/A	1.67	0.67

Unit Mounting Description:

Unit was rigid base mounted to the fixture using (6) 5/16" Grade 8 bolts with clipped washers.





UUT-01 Interior View

UUT-01 Front View



UUT-04

DCL Test Report Number: 10322-2201 (was UUT1 in test report)

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Model Number: CH.30E2P4.R410.M

Product Construction Summary: Painted Carbon Steel

Options / Component Summary: Compressors, evaporators, pumps, condensers and controller.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

			UUT	Properties				
Operating Weight		Din	nensions (in)			Lowest N	Natural Freque	ency (Hz)
(lb)	UUT		Depth	Width	Height	Front-Back	Side-Side	Vertical
1,440	UUT-04		37.3	65.5	67.0	16.0	6.0	30.0
		NEV	Seismic Te	est Parameter	s			
Building Code	Test Criteria	Sds (g)	z/h	_ lp	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.00	1.0	-0580	3.20	2.40	N/A	N/A
CBC 2022		2.50	0.0SP		N/A	N/A	1.67	0.67

Unit Mounting Description:

Unit was base mounted to the steel shake table interface plate with (4) Grade 8 5/8" bolts, flat washers, and manufacturer-supplied 4.0" x 4.0" x 0.8" nitrile butadiene rubber pads with a part number of 8254500670 manufactured by AIRSYS. The bolts were spaced 51" on-center in the X-direction and 33" on-center in the Y-direction using the manufacturer-provided channels at the base of the unit.





UUT-04 Interior View

UUT-04 Front View



UUT-02

Manwill Engineering Test Report Number: 18042TR1.0

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Model Number: CH10E1P4R407.M.GEH

Product Construction Summary: Painted Carbon Steel

Options / Component Summary: Compressors, evaporators, pumps, condensers and controller.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

			UUT	Properties				
Operating Weight		Din	nensions (in)			Lowest N	latural Freque	ency (Hz)
(lb)	UUT		Depth	Width	Height	Front-Back	Side-Side	Vertical
2,130	UUT-02		79.9	55.1	78.3	6.2	8.5	16.9
		NE	Seismic To	est Parameters	5			
Building Code	Test Criteria	Sds (g)	z/h	l p	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.00	1.0	-0580	3.20	2.40	N/A	N/A
		2.50	0.0SP		N/A	N/A	1.67	0.67

Unit Mounting Description:

Unit was base mounted to the fixture using (6) 4"x4"x0.75" neoprene pads and (6) 5/8" Grade 8 bolts.



UUT-02 Front View



UUT-02 Interior view



UUT-03

Manwill Engineering Test Report Number: 18042TR1.0

Manufacturer: AIRSYS Refrigeration Engineering Technology (Beijing) Co., Ltd., designed for Advanced Cooling Technologies, Inc.

Product Line: MEDICOOL

Model Number: CH70E4P4R410.M

Product Construction Summary: Painted Carbon Steel

Options / Component Summary: Compressors, evaporators, pumps, condensers and controller.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component and attachment system and force-resisting systems was maintained.

			UUT	Properties				
Operating Weight		Din	nensions (in)			Lowest N	Natural Freque	ency (Hz)
(lb)	UUT		Depth Width		Height	Front-Back	Side-Side	Vertical
2,920	UUT-03		111.4	40.9	75.2	8.9	7.4	22.9
		NE	Seismic To	est Parameter	s			
Building Code	Test Criteria	Sds (g)	z/h	l p	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2022	ICC-ES AC156	2.00	1.0	-0580	3.20	2.40	N/A	N/A
CBC 2022		2.50	0.0SP		N/A	N/A	1.67	0.67

Unit Mounting Description:

Unit was base mounted to the fixture using (6) 4"x4"x0.75" neoprene pads and (6) 5/8" Grade 8 bolts.



UUT-03 Back View