



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0629

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: AMETEK Powervar

Manufacturer's Technical Representative: On File

Mailing Address: 1450 Lakeside Drive, Waukegan, IL, 60085

Telephone: On File

Email: On File

Product Information

Product Name: 3400 Series UPS

Product Type: Uninterruptable Power Supply

OSP-0629

Product Model Number: See attached

(List all unique product identification numbers and/or part numbers)

General Description: The units are enclosures with a Main Board, Silicon Controlled Rectifier, Fuse, Insulated Gate Bipolar Transistor, Capacitor, Fans, Contactor, Battery Inductor, Power Factor Correction Inductor, and Inverter Inductor.

Mounting Description: Units are rigid base mounted.

Applicant Information

Applicant Company Name: The VMC Group

Contact Person: John Giuliano

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780

Email: john.giuliano@thvmcgroup.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.


Signature of Applicant: _____

Date: 12/2/19

Title: President

Company Name: The VMC Group

Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: The VMC Group

Name: Kenneth Tarlow California License Number: SE-2851

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403


Telephone: (973) 838-1780 Email: ken.tarlow@thevmcgroup.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____




Testing Laboratory

Company Name: DCL Labs

Contact Name: Josh Sailer, Laboratory Manager

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Email: josh@shaketest.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-16 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.44 ($S_{DS} = 2.00, z/h = 1$); 1.13 ($S_{DS} = 2.50, z/h = 0$)

S_{DS} (Design spectral response acceleration at short period, g) = 2.00 ($z/h = 1$), 2.50 ($z/h = 0$)

a_p (In-structure equipment or component amplification factor) = 1

R_p (Equipment or component response modification factor) = 2.5

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1 ($S_{DS} = 2.00$), 0 ($S_{DS} = 2.50$)

Equipment or Component Natural Frequencies (Hz) = See attachment

Overall dimensions and weight (or range thereof) = See attachment

Equipment or Components @ grade designed in accordance with ASCE 7-16 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = by William Staehlin

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): _____

OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025

Signature: William Staehlin

Date: April 17, 2021

Print Name: William Staehlin

Title: Senior Structural Engineer

Special Seismic Certification Valid Up to : S_{DS} (g) = See Above

z/h = See Above

Condition of Approval (if applicable): _____




Table 1 - Certified Components



Mounting Configuration: Rigid base mounted

Test Levels: Sds=2.0g, z/h=1.0; Sds=2.5g, z/h=0.0

Manufacturer: Kehua for AMETEK Powervar

Product Type: Uninterruptable Power Supply (UPS)

Product Line: 3400 Series UPS

Model Number	Max. Dimensions (in)			Max. Weight (lb)	Unit
	Length	Width	Height		
34080-01R	31.5	28.0	71.0	990	UUT 1
34100-01R	31.5	28.0	71.0	1000	Interpolated
34125-01R	31.5	28.0	71.0	1020	UUT 2



Table 2 - Certified Subcomponents



Mounting Configuration: Rigid base mounted

Test Levels: Sds=2.0g, z/h=1.0; Sds=2.5g, z/h=0.0

Manufacturer: Kehua for AMETEK Powervar

Product Type: Uninterruptable Power Supply (UPS)

Product Line: 3400 Series UPS

Subcomponent	Model Number	Description	Material	Weight (lb)	Unit
Main Board	A26-00288	ACDEF80.0-48D	Printed Circuit Board	1.1	UUT 1
	A26-00258	STA33125-H(V1.0)	Printed Circuit Board	1.1	Interpolated
			Printed Circuit Board	1.1	UUT 2
Silicon Controlled Rectifier (SCR)	A71-00014	MCC200-16iO1 1600V 216.0A	Ceramic, Aluminum	1.1	UUT 1
	A71-00013	SCR MCC200-16iO1 1600V 216.0A		0.8	UUT 2
Fuse	A35-00092	690V 315.0A	Copper, Fiberglass, Ceramic	0.2	UUT 1, UUT 2
Insulated Gate Bipolar Transistor (IGBT)	A74-00007	1200V 600A	Ceramic, Aluminum	0.7	UUT 2
	A74-00007	1200V 600A		0.7	Interpolated
	A74-00008	650V 600A		0.7	Interpolated
	A74-00008	650V 600A		0.7	UUT 2
	A74-00009	1200V 400A		0.7	UUT 2
	A74-00010	650V 450A		0.8	UUT 1
Capacitor	A32-00009	12 count (UUT 1) to 20 count (UUT 2) 500V 5600.0uF	Aluminum Electrolytic	2.7	UUT 1, UUT 2
Enclosure	3400-ENCLOSURE	Dimensions: 31.5" L x 28.0" W x 71.0" H	Powder Coated Carbon Steel	NA	UUT 1, UUT 2
Fan	A37-00055	(6) count DC Fan 4715VL-05W-869/DC24	Plastic	0.8	UUT 1, UUT 2
	A37-00056	(2) count DC Fan 9G0824G101/DC24	Plastic	0.37	UUT 1, UUT 2
Contactors	A48-00042	1NO+1NC 100-250V AC/DC 1000Vac 190.0A	Plastic	7.0	UUT 1, UUT 2
Battery Inductors	A07-00209	90uH	Aluminum, Ferrous Silicon	24.3	UUT 1, UUT 2
Power Factor Correction (PFC) Inductor	A07-00209	140uH	Aluminum, Silicon Steel	22.1	UUT 1, UUT 2
Inverter (INV) Inductor	A07-00211	150uH	Aluminum, Ferrous Silicon	19.4	UUT 1, UUT 2




Table 3 - Tested Units



Mounting Configuration: Rigid base mounted

Test Levels: Sds=2.0g, z/h=1.0; Sds=2.5g, z/h=0.0

Manufacturer: Kehua for AMETEK Powervar

Product Type: Uninterruptable Power Supply (UPS)

Product Line: 3400 Series UPS

Model Number	Dimensions (in)			Weight (lb)	Mounting	Unit
	Length	Width	Height			
34080-01R	31.5	28.0	71.0	990	Rigid base	UUT 1
34125-01R	31.5	28.0	71.0	1020	Rigid base	UUT 2



Unit Under Test (UUT) Summary Sheet

Manufacturer:	AMETEK Powervar (by Kehua)
Product Type:	Uninterruptable Power Supply
Product Line:	3400 Series Uninterruptable Power Supply
Model Number:	34080-01R
Mounting:	Rigid Base Mount

Product Construction Summary:
Powder Coated Carbon Steel

Options / Component Summary:
The unit is an Enclosure that encapsulates the following: a Main Board, Silicon Controlled Rectifier, Fuse, Insulated Gate Bipolar Transistor, Capacitor, Fans, Contactor, Battery Inductor, Power Factor Correction Inductor, and Inverter Inductor.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

UUT Properties

Operating Weight (lb)	Dimensions (inches)			Lowest Natural Frequency (Hz)		
	Length	Width	Height	Front-Back	Side-Side	Vertical
990	31.5	28.0	71.0	18.0	20.0	>33.3

Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2016	ICC-ES AC156	2.00	1.0	1.5	3.20	2.40	1.33	0.53
		2.50	0.0	1.5	2.50	1.00	1.67	0.68

Unit Mounting Description:



UUT 1 was rigid base mounted to a shake table interface plate with (4) 1/2" grade 5 bolts and washers at the base of the unit. The holes at the base of the unit were spaced 24" widthwise and 22" lengthwise. The unit had (3) manufacturer provided brackets (drawing: A05-00955) screwed to the side of the base of the unit with (2) manufacturer provided machine screws. Each bracket had (3) 3/8" grade 5 bolts and washers to mount it to the shake table interface plate for a total of (9) bolts mounted via the brackets. Each bolt on the bracket is spaced 10" apart.

UUT 2 Unit Under Test (UUT) Summary Sheet

Manufacturer:	AMETEK Powervar (by Kehua)
Product Type:	Uninterruptible Power Supply
Product Line:	3400 Series Uninterruptible Power Supply
Model Number:	34125-01R
Mounting:	Rigid Base Mount

Product Construction Summary:

Powder Coated Carbon Steel

Options / Component Summary:

The unit is an Enclosure that encapsulates the following: a Main Board, Silicon Controlled Rectifier, Fuse, Insulated Gate Bipolar Transistor, Capacitor, Fans, Contactor, Battery Inductor, Power Factor Correction Inductor, and Inverter Inductor.

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

UUT Properties

Operating Weight (lb)	Dimensions (inches)			Lowest Natural Frequency (Hz)		
	Length	Width	Height	Front-Back	Side-Side	Vertical
1,020	31.5	28.0	71.0	10.5	14.5	>33.3

Seismic Test Parameters

Building Code	Test Criteria	Sds (g)	z/h	Ip	Aflx-H (g)	Arig-H (g)	Aflx-V (g)	Arig-V (g)
CBC 2016	ICC-ES AC156	2.00	1.0	1.5	3.20	2.40	1.33	0.53
		2.50	0.0	1.5	2.50	1.00	1.67	0.68



Unit Mounting Description:






UUT 2 was rigid base mounted to a shake table interface plate with (4) 1/2" grade 5 bolts and washers at the base of the unit. The holes at the base of the unit were spaced 24" widthwise and 22" lengthwise. The unit had (3) manufacturer provided brackets (drawing: A05-00955) screwed to the side of the base of the unit with (2) manufacturer provided machine screws. Each bracket had (3) 3/8" grade 5 bolts and washers to mount it to the shake table interface plate for a total of (9) bolts mounted via the brackets. Each bolt on the bracket is spaced 10" apart.

REV	ECN	CHANGE DESCRIPTION	ENG	DATE	APP'D
X1		NEW RELEASE	NLF	06-04-2019	
X2		CHANGED STEEL THICKNESS TO 7 GA (FROM 3 GA)	NLF	06-05-2019	
X3		CHANGED LENGTH OF BRACKET FROM 31.006 to 30.006 (0.5 INCHES ON BOTH SIDES)	NLF	06-21-2019	

TOP VIEW



FRONT VIEW




HOLE LEGEND

HOLE	QUANTITY	SIZE	TOLERANCE	PEM
A	6	.492	--	--
B	2	.261	--	--
C	6	.492 x 1.557	--	--
D	3	.397	--	--

- NOTES: (UNLESS OTHERWISE SPECIFIED)
 1. ALL DIMENSIONS ARE IN INCHES.
 2. BREAK ALL SHARP EDGES.
 3. REF. CAD DATABASE FOR DIMENSIONS

TOLERANCE: XX=±.01 XXX=±.005	POWERVER INC.	SIZE: B
MATERIAL: 7 GA(.1793) COLD-ROLLED STEEL	FILE: A05-00955.DWG	PAGE 1 OF 2
FINISH: POWDER-COATED BLACK	SEISMIC MOUNTING BRKT, SIDE, 3400 SERIES	
SCALE: 0.250	BY: NLF	DWG No: A05-00955
		REVISION: X3

FLAT VIEW (DOTTED LINES ARE REF. BEND LINES)



TOLERANCE: XX=±.01 XXX=±.005		POWERVER INC.	SIZE: B
MATERIAL: 7 GA(.1793) COLD-ROLLED STEEL		FILE: A05-00955.DWG	PAGE 2 OF 2
FINISH: POWDER-COATED BLACK		SEISMIC MOUNTING BRKT, SIDE, 3400 SERIES	
SCALE: 0.250	BY: NLF	DWG No: A05-00955	REVISION: X3