



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0640**

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Vertiv Corporation

Manufacturer's Technical Representative: Julian Freeman

Mailing Address: 975 Pittsburgh Drive, Delaware, OH 43015

Telephone: (740) 833-8910

Email: julian.freeman@vertiv.com

**Product Information**

Product Name: UPS and Batteries

Product Type: UPS

Product Model Number: Varies (See attachment)

General Description: UPS Cabinets

Mounting Description: Rigid, Floor Mounted

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

**Applicant Information**

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.


Contact Person: Daniel Zentner

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: (541) 292-5839

Email: dzentner@structint.com

Title: Program Manager





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**


Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.  
Name: Andrew Coughlin California License Number: S6082  
Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 951381025  
Telephone: (415) 635-8461 Email: acoughlin@structint.com

**Certification Method**

GR-63-Core       ICC-ES AC156       IEEE 344       IEEE 693       NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)  
Contact Person: Jeremy Lange  
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513  
Telephone: (972) 247-9657 Email: jeremy@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.12 (SDS = 1.55, z/h = 1); 1.01 (SDS = 2.25, z/h = 0)

SDS (Design spectral response acceleration at short period, g) = 1.55 (z/h = 1), 2.25 (z/h = 0)

$a_p$  (Amplification factor) = 1.0

$R_p$  (Response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment


**HCAI Approval (For Office Use Only) - Approval Expires on 08/26/2028**

Date: 8/26/2022

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = See Above z/h = See Above

Condition of Approval (if applicable): DATE: 08/26/2022



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation						<b>TABLE 1</b>	
<b>Model Line:</b> Liebert EXS UPS							
<b>Certified Product Construction Summary:</b> Carbon Steel Frame and Skins							
<b>Certified Options Summary:</b> 10, 15, 20, and 30 kVA/kW 208/220V Three-Phase Power							
<b>Mounting Configuration (Standalone):</b> Base mounted - rigid Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.							
<b>Building Code: CBC 2022</b>		<b>Seismic Certification Limits:</b>			$S_{DS} = 1.55 g$ $z/h=1.0$	$I_p = 1.5$	
					$S_{DS} = 2.25 g$ $z/h=0.0$		
Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
EXS Frame 1 10 kVA	53S10AC1AXXXXX	25.6	13.2	51.2	437	1 Battery String	Extrap.
	...	...	...	...	...		Extrap.
EXS Frame 1S with Extended Battery 10 kVA	53S10EC2A0B0052	25.6	13.2	51.2	627.5	2 Battery Strings	1
	53S10AC3AXXXXX	25.6	22.7	51.2	893	3 Battery Strings	Interp.
	...	...	...	...	...		Interp.
EXS Frame 2 15-20 kVA	53S10FC4A0A0052	25.6	22.7	51.2	1,128.5	4 Battery Strings	2
	53S15GC2B0XXXXX	29.5	17.3	63.0	734	Identical to EXS 20kVa, Software	Interp.
	53S15AG3AXXXXX	29.5	17.3	63.0	888		Interp.
	53S15GC4AXXXXX	29.5	17.3	63.0	1,042		Interp.
	53S20GC6A0000CB	29.5	17.3	63.0	767.5	2 Battery Strings	3
	53S20GCXAXXXXXX	29.5	17.3	63.0	888		Interp.
53S20GC8A0C00CO	29.5	17.3	63.0	1,124.5	4 Battery Strings	4	
EXS Fame 3 30 kVA	53S30HCERXXXXXX	23.6	33.5	63.0	1,162	1 Battery String	Interp.
	53S30HCFR000CST	23.6	33.5	63.0	1,079.5	2 Battery Strings	5
EBC Frame 3	53BP30H11L1	23.6	33.5	63.0	870	1 Battery String	7
	53BP30H12L1	23.6	33.5	63.0	1,376	2 Battery Strings	6



# SPECIAL SEISMIC CERTIFICATION NOMENCLATURE MATRIX

1900510-CR-001-R4



**Manufacturer:** Vertiv Corporation  
**Model Line:** Liebert EXS UPS

**TABLE 3**

1-2	3	4-5	6	7	8	9	10	11	12	13-15
Product Line	System Type	Nameplate Rating	Frame Type	Input & Output Voltage	Battery String Qty & No. of Jars/String	Battery Model Code <sup>1</sup>	Factory Installed Communication Cards <sup>1,2</sup>	Factory Installed Distribution Slot 1	Factory Installed Distribution Slot 2 <sup>3</sup>	Config Digits
53 = Liebert EXS	S = Single Module	10 = 10kVA/10kW 15 = 15kVA/15kW 20 = 20kVA/20kW 30 = 30kVA/30kW	A = Frame 1 335mm, 10kA B = Frame 1S 570mm, 10kA E = Frame 1 335mm, 30kA F = Frame 1S 570mm, 30kA G = Frame 2 440mm, 30kA H = Frame 3 600mm, 30kA	C = 208/120 in 208/120 out Y = 220/127 in 220/127 out	O = None 1 = 1 String - 32 Jars 2 = 2 Strings - 32 Jars 3 = 3 Strings - 32 Jars 4 = 4 Strings - 32 Jars 6 = 2 Strings - 28 Jars 7 = 3 Strings - 28 Jars 8 = 4 Strings - 28 Jars E = 1 String - 20 Jars F = 2 Strings - 20 Jars G = 3 Strings - 20 Jars H = 4 Strings - 20 Jars	O = No Battery A = CSB HRL1234WF2FR R = CSB HRL12150WFR	O = IS-UNITY-LIFE / None 1 = IS-UNITY-SNMP / None 2 = IS-UNITY-DP / None 3 = IS-UNITY-LIFE / IS-RELAY 4 = IS-UNITY-LIFE / IS-485EXI 5 = IS-UNITY-SNMP / IS-RELAY 6 = IS-UNITY-SNMP / IS-485EXI 7 = IS-UNITY-DP / IS-RELAY 8 = IS-UNITY-DP / IS-485EXI A = IS-UNITY-DP / IS-UNITY-DP B = IS-UNITY-DP / IS-UNITY-SNMP C = IS-UNITY-SNMP / IS-UNITY-SNMP D = IS-485EXI / None E = IS-485EXI / IS-RELAY	These characters are shared for digits 11 & 12: O = None A - (2) L21-30R [PD3-001] B - (6) L6-30R [PD3-002] C - (6) L5-30R [PD3-003] D - (1) IEC60309 3W [PD3-004] E - (6) L5-20R [PD3-005] F - (6) L6-20R [PD3-006] G - (2) L15-30R [PD3-007] H - (1) CS8365C [PD3-008] J - (2) L21-20R [PD3-009] K - (2) L15-20R [PD3-010] L - (1) IEC60309 4W [PD3-011] 1 = (2) L6-30R, (8) 5-15/20R, [PD2-101] 2 = (4) L6-20R, (4) 5-15/20R, [PD2-102] 3 = (4) L6-30R, (4) 5-15/20R, [PD2-103] 4 = (2) L6-30R, (2) L6-20R, (4) 5-15/20R, [PD2-104] 5 = (2) L5-30R, (2) L5-20R, (4) 5-15/20R, [PD2-105] 6 = (4) L6-20R, (4) L5-20R, [PD2-106] 7 = (4) L5-20R, (4) 5-15/20R, [PD2-107] 8 = (2) L6-30R, (2) L6-20R, [PD2-108] 9 = (2) L14-30R, [PD2-109] W = (4) IEC320-C19, (4) IEC320-C13, [PD2-200] X = (2) IEC320-C19, (8) IEC320-C13, [PD2-201] Y = (12) IEC320-C13, [PD2-202] Z = (2) IEC320-32A, (4) IEC320-C13, [PD2-204]	Unique Number Automatic Assigned	

**Notes:**

1. Communication card code 3 is standard for the Liebert EXS 10 kVA model
2. Communication card codes A, B, and C are only available in Liebert EXS Frames 2 & 3 (15-30 kVA)
3. Distribution Slot #2 is only available on the Liebert EXS Frames 2 & 3 (15-30 kVA)

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1900510-CR-001-R4



Manufacturer: Vertiv Corporation		Table Description: Subcomponents					TABLE 4	
Model Line: Liebert EXS UPS								
Building Code: CBC 2022		Seismic Certification Limits: $S_{DS} = 1.55 g$ $z/h = 1.0$ $S_{DS} = 2.25 g$ $z/h = 0.0$					$I_p = 1.5$	
Model Line (Manufacturer)	Model	Dimension (in)			Weight (lb)	Material	Notes	UUT
		Depth	Width	Height				
Battery (CBS)	HRL123W-F2FR	2.60	6.00	3.70	6.00	Lead Acid		1, 2, 3, 4, 5
	HRL12150W-FR	7.70	5.12	6.80	26.50	Lead Acid		6, 7, 8
Battery (Data Safe)	12HX150	7.68	5.12	6.46	22.50	Lead Acid		8
Bypass /Maintenance Isolation Breaker (ABB)	S203-C40	2.10	2.70	3.50	0.80	Plastic		1, 2, 3
Maintenance Bypass Breaker (ABB)	S203-C50	2.10	2.70	3.50	0.80	Plastic		1, 2, 3
Rectifier Input Breaker (ABB)	S204-C40	2.80	2.70	3.50	1.10	Plastic		1, 2, 3
Breaker (NADER)	NDM1-125C80/3	2.80	2.70	3.50	1.20	Plastic		4, 5
	NDM1-125C125/3	2.80	2.70	3.50	1.20	Plastic		8
Breaker (Siemens)	3VA5217-5EC31-0AA0	4.20	4.10	7.30	4.50	Plastic		6, 7, 8
Communication Cards (Liebert)	IS-UNITY-LIFE		3.00	1.50	0.44	Carbon Steel and Plastic		1, 2
	IS-UNITY-SNMP		3.00	1.50	0.44			3
	IS-UNITY-DP		3.00	1.50	0.44			4
	IS-RELAY		3.00	1.50	0.44			5, 6
	IS-485EXI		3.00	1.50	0.44			5, 6





# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



**Manufacturer:** Vertiv Corporation

**Model Line:** Liebert EXS UPS

UUT	Unit Description	Report Number	Testing Lab	Year Tested	ISO 17025 Accredited?	S <sub>DS</sub>	z/h	I <sub>p</sub>
1	EXS Frame 1 (10kVA)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
2	EXS Frame 1S (10kVA w/ Battery)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
3	EXS Frame 2 (20kVA)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
4	EXS Frame 2 (20kVA)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
5	EXS Frame 3 - 30 kVA (2 String)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
6	EBC Frame 3 (2 String)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
7	EBC Frame 3 (1 String)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5
8	EBC Frame 3 - EXS Frame 3 (Ganged- 4 String)	15392, Rev.3	Environmental Testing Lab (ETL)	2019	Yes	1.55 2.25	1.0 0.0	1.5

**Notes:**

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 1</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53S10EC2A0B0052	
<b>Serial Number:</b> M19GBE0002	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 2 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL123W-F2FR), **Bypass/Maintenance Isolation Breaker:** ABB (S203-C40),  
**Maintenance Bypass Breaker:** ABB (S203-C50), **Rectifier Input Breaker:** ABB (S204-C40),  
**Communication Cards:** Liebert (IS-UNITY-LIFE), **Power Output Distribution:** Vertiv (PD3-002)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
627.5	25.6	13.2	51.2	13.84	10.59	22.50

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT1 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 610267P1) was attached to the unit with two (2) 3/8" Grade 5 Bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 2</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53S10FC4A0A0052	
<b>Serial Number:</b> M19GBE0003	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 4 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL123W-F2FR), **Bypass/Maintenance Isolation Breaker:** ABB (S203-C40),  
**Maintenance Bypass Breaker:** ABB (S203-C50), **Rectifier Input Breaker:** ABB (S204-C40),  
**Communication Cards:** Liebert (IS-UNITY-LIFE), **Power Output Distribution:** Vertiv (PD3-001)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,128.5	25.6	22.7	51.2	8.62	11.02	28.40

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT2 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 660130P1 & 660130P2, QTY 1 each) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 3</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53S20GC6A0000CB	
<b>Serial Number:</b> M19GB00002	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 2 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL123W-F2FR), **Bypass/Maintenance Isolation Breaker:** ABB (S203-C40),  
**Maintenance Bypass Breaker:** ABB (S203-C50), **Rectifier Input Breaker:** ABB (S204-C40),  
**Communication Cards:** Liebert (IS-UNITY-SNMP)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
767.5	29.5	17.3	63.0	11.52	5.92	>33.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT3 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 610224P1) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 4</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53S20GC8A0C00CO	
<b>Serial Number:</b> M19GB00003	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 4 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL123W-F2FR), **Breaker:** Nader (NDM1-125C80/3), **Communication Cards:** Liebert (IS-UNITY-DP),  
**Power Output Distribution:** Vertiv (PD3-003)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,124.5	29.5	17.3	63.0	9.06	3.79	19.97

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT4 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 610224P1) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 5</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53S30HCFR000CST	
<b>Serial Number:</b> M19GBE008	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 2 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL123W-F2FR), **Breaker:** Nader (NDM1-125C80/3), **Communication Cards:** Liebert (IS-RELAY, IS-485EXI)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,079.5	23.6	33.5	63.0	12.01	5.51	17.24

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT5 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 660124P1) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 6</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53BP30H12L1 <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 2 Battery Strings

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL12150W-FR), **Breaker:** Siemens (3VA5217-5EC31-0AA0), **Communication Cards:** Liebert (IS-RELAY, IS-485EXI)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1,376	23.6	33.5	63.0	11.21	6.44	22.20

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT6 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 609885P1) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 7</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53BP30H11L1 <b>Serial Number:</b> N/A	

**Product Construction Summary:**  
Carbon Steel Frame and Skin, 1 Battery String

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL12150W-FR), **Breaker:** Siemens (3VA5217-5EC31-0AA0)

**UUT Properties**

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
870	23.6	33.5	63.0	15.61	7.27	22.33

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



UUT7 was base mounted - rigid to the shake table with mounting brackets at the front and rear base of the unit. Each mounting bracket (Vertiv-PN: 609885P1) was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

1900510-CR-001-R4



<b>Manufacturer:</b> Vertiv Corporation	<b>UUT 8</b>
<b>Model Line:</b> Liebert EXS UPS	
<b>Model Number:</b> 53BP30H21L1 & 53S30HCER000CST	
<b>Serial Number:</b> M19GBE0007 & M19GBE0008	

**Product Construction Summary:**  
Carbon Steel Frame and Skin. Units ganged together and 4 Battery Strings.

**Options/Subcomponent Summary:**  
**Battery:** CBS (HRL12150W-FR) & Data Safe (12HX150), **Breaker:** Nader (NDM1-125C125/3) & Siemens (3VA5217-5EC31-0AA0)

**UUT Properties**

Weight <sup>1</sup> (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
2,957	23.6	67.0	63.0	7.22	4.13	17.48

**UUT Highest Passed Seismic Run Information**

Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022	ICC-ES AC156	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

**Test Mounting Details:**



<sup>1</sup>Weight listed is the total for ganged EXS and EBC. Individual details are as follows:  
  
EXS Frame 3: 1,581 lbs.  
EBC Frame 3: 1,376 lbs.

UUT8 ganged together with two (2) M10 bolts at the front and back junction of the cabinets. UUT8 was base mounted - rigid to the table with four (4) brackets provided by manufacturer (Vertiv-PN:660124P1 & 609885P1, QTY 2 each). Each mounting bracket was attached to the unit with four (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.