

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0640
HCAI Special Seismic Certification Preapproval (OSP)	
Type: New X Renewal	
Manufacturer Information	
Manufacturer: Vertiv Corporation	
Manufacturer's Technical Representative: Julian Freeman	
Mailing Address: 975 Pittsburgh Drive, Delaware, OH 43015	
Telephone: (740) 833-8910 Email: julian.freeman@ve	ertiv.com
Product Information	
Product Name: Varies (See attachment)	76.
Product Model Number(s): Varies (See attachment)	
Product Category: UPS and Batteries	72
Product Sub-Category: UPS USP-0640	
General Description: UPS Cabinets	
Mounting Description: Base Mounted Rigid	
Tested Seismic Enhancements: Seismic enhancements made to the test unanomalies during the tests shall be incorp	units and/or modifications required to address porated into the production units.
Applicant Information	
Applicant Company Name: Pre Compliance	4.
Contact Person: Galen Reid	
Mailing Address: 324 NW Hill St., Bend, OR 97703	
Telephone: (541) 241-2310 Email: galen@go-pre.cor	m



"A healthier California where all receive equitable, affordable, and quality health care"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Title: Principal and Program Manager



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: PRE COMPLIANCE
Name: Andrew Coughlin California License Number: S6082
Mailing Address: 324 NW Hill St, Bend, OR 97703
Telephone: (415) 635-8461
Certification Method
☐ GR-63-Core
Other (Please Specify):
Testing Laboratory
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Jeremy Lange
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: Jeremy@etldallas.com
Company Name: UNIVERSITY OF NEVADA, RENO (UNR)
Contact Person: Patrick LaPlace Py: Wonammad Karim
Mailing Address: 1664 N. Virginia Street, Reno NV 89557
Telephone: (775) 784-6937 Email: laplace@unr.edu

HCA

"A healthier California where all receive equitable, affordable, and quality health care"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Certified Response Spectral Acceleration Factors:(Fp/Wp)

Horizontal (A Flx-H), g= 2.48 (A Rig-H), g= 1.66

Vertical (A Flx-V), g= 1.50 (A Rig-V), g= 0.60

SDS (Design spectral response acceleration at short period, g) = 1.55 (z/h = 1), 2.25 (z/h = 0)

Hf (Force amplification height factor) = 1 @ z/h = 0; 3.5 @ z/h = 1

Ru (Structure ductility redution factor) = 1 @ z/h = 0; 1.3 @ z/h = 1

Ip (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

HCAI Approval (For Office Use Only) - Approval Expires on 11/03/2031

Date: 11/3/2025

Name: Mohammad Karim Title: Supervisor, Health Facilities

Condition of Approval (if applicable):

BY: Mohammad Karim

DATE: 11/03/2025



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENTS

Manufacturer: Vertiv Corporation

v Corporation Seismic Parameters

Building Codes

Product Type: UPS Model Line: EXS

 $S_{DS} = 1.55g \text{ for } R_{\mu}=1.3, H_f=3.5$ $S_{DS} = 2.25g \text{ for } R_{u}=1.0, H_f=1.0$

 $I_{\rm p} = 1.5$

CBC 2025

TABLE 1

Mounting Configuration: Rigid Base Mounted (Standalone)

Construction Summary

Options Summary

Carbon Steel Frame and Skins

10, 15, 20, and 30 kVA/kW 208/220V Three Phase Power

Model Line	Model	Max. Dimensions (in)		Wt.	Notes	UUT	
Model Lille	IVIOGCI	D	W	Н	(lb)	Notes	001
FVC Frame 1	53S10AC1AXXXXX	25.6	13.2	51.2	437	1 Battery String	Extrap.
EXS Frame 1 10 kVA				W 1994	HALL.		Extrap.
IOKVA	53S10EC2A0B0052	25.6	13.2	51.2	628	2 Battery Strings	1
EXS Frame 1S with	53S10AC3AXXXXX	25.6	22.7	51.2	893	3 Battery Strings	Interp.
Extended Battery			· 14		11:4		Interp.
10 kVA	53S10FC4A0A0052	25.6	22.7	51.2	1129	4 Battery Strings	2
	53S1 <mark>5GC2</mark> B0XXXX	29.5	al17.31a	63	734		Interp.
	53S1 <mark>5AG3</mark> AXXXXX	29.5	17.3	63	888	Id <mark>entic</mark> al to EXS 20kVA, Software	Interp.
5V0 5 0	53S15GC4AXXXXX	29.5	17.32	2635	1042		Interp.
EXS Frame 2	53S20GC6A0000CB	29.5	17.3	63	768	2 Battery Strings	3
15-20 kVA	53S20GCXAXXXXXX	29.5	17.3	63	888	29/	Interp.
	53S20GC8A0C00CO	29.5	17.3	63	1125	4 Battery Strings	4
	53S20GC8A0M00CO	29.5	17.3	63	1135	4 Battery Strings	9
EXS Frame 3	53S30HCERXXXXXX	23.6	33.5	63	1162	1 Battery String	Interp.
30 kVA	53S30HCFR000CST	23.6	733.5	63	1080	2 Battery Strings	5
EDO E	53BP30H11L1	23.6	33.5	63	870	1 Battery String	7
EBC Frame 3	53BP30H12L1	23.6	33.5	63	1376	2 Battery Strings	6



SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENTS

Manufacturer: Vertiv Corporation

Seismic Parameters

Building Codes

Product Type: UPS Model Line: EXS

 $S_{DS} = 1.55g$ for $R_{\mu}=1.3$, $H_f=3.5$ $S_{DS} = 2.25g$ for $R_{\mu}=1.0$, $H_f=1.0$

 $I_{p} = 1.5$

CBC 2025

TABLE 2

Mounting Configuration: Rigid Base Mounted (Ganged¹)

Construction Summary

Options Summary

Carbon Steel Frame and Skins

30 kVA/kW 208/220V Three Phase Power

Model Line	Model		Dimensio		Wt.	Notes	UUT
Wiodel Ellie	IVIOGOI	D	W	Н	(lb)	110103	
EXS Frame 3	53S30HCERXXXXXX	23.6	33.5	63	1162	1 Battery String	Extrap
30 kVA	53S30HCFR000CST	23.6	33.5	63	1080	2 Battery Strings	8
EBC Frame 3	53BP30H11L1	23.6	33.5	63	870	1 Battery String	Extrap
EBC Frame 3	53BP30H12L1	23.6	33.5	L <u></u> 63	1376	2 Battery Strings, 1344.5 lbs ²	8
	I R						
	OBBY	: Mor	amma	id Kar	m	70	
				#########	111/12		
		TC.	11/03	2025			
	T D	HE.	1703/	2020	7	187	
			1		444	2	
						V /	
	100					7	
	17/7				10		
		PI	TIDI	KIG			
		50	HLDI	140			

Notes:

- 1. UUT5 was ganged to an EBC Frame 3 Battery Cabinet (2 String) to create UUT8
- 2. EBC Frame 3 ganged battery cabinet weighs less than identical standalone due to right panel being removed to attach the unit to a UPS



SPECIAL SEISMIC CERTIFICATION NOMENCLAURE

Manufacturer: Vertiv Corporation

Seismic Parameters

Building Codes

Product Type: UPS Model Line: EXS

 S_{DS} = 1.55g for R_{μ} =1.3, H_f =3.5 S_{DS} = 2.25g for R_{μ} =1.0, H_f =1.0

I_p=1.5

CBC 2025

TABLE 3

MODEL LINE NUMBERING

					Liebert EXS UPS	Model Number Nomencla	ture			
1-2	3	4.5	- 6	7		9	10	- 11	12	13-14-15
Product Line	System Type	Name Plate Rating	Frame Type	Input/Output Voltage	Internal String City & # Jans/String	internal Battery Model Code	Factory installed Communications Cards (Slot 1/2) Note: red tax numbinations are only assemble to Frame 2 8 3 8 5	Factory installed POD Stat 1	Factory Installed POD Stot 2 Name: 2 and start parameters are analy accompanies for frame 2 & 2 & 2 & 3	Corrfle Digita
3 - Liebert EXS	3 - Single	10 - 10 kVA/kW	A - 335 mm (Frame 1), 10kA withstand	C+208/120-208/120	0 - None	0 - No Battery	0 - IS-UNITY-LIFE / None	0 - None	0 - None	100
	F - Parallel	15 - 15 kVA/kW	B - 570 mm (Frame 1 + Sidecar); 10kA withstand	V - 220/127-220/127	1-1 String-32 Jars	A - CSB HRL1234WF2FR	1 - IS-UNITY-SNMP / None	A - (2) L23-30R [PD3-001]	A - (2) (21-30K (PD3-001)	
	7 7 7	20 - 20 kVA/kW	E = 335 mm (Frame 1), 30kA withstand		2 - 2 Strings - 32 Jars	R - CSB HRL12150WFR	Z - IS-UNITY-DF / None	B - (6) L6-30R [FD3-002]	8 - (6) 1.6-308 [FD3-002]	
		30 - 30 kVA/kW	F - 570 mm (Frame 1 + Sidezar); 30vA withstand		3 - 3 Serings - 32 Jans	T - CSB HR1.12200WFR	Z - IS-UNITY-LIFE / IS-RELAY	C - (6) LS 30R [PD3-003]	C (6) 15-306 [FD3-003]	
		40 - 40 kVA/kW	G - 440 mm (Frame 2): 30kA withstand		4 - 4 Strings - 32 Jars	Uw Energys 12HX-150EFR	4 - 15-UNITY-UFE / IS-485EXI	D - (1) (EC60309 3 wire [PD3-004]	D=(1) (ECB0309 X with [PD3-004]	
			H - 600 mm (Frame 3) 30kA winnstand		6 - 2 Strings - 28 tars	Viv Energys 12HX-205FR	S - IS-UNITY-SNAAP / IS-RELAY	E - [6] 15-208 [PD3-005]	E - [6] LS-70R [PD3-005]	
			J - 600 mm (Frame 5); 30kA withstand		7 - 3 Serings - 28 Jany	1	6 - IS-UNITY-SHMP / IS-485EXI	# - (6) L6-20# [PD3-006]	F - (6) L6-20R [PD3-006)	
			K-600 mm (Frame 5); 30kA withstand, with Top Fan Mount		8 - 4 Strings - 28 Jars		7 - IS-UNITY-OF / IS-RELAY	6 - [1 (ab-alls (+0 nod))	G - (2) c15-308 [FO3-027]	
					\$-1 Sering - 20 Jara		6 - IS-UNITY-DP / IS-465 D0	H-(H) CHARS-CHROSONI	H - (1) C5836-AC [PD3-658]	
					F = 2 Strings = 20 Janu		A - IS-UNITY-DP / IS-UNITY-DP	7 - (2) LZ1-20K [FD8-009]	(-(3) 121/208 (FD.E-009)	
					G - 3 Strings - 20 lare		B - IS-UNITY DP / IS-UNITY-SNMP	F (ST) 20 200 FFC 6 HIS	K- (F) L15-7HR (PUR-H10)	
					H - 4 Strings - 20 Jans		C - IS-UNITY-SNMP / IS-UNITY-SNMP	L - (1) ICC60509 4-wire [FG3-011]	L - (1) Inciation 4-wire [Post-011]	
							D : IS-48SEXI / None	GNO Quepur (PD3-300)	(4 – (1) nurseppe TB – 4 by re + 0 pD trgue (4 by a + 0 pD Organ (PO) - 100)	
							F - IS-GESEXI / IS-RELAY	1 - (2) L6-30R, (R) 5-15/20R [PD2-101]	1 - (3) 16-10K, (K) 5-16/20K [PD2-103.]	
								2-(4) L6-20R, (4) 5-15/20R [FD2-102]	2 - (4) L6-208, (4) 5-15/208 [FD2-162]	
								3 - (4) L6-50R (4) 5-15/208 [PD2-103]	3-(4) LG-30K, (4) 5-15/208 [P02-(03]	
	_								4 - (2) 10-808, (2) 16-208; (4) 5-15/208 [PD2-104]	_
									5 - (2) L5-90K, (2) L5-20K, (4) 5-15/20K [PD2-105]	
					_	_		6 (4) L6-208, (4) L5-208 [FD2-106]	6 (4) 16 208 (4) LS 208 [FDZ-106]	
	_			_				7 - (4) L5-20R, (4) 5-15/20R [PD2-107]	7 - [4] LS-208, [4] S-18/208 [PD2-107]	_
	_			_	_	_		8 - [2] L6-30R, [2] L6-20R [PD2-108]	6-12) L6-809, [2] L6-20R [902-108]	_
				_	_	+		9 - (2) L14-30R [PD2-109]	8 (5) F14 USE [LICS-100]	_
	_			_	_			W - (4) (EC320-C19, (4) (EC320-C13 [PD2-200]	W - [4] (BC-820-C19, [4] (BC-820-C13 [FD2-200]	_
	-			_	+	1		X - (2) (EC326-C19, (8) (EC326-C18 [PD2-201] Y - (12) (EC326-C13 [PD2-202]	X - (3) WC330-C33 (8) WC330-C33 (P02-703) V - (12) WC330-C33 (P02-202)	_
	_			_	_			7 - 1221 (EC320-C13 (PD2-202) Z - (2) (EC320-32A, (4) (EC320-C13 (PD2-204)	7 - (12) (C.120-12A, (4) (C.120-C13 [PO2-208]	_
	_				+	_		e-16 acted and tal acted of 12 land foul	E. 151 acres and or the transfer start.	_

DATE: 11/03/2025

- 1. Communication card code 3 is standard for the Liebert EXS 10 kVA Model
- 2. Communication card codes A, B, and C are only available in Liebert EXS Frames 2 & 3 (15-30 kVA)
- 3. Distribution Slot #2 is only available on the Liebert EXS Frame 2 & 3 (15-30 kVA)



SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENTS

Manufacturer: Vertiv Corporation

Seismic Parameters

Building Codes

Product Type: UPS Model Line: EXS

 S_{DS} = 1.55g for R_{μ} =1.3, H_f =3.5 S_{DS} = 2.25g for R_u =1.0, H_f =1.0

I_p=1.5

CBC 2025

TABLE 4

Table Description: Electrical Components

Component (Manufacturer)	Model	Dim D	ensions W	(in)	Wt. (lb)	Material	UUT
Battery	HRL123W-F2FR	2.6	6.0	3.7	6	Lead Acid	1,2,3,4,5,9
(CSB)	HRL12150W-FR	7.7	5.12	6.8	26.5	Lead Acid	6,7,8
Battery (Data Safe)	12HX150	7.68	5.12	6.46	22.5	Lead Acid	8
Bypass/ Maintenance Isolation Breaker (ABB)	S203-C40	2.1 OSI	2.7	3.5	0.8	Plastic	1,2,3
Maintenance Bypass Breaker (ABB)	\$203-C50	2.1	2.7	3.5 ad Kar	0.8 im	Plastic	1,2,3
Rectifier input Breaker (ABB)	S204-C40	2.8	2.7	3.5	1.1	Plastic	1,2,3
Breaker	NDM1-125C80/3	2.8	2.7	3.5	1.2	Plastic	4,5,9
(Nader)	NDM1-125C125/3	2.8	2.7	3.5	1.2	Plastic	8
Breaker (Siemens)	3VA5217-5EC31-0AA0	4.2	4.1	7.3	4.5	Plastic	6,7,8
	IS-UNITY-LIFE		3.0	1.5	0.44		1,2
Communication	IS-UNITY-SNMP		7 (3.0)	1.5	0.44		3
Cards	IS-UNITY-DP		3.0	1.5	0.44	Carbon Steel and Plastic	4,9
(Liebert)	IS-RELAY		3.0	1.5	0.44		5,6
	IS-485EXI		3.0	1.5	0.44		5,6

Pre Compliance www.go-pre.com (541) 241-2310

11/03/2025 OSP-0640 Page 7 of 18



SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENTS

Vertiv Corporation

Seismic Parameters

Building Codes

Product Type: UPS Model Line: EXS

Manufacturer:

 $S_{DS} = 1.55g \text{ for } R_{\mu}=1.3, H_f=3.5$ $S_{DS} = 2.25g \text{ for } R_{u}=1.0, H_f=1.0$

 $I_p = 1.5$

CBC 2025

TABLE 5

Table Description: Power Output Distribution (PODS)

Component	Model	Dim	ensions	s (in)	Wt.	Material	Notes	UUT
(Manufacturer)	Model	D	W	Н	(lb)	Material	Notes	001
	PD3-001		7.4	5.7	4.4		(2) L21-30R	2
	PD3-002		7.4	5.7	6.6		(6) L6-30R	1
	PD3-003		7.4	5.7	6.6		(6) L5-30R	4
	PD3-004		7.4	5.7	4.4	111	(1) IEC60309 - 60A (4W+G)	Interp.
D	PD3-005		7.4	5.7	6.6		(6) L5-20R	Interp.
Power Output Distribution	PD3-006		7.4	5.7	6.6	Carbon Steel and	(6) L6-20R	Interp.
(Vertiv)	PD3-007		7.4	5.7	4.4	Plastic	(2) L15-30R	Interp.
(Vertiv)	PD3-008/		(7,4)	D_5.76_	4.4	1 lastic	(1) CS8364C- 60A	Interp.
	PD3-009		7.4	5.7	4.4		(2) L21-20R	Interp.
	PD3 <mark>-010</mark>		7.4	5.7	4.4		(2) L15-20R	Interp.
	PD3-011		7.4	1215.712	4.4	im /	(1) IEC60309 - 60A (3W+G)	Interp.
	PD3-100	4.9	16.7	12.7	17			9
			TE	1/03	2025			
		1 2/	· · ·		2444iii		//	
				7.4		組織	/	
		5		AI.				
		PA						
			1			.0.		
			BC	II DI	NO			



SPECIAL SEISMIC CERTIFICATION TESTING SUMMARY

UUT	Model Description	Test Report	Testing Lab	Test Date	S _{DS}	R_{μ}	H _f	I _p
1	EXS Frame 1 (10 kVA)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
2	EXS Frame 1S (10 kVA w/Battery)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
3	EXS Frame 2 (20 kVA)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
4	EXS Frame 2 (20 kVA)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
5	EXS Frame 3 - 30 kVA (2 String)	15392, Rev.3	DE CO	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
6	EBC Frame 3 (2 String)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
7	EBC Frame 3 (1 String)	15392, Rev.3	ETL	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
8	EBC Frame 3 - EXS Frame 3 (Ganged - 4 String)	15392, Rev.3)640 _{ETL}	8/5/2019	1.55 2.25	1.3 1.0	3.5 1.0	1.5
9	EXS Frame 2 - 20 kVA (4 String)	TR251751-01-R0 (UUT1)	mad KNRm	9 <mark>/11/20</mark> 25	1.55 2.25	1.3 1.0	3.5 1.0	1.5
Notes:		DATE: 11/	03/2025 DING CO					



 H_f

3.5

1.0

UUT 1

SDS

1.55

2.25

 R_{μ}

1.3

1.0

Test Report# 15392, Rev.3

Highest Passed Test Level

 A_{flx-h}

2.48

 A_{rig-h}

1.66

 $\boldsymbol{A}_{\text{flx-v}}$

1.50

 A_{rig-v}

0.60

Manufacturer: Vertiv Corporation

Model Line: EXS

Model Number: 53S10EC2A0B0052

Serial Number: M19GBE0002 **Description:** 10kVA Frame 1 UPS

Dimensions/Weights

Depth (in) Width (in) Height (in) Weight (lbs.)

25.6 13.2 51.2 628

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 13.8 10.6 22.5

1.5

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin
2 Battery Strings

UUT Mounting Details:



ť	List of Included Su	ubcomponents
	Description (Manufacturer)	Model #
	Batteries (CSB)	HRL123W-F2FR
	Circuit Breaker (ABB)	S203-C40
	Circuit Break <mark>er (AB</mark> B)	S203-C50
	Circuit Breaker (ABB)	S204-C40
	Communication Card (Liebert)	IS-UNITY-LIFE
	POD (Vertiv)	PD3-002

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:610267P1) and were attached to the unit using (2) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



Test Report# 15392, Rev.3

Manufacturer: **Vertiv Corporation**

Model Line: EXS

Model Number: 53S10FC4A0A0052

Serial Number: M19GBE0003

Description: 10kVA Frame 1S w/extended battery

Dimensions/Weights

Height (in) Depth (in) Width (in) Weight (lbs.)

25.6 22.7 51.2

1129

 H_f A_{flx-h} SDS R_{μ} A_{riq-h}

 $\boldsymbol{A}_{\text{flx-v}}$ A_{riq-v} 1.55 1.3 3.5 1.5 2.48 1.66 1.50 0.60

Highest Passed Test Level

2.25 1.0 1.0

JING COOK

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 8.6 11.0 28.4

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin 4 Battery Strings

UUT Mounting Details:



Liet of Ir	cluded	Subcom	nonente

Description (Manufacturer)	Model #					
Batteries (CSB)	HRL123W-F2FR					
Circuit Breaker (ABB)	S203-C40					
Circuit Break <mark>er (AB</mark> B)	S203-C50					
Circuit Breaker (ABB)	S204-C40					
Communication Card (Liebert)	IS-UNITY-LIFE					
POD (Vertiv)	PD3-001					
erinnillati i i i i v						

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:660130P1 & 660130P2) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (4) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



Test Report# 15392, Rev.3

Manufacturer: **Vertiv Corporation**

Model Line: EXS

Model Number: 53S20GC6A0000CB

Serial Number: M19GB00002

Description: 20kVA Frame 2 UPS

Dimensions/Weights

Weight (lbs.) Depth (in) Width (in) Height (in)

768 29.5 17.3 63

Highest Passed Test Level H_f

1.5

 A_{flx-h} $\boldsymbol{A}_{\text{flx-v}}$ SDS R_{μ} A_{riq-h} A_{riq-v} 1.55 1.3 3.5 2.48

1.66

1.50

0.60

2.25 1.0 1.0

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 11.5 5.9 >33.3

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

E: 11/03/2

Construction/Option Summary

Carbon Steel Frame and Skin 2 Battery Strings

UUT Mounting Details:



List of Included Subcomponents						
Description (Manufacturer)	Model #					
Batteries (CSB)	HRL123W-F2FR					
Circuit Breaker (ABB)	S203-C40					
Circuit Break <mark>er (AB</mark> B)	S203-C50					
Circuit Breaker (ABB)	S204-C40					
Communication Card (Liebert)	IS-UNITY-SNMP					
POD (Vertiv)	PD3-001					

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:610224P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



JUJT 4

SDS

1.55

2.25

Test Report# 15392, Rev.3

Highest Passed Test Level

1.5

 A_{flx-h}

2.48

 $\boldsymbol{A}_{\text{flx-v}}$

1.50

 A_{rig-v}

0.60

 A_{riq-h}

1.66

Manufacturer: Vertiv Corporation

Model Line: EXS

Model Number: 53S20GC8A0C00C0

Serial Number: M19GB00003

Description: 20kVA Frame 2 UPS

Lowest Natural Frequency (Hz)

 R_{μ}

1.3

1.0

 H_f

3.5

1.0

 Depth (in)
 Width (in)
 Height (in)
 Weight (lbs.)
 Front-Back
 Side-Side
 Vertical

 29.5
 17.3
 63
 1125
 9.1
 3.8
 20.0

Building Codes

Test Criteria

Construction/Option Summary

Carbon Steel Frame and Skin 4 Battery Strings

CBC 2025

ICC-ES AC156

OSP-0

Mohami

UUT Mounting Details:

Dimensions/Weights



minutes III IIII	
List of Included Subcomponents	
Description (Manufacturer)	Model #
Batteries (CSB)	HRL123W-F2FR
Circuit Breaker (Nader)	NDM1-125C80/3
Communication Card (Liebert)	IS-UNITY-DP
13/2025 POD (Vertiv)	PD3-003

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:610224P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



 H_f

3.5

1.0

JUT 5

SDS

1.55

2.25

 R_{μ}

1.3

1.0

Test Report# 15392, Rev.3

Highest Passed Test Level

 A_{flx-h}

2.48

 $\boldsymbol{A}_{\text{flx-v}}$

1.50

 A_{rig-v}

0.60

 A_{riq-h}

1.66

Manufacturer: Vertiv Corporation

Model Line: EXS

Model Number: 53S30HCFR000CST

Serial Number: M19GBE008

Description: 30kVA Frame 3 UPS

Dimensions/Weights

Depth (in) Width (in) Height (in) Weight (lbs.)

23.6 33.5 63 1080

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 12.0 5.5 17.2

1.5

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin
2 Battery Strings

UUT Mounting Details:



	List of included Subcomponents	
34	Description (Manufacturer)	Model #
	Batteries (CSB)	HRL123W-F2FR
12	Circuit Breaker (Nader)	NDM1-125C80/3
	Communication Card (Liebert)	IS-RELAY
3	Communication Card (Liebert)	IS-485EXI

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:660124P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



Test Report# 15392, Rev.3

Manufacturer: **Vertiv Corporation**

Model Line: EXS EBC Model Number: 53BP30H12L1

Serial Number: N/A

Description: EBC Frame 3

Dimensions/Weights

Depth (in) Width (in) Weight (lbs.) Height (in) 1376 23.6 33.5 63

 H_f $\boldsymbol{A}_{\text{flx-v}}$ SDS R_{μ} A_{flx-h} A_{riq-h} A_{rig-v} 1.55 1.3 3.5 1.5 2.48 1.66 1.50 0.60 2.25 1.0 1.0

Highest Passed Test Level

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 11.2 6.4 22.2

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

OSP-06

Construction/Option Summary

Carbon Steel Frame and Skin 2 Battery Strings

UUT Mounting Details:



List of included Subcomponents		ibcomponents
2	Description (Manufacturer)	Model #
	Batteries (CSB)	HRL12150W-FR
2	Circuit Breaker (Siemens)	3VA5217-5EC31-0AA0
	Communication Card (Liebert)	IS-RELAY
3	Communication Card (Liebert)	IS-485EXI
01		

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:609885P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



 H_f

3.5

1.0

SDS

1.55

2.25

 R_{μ}

1.3

1.0

Test Report# 15392, Rev.3

Highest Passed Test Level

 A_{flx-h}

2.48

 $\boldsymbol{A}_{\text{flx-v}}$

1.50

 A_{riq-v}

0.60

 A_{riq-h}

1.66

Manufacturer: **Vertiv Corporation**

Model Line: EXS EBC Model Number: 53BP30H11L1

Serial Number: N/A

Description: EBC Frame 3

Dimensions/Weights

Weight (lbs.) Depth (in) Width (in) Height (in) 23.6

870 33.5 63

Lowest Natural Frequency (Hz)

1.5

Side-Side Front-Back Vertical 15.6 7.3 22.3

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin 1 Battery String

of Included Subcomponents

UUT Mounting Details:



List of misladed subscinipenients	
Description (Manufacturer)	Model #
Batteries (CSB)	HRL12150W-FR
Circuit Breaker (Siemens)	3VA5217-5EC31-0AA0

F· 11/03/2025

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:609885P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.



UUT 8 Test Report# 15392, Rev.3

 R_{μ}

 H_f

Manufacturer: Vertiv Corporation

Model Line: EXS + EBC

Model Number: 53S30HCFR000CST + 53BP30H12L1

Serial Number: M19GBE0008 + M19GBE0007

Description: 30kVA Frame 3 UPS + EBC Frame 3

Dimensions/Weights

Depth (in) Width (in) Height (in) Weight (lbs.)¹
23.6 67 63 2957

Weight (lbs.)¹ Front-Back

SDS

 A_{flx-h}

 $\boldsymbol{A}_{\text{flx-v}}$

 A_{riq-v}

 A_{riq-h}

Highest Passed Test Level

Lowest Natural Frequency (Hz)

Front-Back Side-Side Vertical 7.2 4.1 17.5

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin Ganged with 4 Battery Strings

UUT Mounting Details:



Description	Model#
(Manufacturer)	Model #

Batteries (CSB) HRL12150W-FR
Batteries (Data Safe) 12HX150
Circuit Breaker (Nader) NDM1-125C125/3
Circuit Breaker (Siemens) 3VA5217-5EC31-0AA0

t of Included Subcomponents

UUT cabinets were ganged together using (2) M10 bolts at front and back junction of cabinets. UUT was rigid base mounted using (4) manufacturer provided mounting brackets (Vertiv PN:609885P1 & 660124P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.

¹ Weight listed is the total for ganged EXS and I	EBC.
Individual details are as follows:	

EXS Frame 3: 1,581 lbs. EBC Frame 3: 1,376 lbs.

INGCOOK



UUT 9

2.25

1.0

1.0

Test Report# TR251751-01-R0 (UUT1)

Manufacturer: Vertiv Corporation

Model Line: EXS

Model Number: 53S20GC8A0M00C0

Serial Number: M25E000141

Description: 20kVA Frame 2 UPS

Dimensions/Weights

Depth (in) Width (in) Height (in) Weight (lbs.)¹

29.5 17.3 63 1135

 S_{DS} R_{μ} H_{f} I_{p} A_{flx-h} A_{rig-h} A_{flx-v} A_{rig-v} 1.55 1.3 3.5 1.5 2.48 1.66 1.50 0.60

Lowest Natural Frequency (Hz)

Highest Passed Test Level

Front-Back Side-Side Vertical 8.3 3.9 19.4

Building Codes

CBC 2025

Test Criteria

ICC-ES AC156

Construction/Option Summary

Carbon Steel Frame and Skin 4 Battery Strings

st of Included Subcomponents

UUT Mounting Details:



List of included subcomponents		
Description (Manufacturer)	Model #	
Batteries (CSB)	HRL123W-F2FR	
Circuit Breaker (Nader)	NDM1-125C80/3	
Communication Card (Liebert)	IS-UNITY-DP	
POD (Vertiv)	PD3-100	

UUT was rigid base mounted using two manufacturer provided mounting brackets (Vertiv PN:610224P1) and were attached to the unit using (4) 3/8" Grade 5 Bolts each, and to the table using (3) 3/8" Grade 5 bolts each.

Unit maintained structural integrity and remained operational per manufacturer requirement following shake table test. All contents were included in the unit per operating conditions.