



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0677

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Water Control Corporation

Manufacturer's Technical Representative: Josh Petersen

Mailing Address: 7150 143rd Avenue NW, Ramsey, MN 55303

Telephone: (763) 427-9638

Email: josh.petersen@watercontrolinc.com

Product Information

Product Name: Phoenix GT High-Capacity Ultrafiltration

Product Model Number(s): See Attachment

Product Category: Other

Product Sub-Category: High-Capacity Ultrafiltration (HUF) Systems

General Description: Floor mounted High-Capacity Ultrafiltration (HUF) systems for legionella and pathogen control in building water systems.

Mounting Description: Base Mounted Rigid

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: Manwill Engineering LLC

Contact Person: Derek Manwill

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: (541) 241-2102

Email: derek@manwillse.com

Title: President



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: MANWILL ENGINEERING LLC

Name: Derek Manwill

California License Number: S6266

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: (541) 241-2102

Email: derek@manwillse.com

**Certification Method**

☐ GR-63-Core

☒ ICC-ES AC156

☐ IEEE 344

☐ IEEE 693

☐ NEBS 3

☐ Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)

Contact Person: Jeremy Lange

Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513

Telephone: (972) 247-9657

Email: jeremy@etldallas.com

BY: Timothy J. Piland

DATE: 08/27/2025



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Certified Response Spectral Acceleration Factors:  $(F_p/W_p)$

Horizontal (A Flx-H),  $g =$  3.20 (A Rig-H),  $g =$  2.40

Vertical (A Flx-V),  $g =$  1.68 (A Rig-V),  $g =$  0.68

SDS (Design spectral response acceleration at short period,  $g$ ) = 2.00 (z/h=1), 2.50 (z/h=0)

H<sub>f</sub> (Force amplification height factor) = 1 @ z/h=0; 3.5 @ z/h=1

R<sub>u</sub> (Structure ductility reduction factor) = 1 @ z/h=0; 1.3 @ z/h=1

I<sub>p</sub> (Importance factor) = 1.5

z/h (Height ratio factor) = 0 and 1

HCAI Approval (For Office Use Only) - Approval Expires on 08/27/2031

Date: 8/27/2025

Name: Timothy Piland

Title: Senior Structural Engineer

Condition of Approval (if applicable): \_\_\_\_\_

OSP-0677

BY: Timothy J. Piland

DATE: 08/27/2025

## ATTACHMENT 1: CERTIFIED COMPONENTS

## SPECIAL SEISMIC CERTIFICATION

### WATER CONTROL CORPORATION Phoenix GT High-Capacity Ultrafiltration

**TABLE 1**

Mounting: Base mounted rigid.	S <sub>DS</sub> (g)	H <sub>f</sub> / R <sub>μ</sub>	A <sub>flx-h</sub>	A <sub>rig-h</sub>	A <sub>flx-v</sub>	A <sub>rig-v</sub>	I <sub>p</sub>
	2.00	3.5 / 1.3	3.20	2.40	1.68	0.68	1.5
	2.50	1.0 / 1.0					

**Product Construction:** Stainless steel framing; modified polyethersulfone (PES) membrane; UPVC membrane housing.

**Options/Subcomponents:** Subcomponents are uniquely identified by the model number of the module.


**Module vs. System:** A complete system (GT-1 through GT-4) consists of one Control Module and one to four Filter Modules. Connections between the Control Module and a Filter Module as well as a Filter Module to another Filter Module shall be flexible connections similar to the test assembly.

Model Number	Dimensions (in)			Max. Wt. (lb)	Description / Notes	Basis
	Depth	Width	Height			
Phoenix GT High-Capacity Ultrafiltration						
Phoenix GT Control Module	23.1	24.6	73.4	225		UUT 1
Phoenix GT Filter Module	23.1	15.9	73.4	315		UUT 2
GT-1	23.1	56.3	73.4	540	Control (UUT 1) + 1 Filter (UUT 2)	UUT 1+2
GT-2	23.1	87.9	73.4	855	Control (UUT 1) + 2 Filters (UUT 2)	EXTRAP
GT-3	23.1	119.6	73.4	1,170	Control (UUT 1) + 3 Filters (UUT 2)	EXTRAP
GT-4	23.1	151.2	73.4	1,485	Control (UUT 1) + 4 Filters (UUT 2)	EXTRAP

End of TABLE 1. Notes, information, and seismic parameters are shown at the beginning of the table.

BY: Timothy J. Piland

DATE: 08/27/2025



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 1

Manufacturer: Water Control Corporation  
 Model number: Phoenix GT Control Module  
 Unit function: High-Capacity Ultrafiltration  
 Serial number: N/A

Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
23.1	24.6	73.4	225	15.5	9.6	14.4

Code & criteria: 2025 CBC, ICC-ES AC156

Test laboratory: Environmental Testing Laboratory

Report: 20095TR1.0 (dated 12-17-20), tested on 11-23-20

$S_{DS}$ (g)	$H_f / R_\mu$	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
2.00	3.5 / 1.3	3.20	2.40	1.68	0.68
2.50	1.0 / 1.0				


Importance Factor,  $I_p = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Base mounted rigid using (4) 3/8in Grade 8 bolts through 2in long 1-3/4x3x1/4in formed carbon steel angle brackets. Each angle bracket is connected to the unit base with (1) 1/2in Grade 2 bolt (4 bolts total).

Construction: Stainless steel framing.

Subcomponents: Subcomponents are uniquely identified by the model number.

Testing notes: UUT 1 and UUT 2 were connected using flexible pipe connections during the test to check functionality. The test units were spaced 15.75in apart to accommodate the flexible connectors.



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 2

Manufacturer: Water Control Corporation  
 Model number: Phoenix GT Filter Module  
 Unit function: High-Capacity Ultrafiltration  
 Serial number: N/A

Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
23.1	15.9	73.4	315	11.5	9.4	>33

Code & criteria: 2025 CBC, ICC-ES AC156

Test laboratory: Environmental Testing Laboratory

Report: 20095TR1.0 (dated 12-17-20), tested on 11-23-20

$S_{DS}$ (g)	$H_f / R_\mu$	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
2.00	3.5 / 1.3	3.20	2.40	1.68	0.68
2.50	1.0 / 1.0				


Importance Factor,  $I_p = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Mounting: Base mounted rigid using (4) 3/8in Grade 8 bolts through 2in long 1-3/4x3x1/4in formed carbon steel angle brackets. Each angle bracket is connected to the unit base with (1) 1/2in Grade 2 bolt (4 bolts total).

Construction: Stainless steel framing; modified polyethersulfone (PES) membrane; UPVC membrane housing.

Subcomponents: Subcomponents are uniquely identified by the model number.

Testing notes: UUT 1 and UUT 2 were connected using flexible pipe connections during the test to check functionality. The test units were spaced 15.75in apart to accommodate the flexible connectors.



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 1+2

Manufacturer: Water Control Corporation

Model number: GT-1

Unit function: High-Capacity Ultrafiltration

Serial number: N/A

Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
23.1	56.3	73.4	540	11.5	9.4	14.4

Code & criteria: 2025 CBC, ICC-ES AC156

Test laboratory: Environmental Testing Laboratory

Report: 20095TR1.0 (dated 12-17-20), tested on 11-23-20

$S_{DS}$ (g)	$H_f / R_{\mu}$	$A_{FLX-H}$ (g)	$A_{RIG-H}$ (g)	$A_{FLX-V}$ (g)	$A_{RIG-V}$ (g)
2.00	3.5 / 1.3	3.20	2.40	1.68	0.68
2.50	1.0 / 1.0				


Importance Factor,  $I_p = 1.5$ : Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Base mounted rigid using (8) 3/8in Grade 8 bolts through 2in long 1-3/4x3x1/4in formed carbon steel angle brackets. Each angle bracket is connected to the unit base with (1) 1/2in Grade 2 bolt (8 bolts total).

**Construction:** Stainless steel framing; modified polyethersulfone (PES) membrane; UPVC membrane housing.

**Subcomponents:** Subcomponents are uniquely identified by the model number.

**Testing notes:** UUT 1 and UUT 2 were connected using flexible pipe connections during the test to check functionality. The test units were spaced 15.75in apart to accommodate the flexible connectors.



## ATTACHMENT 3: MODEL NOMENCLATURE

## SPECIAL SEISMIC CERTIFICATION

### WATER CONTROL CORPORATION Phoenix GT High-Capacity Ultrafiltration

Phoenix GT High-Capacity Ultrafiltration																								
Digit:	1	2	3	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Sample:	G	T	-	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Digit	Digit Description	Codes	Definitions
1-2	Model Line	GT	Phoenix GT High-Capacity Ultrafiltration
4	Filter Module Designation	1	System with 1 Filter Module
		2	System with 2 Filter Modules
		3	System with 3 Filter Modules
		4	System with 4 Filter Modules

