

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0698 HCAI Special Seismic Certification Preapproval (OSP)** Renewal Type: New **Manufacturer Information** Manufacturer: Schneider Electric Manufacturer's Technical Representative: Hao Ding Mailing Address: 330 Weakley Ln., Smyrna, TN 37167 Telephone: (561) 848-0396 Email: hao.ding@se.com **Product Information** Product Name: UPS and Batteries Product Type: Batteries Product Model Number: Galaxy Lithium Ion Battery Cabinet General Description: Li-ion Battery Cabinet with 10, 13, 14, 16, or 17 modules. Mounting Description: Rigid, Floor Mounted None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Structural Integrity Associates, Inc. Contact Person: Galen Reid Mailing Address: 233 SW Wilson Ave Suite 101, Bend, OR 97702 Telephone: (541) 604-7225 Email: greid@structint.com





Title: Manager, TRU Compliance

05/27/2022 OSP-0698 Page 1 of 9



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

| California Licensed Structural Engineer Responsible for the Engineering and Test Report(s) |
|--|
| Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC. |
| Name: Andrew Coughlin California License Number: S6082 |
| Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 95138-1025 |
| Telephone: (415) 635-8461 Email: acoughlin@structint.com |
| |
| Certification Method |
| ☐ GR-63-Core |
| Other (Please Specify): |
| EOR CODE CO. |
| Testing Laboratory |
| Company Name: CHINA TELECOMMUNICATION TECHNOLOGY LABS (CTTL) |
| Contact Person: Lanfang Cui |
| Mailing Address: No. 299 Tengfei Road, Industrial Park, Lianchi District, Baoding, Hebei China |
| Telephone: +86 0312-6798950 Email: cuilanfang@caict.ac.cn |
| |
| DATE: 05/27/2022 |



OSP-0698





05/27/2022



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design Basis of Equipment or Components (Fp/Wp) = 1.44 (SDS = 2.0); 1.13 (SDS = 2.5)

SDS (Design spectral response acceleration at short period, g) = 2.0 (z/h = 1); 2.5 (z/h = 0)

ap (Amplification factor) = 1.0

 R_p (Response modification factor) = 2.5

 Ω_0 (System overstrength factor) = 2.0

 I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 05/27/2028

Date: 5/27/2022 OSP-0698

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: Sps (g) = See Above z/h = See Above

Condition of Approval (if applicable): DATE 05/27/2022





05/27/2022 OSP-0698 Page 3 of 9

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

2200264-CR-001-R1



Manufacturer: Schneider Electric

Model Line: Galaxy Lithium Ion Battery Cabinet

TABLE 1

Certified Product Construction Summary:

Carbon steel cabinet

Certified Options Summary:

10, 13, 14, 16, or 17 Li-ion battery modules. Standalone or Ganged

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2019

Seismic Certification Limits:

 $S_{DS} = 2.0 g$ z/h=1.0 $S_{DS} = 2.5 g$ z/h=0.0

I_P= 1.5

| Model Line | Model | Qi | mensions (| (in) o | Weight | Notes | UUT |
|--------------------|-----------------------------|--|--|----------|--------|--------------|---------|
| Model Line | | Depth | Width | Height | (lb) | Notes | 001 |
| | LIBSESMG10UL | 23.2 | 25.6 | 77.6 | 700 | 10 Batteries | Interp. |
| | LIBSESMG10IEC | 23.2 | 25.6 | 77.6 | 700 | 10 Batteries | Interp. |
| | LIBSES <mark>MG13</mark> UL | 23.2 | 25.6 | 77.6 | 866 | 13 Batteries | Interp. |
| | LIBSESMG13IEC | 23.2 | 25.627 | 7/277.62 | 866 | 13 Batteries | 2 |
| Galaxy Lithium Ion | LIBSESMG14UL | 23.2 | 25.6 | 77.6 | 923 | 14 Batteries | Interp. |
| Battery Cabinets | LIBSESMG14IEC | 23.2 | 25.6 | 77.6 | 923 | 14 Batteries | Interp. |
| | LIBSESMG16UL | 23.2 | 25.6 | 77.6 | 1036 | 16 Batteries | Interp. |
| | LIBSESMG16IEC | 23.2 | 25.6 | 77.6 | 1036 | 16 Batteries | Interp. |
| | LIBSESMG17UL | 23.2 | 25.6 | 77.6 | 1069 | 17 Batteries | 3 |
| | LIBSESMG17IEC | 23.2 | 25.6 | 77.6 | 1069 | 17 Batteries | 1,3 |
| | | | ! | | | | |
| | | | ! | | | | |
| | | | ! | | | | |
| | | | 1 | | | | |
| | | | , | | | | |
| | | | ! | | | | |
| | | | † | | | | |
| | | | , | | | | |
| | | | + | | | | |
| | | | + | | + | | |
| | | | + | | + | | |
| | | | + | | + | | |
| | | | + | | | | |
| | | | | | + | | |
| | i | | + | 1 | + | | |

TRU Compliance, by Structural Integrity Associates, Inc. 844-TRU-0200 | info@trucompliance.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

2200264-CR-001-R1



Table Description: Electrical Components Manufacturer: Schneider Electric **TABLE 2** Model Line: Galaxy Lithium Ion Battery Cabinet $S_{DS} = 2.0 g z/h = 1.0$ Building Code: CBC 2019 **Seismic Certification Limits:** $I_{P} = 1.5$ $S_{DS} = 2.5 g z/h = 0.0$ Description **Component Type** Manufacturer Model UUT **Notes** IEC Breaker LV438279 Molded Case Circuit 1,2,3 Schneider Electric Breaker **UL** Breaker LLF37060D33 3 IEC Switchgear Box ON-87889 1,2,3 Switchgear Box Schneider Electric UL Switchgear Box 0N-2191 3 Battery Module Type A 1,2,3 LIBSMG95MODA **Battery Modules** Samsung SDI LIBSMG95MODBV • N Battery Module Type B 1,2,3 0N-2192 SMPS Box IEC 1,2,3 SMPS Box Schneider Flectric 0N-1588 SMPS Box UL 3





| Manufactui Model Line: | | Electric iium Ion Battery Cab | inet | | | | | |
|---------------------------|---------------------------------|----------------------------------|--|----------------|--------------------------|-----------------|------------|----------------|
| UUT | Unit Description | Report Number | Testing Lab | Year Tested | ISO 17025 Accredited? | S _{DS} | z/h | I _P |
| 1 | LIBSESMG17IEC | B20X80867 | China Telecommunication Technology Labs China | 2020 | Yes | 2.0 2.5 | 1.0 0.0 | 1.5 |
| 2 | LIBSESMG13IEC | B20X80868 | Telecommunication Technology Labs | 2020 | Yes | 2.0 2.5 | 1.0 0.0 | 1.5 |
| 3 | LIBSESMG17IEC + LIBSESMG17UL | B21X80065 | China Telecommunication Technology Labs | 2021 | Yes | 2.0 2.5 | 1.0 0.0 | 1.5 |
| | | A FO | R CODE CO | OMPL | AZCE. | | | |
| | | BY:N | ohammad Ka | rim | 0 | | | |
| | \ | DATE | : 05/27/202 | 2 | 079 | | | |
| | | CPA | | | | | | |
| | | IAL | BUILDING | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| Notes: | | | | | | | | |

2200264-CR-001-R1



UUT 1

Manufacturer: Schneider Electric

Model Line: Galaxy Lithium Ion Battery Cabinet

Model Number: LIBSESMG17IEC Serial Number: N/A

Product Construction Summary:

Carbon steel cabinet

Options/Subcomponent Summary:

17 battery modules (8 Type A, 9 Type B), LV438279 Molded Case Circuit Breaker, 0N-87889 IEC Switchgear Box, 0N-2192 SMPS Box IEC

| | | | UUT Pi | operties | | \(\frac{1}{2}\) | | | | |
|----------|---------------------------|-------------------|-------------------------------|----------------|-----------|-----------------|------------------------|------------------------|------------------------|------------------------|
| Weight | | Dimension (in) | Lowest Natural Frequency (Hz) | | | | | | | |
| (lb) | Depth | Width | OSH | eight 98 | Front | -Back | Side-Side | | Vertical | |
| 1,069 | 23.2 | 25.6 | 40 1000 1 | 7.6 | 14.8 | | 11.9 | | >33.3 | |
| | | UUT Highes | t Passed S | eismic Run | Informa | tion | | | | |
| Buildi | Building Code Test Criter | | | | z/h | I _P | A _{FLX-H} (g) | A _{RIG-H} (g) | A _{FLX-V} (g) | A _{RIG-V} (g) |
| CBC 2019 | | ICC-ES AC156 05/2 | | 2-7-0-2 2.5 | 2 1.0 0.0 | 1.5 | 3.20 | 2.40 | 1.67 | 0.67 |

Test Mounting Details:





Rear Seismic BKT



Front Seismic BKT

UUT was rigid base mounted to the shake table using (5) Grade 8.8 M12 Bolts in the front bracket (PN: 870-51164A), and (4) Grade 8.8 M12 Bolts in the rear bracket (PN: 870-51147).

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

2200264-CR-001-R1



UUT 2

Manufacturer: Schneider Electric

Model Line: Galaxy Lithium Ion Battery Cabinet

Model Number: LIBSESMG13IEC Serial Number: N/A

Product Construction Summary:

Carbon steel cabinet

Options/Subcomponent Summary:

13 battery modules (6 Type A, 7 Type B), LV438279 Molded Case Circuit Breaker, 0N-87889 IEC Switchgear Box, 0N-2192 SMPS Box IEC


| | | | UUT P | roperties | | 7 | | | | | |
|----------|---------|-------------------|-------------------------------|---------------------------|------------|----------------|------------------------|------------------------|------------------------|------------------------|--|
| Weight | | Dimension (in | Lowest Natural Frequency (Hz) | | | | | | | | |
| (lb) | Depth | Width | OS Height 98 | | Front-Back | | Side-Side | | Vertical | | |
| 866 | 23.2 | 25.6 | 77.6 | 14.8 | | 11.9 | | >33.3 | | | |
| | | UUT Highe: | st Passed S | Seismic Run | Informa | tion | | | , | | |
| Buildi | ng Code | Test Crit | eria S _{DS} (g) | | z/h | I _P | A _{FLX-H} (g) | A _{RIG-H} (g) | A _{FLX-V} (g) | A _{RIG-V} (g) | |
| CBC 2019 | | ICC-ES AC156 05/2 | | / 272.0 2.5 | 2 1.0 0.0 | 1.5 | 3.20 | 2.40 | 1.67 | 0.67 | |

Test Mounting Details:





Rear Seismic BKT



Front Seismic BKT

UUT was rigid base mounted to the shake table using (5) Grade 8.8 M12 Bolts in the front bracket (PN: 870-51164A), and (4) Grade 8.8 M12 Bolts in the rear bracket (PN: 870-51147).

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

2200264-CR-001-R1



UUT3

Manufacturer: Schneider Electric

Model Line: Galaxy Lithium Ion Battery Cabinet

Model Number: LIBSESMG17IEC + LIBSESMG17UL **Serial Number:** N/A

Product Construction Summary:

Carbon steel cabinet

Options/Subcomponent Summary:

17 battery modules per section (8 Type A, 9 Type B), LV438279 Molded Case Circuit Breaker, LLF37060D33 Molded Case Circuit Breaker, 0N-87889 IEC Switchgear Box, 0N-2191 UL Switchgear Box, 0N-2192 SMPS Box IEC, 0N-1588 SMPS Box UL

| | | | | | WV WWA JAAA | | | | | | | |
|--|---|------------------|-----------|-------------|-------------|---------|----------------|------------------------|------------------------|------------------------|------------------------|--|
| | | 14 | | UUT Pro | perties | | 7 | | | | | |
| Weight Dimension (in) Lowest Natural Frequency | | | | | | | | | | լuency (Hz) | | |
| (lb)¹ | Depth | Depth Width Shei | | | | Front | -Back | Side | Side-Side | | Vertical | |
| 2,138 | 23.2 | 23.2 51.2 7 | | | | 12.1 | | 12.9 | | >33.3 | | |
| | | U | UT Highes | t Passed Se | ismic Run | Informa | tion | | | | | |
| Buildi | Building Code Test Criteria S _{DS} (g) | | | | | | I _P | A _{FLX-H} (g) | A _{RIG-H} (g) | A _{FLX-V} (g) | A _{RIG-V} (g) | |
| CBC 2019 | | ICC-ESAC156 05/2 | | 2.0 2.5 | 2 1.0 0.0 | 1.5 | 3.20 | 2.40 | 1.67 | 0.67 | | |

Test Mounting Details:



¹Combined weight of ganged cabinets.



Rear Seismic BKT



Front Seismic BKT

UUT was rigid base mounted to the shake table using (10) Grade 8.8 M12 Bolts in the front brackets (PN: 870-51164A), and (8) Grade 8.8 M12 Bolts in the rear brackets (PN: 870-51147)

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.