

Title: President

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0792
HCAI Special Seismic Certification Preapproval (OSP)	
Type: X New Renewal	
Manufacturer Information	
Manufacturer: ABB - Branded for CAT	
Manufacturer's Technical Representative: Dhirendra Tiwari	
Mailing Address: 41 Woodford Ave, Plainville, CT 06062	
Telephone: (860) 747-7935 Email: dhirendra.tiwari@	us.abb.com
Product Information	10,
Product Name: Emergency and Standby Power Systems	
Product Type: Automatic Transfer Switches	
Product Model Number: CX, CG(D), CS(D) ATS	
General Description: Transfer switches that provide manual / automatic p power source (30A to 1200A).	ower switching from a primary source to a backup
Mounting Description: Rigid, Floor/Wall Mounted	
Tested Seismic Enhancements: None	
Applicant Information	OV.
Applicant Company Name: WE Gundy & Associates, Inc	
Contact Person: Travis Soppe	
Mailing Address: PO Box 9121, Boise, ID 83707	
Telephone: (208) 342-5989 Email: tsoppe@wegai.co	om





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: W.E. GUNDY & ASOCIATES INC.
Name: Travis Soppe California License Number: S6115
Mailing Address: P.O. Box 9121, Boise, ID 83707
Telephone: (208) 342-5989 Email: tsoppe@wegai.com
Certification Method
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
Other (Please Specify):
FOR CODE CO
Testing Laboratory
Company Name: CLARK TESTING LABORATORY, INC.
Contact Person: Suzanne Mazon
Mailing Address: 1801 Route 51, Jefferson Hills PA 75229-3513
Telephone: (972) 247-9657 Email: smazon@clarktesting.com
DATE: 11/27/2023





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters							
Design Basis of Equipment or Components	(Fp/Wp) = 1.5						
SDS (Design spectral response acceleration at short period, g) = $\underline{2.0}$							
ap (Amplification factor) =	2.5						
R _P (Response modification factor) =	6.0						
Ω_0 (System overstrength factor) =	2.0						
Ip (Importance factor) =	1.5						
z/h (Height ratio factor) =	1						
Natural frequencies (Hz) =	See Attachment						
Overall dimensions and weight =	See Attachment ODE						

HCAI Approval (For Office Use Only) - Approval Expires on 11/27/2029									
Date:	11/27/2023 OSP-0792	12							
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities						
Special	Seismic Certification Valid Up to: SDS (g) = 2.0	z/h =	1						
Conditio	on of Approval (if applicable): DATF 11/27/2023								





"A healthier California where all receive equitable, affordable, and quality health care"

CATERPILLAR CX, CG(D), CS(D) AUTOMATIC TRANSFER SWITCHES WITH TruONE SPECIAL SEISMIC CERTIFICATION PRODUCT LINE MATRIX



	Ampre	D 1	2	Enclosu	re Dimensio	ons (in)	Service	Representative UUT		
ID Number ¹	Rating	Pole	NEMA Rating ²	Width	Depth	Height	Weight (lbs)			
TABLE 1: WALL MOUNTED ATS PRODUCT LINE - MAX $S_{DS} = 2.5$ at $z/h = 0$ and $S_{DS} = 2.0$ at $z/h = 1.0$										
CGOG3XX32	200	3	3R	24.0	12.3	32.0	96	UUT-1		
CX, CG(D), CS(D) Series	30-200	2/3/4	1/3R/4/12	24.0	12.0-12.3	32.0	95 - 125	interpolated		
CX, CG(D), CS(D) Series	260	2/3/4	1/3R/4/12	24.0	14.0-14.3	46.0	100-140	interpolated		
CX, CG(D), CS(D) Series	400	2/3/4	1/3R/4/12	24.0	14.0-14.3	46.0	105-142	interpolated		
CGOK3SX12	400	4	1	24.0	14.0	46.0	142	UUT-2		
TABLE 2: FLOOR M	OUNTED AT	S PRODUC	CT LINE - MAX	$S_{DS} = 2.5 at$	z/h = 0 and	$S_{DS} = 2.0 a$	t z/h = 1.0			
CGOL3XX12	600	4	SP 0 ¹ 02	28.0	19.5	54.0	252	UUT-3		
CX, CG(D), CS(D) Series	600	2/3/4	1/3R/4/12	28.0	19.5-19.8	54.0	210 - 252	interpolated		
CX, CG(D), CS(D) Series	80 <mark>0 - 12</mark> 00	B3/.4	1/3R/4/12	40.0	19.5-19.8	74.0	435 - 478	interpolated		
CGDP3SX32	1200	4	3R	40.0	19.8	74.0	478	UUT-4		

Notes:

CX - CXOxxxxxx

CG(D) - CGOxxxxxx / CGDxxxxxx

CS(D) - CSAOxxxxxx / CSADxxxxxx

CXO - CX Open transition

CGO - CG Open transition

CGD - CG(D) Delay transition

CSAO - CS Open transition

CSAD - CS(D) Delay transition

¹ All components are manufactured by ABB and branded for Caterpillar. The part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-component within the tested units.

² Enclosures are constructed of welded carbon steel.

The CX/CG(D)/CS(D) series products are represented with the following ID numbers:

⁴ The CX/CG(D)/CS(D) automatic transfer switches (ATS) are of nearly identical construction with minor control differences listed below:

CATERPILLAR CX, CG(D), CS(D) AUTOMATIC TRANSFER SWITCHES WITH TruONE SPECIAL SEISMIC CERTIFICATION SUBCOMPONENT MATRIX



Subcomponent	Description	Manufacturer	Genera	l Dimensio	ons (in)	Weight	Representative
ID Number ¹	Description	Manufacturer	Width	Depth	Height	(lbs)	UUT
	l Mounte	d					
OXA200U3X2QB-ZE	200A 3-Pole open transition power panel	ABB	13.0	7.2	15.4	32	UUT-1
OXx260Uxxxxx-ZE	260A 2/3/4-Pole open/delay transition power panel	ABB	12.8-17.9	7.2-8.4	14.8-20.8	28 - 39	interpolated
OXx400Uxxxxx-ZE	400A 2/3/4-Pole open/delay transition power panel	ABB	15.1-20.2	7.2-8.4	14.8-20.8	32 - 52	interpolated
OXA400U3S3QB-ZE	400A 4-Pole open transition power panel	ABB	20.2	7.2	18.9	45	UUT-2
	Table 4: Automatic Transfer Switch Power	Panel Assem	bly - Floo	r Mounte	d		
OBX600U3S3QB-ZE	600A 4-Pole open transition power panel	ABB	17.6	8.4	18.9	45	UUT-3
OXx600Uxxxxx-ZE	600A 2/3/4-Pole open/delay transition power panel	ABB	15.1-20.2	7.2-8.4	14.8-20.8	32 - 52	interpolated
OXx800-1200Uxxxxx-ZE	800-1200A 3/4-Pole open/delay transition power panel	KariABB	23.5-28.1	7.2-8.4	14.1-20.9	95 - 127	interpolated
OXA1200U3S3QB-ZE	1200A 4-Pole delay transition power panel	ABB	28.0	8.4	19.2	127	UUT-4
	Table 5: Electrical Panel / Controler Con	nponents - Wa	<mark>ill/</mark> Floor	Mounted			
OXAMI1-L3	Open transition Level 3 HMI	ABB	4.0	0.8	6.5	2.0	UUT-1, 3
OXAMI1-L2	Open transition Level 2 HMI	ABB	4.0	0.8	6.5	2.0	interpolated
OXBMI1-L3	Delay transition Level 3 HMI	ABB	4.0	0.8	6.5	2.0	interpolated
OXBMI1-L4	Delay transition Level 4 HMI	ABB	4.0	0.8	6.5	2.0	inerpolated
OXAMI1-L4	Open transition Level 4 HMI	ABB	4.0	0.8	6.5	2.0	UUT-2, 4

Notes:

¹ The "xxxx" designation at the end of the model number provides differences in control software for the power panels.

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with 4 - 3/8" grade 5 bolts





1.67

0.67

Manufacturer: Caterpillar (ABB)

Product Line: CX, CG(D), CS(D) Automatic Transfer Switch

Component ID: CGOG3XX32 | Test Report Component ID: OXA200U3X2QB-ZE*

(ZGOG3XX32)

UUT Function: Manual/Automatic power switching from utility power to emergency power.

UUT Description: 200A 3-Pole Automatic Transfer Switch with OXA200U3X2QB-ZE Power Panel, OXAMI1-L2 open transition level 3 HMI controller, and NEMA 3R enclosure.

DATE: 11/27/2023

Test Location: Clark Dynamic Test Laboratory, Inc., PA | **Test Date:** April-May 2019

2.50

UUT PROPERTIES

Waight (1b)		Dimensio	Natural Fequency (Hz)					
Weight (lb)	Width	Depth		Height		FB	SS	V
96	24.0	12	2.3	3	32.0	N/A	N/A	N/A
		SEISM	IIC TEST	PARAM	ETERS			
Building Co	Building Code / Test Criteria $S_{DS}(g)$ z/h I_P $A_{FLX-H}(g)$ $A_{RIG-H}(g)$ $A_{FLX-V}(g)$ $A_{RIG-V}(g)$							
CBC 2022	/ ICC-ES AC156	2.00	1.0	1.5	3.20	2.40		
CBC 2022	ICC-ES ACISO							

Note: The unit was full of contents during testing and remained fuctional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test. *The lab report identified the system using the internal component number not the complete system coponent identification number. The UUT is manufactured by ABB and branded Caterpillar. The first digits of the ID are "ZT" for ABB and this is changed to "C" for the branded Caterpillar product.

1.5

0.0

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with 4 - 1/2" grade 5 bolts





Manufacturer: Caterpillar (ABB)

Product Line: CX, CG(D), CS(D) Automatic Transfer Switch

Component ID: CGOK3SX12 Test Report Component ID: OXA400U3S3QB-ZE*

(ZGOK3SX12)

Test report Component ID. Graft 100 63 63 QB 2E

UUT Function: Manual/Automatic power switching from utility power to emergency power.

UUT Description: 400A 4-Pole Automatic Transfer Switch with OXA400U3S3QB-ZE Power Panel, OXAMI1-L4 open transition level 3 HMI controller, and NEMA 1 enclosure.

Test Location: Clark Dynamic Test Laboratory, Inc., PA | **Test Date:** April-May 2019

UUT PROPERTIES

Weight (lb)	Dimensions (inches)						Natural Fequency (Hz)				
weight (10)	Width	Depth		Height		FB	SS	V			
142	24.0	14	1.0	4	6.0	N/A	N/A	N/A			
	SEISMIC TEST PARAMETERS										
Building Co	ode / Test Criteria	$S_{DS}(g)$	z/h	I_P	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$			
CPC 2022	LICC ES AC156	2.00	1.0	1.5	3.20	2.40					
CBC 2022 /	CBC 2022 / ICC-ES AC156		0.0	1.5			1.67	0.67			

Note: The unit was full of contents during testing and remained fuctional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test. *The lab report identified the system using the internal component number not the complete system coponent identification number. The UUT is manufactured by ABB and branded Caterpillar. The first digits of the ID are "ZT" for ABB and this is changed to "C" for the branded Caterpillar product.

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid floor mounted with 4 - 1/2" grade 5 bolts



Manufacturer: Caterpillar (ABB)

Product Line: CX, CG(D), CS(D) Automatic Transfer Switch

Component ID: CGOL3XX12 | Test Report Component ID: OBX600U3S3QB-ZE*

(ZGOL3XX12)

UUT Function: Manual/Automatic power switching from utility power to emergency power.

UUT Description: 600A 4-Pole Automatic Transfer Switch with OBX600U3S3QB-ZE Power Panel, OXAMI1-L3 open transition level 3 HMI controller, and NEMA 1 enclosure.

Test Location: Clark Dynamic Test Laboratory, Inc., PA | **Test Date:** April-May 2019

UUT PROPERTIES

Waight (lb)		Dimensio	Natural Fequency (Hz)					
Weight (lb)	Width	Depth		Height		FB	SS	V
252	28.0	19).5	5	54.0	25.7	18.5	>33
		SEISM	IIC TEST	PARAM	ETERS			
Building Co	ode / Test Criteria	$S_{DS}(g)$	z / h	I_P	$A_{FLX-H}(g)$	A _{RIG-H} (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
					1		· · · · · · · · · · · · · · · · · · ·	

Building Code / Test Criteria	$S_{DS}(g)$	z / h	I_P	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
CDC 2022 / ICC ES A C156	2.00	1.0	1.5	3.20	2.40		
CBC 2022 / ICC-ES AC156	2.50	0.0	1.5			1.67	0.67

Note: The unit was full of contents during testing and remained fuctional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test. *The lab report identified the system using the internal component number not the complete system coponent identification number. The UUT is manufactured by ABB and branded Caterpillar. The first digits of the ID are "ZT" for ABB and this is changed to "C" for the branded Caterpillar product.

UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid floor mounted with 4 - 1/2" grade 5 bolts



Manufacturer: Caterpillar (ABB)

Product Line: CX, CG(D), CS(D) Automatic Transfer Switch

Component ID: CGDP3SX32 Test Report Component ID: OXA1200U3S3QB-ZE*

(ZGDP3SX32)

UUT Function: Manual/Automatic power switching from utility power to emergency power.

UUT Description: 1200A 4-Pole Automatic Transfer Switch with OXA1200U3S3QB-ZE Power Panel, OXAMI1-L4 open transition level 4 HMI controller, and NEMA 3R enclosure.

Test Location: Clark Dynamic Test Laboratory, Inc., PA | **Test Date:** April-May 2019

UUT PROPERTIES

Waight (1h)	Dimensions (inches)						Natural Fequency (Hz)		
Weight (lb)	Width	Depth		Height		FB	SS	V	
478	40.0	19	0.8	7	4.0	25.7	13.8	>33	
		SEISM	IC TEST	PARAM	ETERS				
Building Co	ode / Test Criteria	$S_{DS}(g)$	z / h	I_P	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$	

Building Code / Test Criteria	$S_{DS}(g)$	z / h	I_P	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
CDC 2022 / ICC ES A C156	2.00	1.0	1.5	3.20	2.40		
CBC 2022 / ICC-ES AC156	2.50	0.0	1.5			1.67	0.67

Note: The unit was full of contents during testing and remained fuctional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 Test. *The lab report identified the system using the internal component number not the complete system coponent identification number. The UUT is manufactured by ABB and branded Caterpillar. The first digits of the ID are "ZT" for ABB and this is changed to "C" for the branded Caterpillar product.