



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**APPLICATION FOR HCAI SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP-0823

HCAI Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Trane

Manufacturer's Technical Representative: Wyatt Martinez

Mailing Address: 101 William White Blvd., Pueblo, CO 81001

Telephone: (719) 585-4374 Email: Wyatt.Martinez@trane.com

Product Information

Product Name: CGAM

Product Model Number(s): Size 20 Ton to 130 Ton

Product Category: Chillers

Product Sub-Category: Chillers - Air Cooled

General Description: Catalogued chillers from 20-130 Ton

Mounting Description: Base Mounted Neoprene Vibration Isolated -

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

Applicant Information

Applicant Company Name: VMC Group

Contact Person: John Giuliano

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780 Email: john.giuliano@thvmcgroup.com

Title: President





DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: THE VMC GROUP
Name: Kenneth Tarlow California License Number: S2851
Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814
Telephone: (832) 627-2214 Email: ken.tarlow@thevmcgroup.com

Certification Method

GR-63-Core ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
 Other (Please Specify): _____

Testing Laboratory

Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)
Contact Person: Amarnath Kasalanati
Mailing Address: 325 Davis Hall, Berkeley CA 94720-1729
Telephone: (510) 642-3437 Email: amarnath1@berkeley.edu

Company Name: QUALTECH/CURTISS WRIGHT/TRENTEC
Contact Person: Timothy Geers
Mailing Address: 4600 East Tech Drive, Cincinnati OH 45245
Telephone: (513) 528-7900 Email: nuclear@curtisswright.com

Company Name: UNIVERSITY OF NEVADA, RENO (UNR)
Contact Person: Patrick Laplace
Mailing Address: 1664 N. Virginia Street, Reno NV 89557
Telephone: (775) 784-8080 Email: plaplace@unr.edu





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) = 3.33

SDS (Design spectral response acceleration at short period, g) = 1.85

a_p (Amplification factor) = 2.5

R_p (Response modification factor) = 2.5 (Isolated using Neoprene Elements)

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 10/29/2030

Date: 10/29/2024

Name: Mohammad Karim Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = 1.85 z/h = 1

Condition of Approval (if applicable): DATE: 10/29/2024




Table 1 - Certified Air Cooled Chillers

Model	Nominal Capacity [ton]	Frequency [Hz]	Efficiency	Coil Design Style	Vertical Support Legs Along Chiller Length	Max. Dimensions			Max. Operating Weight [lb]	Installation Method ¹	UUT	
						Length [in]	Width [in]	Height [in]				
CGAM020	020	60	XE	Slant config	None	113.8	50.4	84.7	2208	Neoprene Pad	Extrapolated	
CGAM026	026					114.0	50.6	84.7	2111	Spring Isolators	UUT-01	
CGAM026	026				113.8	50.4	84.7	2278	Neoprene pad	Interpolated		
CGAM030	030				149.8	50.4	84.7	2880				
CGAM035	035				149.8	50.4	84.7	2920				
CGAM040	040				113.8	88.4	84.8	3697				
CGAM052	052			V config	None	117.0	89.0	84.0	3520	Neoprene Pad	UUT-03	
CGAM052	052					113.8	88.4	84.8	3806	Neoprene Pad	Interpolated	
CGAM060	060			1	149.8	88.4	84.8	5033				
CGAM070	070				149.8	88.4	84.8	5121				
CGAM080	080			High	W config	1	143.1	88.2	92.6			5692
CGAM090	090						143.1	88.2	92.6			5961
CGAM100	100						165.9	88.2	92.5			6759
CGAM110	110						165.9	88.2	92.5	6845		
CGAM120	120						146.9	88.0	85.2	6500	Spring Isolators	UUT-02
CGAM120	120						165.9	88.2	92.5	6884	Neoprene Pad	Interpolated
CGAM130	130	2	201.9	88.2	92.5	7530	Neoprene Pad	UUT-04				

Notes:

1) Trane currently only offers units to be installed on neoprene pads. Original test units UUT-1 and UUT-2 were tested on spring isolators.

Table 2 - Certified Compressors

Model/Part Number	Size	MFR	Type	Voltage	Weight [lb]	UUT
CSHE117	10T LC	Trane	Scroll (Refrigerant Type 454B)	200 to 575	141	Interpolated
CSHE152	13T LC	Trane		200 to 575	150	UUT-3
CSHE177	15T LC	Trane		200 to 575	161	Interpolated
CSHP234	20T	Trane		200 to 575	236	UUT-4
CSHP297	25T	Trane		200 to 575	337	UUT-4
CSHP346	30T	Trane		200 to 575	362	Extrapolated
CSH374	30T	Trane	Scroll (Refrigerant Type 410A)	200 to 575	360	UUT-2

Table 3a - Certified Control Panels

Unit Size	MFR	Dimensions [mm]			Material	Weight [lb]	UUT
		L	W	H			
20-35T	Trane	948	213	1090	2mm Steel enclosure and doors	274	UUT-3
40-70T	Trane	1905	213	830		346	Interpolated
80-130T	Trane	2254	284	829		518	UUT-4

Table 3b - Certified Control Panel Subcomponents

Model/Part Number	Description	Manufacturer	Input Voltage	Output [Voltage /Current/Power]	Weight [lb]	UUT
X13651678	Operator Interface (Main Controller)	Symbio 800	24 VDC	N/A	<5	UUT-3, UUT-4
X13550019	Transformer	Precision, Inc	200/230/380/400/ 460/575 VAC	115/24 VAC 60hz	~5	UUT-3, UUT-4
X1305102, X1305110	Circuit Breaker	ABB	200/230/380/400 /460/575 VAC	200/230/380/ 400/460/575	~10	UUT-3, UUT-4
X13651698	Remote Interface Modules	BacNet, LonTalk, Tracer	24 VDC	N/A	<5	UUT-3, UUT-4
X13170817080,120,130	Fan VFD	Trane/ Danfoss	200/230/380/400/ 460/575 VAC	200/230/380/400/ 460/575 VAC	11	UUT-3
X13170817150,160	Fan VFD	Trane/ Danfoss	200/230/380/400/ 460/575 VAC	200/230/380/400/ 460/575 VAC	15	Inteprolated
X13170817170	Fan VFD	Trane/ Danfoss	200/230/380/400/ 460/575 VAC	200/230/380/400/ 460/575 VAC	51	UUT-4
X13170817140,180,190	Fan VFD	Trane/ Danfoss	200/230/380/400/ 460/575 VAC	200/230/380/400/ 460/575 VAC	27	Inteprolated
X1306087, X1306089	Compressor Contactors	ABB	200/230/380/400/ 460/575 VAC	200/230/380/400/ 460/575 VAC	<5	UUT-3, UUT-4

Table 4 - Certified Evaporators

Model	MFR	Style	Max # of plates	Tons/ Efficiency	Plate and Connection Material	Max Weight [lb]	UUT
P80	Swep	Brazed plate heat exchanger	96	20-130	Stainless Steel	46	UUT-1
DP120			88	26, 30		82	Intepolated
DP121			88	35		101	Intepolated
DP400			206	52		132	UUT-3
			206	20-130		321	Interpolated
			206	120,130		321	UUT-4

Table 5a - Certified Fans

Description	Manufacturer	# of Blades	Blade Material	Weight [lb]	UUT
Skinny IV Fan	King's Eco Plastics	11	Plastic	~10	UUT-3, UUT-4

Table 5b - Certified Fan Motors

Model Number	MFR	Input Voltage [VAC]	Output Rating [HP]	Type	Weight [lb]	UUT
P56AE86A05R	Regal Beloit	400-480VAC	1.3	TEAO	50	UUT-1, UUT-2
P56AE86A05		200-230 VAC	1.3	TEAO	50	Interpolated
P56AK26A05		575VAC	1.3	TEAO	48	Interpolated
P56AK29AD5		400-480VAC	1.3	TEAO	48	Interpolated
P56AK25A05		400-480VAC	1.3	TEAO	50	UUT-3, UUT-4
P56AK24AD5		380 VAC	1.3	TEAO	52	Extrapolated
P56AK27AD5		200-230 VAC	1.3	TEAO 2 Speed	55	Extrapolated
P56AK28AD5		400-480VAC	1.3	TEAO 2 Speed	54	Extrapolated

Table 6 - Certified Condenser Coils

Unit Size	MFR	Coil Dimension [in]			# of Rows	Weight [lb]	UUT
		Length	Depth	Height			
20T, 26T	Trane	91	4.5	68	3	288	Extrapolated
30T, 35T	Trane	127	4.5	68	3	392	
40T, 52T	Trane	91	4.5	68	3	288	UUT-3
60T, 70T	Trane	127	4.5	68	3	392	Interpolated
80T, 90T	Trane	121	4.5	42	3	297	
100T,110T,120T	Trane	144	4.5	42	3	346	
130T	Trane	180	4.5	42	3	423	UUT-4



UNIT UNDER TEST (UUT) Summary Sheet

UUT-1

Test Report: PEER-STI/2010-10

Model Line	Model Number	Manufacturer
CGAM	26	Trane

Product Construction Summary

Carbon Steel Base Frame, Carbon Steel Panels

Options / Subcomponent Summary

Compressor: Trane ; Control Panel: Trane ; Evaporator: Swep ; Fan: King's Eco Plastics ; Fan Motor: Regal Beloit ; Coil: Trane

UUT Properties

Weight [lbs]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
2,111	114.0	50.6	84.7	2.2	1.7	3.8

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.23	0.49

Test Mounting Details

UUT-1 base mounted to (4) VMC MSSH-1E Spring Vibration Isolators. Isolators bolted to shake table using (16) 5/8" Dia. Grade 8 Bolts.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



UNIT UNDER TEST (UUT) Summary Sheet

UUT-2

Test Report: Trentec Q9019.0; UUT-1

Model Line	Model Number	Manufacturer
CGAM	120	Trane

Product Construction Summary

Carbon Steel Base Frame, Carbon Steel Panels

Options / Subcomponent Summary

Compressor: Trane ; Control Panel: Trane ; Evaporator: Swep ; Fan: King's Eco Plastics ; Fan Motor: Regal Beloit ; Coil: Trane

UUT Properties

Weight [lbs]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
6,500	146.9	88.0	85.2	2.4	1.3	4.7

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.23	0.49

Test Mounting Details

UUT-2 base mounted to (6) VMC M2SS-1E Spring Vibration Isolators. Isolators bolted to shake table using (24) 5/8" Dia. Grade 5 bolts.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



UNIT UNDER TEST (UUT) Summary Sheet

UUT-3

Test Report: DCL-24408-2401-AC156-Rev0

Model Line	Model Number	Manufacturer
CGAM	52	Trane

Product Construction Summary

Carbon Steel Base Frame, Carbon Steel Panels

Options / Subcomponent Summary

Compressor: Trane ; Control Panel: Trane ; Evaporator: Swep ; Fan: King's Eco Plastics ; Fan Motor: Regal Beloit ; Coil: Trane

UUT Properties

Weight [lbs]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
3,520	117.0	89.0	84.0	6.5	6.0	13.5

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.23	0.49

Test Mounting Details

UUT-3 was base mounted to the shake table using (4) 5/8" Dia. Grade 8 Bolts and (4) VMC Shear-Flex red 0.6" thick isolator pads.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.



UNIT UNDER TEST (UUT) Summary Sheet

UUT-4

Test Report: DCL-24408-2401-AC156-Rev0

Model Line	Model Number	Manufacturer
CGAM	130	Trane

Product Construction Summary

Carbon Steel Base Frame, Carbon Steel Panels

Options / Subcomponent Summary

Compressor: Trane ; Control Panel: Trane ; Evaporator: Swep ; Fan: King's Eco Plastics ; Fan Motor: Regal Beloit ; Coil: Trane

UUT Properties

Weight [lbs]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
7,530	203.0	89.0	92.0	4.5	4.0	10.0

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2022	ICC-ES AC156	1.85	1.0	1.5	2.96	2.22	1.23	0.49

Test Mounting Details

UUT-4 base mounted using (8) 5/8" Dia. Grade 8 Bolts and (8) VMC Shear-Flex red 0.6" thick isolator pads.



All units were filled with contents and maintained structural integrity and functionality after AC-156 test.