

Telephone: (650) 312-9233

Title: Structural Engineer

## DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

## OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP) APPLICATION #: OSP-0824 **HCAI Special Seismic Certification Preapproval (OSP)** X New Type: Renewal **Manufacturer Information** Manufacturer: Stanford Health Care and School of Medicine Manufacturer's Technical Representative: Matt Martin Mailing Address: 1830 Embarcadero Rd., Palo Alto, CA 94303 Telephone: (408) 915-1572 Email: MattMartin@stanfordhealthcare.org **Product Information** Product Name: See Certified Product list Product Model Number(s): See Certified Product list Product Category: Internal Communication Servers and Routers Product Sub-Category: Wireless Communication Systems Servers, Routers, UPS, PDU, and Switches General Description: Mounting Description: Rigid Floor Mounted Rack Supported None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Universal Structural Engineers, LLC Contact Person: Kevin OKeefe Mailing Address: 1660 S. Amphltett Blvd., Suite 335, San Mateo, CA 94402

Email: ktokeefe@universalstructuralengineers.com

"A healthier California where all receive equitable, affordable, and quality health care"





Page 1 of 6

10/31/2024 OSP-0824



# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer	Responsible for the Engineering and Test Report(s)						
Company Name: UNIVERSAL STRUCTURAL I							
Name: Kevin O'Keefe							
Mailing Address: 1660 Amphlett Blvd., Suite 33	5, San Mateo, CA 94402						
Telephone: (650) 312-9233 Email: ktokeefe@universalstructuralengineers.com							
Certification Method							
GR-63-Core X ICC-ES AC15	6						
Other (Please Specify):							
	FOR CODE CO						
Testing Laboratory							
Company Name: NATIONAL TECHNICAL SYS	STEMS (NTS)						
Contact Person: Morgan Foster	TILLIN Handle John Strate Control of the Control of						
Mailing Address: 38995 Cherry Street, Newark	CA 94560						
Telephone: (510) 578-3500	Email: Morgan.Foster@element.com						
\ <u>C</u>	DATE: 10/31/2024						





10/31/2024 OSP-0824 Page 2 of 6



#### **DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION** OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters					
Design Basis of Equipment or Components (Fp/Wp) = 1.26					
SDS (Design spectral response acceleration at short period, g) = 1.75					
ap (Amplification factor) =	1				
R <sub>P</sub> (Response modification factor) =	2.5				
$\Omega_0$ (System overstrength factor) =	2.0				
Ip (Importance factor) =	1.5				
z/h (Height ratio factor) =	1				
Natural frequencies (Hz) =	See Attachment				
Overall dimensions and weight =	See Attachment				

HCAI Approval (For Office Use Only) - Approval Expires on 10/31/2030							
Date:	10/31/2024 OSP-0824	12					
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities				
Special S	Seismic Certification Valid Up to: Sps (g) = 1.75	z/h =	1				
Conditio	n of Approval (if applicable): DATE: 10/31/2024						





Page 3 of 6

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

## Universal Structural Engineers, LLC



### STANFORD OSP ATTACHMENT 1

Table 1a-Certified Product List

	OSHPD Special Sei	smic Certif	rication Sur	nmary of C	ertified Units			
Manufacturer: Varie	es, See below							
Equipment: IT Equi	pment (Equipment Configura	ation per be	elow)					
Mounting Condition Tested: Mounted in RXL, 5570-BK452432 - 4 Post rack bolted at the base								
Manufacturer	Model #	Height	Width	Depth	Equipment	Unit		
		(in.)	(in.)	(in.)	Weight (lbs.)			
RXL	RXL-5570-							
	BK842432TNNNN (4-	84	24	32	829 <sup>1</sup>	UUT1		
	Post Rack)							
Cisco	9800-80 w/ modular	DR CC	JUE r					
	uplink card	3.47	17.3	20.5	34.5	UUT1		
				1/0)				
Infoblox	TE-1405 Trinzic	1.73	17.36	21.54	20	UUT1		
Cisco	C9500-24Y4C	1.73	17.5	18	22	UUT1		
Eaton	5PX1500RTN	3.4	17.4	20.6	65	UUT1		
Eaton	9PX1500RT	3.4 P	-017.34	17.7	42.5	UUT1		
		XXXXXXXXXXX						
	DV.							
	O DI.	wonan	mad Na					
		Rack Cen	ter of Grav	rity				

1. Center of Gravity for the whole rack including equipment, the rack and the vertical wire manager = 34.6 inches from the bottom of the rack.

TOPNIA BUILDING CODE.

# Universal Structural Engineers, LLC



#### STANFORD OSP ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

Table 2a-UUT1 Product Summary-4 Post Rack

OSHPD Spec	ial Seis	mic Cert	tification: Un	it Under Test S	Summary-UUT 1
	UUT	Cer Cor	nponent		
Rack:	1	RX	L 4 Post (5570	)-	
		BK	452432TNNN	IN)	
Equipment:		See	Table 2a	•	
Unit Function	Netw	vorking e	quipment		
Unit Properties	}				
Total		Ι	Dimensions (in	1)	The Control of the Co
Weight (lbs)		epth	Width	R Height E	
829	`	32	24	84	
			Frequency (Hz		
Front-Back		e-Side /	Vertical	45 🛆	y ar a final
8.84		.84	17.07	6.07	
Unit	Bolte	d to shake	e table with for	ur)SP-0824	
Mounting:		" diamete	er bolts.	NYAVANANANANANANANANANANANANANANANANANAN	
Seismic Test P					
Building Code:				dedeammad K	
Test Criteria:		C-ES AC	THE RESERVE THE PROPERTY OF TH		
Lab Report No	. TR-	-180 <mark>446.</mark> (	01-AC156 Rev	v-0 10/21/20	
Sds (g)	I		z/h	10/31/20	
1.75	1.	.5	1.0		
$A_{RIG}(g)$	$A_{FLX}$		$A_{RIG}(g)$	$A_{FLX}(g)$	
(horizontal)	(horiz		(vertical)	(vertical)	
2.1	2.	.8	.47//	1.17	
			14	BLITIDING	
				OILDIN	
		2 1 0	1 D 1		
Construction: Carbon Steel Rack				1	
Component	Components: 1) CISCO 9800-80 w/ modular uplink car		ard		
2) INFOBLOX TE-1405 Trinzic					
3) CISCO C9500-24Y4C					
4 EATON 5PX1500RT 5) EATON 9PX1500RTN					
J) LATON /I ATOUNTIN					
Center of Gra	vity 3	34.6 inche	es from the bo	ttom of the rack.	
	-				nained function before and after the ICC ES

Note: The unit was full of contents during testing and remained function before and after the ICC-ES AC156 test. The unit maintained integrity during and after the ICC-ES AC156 Test.

1660 S. Amphlett Blvd., Suite 335 San Mateo, CA 94402 Phone 650-312-9233 ~ Fax 650-312-9229 e-mail: ktokeefe@UniversalStructuralEngineers.com

## Universal Structural Engineers, LLC



Table 2a-UUT1 Components and Subcomponents

OS	OSHPD Special Seismic Certification: Unit Under Test Summary: Components and Subcomponent						
# 45	RXL 5570	Total Equip Weight(lb)	Sub-components	Height (COG) (in)	Component Mounting		
44 43	9800-80 (Rail weight=6.5lb)	41	(CISCO) Modular Uplink Card	77.25	(4) #12 Screws in Back & Front		
42 41	TE-1405 Trinzic	20		72.875	(4) #12 screws in Front		
40							
39 38	C9500-24Y4C	22		69.375	(4) #12 screws in Front		
37 36 35 34 33		NEDFOR	CAI	0,			
32 31 30 29			CAi	室			
28 27 26	DUMMY WEIGHT	114		48.375	(4) #12 Screws in Back & Front for rail (4) #12 screws in front unit to rail		
25 24 23 22	0	BY: Moha	ammad Karim				
21 20 19	DUMMY WEIGHT	110		36.125	(4) #12 Screws in Back & Front for rail (4) #12 screws in front unit to rail		
18 17 16				4.			
15 14 13	DUMMY WEIGHT	108		25.625	(6) #12 Screws in Front		
12 11		30	ILDIN				
10 9	5PX1500RT (Rail weight=8lb)	73		17.75	(2) #12 Screws in Back & Front for rail (4) #12 screws in front unit to rail		
8 7 6	9PX1500RTN (Rail weight=8lb)	51		12.5	(2) #12 Screws in Back & Front for rail (4) #12 screws in front unit to rail		
5							
3 2 1	DUMMY WEIGHT	110		6.9375	(4) #12 Screws in Back & Front for rail (4) #12 screws in front unit to rail		
0							
0	RXL 5570-BK452432TNNNN	180		42	(4) 1/2" Diameter Bolts		
	Calculated Weight W/O Cables= Component Weight (W/O Dummy Weight)=	829 387	COG=	34.6			

1660 S. Amphlett Blvd., Suite 335 San Mateo, CA 94402 Phone 650-312-9233 ~ Fax 650-312-9229 e-mail: ktokeefe@UniversalStructuralEngineers.com