

Title: President

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE USE ONLY
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0826
HCAI Special Seismic Certification Preapproval (OSP)	
Type: New X Renewal	
Manufacturer Information	
Manufacturer: BSD Builders, Inc.	
Manufacturer's Technical Representative: Jeff Blair	
Mailing Address: 8369 Vickers Street #100, San Diego, CA 92111	
Telephone: (858) 657-9186 Email: Jeff@BSDBuilde	ers.com
Product Information	
Product Name: BSD SSC Microgrid Cogeneration System	Mp.
Product Model Number(s): BSD SSC 100-420, BSD-SSC-FSS-34MSCF.	4
Product Category: Emergency and Standby Power Systems	2
Product Sub-Category: Generators	
General Description: Microgrid Cogeneration System consisting of Coge	en Power <mark>Plant</mark> & Fuel Storage System.
Mounting Description: Base Mounted Rigid	
Tested Seismic Enhancements: None None	
Applicant Information	227 411
Applicant Company Name: BSD Builders, Inc.	
Contact Person: Jeff Blair	20%
Mailing Address: 8369 Vickers Street #100, San Diego, CA 92111	
Telephone: (858) 657-9186 Fmail: .leff@BSDBuilde	ers com

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY





DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)							
Company Name: JUNKER ENGINEERING GROUP							
Name: Dan Junker California License Number: S6178							
Mailing Address: 8950 Jefferson Ave, La Mesa, CA 91941							
Telephone: (619) 606-5058 Email: dan@junkereng.com							
Certification Method							
GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3							
Other (Please Specify):							
Testing Laboratory							
Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)							
Contact Person: Jeremy Lange							
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513							
Telephone: (972) 247-9657 Email: info@etldallas.com							
Company Name: UNIVERSITY OF CALIFORNIA, BERKELEY (PEER)							
Contact Person: Amarnath Kasalanati BY: Hmothy J. Piland							
Mailing Address: 325 Davis Hall, Berkeley CA 94720-1729							
Telephone: (510) 642-3437 Email: amarnath1@berkeley.edu							

HCAi

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Certified Response Spectral Acceleration Factors:(Fp/Wp)

Horizontal (A Flx-H), g=1.00 2.50 (A Rig-H), g=

Vertical (A Flx-V), g= 1.67 0.67 (A Rig-V), g=

SDS (Design spectral response acceleration at short period, g) = 2.5

Hf (Force amplification height factor) = 1.0

1.0 Ru (Structure ductility redution factor) =

Ip (Importance factor) = 1.5

z/h (Height ratio factor) = 0

HCAI Approval (For Office Use Only) - Approval Expires on 08/28/2031

Date: 8/28/2025

Name: Timothy Piland Title: Senior Structural Engineer

Condition of Approval (if applicable):

F· 08/28/2025



STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



08/28/2025 OSP-0826 Page 3 of 11

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT SUMMARY



Manufacturer BSD Builders, Inc.

Product Type Microgrid Cogeneration System

Model LineBSD SSC Power PlantTable DescriptionCertified Components

Table 1

Construction Summary

Generator: Steel container with 3.425" thick insulated walls containing an engine, a catalyst, silencers radiator, load bank, gas train, heat exchanger, and various fan, ducts, and electrical components.

Gas Tank: 48" diameter, 1.25" thick, 11 ft tall carbon fiber tank in structural steel frame and sheet metal enclosure panels.

Certification Parameters

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

 $S_{DS} = 2.5g$ for $R_{\mu} = 1.0$, $H_f = 1.0$

Mounting Summary

Rigidly base mounted.

Notes

Dimensions listed include exterior container subcomponents.

Manufacturer	Model Line	Model	Maximu	n Dimen	sions (in)	Max Weight	Description	UUT
Manufacturer	Model Lille	Name Length Width Height (lbs.)	(lbs.)	Description	001			
		BSD SSC 100	315	118	210	34,750	Alternator power rating = 100 kW	Extrapolated
		BSD SSC 135	315	118	210	34,750	Alternator power rating = 135 kW	Extrapolated
	BSD SSC	BSD SSC 170	315	-4182	210	36,550	Alternator power rating = 170 kW	Extrapolated
BSD Builders, Inc.	Power Plant	BSD SSC 200	315	118	210	3 <mark>6,550</mark>	Alternator power rating = 200 kW	Extrapolated
IIIC.		BSD SSC 280	315	118	210	39,500	Alternator power rating = 280 kW	2
		BSD SSC 420	315	118	210	41,000	Alternator power rating = 420 kW	1
	BSD SSC Fuel Storage System	BSD-SSC- FSS- 34MSCF	58	71	162	6,130	-	3 & 4
	,			₩				
		10				4.1/		
		71						
			A DIT	TI DIN	167			
			, DU	LLDIN	10			

build better together.

www.junkergonzalez.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT SUMMARY



Manufacturer Various, See Below

Product Type Microgrid Cogeneration System

Model LineBSD SSC Power PlantTable DescriptionCertified Sub-Components

Table 2

Construction Summary

Construction as described below.

Certification Parameters

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

 $S_{DS} = 2.5g$ for $R_{\mu} = 1.0$, $H_f = 1.0$

Mounting Summary

Notes

Mounted on component.

Manufacturer &	Model Number			Max Weight	Notes	UUT	
Product Line	woder Number	Length	Width	Height	(lbs.)	Notes	001
		Nat	ural Gas Gen	erators Sub	components		
			E	nclosure			
2G Energy AG	8m Avus500+	315	118	118	16,535	Steel container with 3.425" panels, insulated with sound dampening mineral glass and 2-hour fire- protection	1, 2
				Iternator			
	LSA 44.3 L10 / 4p	32	22.5	25.5	439	Steel frame, cast-iron	Extrapolated
Leroy-Somer	LSA 46.3 S4 / 4p	35	22.5	30	888	Ilanges and shields, ip 23	2
	LSA 47.3 VS3 / 4p	40	28 - 0	O ∠ 32	1392	protection rating	1
			Lo	oad Bank			
Crestchic	DC Load Bank	40	34.5	27 I Dilou	265	20" Diameter fan, stainless steel fins, 3-phase	1, 2
			;	Silencer			
Discom Exhaust	L25	56	30	30	496	Primary Silencer; S235JR steel	1,2
Technology	L45	87	24	24	540	Secondary Silencer; S235JR steel	1,2
			G	enerator			
	Aura 404	126	39	76	7,165	Cast-iron engine block &	Extrapolated
00.5	Aura 406	157	44	83	9,667	cylinder head, copper-	Extrapolated
2G Energy AG	Aura 408	160	52	91	12,258	brass oil cooler, stainless	2
	Aura 412	179	52	91	14,191	steel & brass inner cooler	1
			G	as Train			
Daniel Orașile ce di cu	50045-00238	27.5	12	10	108	Galvanized steel shut-off	Extrapolated
Dungs Combustion	50045-00239	32	12	7T 10	110	valve, cat-aluminum gas	2
Controls Heat Engine Base	50045-00240	35	12	11	117	pressure regulator, cast- iron housing	1
			Ven	tilation Fan		J	
Ziehl-Abegg	FC063	32	10	32	20	Aluminum die-cast blades, 3-phase fan, diameter= 27.75"	1,2
			l	Radiator			
Friga-Bohn FC Neostar Axial	FCH SN 08D P02 B2-1C-50V-M60- SCU	79	91	52.5	925	Two-speed motor, galvanized sheet metal, 2 26" diameter fans	2
Fan Dry Cooler	FC PN 06D P04 A3- 1C-134V	112	91	52.5	1430	Two-speed motor, galvanized sheet metal, 4 26" diameter fans	1
				Catalyst	1		
	61014-26611	13	13	5	27.3		Extrapolated
Interkat Catalyst	61014-26612	14	14	5	29.2	Stainless steel 304	Extrapolated
micikal Galaiysi	61014-26613	15	15	5	30.5	Clairiless steel 504	2
	61014-26614	18	18	5	41.9		1

build better together.

www.junkergonzalez.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT SUMMARY



Manufacturer Various, See Below

Product Type Microgrid Cogeneration System

Model LineBSD SSC Power PlantTable DescriptionCertified Sub-Components

Table 2

Construction Summary

Construction as described below.

Certification Parameters

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

 S_{DS} = 2.5g for R_{μ} = 1.0, H_f = 1.0

Mounting Summary

Notes

Mounted on component.

Manufacturer &	No. del Niverber	Max Dimensions (in)		s (in)	Max Weight	Notes	UUT
Product Line	Model Number	Length	Width	Height	Max Weight (lbs.)	Notes	001
		<u> </u>	Hea	Exchanger			•
GEA	20212135-2	8	10	24.5 24.5	130		Extrapolated
WTT Plate Heat	20212135-3	11	10	24.5	135	Otabalaaaataal	Extrapolated
Exchanger	20212135-4	14	10	24.5	145	Stainless steel	2
Exchanger GBS910M	20212135-5	20	10	24.5	205		1
		-	-	_			
					44		
					HHA VI		
					HHI		
					IBITE TO		
					141147		
					nd 77		
					U 772		
					THITHI		
					774		
					5 410		
					46		
					THHIAN		
					11177 V/		
					+		
				l			

build better together.

www.junkergonzalez.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT SUMMARY



Manufacturer Various, See Below

Product Type BSD SSC Fuel Storage System

Model Line: BSD SSC FSS

Table Description Certified Sub-Components

Table 3

Construction Summary Certification Parameters

Building Code: CBC 2025 Construction as described below. Component Importance Factor: $I_p = 1.5$

 S_{DS} = 2.5g for R_{μ} = 1.0, H_f = 1.0

Mounting Summary Notes

Mounted on component.

Manufacturer	Model		Dimension		Weight	Notes	UUT
Manufacturei	Number	Length	Width	Height	(lbs.)	Notes	001
		F	uel Tank Ass		omponents		
	T			Enclosure			
Hydria	NA	58	71	162	3,850	Carbon steel frame, 12 ga stainless steel sheet metal	3 & 4
	.			Gas Tank			
Hydria	CAT1502 105	46.5	46.5	132	1,200	Carbon fiber tank, 1.25" thick wall	3 & 4
	.			at Exchanger			
Hydria	SCBP-HX	36	25	25	1,015	Carbon steel	3 & 4
	T			Regulator			
Swagelok	RSN2-02-LLK	-	-	-	3	3,600 PSI to 2,800 PSI; Stainless steel	3 & 4
Swagelok	RSHN6-02-3-LLK- GN2	-	-	-	nd 5	2,800 PSI to 100 PSI; Stainless steel	3 & 4
Belgas	P301H4008043F0	-	-	-	16	100 PSI to 5 PSI; Cast-iron body, aluminum lower casing	3 & 4
			Press	ure Relief Va	lve	, , ,	
Caraba	951100MFA	-	-	-	7	Pressure Relief, Direct Spring Oper Type, 0.5"X1" MXF NPT, Setpoint: 125 PSIG, ASME8 Orifice; Stainless steel base, carbon steel cylinder	3 & 4
Crosby	981105MFA	-	-	ı	33	Pressure Relief, Direct Spring Oper Type, 1.5"X2" MXF NPT, Setpoint: 7 PSIG, ASME 8 Orifice; Stainless steel base, carbon steel cylinder	3 & 4
			Par	ticulate Filte	<u> </u>		
Parker	FFC-116-10	-	-	-	2	Filter, Particulate/Coalescent, 40- micron, 4500 psig min Rating; Stainless steel	3 & 4
			Pres	ssure Sensor	'S		
0	CS50- 2A02000PS4Z000 1-01	-	-	-	1	Pressure range 0-200psi. Output: 4-20mA, Supply 10-28 VDC; Stainless steel	3 & 4
Core Sensors	CS50- 2A05000PS4Z000 2-02	-	-	-	1	Pressure range 0-5000 psi. Output: 4-20mA, Supply 10-28 VDC; Stainless steel	3 & 4
			Tem	perature Prol	be		
Sandelius Instruments	RTD	-	-	-	1	Platinum, Max temp 500°F	3 & 4

build better together.

www.junkergonzalez.com



Manufacturer: BSD Builders, Inc.

Model Line: Microgrid Cogeneration System

Model Number: BSD SSC 420 Serial #: G6463

UUT 1

Construction Summary:

Steel container with 3.425" thick insulated wall panels. Certified component construction shall be identical to construction of UUT's.

Options Summary:

Container: 8m Avus500+, Generator: 2G Energy Aura 412, Gas Train: Heat Engine Base 50045-00240, Alternator: Leroy-Somer LSA 47.3 VS3 / 4p, Load Bank: Crestchic DC Load Bank, Silencers: Discom Exhaust Technology L256 & L45, Ventilation Fan: Ziehl-Abegg FC063 Radiator: Friga-Bohn FC PN 06D P04 A3- 1C-134V, Catalyst: Interkat 61014-26614, Heat Exchanger: GEA WTT Plate Heat Exchanger 20212135-5

Mounting Summary:

Rigid floor mounted. Fastened to test fixture using eight (8) manufacturer provided angles with 8-3/4" diameter A325 thru bolts.

Test Parameters:

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

Test Criteria: AC-156

Test Report:

PEER # 2023-238-SQTR-01-00; UUT 1

Notes:

Contents were included in testing per operating conditions.

UUT Image



UUT Properties

	Dimensions (in)			Min. First Natural Frequency (Hz)			
Length	Width	Height	Weight (lbs.)	F-B	S-S	Vert	
315	118	210	41,000	9.0	8.4	N/A	

Unit maintained structural integrity and remained operational

per manufacturer requirement when subjected to AC 156 test with the following test parameters

S _{DS} (g)	R_{μ}	H _f	A _{FLX-H} (g)	$A_{RIG-H}(g)$	A _{FLX-V} (g)	$A_{RIG-V}(g)$	
2.50	1.0	1.0	2.50	1.00	1.67	0.67	

build better together.

www.junkergonzalez.com

Page 5

08/28/2025 OSP-0826 Page 8 of 11



Manufacturer: BSD Builders, Inc.

Model Line: Microgrid Cogeneration System

Model Number: BSD SSC 280 Serial #: G6462

UUT 2

Construction Summary:

Steel container with 3.425" thick insulated wall panels. Certified component construction shall be identical to construction of UUT's.

Options Summary:

Container: 8m Avus500+, Generator: 2G Energy Aura 408, Gas Train: Dungs Combustion Controls Heat Engine Base 50045-00239, Alternator: Leroy-Somer LSA 46.3 S4 / 4p, Load Bank: Crestchic DC Load Bank, Silencers: Discom Exhaust Technology L256 & L45, Ventilation Fan: Ziehl-Abegg FC063, Radiator: Friga-Bohn FCH SN 08D P02 B2-1C-50V-M60-SCU, Catalyst: Interkat 61014-26613, Heat Exchanger: GEA WTT Plate Heat Exchanger 20212135-4

Test Parameters:

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

Test Criteria: AC-156

Test Report:

PEER # 2023-238-SQTR-01-00; UUT 2

Mounting Summary:

Rigid floor mounted. Fastened to test fixture using eight (8) manufacturer provided angles with 8-3/4" diameter A325 thru bolts.

Votes

Contents were included in testing per operating conditions.

UUT Image



UUT Properties

Dimensions (in)			Weight (lbs.)	Min.	First Natural Frequency (Hz)		
Length	Width	Height	weight (ibs.)	F-B	S-S	Vert	
315	118	210	39,500	9.6	9.2	N/A	

Unit maintained structural integrity and remained operational

per manufacturer requirement when subjected to AC 156 test with the following test parameters

S _{DS} (g)	R_{μ}	H _f	A _{FLX-H} (g)	A _{RIG-H} (g)	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
2.50	1.0	1.0	2.50	1.00	1.67	0.67

build better together.

www.junkergonzalez.com

Page 6

08/28/2025 OSP-0826 Page 9 of 11



UUT 3

Page 7

BSD Builders, Inc. Manufacturer: **Model Line: BSD SSC FSS**

Model Number:

BSD-SSC-FSS-34MSCF

Construction Summary:

Steel HSS welded frame with 12 Ga sheet metal panels containing a 48" diameter, 1.25" thick, 11 ft tall carbon fiber tank and subcomponents as listed.

Options Summary:

Gas Tank: Hydria CAT1502 105, Heat Exchanger: Hydria SCBP-HX, Regulators: Swagelok RSN2-02-LLK & RSHN6-02-3-LLK-GN2, Belgas P301H4008043F0, Pressure Relief Valves: Crosby 95100MFA & 981105MFA, Particulate Filter: Parker Particulate/Coalescent Filter FCC-116-10, Pressure Sensors: Core Sensors CS50-2A02000PS4Z0001-01 & 02, Temperature Probe: Sandelius Instruments RTD.

Test Parameters:

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

Contents were included in testing per operating

Test Criteria: AC-156

Test Report:

Notes:

ETL # 17578 Rev. 1; UUT 1

Mounting Summary:

The unit is mounted to the shake-table with (4) 1" Grade 8 bolts

UUT Image



UUT Properties

build better together.

Dimensions (in)			Weight (lbs.)	Min. First Natural Frequency (Hz)			
Length	Width	Height	weight (ibs.)	F-B	S-S	Vert	
58	71	162	6,124	7.46	11.15	>33.3	

Unit maintained structural integrity and remained operational

per manufacturer requirement when subjected to AC 156 test with the following test parameters

			g to the parameter and the par					
S _{DS} (g)	R_{μ}	H _f	A _{FLX-H} (g)	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$		
2.50	1.0	1.0	2.50	1.00	1.67	0.67		

www.junkergonzalez.com



Manufacturer: BSD Builders, Inc.

Model Line: BSD SSC FSS

Model Number: BSD-SSC-FSS-34MSCF

_{UUT} **4**

Construction Summary:

Steel HSS welded frame with 12 Ga sheet metal panels containing a 48" diameter, 1.25" thick, 11 ft tall carbon fiber tank and subcomponents as listed.

Options Summary:

Gas Tank: Hydria CAT1502 105, Heat Exchanger: Hydria SCBP-HX, Regulators: Swagelok RSN2-02-LLK & RSHN6-02-3-LLK-GN2, Belgas P301H4008043F0, Pressure Relief Valves: Crosby 95100MFA & 981105MFA, Particulate Filter: Parker Particulate/Coalescent Filter FCC-116-10, Pressure Sensors: Core Sensors CS50-2A02000PS4Z0001-01 & 02, Temperature Probe: Sandelius Instruments RTD.

Test Parameters:

Building Code: CBC 2025

Component Importance Factor: $I_p = 1.5$

Test Criteria: AC-156

Test Report:

ETL # 17578 Rev. 1; UUT 2

Mounting Summary:

The unit is mounted to the shake-table with (4) 1" Grade 8 bolts.

UUT Image



Contents were included in testing per operating conditions



UUT Properties

Dimensions (in)			Wainht (lha)	Min. First Natural Frequency (Hz)			
Length	Width	Height	Weight (lbs.)	F-B	S-S	Vert	
58	71	162	6,130	4.76	5.19	>33.3	

Unit maintained structural integrity and remained operational

per manufacturer requirement when subjected to AC 156 test with the following test parameters

S _{DS} (g)	R_{μ}	H _f	A _{FLX-H} (g)	$A_{RIG-H}(g)$	A _{FLX-V} (g)	$A_{RIG-V}(g)$
2.50	1.0	1.0	2.50	1.00	1.67	0.67

build better together. www.junkergonzalez.com Page 8