



**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

**APPLICATION #: OSP-0839**

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Johnson Controls

Manufacturer's Technical Representative: Ismail Erdi Kurtyigit

Mailing Address: 5000 Renaissance Drive, New Freedom, PA 17349

Telephone: (717) 668-7356 Email: ismail.erdikurtyigit@jci.com

**Product Information**

Product Name: CYK - Centrifugal Liquid Heat Pump Chiller

Product Model Number(s): CYK-P8QD-ETEVACS

Product Category: Chillers

Product Sub-Category: Chillers - Water Cooled

General Description: Self-contained heat pump or heat recovery chiller package with two compressors and motors, economizer, PLC panel, and remote mounted VSDs for indoor use.

Mounting Description: Base Mounted Neoprene Vibration Isolated - VSD: Rigidly mounted at the base and secured to the wall at the top.

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

**Applicant Information**

Applicant Company Name: Manwill Engineering LLC

Contact Person: Derek Manwill

Mailing Address: PO Box 1194, Bend, OR 97709

Telephone: (541) 241-2102 Email: derek@manwillse.com

Title: President





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: MANWILL ENGINEERING LLC  
Name: Derek Manwill California License Number: S6266  
Mailing Address: PO Box 1194, Bend, OR 97709  
Telephone: (541) 241-2102 Email: derek@manwillse.com

**Certification Method**

GR-63-Core       ICC-ES AC156       IEEE 344       IEEE 693       NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: U.S. ARMY ENGINEER RESEARCH AND DEVELOPMENT CENTER, CONSTRUCTION ENGINEERING RESEARCH LABORATORY (CERL)  
Contact Person: James Wilcoski  
Mailing Address: 2902 Newmark Dr., Champaign IL 61822-1076  
Telephone: (217) 373-4565 Email: james.wilcoski@usace.army.mil

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)  
Contact Person: Jeremy Lange  
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513  
Telephone: (972) 247-9657 Email: jeremy@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 3.15 (SDS=1.75, z/h=1), 1.50 (SDS=2.50, z/h=0)

SDS (Design spectral response acceleration at short period, g) = 1.75 (z/h=1), 2.50 (z/h=0)

$a_p$  (Amplification factor) = 2.5

$R_p$  (Response modification factor) = 2.5


$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment



**HCAI Approval (For Office Use Only) - Approval Expires on 04/19/2031**

Date: 02/11/2025

Name: Mohammad Karim Title: Supervisor, Health Facilities Review

Special Seismic Certification Valid Up to: SDS (g) = 1.75 z/h = 1

Condition of Approval (if applicable): \_\_\_\_\_




**JOHNSON CONTROLS**  
**CYK - Centrifugal Liquid Heat Pump Chiller**

**TABLE 1 - CYK**

Model Number	Dimensions (in)			Max. Wt. (lb)	Description / Notes	Basis
	Depth	Width	Height			
<b>CYK - Centrifugal Liquid Heat Pump Chiller</b>						
CYK-P8QD-ETEVACS	108.0	222.0	143.0	48,400		<b>UUT 1</b>
<b>Mounting:</b> Base Mounted Neoprene Vibration Isolated.				<b>Seismic Levels:</b>	$S_{DS} = 1.75g$ for $z/h = 1$ $S_{DS} = 2.50g$ for $z/h = 0$	$I_p = 1.5$

**Product Construction:** Welded carbon steel vessels. NEMA 1 carbon steel electrical panels. Copper tubes.

**Options/Subcomponents:** Since only one unit was tested, variations are not allowed. The following option selections are required: 300psi, no insulation, flanged nozzle connection, 2 pass evaporator, 3 pass double bundle condenser, marine water boxes, no hinges, no condenser epoxy coating, no sound attenuation, no falling film bypass, hot gas bypass, isolation valve.




**JOHNSON CONTROLS**  
**CYK - Centrifugal Liquid Heat Pump Chiller**

**TABLE 2 - VSD**

Model Number	Dimensions (in)			Max. Wt. (lb)	Description / Notes	Basis
	Depth	Width	Height			
<b>VSD</b>						
VSD790KFT-46	26.0	59.0	52.0	1,900		EXTRAP
VSD1055KFT-46	26.0	64.0	56.0	2,104		<b>UUT 6</b>
VSD1300KFT-46	36.0	75.0	59.0	2,522		<b>UUT 7</b>
<b>Mounting:</b> Rigidly mounted at the base and secured to the wall at the top.				<b>Seismic Levels:</b>	$S_{DS} = 1.75g$ for $z/h = 1$ $S_{DS} = 2.50g$ for $z/h = 0$	$I_p = 1.5$

**Product Construction:** NEMA 1 carbon steel enclosure.


**Options/Subcomponents:** Model number uniquely identifies the configuration, manufacturers, and materials of the sub-components within the unit. Subcomponent manufacturers and materials within the tested units used for interpolation are the same. Subcomponent manufacturers and materials within the interpolated units are the same as the tested units used for interpolation. Configuration of the interpolated units is similar to the tested units used for interpolation.



**JOHNSON CONTROLS**  
**CYK - Centrifugal Liquid Heat Pump Chiller**

**TABLE 3. SUBCOMPONENTS for CYK**

Model Number	Dimensions (in)			Max. Wt. (lb)	Description / Notes	Basis
	Depth	Width	Height			
<b>Type: Evaporator - Mfr: Johnson Controls</b>						
FA2914-373CZXXS3FMLX	168.0	38.0	47.0	10,493		UUT 1
<b>Type: Condenser - Mfr: Johnson Controls</b>						
DA3614-262CZCZW3FMLL	168.0	47.0	79.0	13,403		UUT 1
<b>Type: Economizer - Mfr: Johnson Controls</b>						
26 ODx52 LG	64.0	35.0	45.0	1,043		UUT 1
<b>Type: Compressor - Mfr: Johnson Controls</b>						
QD	35.0	34.0	35.0	1,669	High stage	UUT 1
P8	45.0	49.0	41.0	2,575	Low stage	UUT 1
<b>Type: Motor - Mfr: WEG</b>						
ET	47.0	22.0	27.0	2,470	Low stage	UUT 1
EV	47.0	22.0	27.0	2,536	High stage	UUT 1
<b>Type: Control Panel - Mfr: Trola</b>						
PLC	36.0	11.0	42.0	250		UUT 1
<b>Mounting:</b> Mounted within unit.				<b>Seismic Levels:</b>		$S_{DS} = 1.75g$ for $z/h = 1$ $S_{DS} = 2.50g$ for $z/h = 0$
<b>Construction/Options:</b> Model number uniquely identifies manufacturer, materials, and configuration of subcomponents.						





ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SPECIAL SEISMIC CERTIFICATION

UUT 1

Manufacturer: Johnson Controls  
 Model number: CYK-P8QD-EDEVACS  
 Unit function: Water-Cooled Centrifugal Chiller  
 Serial number: N/A



Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
108.0	222.0	143.0	48,400	5.8	4.9	18.9

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: US Army ERDC-CERL

Report: 24025TR1.0 (dated 2-7-25), tested on 12-11-24

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
1.75	1.00	2.80	2.10	1.68	0.68
2.50	0.00				


Importance Factor, I<sub>p</sub> = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Base mounted neoprene vibration isolated. UUT was mounted on (4) Mason neoprene pad assemblies (P/N 028-12850-000) with a total of (16) 1-1/4-in Grade 8 bolts (4 per pad). Pad assembly consists of: 15x15x3/8-in A36 plate on 14x14x3/4-in 60 duro neoprene pad, bolt goes through steel sleeve that sits inside neoprene sleeve, bolt head rests on structural washer and 4-in OD x 1/4-in thick washer which sits on 1/4-in neoprene washer.

**Construction:** Welded carbon steel vessels. NEMA 1 carbon steel electrical panels. Copper tubes. The following options were selected for the test unit: 300psi, no insulation, flanged nozzle connection, 2 pass evaporator, 3 pass double bundle condenser, marine water boxes, no hinges, no condenser epoxy coating, no sound attenuation, no falling film bypass, hot gas bypass, isolation valve.

**Subcomponents:** Johnson Controls - Evaporator (FA2914-373CZXXS3FMLX), Johnson Controls - Condenser (DA3614-262CZCZW3FMLL), Johnson Controls - Economizer (26 ODx52 LG), Johnson Controls - Compressor (QD, P8), WEG - Motor (ET, EV), Trola - Control Panel (PLC).

**Testing notes:** Testing at non-accredited laboratory meets the requirements of PIN 58 Item #16.



ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SPECIAL SEISMIC CERTIFICATION

UUT 6

Manufacturer: Johnson Controls  
 Model number: VSD1055KFT-46  
 Unit function: Variable Speed Drive  
 Serial number: N/A



Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
26.0	64.0	56.0	2,104	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: Environmental Testing Laboratory

Report: 17033TR2.0 (dated 4-4-23), tested on 12-13-22

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
3.74	1.00	5.98	4.49	2.51	1.01
3.74	0.00				


Importance Factor, I<sub>p</sub> = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Rigidly mounted at the base and secured to the wall at the top. VSD was bolted down at its base with (4) 7/16-in Grade 5 bolts and bolted to its top brace with (2) 1/2-in Grade 5 bolts. The welded base support structure was rigid mounted to the table. The welded structural steel top brace assembly was rigid mounted to a wall structure.

**Construction:** NEMA 1 carbon steel enclosure.

**Subcomponents:** Model number uniquely identifies the configuration, manufacturers, and materials of the subcomponents within the unit.

**Testing notes:** Testing was performed to an amplified level on a welded structural steel support structure to mimic the worst case scenario mounted on a chiller. Only remote mounting (not on a chiller) is considered here.





ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SPECIAL SEISMIC CERTIFICATION

UUT 7

Manufacturer: Johnson Controls  
 Model number: VSD1300KFT-46  
 Unit function: Variable Speed Drive  
 Serial number: N/A



Dimensions (in)			Weight (lb)	Res. Freq. (Hz)		
Depth	Width	Height		F-B	S-S	V
36.0	75.0	59.0	2,522	N/A	N/A	N/A

Code & criteria: 2022 CBC, ICC-ES AC156

Test laboratory: Environmental Testing Laboratory

Report: 17033TR2.0 (dated 4-4-23), tested on 12-14-22

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
3.74	1.00	5.98	4.49	2.51	1.01
3.74	0.00				

Importance Factor, I<sub>p</sub> = 1.5: Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**Mounting:** Rigidly mounted at the base and secured to the wall at the top. VSD was bolted down at its base with (4) 7/16-in Grade 5 bolts and bolted to its top brace with (2) 1/2-in Grade 5 bolts. The welded base support structure was rigid mounted to the table. The welded structural steel top brace assembly was rigid mounted to a wall structure.

**Construction:** NEMA 1 carbon steel enclosure.

**Subcomponents:** Model number uniquely identifies the configuration, manufacturers, and materials of the subcomponents within the unit.

**Testing notes:** Testing was performed to an amplified level on a welded structural steel support structure to mimic the worst case scenario mounted on a chiller. Only remote mounting (not on a chiller) is considered here.

