

Executive Summary

Health and Safety Code Section 130062 (Assembly Bill 2190, Chapter 673, Statutes of 2018) requires the Office of Statewide Health Planning and Development (OSHPD), before June 1, 2019, to provide the Legislature with an inventory of the Structural Performance Category (SPC) of each general acute care hospital building in California.

OSHPD also provides the SPC rating of each general acute care buildings on its website here:

<https://oshpd.ca.gov/ml/v1/resources/document?rs:path=/Construction-And-Finance/Documents/Seismic-Compliance/SPC-NPC-Ratings-List.pdf>

Under current law, by January 1, 2020 every acute care building must be structurally capable of remaining standing after a strong earthquake (SPC-2, or higher), unless the building has been granted an approved extension from OSHPD. AB 2190 provides for limited-term extensions for eligible hospitals. Hospitals that choose to retrofit existing acute care buildings, or replace acute care services in structurally non-compliant buildings may be eligible for an extension up to July 1, 2022. Hospitals that elect to rebuild may qualify for an extension up to January 1, 2025 to achieve a certificate of occupancy.

Hospitals had until April 1, 2019 to apply for an extension to the January 1, 2020 requirements. OSHPD has received extension applications for 85 buildings.

Out of the total California hospital building inventory of 3,109 acute care buildings, as of April 1, 2019, more than 95 percent are in compliance with the January 1, 2020 seismic standard.

Program Authority

The Alfred E. Alquist Hospital Facilities Seismic Safety Act (Health and Safety Code Sections 130000 through 130070) define OSHPD's various roles in enforcing the Act.

Seismic Ratings Background

OSHPD assigns an SPC rating to each general acute care hospital building in California. SPC ratings range from 1 to 5 with SPC-1 assigned to buildings that may be at risk of collapse during a strong earthquake and SPC-5 assigned to buildings reasonably capable of providing services to the public following a strong earthquake.

More detailed definitions of SPC ratings can be found on the OSHPD website here:

<https://oshpd.ca.gov/construction-finance/seismic-compliance-and-safety/seismic-performance-ratings/>

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01278	Original Hospital	In Service	1		27.63	1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01279	Stephens Wing	In Service	1		10.25	1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01280	West Wing	In Service	2			1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01281	South Wing	In Service	3s			1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01282	Radiology Addition	In Service	5s			4s
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01283	Medical Gas Storage	In Service	3s			1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-02630	Compactor Shed	In Service	4			2
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-03120	Emergency Room Relocation	In Service	3s			1
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-05597	LOX Tank	Under Construction	N/A			
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00695	Ehman Building	In Service	2		1.17	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00696	North Wing	In Service	2			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00698	East Wing	In Service	2		0.71	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00699	Original West Wing	In Service	1		26.18	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00700	West Service Wing - Building 1	In Service	1		16.85	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00701	Physio-Therapy Building	In Service	2			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00702	Original Emergency Wing	In Service	2			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00703	Special Procedures Addition	In Service	3			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00704	Emergency Department Expansion	In Service	5s			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00705	Cogeneration Building	In Service	4s			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00706	Emergency Generator Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00707	Transformer Building	In Service	2		0.37	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03431	South Wing - Phase 2	In Service	3			2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03433	West Service Wing - Building 2	In Service	1		21.08	2
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03434	Orig Emergency Wing - East Wing	Not an Independent Building	N/A			N/A
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-05300	Patient Care Pavilion	In Service	5			4
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-06010	New LOX Tank	Under Construction	N/A			
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-06060	Emergency Generator Yard	Equipment Yard	N/A			4
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-00708	Main Hospital Building	In Service	3			2
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-03443	Main Entrance Canopy	In Service	3			2
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-03444	Bridge at Link	In Service	3			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01285	Admin.	In Service	2			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01286	Laundry/Hall of Health	In Service	2			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01287	Boiler	In Service	2			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01288	1968 Building	In Service	2			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01289	1975 Building	In Service	2			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01290	1985 Building	In Service	4			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01291	Electric Service Building	In Service	4			2
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01292	Oxygen Tank Enclosure	Equipment Yard	N/A			2
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05340	Replacement Hospital	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05341	Chiller Building	In Service	5			4
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05342	Main Entrance Canopy	In Service	5			4
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05343	Emergency Entrance Canopy	In Service	5			4
01 - Alameda	11268	Fairmont Hospital	San Leandro	BLD-01311	Building B	Skilled Nursing Only	N/A			1
01 - Alameda	11268	Fairmont Hospital	San Leandro	BLD-01312	Building H	In Service	1		1.22	1
01 - Alameda	11288	Highland Hospital	Oakland	BLD-01315	Critical Care Building	In Service	5s			4s
01 - Alameda	11288	Highland Hospital	Oakland	BLD-01318	Chiller Building	In Service	1			1
01 - Alameda	11288	Highland Hospital	Oakland	BLD-01319	Boiler Plant	In Service	1			1
01 - Alameda	11288	Highland Hospital	Oakland	BLD-02957	New Acute Care Building	Under Construction	5s			4s
01 - Alameda	11288	Highland Hospital	San Leandro	BLD-05785	John George Psychiatric Hospital	Acute Psych Only	N/A			
01 - Alameda	11288	Highland Hospital	Oakland	BLD-06256	Critical Care Parking Structure	In Service	5s			4s
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02489	Hospital Patient Wing North	In Service	3			3
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02490	Hospital Patient Wing South	In Service	3			3
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02491	Hospital North	In Service	3			3
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02492	Hospital South	In Service	3			3
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02493	Central Plant	In Service	5			3
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02494	General Services Building	In Service	3s			3
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-02986	Hospital	In Service	5			4
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-02987	Central Plant	In Service	5			4
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-05716	Loading Dock and Plaza	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	San Leandro	BLD-03481	Templated Hospital Project	In Service	5			4
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	San Leandro	BLD-03482	Central Utility Plant	In Service	5			4
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00692	Original Building	In Service	2	23.62	1.04	3
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00693	Outpatient Diag. & Treat. Center	In Service	5			3
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00694	Boiler Enclosure	In Service	4			3
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-03083	Surgery Addition	Not an Independent Building	N/A			N/A
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-05427	Emergency Generator	Equipment Yard	N/A			3
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-05428	Liquid Oxygen Enclosure	Equipment Yard	N/A			3
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-01300	Main/Original Building	In Service	3			2
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-02709	Emergency Addition	In Service	5			2
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00709	Main Hospital Building	In Service	2	0.61		2
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00710	Engineering/Boiler Building	Not an Independent Building	N/A			N/A
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00711	Emergency and Critical Care Building	In Service	3			2
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00712	Chiller/Generator Building	In Service	5			2
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-03084	Skilled Nursing Facility	Skilled Nursing Only	N/A			N/A
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02532	Hospital Ambulatory Care & Inc. II	In Service	3			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02533	Central Plant	In Service	5			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02534	Valleycare (New) Addition	In Service	5			4
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02699	Arcade - Phase I - Portion 1	In Service	2			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02700	Arcade - Phase II - Portion 1	In Service	2			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02701	Porte Cochere	In Service	5			4
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02901	Arcade - Phase I - Portion 2	In Service	2			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02902	Arcade - Phase I - Portion 3	In Service	2			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-02903	Arcade - Phase II - Portion 2	In Service	2			2
01 - Alameda	16632	Stanford Health Care - Valleycare	Pleasanton	BLD-06430	Ambulance Drop Off Canopy	Proposed	5s			4s
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01293	Cardiac Cath Lab - MPOE	In Service	5			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01294	Patient Tower	In Service	3			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01295	West Site Plant	In Service	3			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01296	Cafeteria Addition	In Service	3			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01297	Diagnostic & Treatment Building	In Service	3			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01298	B/C Wing	In Service	1		3.28	2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01299	A/B Wing	In Service	1		15.07	2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-03121	Loading Dock	In Service	3			2
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05214	Western Expansion Building	In Service	5			4
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05822	Outpatient Clinic	Clinic - Local Jurisdiction	N/A			
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05837	Chiller Plant	Under Construction	5s			4s
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05856	Outpatient Center 2	Clinic - Local Jurisdiction	N/A			
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-00005	Hospital Building	In Service	2	0.63		2
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-00006	Boiler Building	In Service	2		0.63	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-00007	Emergency Generator Building	In Service	4			2
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-00008	Hospital Building-1967 Addition - Structurally connected to BLD-00005	Not an Independent Building	N/A			N/A
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-00009	Hospital Building - 1977 Addition - Structurally connected to BLD-00005	Not an Independent Building	N/A			N/A
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-02992	Lobby Addition to Hospital Building	In Service	3			2
01 - Alameda	11363	Valley Memorial Hospital	Livermore	BLD-03085	Building D: Service Building	In Service	4s			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00713	Original Hospital	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00714	South Wing Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00715	Emergency Wing Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00716	Areas No. 1 and 2 Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00717	Area No. 3 Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00718	Area No. 4 Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00719	Area No. 5 Addition	In Service	2			2
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00720	Entrance Canopy	In Service	5			4
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03561	Center for Joint Replacement	In Service	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03562	Central Plant	In Service	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03563	Center for Joint Replacement - Bridge	In Service	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03564	Interim Loading Dock	In Service	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03565	Underground Service Passage	In Service	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05627	Main Building	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05628	Canopy #1	Under Construction	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05629	Canopy #2	Under Construction	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05630	Canopy #3	Under Construction	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05631	Decontamination Building	Under Construction	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05632	Pedestrian Walkway #1	Under Construction	5s			4s
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05633	Pedestrian Walkway #2	Under Construction	5s			4s
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-00089	Hospital Building	In Service	5			4
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-05532	Emergency Department Entry Porte Cochere - Low	In Service	5			4
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-05533	Emergency Department Entry Porte Cochere - High	In Service	5			4
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00125	Upper Hospital	In Service	2	0.00		2
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00126	Dietary Building - Structurally connected to BLD-00125	Not an Independent Building	N/A			N/A
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00127	X-Ray/ER/ICU Building	In Service	4			2
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00128	Cardiac Cath. Lab Building	In Service	4s			2
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00129	Perinatal Services Building	In Service	4			2
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-00130	HVAC Building	In Service	4			2
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-02937	Emergency Department Canopy	In Service	5			4
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-03739	Emergency Department Addition	In Service	5			4
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-03740	Loading Dock	In Service	5			4
04 - Butte	10014	Adventist Health Feather River	Paradise	BLD-06393	Utility Tunnel	Tunnels	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00101	Original Hospital and Additions	In Service	1			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00102	Radiology Addition	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00103	Behavioral Health & Administration	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00104	Radiology Addition	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00105	Central Stores	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00106	Cardiac Cath Lab	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00107	Administration	In Service	4			1
04 - Butte	10009	Enloe Medical Center - Cohasset	Chico	BLD-00108	Surgery Addition	In Service	4			1
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00110	Original Hospital	In Service	2		0.13	2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00111	O.B. First Addition - Structurally connected to BLD-00110	Not an Independent Building	N/A			N/A
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00112	O.B. Second Addition - Structurally connected to BLD-00110	Not an Independent Building	N/A			N/A
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00113	Administration Third Addition - Structurally connected to BLD-00110	Not an Independent Building	N/A			N/A
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00114	Surgery Wing	In Service	2			2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00115	Corridor No. 1	In Service	2		1.17	2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00116	South Wing - Structurally connected to BLD-00110	Not an Independent Building	N/A			N/A
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00117	Trauma	In Service	2		0.00	2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00118	Pharmacy	In Service	2		0.00	2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00119	Tower	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00120	Cath Lab No. 1	In Service	4			2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00121	Radiology - Oncology	Not an Independent Building	N/A			N/A
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00122	Cath Lab No. 2	In Service	4			2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00123	Surgery Addition	In Service	4			2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-00124	Waiting Area/Corridor No. 2	In Service	4			2
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-02934	Magnolia Tower	In Service	5			4
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-02935	O.R. Addition	In Service	5			4
04 - Butte	10013	Enloe Medical Center - Esplanade	Chico	BLD-02936	E.R. Addition	In Service	5			4
04 - Butte	16464	Enloe Rehabilitation Center	Chico	BLD-00086	Rehabilitation Center	In Service	4			2
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00090	Main Hospital Building & Additions	In Service	2	0.54		2
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00091	East Wing Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00092	North Wing Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00094	Boiler Building	In Service	2	0.02		2
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00095	Warehouse Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00096	18 Bed Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00097	Surgical Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00098	X-Ray Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00099	Entry Addition - Structurally connected to BLD-00090	Not an Independent Building	N/A			N/A
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00100	ICU Addition	In Service	4			2
04 - Butte	10006	Orchard Hospital	Gridley	BLD-02933	Bulk Oxygen Yard	Proposed	N/A			
04 - Butte	10006	Orchard Hospital	Gridley	BLD-06355	Main Building	Skilled Nursing Only	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00134	1960 Original Building	In Service	2	0.07		2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00135	1963 Structural Addition - Structurally connected to BLD-00134	Not an Independent Building	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00136	1968 36 Bed Addition - Structurally connected to BLD-00134	Not an Independent Building	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00137	1971 X-Ray Addition - Structurally connected to BLD-00134	Not an Independent Building	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00138	1972 ICU Addition - Structurally connected to BLD-00134	Not an Independent Building	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00139	1974 ER Addition	In Service	4			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00140	1978 Pathology Addition	In Service	4			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00141	1979 Business/Lobby Addition	In Service	4			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00142	1979 Nuclear Medicine Addition Structurally connected to BLD-00140	Not an Independent Building	N/A			N/A
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00143	1989 South Wing Addition	In Service	4s			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00144	1997 Addition	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
04 - Butte	10019	Oroville Hospital	Oroville	BLD-03175	1979 Kitchen/Dining Addition	In Service	4			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-03844	1989 South Wing Addition - 1 story	In Service	4s			2
04 - Butte	10019	Oroville Hospital	Oroville	BLD-06111	Orohealth Hospital New Patient Tower	Proposed	5s			4s
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-00131	North Wing	In Service	2	0.00		2
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-00132	South Wing	In Service	4s			2
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-02938	ED Pedestrian Canopy	Proposed	5s			4s
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-06006	South Wing - Link Corridor	In Service	4s			2
06 - Colusa	10032	Colusa Medical Center	Colusa	BLD-00133	Main Hospital	In Service	2	0.01		2
06 - Colusa	10032	Colusa Medical Center	Colusa	BLD-06329	Bulk Medical Gas Yard	Equipment Yard	N/A			4
06 - Colusa	10032	Colusa Medical Center	Colusa	BLD-06475	Skilled Nursing Building	Proposed	N/A			
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-02468	1 - Main Hospital	In Service	5			2
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-02469	16 - Main Entrance Canopy	In Service	5			3
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-03719	2 - Clinical Lab	In Service	5s			2
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-03852	Cafeteria	In Service	2		0.30	3
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-05505	Lower Generator Building	In Service	2			3
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02472	Original Hospital (Elevator Tower)	In Service	2		22.67	2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02473	C Wing	In Service	2			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02474	Elevator/Stair Tower - Structurally connected to BLD-02472	Not an Independent Building	N/A	9.76		N/A
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02475	C Wing-East Wing-North West Element - Structurally connected to BLD-02476	Not an Independent Building	N/A	4.48		N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02476	D Wing	In Service	1	7.03		2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02477	D Wing-North Wing-Infill - Structurally connected to BLD-02473	Not an Independent Building	N/A			N/A
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02478	C Wing Addition	In Service	2			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02479	Linear Accelerator	In Service	4			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02480	B Wing / Surgery Equipment Room	In Service	2		1.11	2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02481	Surgery Equipment Room - Structurally connected to BLD-02480	Not an Independent Building	N/A			N/A
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02482	Cancer Center	In Service	5			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02483	Emergency Room	In Service	3			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02484	Canopy - Structurally connected to BLD-02483	Not an Independent Building	N/A			N/A
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02485	A Wing	In Service	3			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02486	Linear Accelerator	In Service	5			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02487	Central Plant	In Service	4			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02488	Boiler Plant	In Service	4			2
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02939	Canopy 1	In Service	5			4
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02940	Ambulance Canopy	In Service	5			4
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02941	Canopy 2	In Service	5			4
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02946	Canopy 3	In Service	5			4
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05223	E Tower	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05921	E-1	In Service	5			4
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05971	HVAC Tunnel	Tunnels	N/A			4
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00478	Original Hospital (Tower & Low Rise)	In Service	2	0.49		2
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00479	Phase 2 Tower	In Service	2	0.47		2
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00480	Phase 2 Cafeteria / Cardiology	In Service	2			2
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00481	Phase 2 ER / Radiology	In Service	2			2
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00482	Phase 3 West Wing	In Service	3			2
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00484	MRI Addition - Structurally connected to BLD-00478	Not an Independent Building	N/A			N/A
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-02944	Central Plant	In Service	5			4
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-05222	Phase 4 Tower	In Service	5			4
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-05308	Phase 3 West Wing - East Portion	In Service	3			2
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-03744	Hospital Building	In Service	5s			4s
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-03745	Central Utility Plant	In Service	5s			4s
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-02453	Hospital Building	In Service	3			3
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-02454	Central Service Building	In Service	5			4
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02447	Central Plant	In Service	4			2
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02448	North Addition (Hospital Tower)	In Service	3			2
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02449	Phase 1 Hospital - Utility Expansion	In Service	3s			2
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02450	Phase II Hospital	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02451	Generator Plant	In Service	5			2
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02452	Waste, Gas Farm Enclosure	In Service	5s			2
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-03504	Phase II Link Corridor	In Service	5			2
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-00276	Main Hospital	In Service	4			3
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-03395	Rehabilitation Hospital	Not an Independent Building	N/A			N/A
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-05620	ED Expansion	In Service	5			4
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-05621	OR Expansion	In Service	5			4
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-06290	New Pharmacy	Proposed	5s			4s
07 - Contra Costa	16166	San Ramon Regional Medical Center South Building	San Ramon	BLD-03688	Rehabilitation Hospital	In Service	3			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02461	Original Hospital	In Service	2	0.35		2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02462	ER / Lab Expansion	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02466	Nursing Tower	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02467	Ambulatory Services	In Service	5			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03032	Mechanical Building - Structurally connected to BLD-02461	Not an Independent Building	N/A			N/A
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03033	OR Storage Expansion	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03034	Entrance Canopy	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03484	Womens Center	In Service	5			4
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03667	Nursing Tower - Central Plant	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03668	Nursing Tower - Dining Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03669	Nursing Tower - Admin Building	In Service	4			2
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03670	Nursing Tower - Lobby Building	In Service	4			2
08 - Del Norte	12784	Sutter Coast Hospital	Crescent City	BLD-01054	Hospital Building	In Service	4			4
08 - Del Norte	12784	Sutter Coast Hospital	Crescent City	BLD-01055	Special Care Unit	In Service	5			4
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00485	Original and Nursing Wing Addition	In Service	2			2
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00486	Two Story Addition	In Service	4			2
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00487	Mechanical Plant and Addition	In Service	4			2
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00488	MRI Addition	In Service	5			4
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-05600	New Central Utility Plant	Under Construction	5s			4s
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00489	Original Building (Bldg I)	In Service	2	0.00		2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00490	1971 Addition No. 1 (Bldg II)	In Service	2	0.00		2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00491	1971 Addition No. 2 (Bldg III)	Not an Independent Building	N/A			N/A
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00492	1974 Addition (Bldg IV)	In Service	4			2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00493	1981 Addition No. 1 (Bldg V)	In Service	4			2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00494	1981 Addition No. 2 (Bldg VI)	In Service	4			2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00495	1988 Addition (Bldg VII)	In Service	4			2
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00496	1991 Addition (Bldg VIII)	Not an Independent Building	N/A			N/A
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00497	1964 Addition (Bldg IX) - Structurally connected to BLD-00489	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-05594	2012 Addition	In Service	5s			4s
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00513	Main Hospital Building	In Service	2	0.00		2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00514	Mechanical Building	In Service	2	0.00		2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00515	Rec. Room & Office Addition	In Service	2	0.00		2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00516	Lab & Storage Addition	In Service	4			2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00517	Canopy Addition	In Service	4			2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00518	Birthing Center	In Service	5			2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-02949	LDR Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-05522	ER / Radiology / Clinic Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-05681	Generator Shed	In Service	2			2
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06036	Lobby Remodel & Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06037	Corridor Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06038	Mechanical & Electrical Building Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06039	Main Entrance Canopy Addition	In Service	5			4
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06040	ER Canopy Addition	In Service	5			4
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00507	Medical / Surgical / Birthing	In Service	2	0.00		2
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00508	Maintenance Building	In Service	2	0.01		2
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00509	Nursing Wing	In Service	2	0.00		2
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00510	Emergency / Laboratory	In Service	4			2
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00511	Multi-Use Facility	In Service	2		0.00	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00512	Warehouse	In Service	2	0.05		2
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00020	Nursing Unit	In Service	4			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00021	Diagnosis and Treatment	In Service	4			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00022	Administration and Support	In Service	4			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00023	Central Plant	In Service	4			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05376	Central Plant Expansion	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05377	Bed Tower	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05378	Diagnostic & Treatment Expansion	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05379	Support Expansion 1	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05380	Support Expansion 2	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05381	Canopy 1	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05382	Canopy 2	In Service	5			4
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06051	North Bed Tower	Under Construction	5s			4s
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06052	Support Expansion 3A	Under Construction	5s			4s
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06053	Support Expansion 3B	Under Construction	5s			4s
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06054	Diagnostic & Treatment Expansion 3A	Under Construction	5s			4s
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06055	Diagnostic & Treatment Expansion 3B	Under Construction	5s			4s
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06056	Utility Tunnel - West	Tunnels	2			2
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06057	Utility Tunnel - East	Tunnels	N/A			2
10 - Fresno	10122	Coalinga Regional Medical Center	Coalinga	BLD-00498	Main Hospital Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-00003	West Wing / East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02535	Radiology Addition	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02536	Aa - East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02537	Ab - East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02538	Ac - East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02539	Ad - East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02540	Ae - East Wing	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02541	Angiography Addition	In Service	4			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02951	Trauma & Critical Care Center	In Service	5s			4s
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02952	New Central Plant	In Service	5			
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02953	Utility Tunnel	Tunnels	N/A			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-03513	D/P Skilled Nursing Facility	In Service	2			2
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-05190	MRI Building	In Service	5s			4s
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-05208	Data Center Building	In Service	5			
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05187	Main Hospital	In Service	5s			4s
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05188	Central Plant	In Service	5s			4s
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05278	Wing A	In Service	5s			4s
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-00294	Recovery Center	In Service	4			4
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-03748	Expansion	In Service	5			4
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-05252	New Tower	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-05366	Equipment Yard	Equipment Yard	N/A			
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00976	Sequoia Mall	In Service	4			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00977	Hospital Tower North	In Service	4			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00978	Hospital Tower South	In Service	4			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00979	Ancillary/Yosemite Building	In Service	4			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00980	Ancillary Building Addition	In Service	4			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00981	Utility/Grapevine Building	In Service	5			2
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06468	Cooling Tower Yard	Equipment Yard	N/A			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00500	Main Building	In Service	2			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00501	West Addition	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00502	Cogeneration Building	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00503	Chapel	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00504	Northwest Addition	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00505	East Addition	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00506	Central Plant	In Service	4s			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-03307	Cath Recovery Building	In Service	5			4
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-03308	North Addition	In Service	5s			4s
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-05548	Canopy and Bridges	In Service	2			2
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-05877	UPS Flywheel Enclosure	In Service	5			
10 - Fresno	16404	San Joaquin Valley Rehabilitation Hospital	Fresno	BLD-02531	Hospital Building	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00519	Main Hospital Building	In Service	2	0.49		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00520	Garage Building	In Service	2	0.07		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00521	600 Wing (Accounting) Addition	In Service	2	0.09		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00522	Nurses Locker Addition	In Service	4			2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-02884	Hospital	Under Construction	5s			4s
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03773	Main Building - ICU Addition	In Service	4			2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03774	Main Building - Dietary / Purchasing	In Service	2	0.49		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03775	Main Building - 700 Wing South	In Service	2	0.04		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03776	Main Building - 700 Wing North	In Service	2	0.04		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03777	Main Building - 800 Wing	In Service	2	0.04		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03778	Main Building - Medical / Surgery	In Service	2	0.04		2
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03825	Shop & Maint. Building	In Service	2	0.01		2
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-00751	Main Building and Additions	In Service	2	0.73		2
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-03334	ER Addition	In Service	4			2
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-05453	Clinic Building and Additions	Outpatient Only	N/A			N/A
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00186	Main Hospital	In Service	2	0.05		2
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00187	Central Plant	In Service	2	0.13		2
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00188	Administration/Urgent Care	In Service	4			2
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00189	Short Stay Surgery	In Service	4s			2
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00190	Obstetrics Addition	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-05471	AHU Platform	Under Construction	5s			4s
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-05715	Conference Room Addition	In Service	4s			2
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-00529	Original Building	In Service	2	0.43		3
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-00530	O.B. Addition	In Service	5			3
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-00531	Generator Building	In Service	5			4
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-00532	East Wing Expansion	In Service	5			3
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-00533	E. Wing Canopy	In Service	4			3
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-03890	Surgery Department	Not an Independent Building	N/A			N/A
12 - Humboldt	10183	Redwood Memorial Hospital	Fortuna	BLD-05824	Rehab. Addition	Under Construction	5s			4s
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00535	Original Hospital and Central Plant	In Service	1		30.48	2
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00536	Linear Accelerator (Phase II)	In Service	5			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00537	Phase III Addition Building	In Service	4			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00538	Emergency Entrance Vestibule	In Service	5			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00539	Radiation Oncology Addition	In Service	5			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00540	Heart Center	In Service	5			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00541	East Wing	In Service	5			4
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-00542	Emergency Entrance Vestibule Addition	In Service	3			3
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-02735	Emergency Generator #1 CMU Building	In Service	4			4
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-02736	Emergency Generator #2 Enclosure Shed	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-03375	Northeast Building Entry Link	Under Construction	5s			4s
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-03376	Fire Pump House	Under Construction	5s			4s
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-03625	Northeast Building	In Service	5s			4s
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-05767	Northeast Building Ambulance Canopy	Under Construction	5s			4s
12 - Humboldt	10184	St. Joseph Hospital	Eureka	BLD-05768	Northeast Building Entry Canopy	Under Construction	5s			4s
12 - Humboldt	10180	The General Hospital	Eureka	BLD-00523	Original Hospital Building	In Service	1		27.22	2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-00524	1950 Addition Building	In Service	1		8.88	2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-00525	1955 Addition Building	In Service	1		19.10	2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-00526	Center Building - 1957 Addition	In Service	1		26.46	2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02651	West Side Building - 1957 Addition	In Service	1		22.68	2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02652	Stair #1	In Service	4			2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02653	Nursery	In Service	4			2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02654	Stair #2	In Service	4			2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02655	Stair #3	In Service	4			2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02656	Radiology Wing	In Service	4			2
12 - Humboldt	10180	The General Hospital	Eureka	BLD-02657	Lobby	In Service	3			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00752	South Wing	In Service	1			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00753	L/D Bldg	In Service	1			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00754	Central Wing	In Service	1			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00755	West Addition	Not an Independent Building	N/A			N/A
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00756	Central Plant	In Service	1			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00757	North Wing	In Service	1			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00758	ICU Addition	Not an Independent Building	N/A			N/A
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00759	Admin Bldg	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00760	OB Building	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00761	Radiology Building	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00762	Rad Annex	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00763	Lab Building	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00764	Annex	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02685	East Wing - South	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02686	New Wing	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02687	New Central Plant	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02887	Admin Bldg Addition	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02888	East Wing - North	In Service	4			2
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-03219	Electrical Room	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-03331	Generator Yard	Equipment Yard	N/A			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05694	Ancillary Services Building	Under Construction	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05926	Bed Expansion	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05927	Bridge Link	Under Construction	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05940	Cooling Tower Yard	Equipment Yard	N/A			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06098	Data Center Building	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06371	Emergency Department Expansion	Proposed	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06389	Entrance Lobby	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06390	Entrance Canopy	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06391	Driveway Canopy	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06392	Ambulance Canopy	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06408	Utility Canopy	Proposed	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06419	North ASB Utility Canopy	Under Construction	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06420	South ASB Utility Canopy	Under Construction	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06421	ASB Covered Link	Under Construction	5s			4s
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06427	Central Plant Shed	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06428	Hazardous Waste Storage	In Service	5			4
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06429	Pharmacy Expansion	In Service	5			4
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00765	Original Hospital	In Service	2	0.72		2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00766	Original Power Plant	In Service	2	0.55		2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00767	Administration Wing	In Service	2	0.29		2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00768	ICU Addition	In Service	4			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00769	Outpatient Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00770	Women's Center	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00771	ER	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00772	New Power Plant	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-00773	Dietary	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-02891	Link between 05B and 05D	Not an Independent Building	N/A			N/A
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-02892	Link between 05B and 01A	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-02893	Link between 05B and 05C	In Service	5			2
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-05909	Surgery Addition	Under Construction	5s			4s
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-06136	ED Expansion	Proposed	5s			4s
13 - Imperial	10192	Pioneers Memorial Healthcare District	Brawley	BLD-06240	Emergency Generator Yard	Equipment Yard	N/A			
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00775	Main Hosp Bldg/Existing Central Plant	In Service	1			2
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00776	ICU Addition	In Service	5s			2
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00777	Central Plant Addition	In Service	5s			2
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00778	Emergency Generator Building	In Service	5			2
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-02922	New Hospital Building	In Service	5s			4s
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-05321	New Central Plant Building	In Service	5s			4s
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00779	Main Hospital Building	In Service	2		1.02	2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00780	Maintenance Building	In Service	2		0.77	2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00781	Entrance Addition	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00782	East Wing Addition	In Service	2		1.07	2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00783	West Wing Addition	Not an Independent Building	N/A			N/A
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00784	Diagnostics & Treatment Addition	In Service	4			2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00785	Patient Room Addition	In Service	4			2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00786	Storage Room Addition	In Service	4			2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00787	Boiler Room Addition	In Service	4			2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00788	Boiler Room 2 Addition	Not an Independent Building	N/A			N/A
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00789	Laundry Building	No Acute Care - OSHPD Bldg	N/A			2
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00790	Storage Building	In Service	2		0.58	2
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00948	Original Building (Main Hospital)	In Service	2			3
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00949	Emergency Department Addition	In Service	5			3
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00951	Emergency Generator Enclosure	In Service	4			3
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00952	Fire Pump Enclosure	In Service	5			3
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00953	Bulk Medical Storage Facility	Equipment Yard	N/A			2
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-06018	Tower Number 2	In Service	5			4
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-03237	Main Entrance Building	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05541	Medical / Surgical Facility Building	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05542	Obstetrical Facilities Building	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05543	D & T Building	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05544	Main Entrance Canopy	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05545	ED Canopy	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05546	CT Trailer Canopy	Under Construction	5s			4s
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05547	Water Tank	Under Construction	N/A			
15 - Kern	17358	Bakersfield Heart Hospital	Bakersfield	BLD-00085	Bakersfield Heart Hospital	In Service	5			4
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00791	Main Hospital / Lobby / Boiler Building	In Service	2	0.48		2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00792	East Wing	In Service	2	0.06		2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00793	Central Plant	In Service	4			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00794	Main Hospital West Wing / Business Office	In Service	2	0.44		2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00795	Maternity Wing	In Service	2	0.21		2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00796	Labor & Delivery	In Service	5			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00797	Labor & Delivery II	In Service	3			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00798	Main Tower	In Service	3			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00799	New Cath Lab & Surgery	In Service	4			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00800	ER Addition	In Service	4			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00801	Main Hospital East Wing	In Service	2	0.08		2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03377	Endoscopy Building	In Service	2		0.31	2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03378	Main Tower - Connecting Corridor	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03379	Laundry / Warehouse Building	No Acute Care - OSHPD Bldg	N/A			N/A
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05215	Entrance Pavilion	In Service	5			4
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05659	Endoscopy Corridor	In Service	2		0.58	2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05896	Cardiac Rehab	No Acute Care - OSHPD Bldg	N/A			N/A
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05897	Physical Therapy / Regional Human Resources	No Acute Care - OSHPD Bldg	N/A			N/A
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05902	Ambulance Porte Cochere	In Service	5s			2
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06326	Kitchen / Shell Bldg.	In Service	5s			4s
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06357	Pediatric Pavilion for Emergency Care	In Service	5			4
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06373	Lobby Expansion.	In Service	5			4
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-01049	Main Building	In Service	2	0.00		1
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-01050	Radiology Addition	In Service	4			1
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-01051	ICU/TCU Facility	In Service	4			1
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-01052	Med Gases Ancillary	In Service	4			1
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-01053	Med Gases	Equipment Yard	N/A			1
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-05953	SNF Building	Skilled Nursing Only	N/A			N/A
15 - Kern	12765	Delano Regional Medical Center	Delano	BLD-06162	Generator Yard	Under Construction	N/A			
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-00281	East Building	In Service	4			2
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-00282	West Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05565	20 Bed Addition	In Service	5			4
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05566	Emergency Power Generator	Equipment Yard	N/A			4
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05567	Bulk Oxygen Enclosure	Equipment Yard	N/A			4
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00811	Original Hospital & Additions	In Service	2	0.02		2
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00812	Pediatrics Wing & Additions	In Service	2		0.19	2
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00813	Patient Wing	In Service	2		0.14	2
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00814	Intensive Care Unit Addition	In Service	4			2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00803	Wing B/C - North	In Service	2	0.57		2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00804	Wing D	In Service	5s			2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00805	Wing E	In Service	5s			2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00806	Infill at E Wing	In Service	5			2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00807	Wing G / Laundry / Boiler Room	In Service	1		13.39	2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00808	Wing G/Dietary	In Service	2	0.61		2
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00809	Central Utilities Plant	In Service	5			4
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-03806	Wing B/C - South	In Service	2	0.31		2
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-00810	Main Hospital Building	In Service	2	0.35		2
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02964	Central Plant Addition	In Service	4s			2
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02965	Surgical Suite Addition	In Service	4s			2
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02966	Service Facility Addition	In Service	4s			2
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02967	Skilled Nursing Addition	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00827	Main Wing/Courtyard Infill	In Service	2	2.44	0.49	2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00828	Addition to the Main Wing	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00829	Patient Tower (T & D Stair No. 3)	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00830	Treatment and Diagnostic Building (Central Plant and Emergency Generator Enclosure)	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00831	T & D Admitting Wing (Boiler Building and Mezzanine)	In Service	2	5.43		2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00832	T & D Stair No. 1 (Laundry Building)	In Service	2	0.10		2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00833	T & D Stair No. 2 (Treatment and Diagnostic Building)	In Service	3			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00834	T & D Stair No. 3 (T & D Stair No. 4)	In Service	3			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00835	T & D Stair No. 4 (Patient Tower)	In Service	3			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00836	Boiler Building and Mezzanine (T&D Stair Number 1)	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00837	Central Plant and Emergency Generator Enclosure (T&D Admitting Wing)	In Service	3			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00838	Laundry Building	Not an Independent Building	N/A			N/A
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-02905	Main Hospital Bldg 1 Old River Road	Not an Independent Building	N/A			N/A
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-02906	Main Hospital Bldg 2 Old River Road	Not an Independent Building	N/A			N/A
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-03315	Corridor - Northwest Side	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-05203	Boiler Building and Mezzanine (T&D Stair Number 2)	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06181	Porte Cochere	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06182	Corridor - Northeast Side	In Service	4			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06196	Bulk Oxygen Enclosure	Equipment Yard	N/A			2
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06207	Emergency Generator and Aboveground Fuel Tank	Equipment Yard	N/A			2
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-02623	Main Hospital Building 1	In Service	4			2
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-02624	Main Hospital Building 2	In Service	4			2
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-05786	MRI Modular Building	Outpatient Only	N/A			
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06359	New Four Story Patient Tower	Proposed	5s			4s
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06360	New Two Story East Addition	Proposed	5s			4s
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06361	New One Story West Addition	Proposed	5s			4s
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06362	New Central Utility Plant	Proposed	5s			4s
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06363	Main Entry Canopy	Proposed	5s			4s
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06364	Loading Dock Canopy	Proposed	5s			4s
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00815	Main Core	In Service	2	0.18		2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00817	B Wing	In Service	2	0.18		2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00818	C Wing	In Service	2	0.18		2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00819	ICU Addition	In Service	4			2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00820	D Wing	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00821	E Wing	In Service	4			2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-03483	Addition to Existing Hospital	In Service	5s			2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-03619	Cafeteria / Dining Expansion	In Service	5s			2
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-06241	Emergency Department Addition	Proposed	5s			4s
15 - Kern	10820	Vibra Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-06330	Vibra Rehabilitation Hospital of Bakersfield	Proposed	5s			4s
15 - Kern	10820	Vibra Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-06332	Emergency Generator Yard	Proposed	N/A			
15 - Kern	10820	Vibra Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-06333	O2 Yard	Proposed	N/A			
15 - Kern	10820	Vibra Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-06334	Main Entry Drop Off Canopy	Proposed	5s			4s
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05346	Main Hospital - West Wing	In Service	5			4
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05347	Main Hospital - East Wing	In Service	5			4
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05570	Womens Center	In Service	5s			4s
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05571	Energy Center	In Service	5s			4s
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00431	East Wing	In Service	2	0.02		2
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00432	West Wing	In Service	4			2
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00433	Emergency Room	In Service	4			2
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00434	Central Supply/Maintenance	In Service	4			2
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-05509	Chiller Platform	Not a Building Structure	N/A			2
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-06023	Emergency Generator Yard	Equipment Yard	N/A			2
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00268	Main Hospital	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00269	Hospital Addition	In Service	4			2
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00270	CT Scanner	In Service	4			2
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-02981	Conference Room	Not an Independent Building	N/A			N/A
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-02982	LDRP Addition	In Service	4			2
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-03052	Purchasing Building	No Acute Care - OSHPD Bldg	N/A			2
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-03558	Surgery & Emergency Department	In Service	5			4
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-06296	Pharmacy Addition	Under Construction	5s			4s
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-06486	ED Canopy	Proposed	5s			4s
18 - Lassen	17940	Banner Lassen Medical Center	Susanville	BLD-05185	Main Building	In Service	5			4
18 - Lassen	17940	Banner Lassen Medical Center	Susanville	BLD-06331	Central Utility Plant	Proposed	5s			4s
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01940	Rehabilitation Wing	In Service	2	0.52		3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01941	Mental Health Building	Acute Psych Only	N/A			1
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01942	Main Building - North East	Not an Independent Building	N/A			N/A
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01943	Main Building - South	In Service	3			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01944	Main Building - West (SICU)	In Service	4			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01945	Main Building - Stair Tower #5	In Service	4			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01946	Wilson Parking Structure	In Service	4			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01949	Link Building	In Service	4			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01950	Link Building - West	In Service	4			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01951	Link Building - East	In Service	4			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01952	TCU	In Service	2		1.08	3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01953	D & T / D & T Plant	In Service	2	0.69		3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03015	Womens Pavilion	In Service	5			4
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03016	Mental Health Bldg South Addition	Acute Psych Only	N/A			1
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03263	Main Building - North East	In Service	3			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03439	West Tower Phase 2 / 3	In Service	5			4
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03440	West Tower Phase 1	In Service	5s			2
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03441	West Tower Link to Main Building	In Service	5s			4s
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03491	Main Building - West (Staircase)	Not an Independent Building	N/A			N/A
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03762	Main Building - Cooling Tower	Not a Building Structure	N/A			4
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03913	Main Building - North	In Service	3			3
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-05932	Exhaust Stack	Not a Building Structure	N/A			
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-06399	Compounding Pharmacy Building	In Service	4			2
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02187	D & T Building (North Tower)	Delicensed Clinic under OSHPD	N/A			2
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02188	East Building	In Service	2			3
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02189	Chiller Building	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02191	East Building North Addition (B-1)	In Service	3			3
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02192	South Building	In Service	3			2
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02193	Emergency Generator Building	In Service	5			4
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03157	East Building South Addition (B-2)	In Service	3			3
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03287	Shop Building Replacement	In Service	5			4
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03288	Boiler Building Replacement	In Service	5			4
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03290	Service Tunnel Replacement	Tunnels	N/A			4
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03291	Specialty Care Tower	In Service	5			4
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03859	Entry Concourse Building	In Service	5s			4s
19 - Los Angeles	11386	Alhambra Hospital Medical Center	Alhambra	BLD-00722	Hospital	In Service	2	0.41	1.23	2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00737	Original Hospital	In Service	1		8.13	2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00738	Storeroom Addition	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00739	East Wing Addition	In Service	1		4.23	2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00740	Dining Room Addition	In Service	2		1.07	2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00741	Cobalt Addition	In Service	2		0.58	2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00742	Hospital Addition	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00743	Central Plant	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00744	Emergency Room Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00745	Storage Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00746	Hospital Tower Addition	In Service	3			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00747	Central Plant Addition	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00748	Entrance Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00749	Kitchen and Dining Additions (west side addition)	Not an Independent Building	N/A			N/A
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-00750	Storeroom & Dock Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-02621	Kitchen Addition	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-02804	New Women's and Children's Hospital	In Service	5			4
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-02805	New WCH Central Plant	In Service	5			4
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-03486	Northeast Canopy	In Service	4			2
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-05484	Kitchen and Dining Additions (east side addition)	Not an Independent Building	N/A			N/A
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-05708	New Women's and Children's Hospital Canopy	In Service	5			4
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-05709	New Women's and Children's Hospital Electrical Room	In Service	5			4
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-05711	New Women's and Children's Hospital LOX Tank	Equipment Yard	N/A			
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-06091	Central Plant Tunnel	Tunnels	N/A			
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-06107	Entrance Canopy	In Service	5			4
19 - Los Angeles	11399	Antelope Valley Hospital	Lancaster	BLD-06108	Central Plant Addition - West	In Service	5			4
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00730	Outpatient Clinic & Lab Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00731	Dining/Kitchen Building & Additions (1902)	In Service	2		1.03	3
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00732	1927 Addition (Original Building)	In Service	1		14.57	2
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00733	1974 Addition "A"	In Service	2		0.34	2
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-02707	1974 Addition "B"	In Service	2		0.53	3
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-02708	1974 Addition "C"	In Service	2		0.53	3
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-03010	Outpatient Clinic & Lab Addition	In Service	4			2
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-03048	Barlow Respiratory Hospital	Under Construction	5s			4s
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-05958	Electrical Equipment Yard	Under Construction	N/A			
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-06457	Utility Building	Proposed	5s			4s
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-06489	Entry Canopy	Proposed	5s			4s
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-06490	Rear Canopy	Proposed	5s			4s
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00613	Service Building & Additions (Block I)	In Service	2		0.17	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00614	Home Health (Block II) Nursing & Lab	In Service	2	1.14	0.85	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00615	Nursing Administration (Block III)	In Service	2		0.10	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00616	Accounting & Respiratory Therapy (IV)	In Service	2		0.10	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00617	Emerson Wing - Nursing Unit (V)	Not an Independent Building	N/A			N/A
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00618	Main Building North (Block VI)	In Service	2		0.85	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00619	Canopy (Block VII)	In Service	4			2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00620	OB Addition (Block VIII)	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-00621	MRI Facility (Block IX)	In Service	5			2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-03872	Main/Utility/Tower (Block VI)	In Service	2	15.48	1.03	2
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-05504	Central Plant and Ambulance Area	In Service	5			4
19 - Los Angeles	11441	Beverly Hospital	Montebello	BLD-06415	Equipment Yard – Hot Water System	Equipment Yard	N/A			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00622	Tibbitts Tower A	In Service	3			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00623	Tibbitts Tower B	In Service	3			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00624	Admitting Building	In Service	3			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00625	D & T Building	In Service	2			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00626	1963 Central Plant	In Service	2	1.47	0.60	2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00627	1969 Central Plant	In Service	2	0.66		2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00628	1964 Tower	In Service	1	13.20		2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03122	Lobby	In Service	3			2
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03212	Emergency Department and Women's Services	Under Construction	5s			4s
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03213	Stair Tower	Under Construction	5s			4s
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03214	Entry Canopy	Under Construction	5s			4s
19 - Los Angeles	12874	California Rehabilitation Institute, Llc	Los Angeles	BLD-00940	Main Hospital	In Service	2	1.22	0.78	2
19 - Los Angeles	12874	California Rehabilitation Institute, Llc	Los Angeles	BLD-02910	Generator and LOX Yard	Equipment Yard	N/A			
19 - Los Angeles	12874	California Rehabilitation Institute, Llc	Los Angeles	BLD-03876	Trigen Central Plant	In Service	2		0.72	2
19 - Los Angeles	12874	California Rehabilitation Institute, Llc	Los Angeles	BLD-03908	Central Plant Expansion 3	In Service	2		0.44	2
19 - Los Angeles	12874	California Rehabilitation Institute, Llc	Los Angeles	BLD-05781	Drop Off Canopy	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-02885	New Replacement Hospital	In Service	5s			4
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05310	Medical Surgical Addition and 31 Bed Hospital	In Service	5			4
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05311	Electrical Building	In Service	5s			4s
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05473	Mechanical Yard Building	In Service	5s			4s
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-06219	Welcome Gallery	In Service	5			4
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-06220	Imaging Connector	In Service	5			4
19 - Los Angeles	11410	Catalina Island Medical Center	Avalon	BLD-00725	Original Building	In Service	2	0.19		2
19 - Los Angeles	11410	Catalina Island Medical Center	Avalon	BLD-00726	East Addition	In Service	4			2
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-01039	Original Building	In Service	2	0.31		2
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-01040	CCU Addition	In Service	4s			2
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-01041	Outpatient Addition	In Service	4s			2
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06232	Pharmacy Addition	Under Construction	5s			4s
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06366	Hospital	Proposed	5s			4s
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06367	Central Utility Plant	Proposed	5s			4s
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06368	Gas Yard	Proposed	N/A			
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06417	ED Modular Building	Proposed	5s			4s
19 - Los Angeles	12744	Cedars-Sinai Marina Del Rey Hospital	Marina Del Rey	BLD-06418	Hospital Entry Canopy	Proposed	5s			4s
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00384	Main Medical Center	In Service	2			3
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00385	Harvey Morse Conference Center	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00386	Becker Building	Not an Independent Building	N/A			N/A
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02806	Imaging Building	In Service	5			4
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02807	Saperstein Critical Care Tower	In Service	5			4
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02808	Central Plant	In Service	5			4
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-03438	Pedestrian Bridge	No Acute Care - OSHPD Bldg	N/A			
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-05255	Thalians Building	Acute Psych Only	N/A			N/A
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-05265	Comprehensive Cancer Center	Outpatient Only	N/A			
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-05304	Advanced Health Sciences Pavilion	Outpatient Only	N/A			
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00633	West Wing/ER Addition	In Service	2	0.06		2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00634	North Wing/Day Surgery	In Service	2	0.04		2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00635	Dietary Storage	In Service	2	0.07		2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00636	East Tower	In Service	4			2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00637	West Tower	In Service	2	8.47	0.80	2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00638	Engineering	In Service	2	0.97	0.97	2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00639	East Wing	In Service	2	0.60		2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00640	Central Plant Addition	In Service	2	0.37		2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00641	Nursery Addition	In Service	2	4.13	0.45	2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-03466	Utility Tunnel	Tunnels	N/A			2
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-05404	Electrical Services Building	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00643	Duque Building	In Service	2	0.27		2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00644	Page Tower	In Service	3			2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00645	McAllister Building	In Service	2	5.60	0.92	2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00646	Page Building	In Service	3			2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00647	Weingart Pavilion	In Service	3			2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00648	McDonald's Building	In Service	3			2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-02847	Linear Accelerator	In Service	4			2
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-02848	DWP Substation	In Service	5s			4
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03292	Central Plant/Anderson Building	In Service	5			4
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03293	Subterranean Parking Structure	In Service	5s			4s
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03294	Cooling Tower - Central Plant	Not a Building Structure	N/A			
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03531	Surgery Center/Anderson Building	In Service	5			4
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-05279	Anderson Pavilion	In Service	5s			4s
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00650	Northwest	In Service	2		0.76	3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00651	Machris	In Service	1		12.86	3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00652	Main Medical	In Service	2	1.17	0.76	3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00653	ICU	In Service	4			3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02575	Wing 1	In Service	2	0.15		3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02576	Wing 5	In Service	2	0.15		3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02577	Wing 6	In Service	2	0.15		3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02578	Food Service Facility	In Service	4			3
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-03091	Chiller Addition	In Service	5			4
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-03851	Helford Clinical Research Hospital	In Service	5			4
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06155	Helford Entry Canopy	In Service	5			4
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02151	Original Building	In Service	2	0.32		2
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02670	Lobby & Dietary Addition	In Service	4			2
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02671	X-ray Entry	In Service	4			2
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02672	OR Addition	In Service	4			2
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-03646	Telephone Equipment Building	In Service	2	1.33	0.12	2
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00402	North and East Wings	In Service	2	0.32		2
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00404	South Wing	In Service	2	0.20		2
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00405	West Wing	In Service	4			2
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00406	Engineering	In Service	2	0.03		2
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00408	Doctor's Main	Not an Independent Building	N/A			N/A
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00409	Doctor's South Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00410	Admin/West Entry Lobby	Not an Independent Building	N/A			N/A
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-02822	Assembly	In Service	2	0.51		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01745	Auditorium Addition	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01746	North Addition & '64 Addn #1	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01747	Maint. & Loading Dock Canopy	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01748	South Wing	In Service	4			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01749	Hatfield Building	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01750	1964 Addition No. 2	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01751	8/8A Elect Vault Bldg & Supply Bldg	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01752	Emergency Generator Building	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01754	HVAC Equip. Bldg & Mechanical Room	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-01757	Ambulatory Services	In Service	5			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-02673	Heart Room Addition	In Service	5s			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03047	1978 Oxygen Yard - Building 14	Equipment Yard	N/A			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03087	2/2A 1957 Addition & Elevator & Stair Addition	In Service	1		IND	2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03089	Cooling Towers	Equipment Yard	N/A			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03141	Original Building (Loggia)	In Service	4			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03143	Original Building (North Wing)	In Service	4			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03144	Original Building (South Wing)	In Service	4			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03145	Original Building (Central Wing)	In Service	4			2
19 - Los Angeles	11792	Community Hospital Long Beach	Long Beach	BLD-03146	9/9A Laundry Building -Trash Canopy	In Service	4			2
19 - Los Angeles	11549	Community Hospital Of Huntington Park	Huntington Park	BLD-00669	Main Hospital	In Service	2		1.01	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11549	Community Hospital Of Huntington Park	Huntington Park	BLD-03426	Emergency Department Canopy	In Service	5			4
19 - Los Angeles	12024	Docs Surgical Hospital	Los Angeles	BLD-01224	Main Hospital	Not an Independent Building	N/A			N/A
19 - Los Angeles	12024	Docs Surgical Hospital	Los Angeles	BLD-03234	Tower Building	In Service	1			2
19 - Los Angeles	12024	Docs Surgical Hospital	Los Angeles	BLD-05236	Main Hospital - Ogden Building	In Service	1		2.66	2
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00670	Original Building	In Service	1	7.34	3.96	2
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00671	East Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00672	North Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00673	South Addition	In Service	2	1.69	0.50	2
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00674	South Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-00191	Original Building	In Service	2			3
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-00192	Gift Shop Addition	In Service	3			3
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-03840	Emergency Dept. And Elevator Tower	In Service	5s			4s
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02019	Original Building	In Service	2		1.18	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02020	East Wing Addition	In Service	2		0.87	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02021	West Wing Addition	In Service	2		0.87	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02022	Psychiatric Wing Addition	In Service	2		1.18	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02023	Lobby Addition	In Service	2		1.09	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02024	Generator Building	In Service	2		2.45	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02025	Power Plant	In Service	4			2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02026	Radiology Addition	In Service	4			2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02027	Conference Room Addition	In Service	4			2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02028	Surgery Wing Addition	In Service	4			2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-05422	CCU Addition	In Service	2		1.17	2
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-05423	Canopy Addition	In Service	4			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01163	Main Building	In Service	2	30.36	0.96	2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01164	Service Building	In Service	4	6.50		2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01165	South Wing Addition	In Service	2	9.74	0.41	2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01166	1968 West Wing Addition	In Service	2		0.42	2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01167	Outpatient Addition	In Service	4			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01168	Mechanical Building	In Service	4			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01169	1983 Lobby Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01170	MRI / CT Building	In Service	2	0.12		2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01171	Chiller Room Addition	In Service	4			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01172	Cardiac Cath Lab Addition	In Service	3			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01173	Maternal & Child Health Center	In Service	5			2
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-03409	Canopy	In Service	5			4
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-05424	Bridge Connector	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00675	North Wing	In Service	2		1.02	2
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00676	West Wing	In Service	2		1.17	2
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00677	Main Tower / Basement / Mech Bldg	In Service	2	0.58		2
19 - Los Angeles	12841	Gardens Regional Hospital And Medical Center	Hawaiian Gardens	BLD-00932	Main Hospital Building	In Service	2	0.04		2
19 - Los Angeles	12841	Gardens Regional Hospital And Medical Center	Hawaiian Gardens	BLD-06472	Medical Gas Enclosure	Equipment Yard	N/A			2
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01934	Main Hospital	In Service	2	3.17	0.82	3
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01935	Nursery/Post Partum	In Service	2		1.17	3
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01936	Emergency Wing	In Service	2		0.91	3
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01937	O.B. Pavilion	In Service	4			4
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01938	O.B. Addition	In Service	4			4
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01939	Cath Lab	In Service	3s			4
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03427	ER Addition	In Service	5			4
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03428	Extended Service Canopy	In Service	4			3
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03429	Service Canopy	In Service	4			3
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-06302	Medical Gas Enclosure	Equipment Yard	N/A			4
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01779	Original Building	No Acute Care - OSHPD Bldg	N/A	7.86		2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01780	1942 Building	No Acute Care - OSHPD Bldg	N/A	7.47		2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01781	Radiology Addition A	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01782	Radiology Addition B	No Acute Care OSHPD Bldg	N/A	1.13		2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01783	South Tower	In Service	1	2.24	26.05	2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01784	Juncture Building	In Service	1	12.62	13.74	2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01785	Patient Tower	In Service	1	1.53	2.67	2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01786	Heart and Emergency Center	In Service	3s			2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01787	Central Plant	In Service	3s			2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01788	Mechanical Building	In Service	4			2
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-03382	Administration Building	Not an Independent Building	N/A			N/A
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-00151	Original Building	In Service	1		3.12	2
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-00152	Emergency Building	In Service	1		2.03	2
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-00153	1966 Addition - West	In Service	1		2.03	2
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-00154	1969 Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-03521	1966 Addition - East	In Service	1		1.77	2
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-05820	Emergency Department Expansion	Proposed	5s			4s
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-05851	Ambulance Canopy	Proposed	5s			4s
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-06102	Electrical Yard	Under Construction	N/A			
19 - Los Angeles	11672	Glendora Community Hospital	Glendora	BLD-06103	Equipment Yard	Under Construction	N/A			
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01993	Main Hospital	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01994	ICU / CCU Addition	In Service	3			2
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01995	Mechanical Plant	In Service	4s			2
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01996	MRI Addition	In Service	4			2
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01997	1927 Building	In Service	1		15.62	2
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01998	1953 Building	In Service	1		10.36	2
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-01999	Linear Accelerator Addition - Structurally connected to BLD-01998	Not an Independent Building	N/A			N/A
19 - Los Angeles	11731	Good Samaritan Hospital	Los Angeles	BLD-03322	Radiation Oncology Building	Clinic - Local Jurisdiction	N/A			
19 - Los Angeles	13224	Greater El Monte Community Hospital	South El Monte	BLD-00214	Main Hospital/Radiology Addition	In Service	2	0.09		2
19 - Los Angeles	13224	Greater El Monte Community Hospital	South El Monte	BLD-00215	Nursery & LDR Addition	In Service	4s			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00216	Main Hospital - Original Building	In Service	5			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00217	Main Hospital - Administration Building	In Service	5			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00218	Main Hospital - Emergency Building	In Service	5			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00219	Main Hospital - Main Lobby Building	In Service	3			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00222	Central Plant Building	In Service	4			4
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00223	Pavilion - Main Building	In Service	4			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00224	Pavilion - Adult Day Health Care	In Service	4			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00225	Pavilion - Pavilion Plant Building	In Service	4			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-02862	Main Hospital - Emergency Entrance Canopy	In Service	4			2
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-02863	Main Hospital- Main Entrance Canopy	In Service	4			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03259	Patient Tower	Under Construction	5s			4s
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03309	Central Utility Plant	Under Construction	5s			4s
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03338	Oxygen Tank Yard	Equipment Yard	N/A			
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03413	Loading Dock	In Service	5			4
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03414	Emergency Department Expansion	In Service	5s			4s
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-05854	Basement Lab Expansion	In Service	5s			4s
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-05855	Connecting Covered Walkway	In Service	5s			4s
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01977	North Wing	In Service	1		17.87	2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01978	South Wing	In Service	1	3.08	6.15	2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01979	D & T Tower	In Service	1	3.83	3.83	2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01980	Patient Tower	In Service	3			2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01981	Kitchen Addition	In Service	1		6.09	2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01982	Emergency Addition	In Service	3s			2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01983	Linear Accelerator Addition	In Service	4s			2
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03505	Chalet Building	Skilled Nursing Only	N/A			
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03506	New Service Yard	Proposed	N/A			
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03507	Acute Care Services Replacement Building	Proposed	5s			4s
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-06293	2nd Floor Pedestrian Walkway	Under Construction	5s			4s
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02000	East Tower (3 story)	In Service	3			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02001	West Tower	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02002	La Vina Building	In Service	3			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02003	Della Martin Center - Psychiatric B	Acute Psych Only	N/A			
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02004	Energy Plant	In Service	5			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02005	Chiller Building	In Service	4			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02008	Cooling Towers	Not a Building Structure	N/A			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02010	Valentine Building	Not an Independent Building	N/A	8.24		N/A
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02011	Wingate / Hahn Building	In Service	1	3.94		3
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02012	Hahn Building	Not an Independent Building	N/A			N/A
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02013	Service Building	In Service	1	7.15		2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02014	1938 Building	In Service	1		24.40	2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02015	1921 Building	In Service	1		14.36	2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02017	North Parking Structure	Not an Independent Building	N/A			N/A
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-02018	Electrical Switchgear Vault	In Service	4			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-03301	East Tower (7 story)	In Service	5			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-03302	East Tower Main Lobby	In Service	3			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-03303	New Boiler Building	In Service	5			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05497	ED Addition	In Service	5			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05498	Ambulance Canopy	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05796	West Tower Tunnel	In Service	5			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05955	South Campus Utility Tunnel	Tunnels	N/A			2
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05956	East Tower Utility Tunnel	Tunnels	N/A			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05957	ED Utility Tunnel	Tunnels	N/A			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05970	East Tower Pedestrian Tunnel	Tunnels	4			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-05990	Bulk Oxygen Storage	Equipment Yard	N/A			4
19 - Los Angeles	11733	Huntington Memorial Hospital	Pasadena	BLD-06058	Bulk Oxygen	Equipment Yard	N/A			4
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02519	Central Plant	In Service	5			3
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02520	Patient Tower	In Service	3			2
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02521	Clinic Wing	In Service	3			2
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02522	MRI Building	In Service	3			3
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-03509	Clinic - MRI Connector	In Service	3			2
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05180	Main Building	In Service	5			4
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05181	Central Plant	In Service	5			4
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05914	Canopy 01	In Service	5			4
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05915	Canopy 02	In Service	5			4
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05916	Main Building - Tower	In Service	5			4
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06157	Central Plant Expansion	Under Construction	5s			4s
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06158	Main Building - Tower Addition	Under Construction	5s			4s
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06159	ED Drop-Off Canopy	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06323	ED Walk-in Canopy	Under Construction	5s			4s
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06324	ED Entry Vestibule	Under Construction	5s			4s
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-01707	Centrex Building	In Service	4			2
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-02792	LAMC Hospital - Phase I	In Service	5s			2
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-02793	Central Utility Plant - 1550 Edgemont	In Service	5s			4
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01696	Hospital Tower	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01697	Elevator Tower	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01698	East MOB	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01699	West Building	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01700	Generator Building	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01701	Generator Building Addition	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-02794	New Hospital Replacement Project	In Service	5s			4s
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-02795	New Central Utility Plant	In Service	5s			4s
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-05676	South Specialty Medical Office Building	Clinic - Local Jurisdiction	N/A			N/A
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02037	South Hospital - Ancillary Wing	In Service	3			3
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02038	South Hospital - Patient Tower	In Service	3s			3
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02039	South Hospital - Elevator Tower	In Service	3s			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02040	South Hospital - Central Plant	In Service	4s			3
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03086	Boiler House	Not an Independent Building	N/A			N/A
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03276	Vermont Pavilion	In Service	5s			4
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03277	Annex Connecting Corridor	In Service	5s			4
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-05247	Annex Building	In Service	5s			4
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-05248	Replacement Hospital	In Service	5s			4s
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06482	Emergency Department Addition	Proposed	5s			4s
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06483	Emergency Department Ambulance Canopy	Proposed	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00327	Medical Center Tower	In Service	3			2
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00328	Plant Services Building	In Service	4			2
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00329	Nursing Tower II	In Service	3			2
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00330	MRI Building	In Service	3			2
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05847	Chiller / Generator Support Building	Under Construction	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05879	Service MSB Yard – Normal Power	Equipment Yard	N/A			
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05984	Emergency Department Expansion	Under Construction	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05985	Emergency Department Expansion Canopy	Under Construction	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06129	Ambulance Canopy	Under Construction	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06221	Canopy No. 2	In Service	5s			4s
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06222	Canopy No. 1	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06452	Tank Farm	Equipment Yard	N/A			2
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00941	Center Tower	In Service	2		0.72	2
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00942	North Tower	In Service	3s			2
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00943	South Tower	In Service	3s			3
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00944	Central Plant	In Service	5			2
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-03275	West Wing Tower	In Service	5			4
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-03539	Generator Building	In Service	4s			2
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-03163	Main Hospital	In Service	4			3
19 - Los Angeles	11768	Kindred Hospital - La Mirada	La Mirada	BLD-01710	Building I	In Service	2	0.75		1
19 - Los Angeles	11768	Kindred Hospital - La Mirada	La Mirada	BLD-03469	Building II	In Service	4			1
19 - Los Angeles	11768	Kindred Hospital - La Mirada	La Mirada	BLD-03470	Building III	In Service	2	3.34	0.66	1
19 - Los Angeles	11768	Kindred Hospital - La Mirada	La Mirada	BLD-06112	Soiled Linen Storage	In Service	4			4
19 - Los Angeles	11768	Kindred Hospital - La Mirada	La Mirada	BLD-06113	Bio-Hazard Storage	In Service	4			4
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00727	Original Building - Building I	In Service	2	12.89	0.89	2
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00728	Southeast Addition - Building III	In Service	3			2
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00729	Power Service Station - Building IV	In Service	4			2
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-03027	Addition - Building II	In Service	2	0.10		2
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-03066	Storage / Maintenance - Building V	In Service	2		0.57	3
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-05829	Entrance Canopy	In Service	2		0.70	2
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-01722	Building I (Acute Care Facility)	In Service	1	3.34	6.42	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-05840	Building II (Acute Care Support Services)	Under Construction	1s			2
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-05841	Building III (Acute Care Facility)	Under Construction	1s			2
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03708	Main Hospital	In Service	2		0.66	1
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03709	Main Hospital Addition	In Service	2		0.66	1
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03710	ICU Addition	In Service	2		0.66	1
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-06115	Emergency Generator #2 Yard	Under Construction	N/A			
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-00909	Hospital	In Service	2	0.02		2
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-00910	Emergency Room	In Service	4			2
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00658	Original Building	In Service	2		0.12	1
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00659	South Addition	In Service	4s			1
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00660	North Addition	In Service	4s			1
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00661	Laboratory Addition	In Service	4			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01759	Main Hospital Building - Patient Tower	In Service	2			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01760	Main Hospital Building - North Wing	In Service	2			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01761	Main Hospital Building - South Wing	In Service	2		18.91	1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01762	Main Hospital Building - Cafeteria	In Service	4			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01763	Main Hospital Building - FCLC	In Service	2			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01764	PCDC Building	In Service	3			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01765	Central Plant Building	In Service	4			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01766	Central Plant West Expansion	In Service	4			1

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01767	Communications Building 2 East	In Service	4			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05316	Surgery / Emergency	In Service	5			4
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05317	Emergency Generator Building	In Service	5s			4s
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05318	Tunnel	Tunnels	N/A			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05884	Bulk Oxygen Tanks	Equipment Yard	N/A			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05885	Cooling Tower	Not a Building Structure	N/A			1
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06025	Surgery / Emergency Lower Entrance Canopy	In Service	5			4
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06026	Surgery / Emergency Upper Entrance Canopy	In Service	5			4
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06029	Surgery / Emergency Elevator Tower	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00337	Main Hospital Building	In Service	4			2
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00338	Central Plant	In Service	4s			2
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00339	Cooling Tower	In Service	4s			2
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-03620	Emergency Services Building	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-03621	Tuberculosis Isolation Building	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-05912	Bulk Oxygen Tanks	Equipment Yard	N/A			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06033	Canopy 05B	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06034	Canopy 04B	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06035	Canopy 04C	In Service	5			4
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06168	Emergency Generator	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02502	Bldg 100 Main Hospital	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02503	Bldg 101/102 Main Hosp Expansion	In Service	4			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02504	Outpatient Entrance Addition	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02505	Building - 900	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02506	JPI Bldg South Wing	In Service	3s			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02507	JPI Bldg North Wing	In Service	3s			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02508	Central Plant	In Service	5			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02509	Fire Pump Building	In Service	5			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02510	Harriman Building	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02511	Safety Police Building	In Service	5			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02512	Med Records Bldg 603/604	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02513	Kitchen	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02514	Building 500	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02515	Old Central Plant	In Service	1			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02516	JPI Bldg West Wing	In Service	3s			4
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02924	JPI Expansion	Under Construction	5s			4s
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02925	JPI Drop-off Canopy	Under Construction	5s			4s
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-05943	JPI Tunnel	Tunnels	N/A			2
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06145	NPC-5 Domestic Water Storage Tank	Under Construction	N/A			
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06146	NPC-5 Sewer Storage Tank	Under Construction	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06147	Ambulance Drop Off Canopy	Under Construction	5s			4s
19 - Los Angeles	11810	LAC+USC Medical Center	Los Angeles	BLD-02749	New Central Plant	In Service	5s			4s
19 - Los Angeles	11810	LAC+USC Medical Center	Los Angeles	BLD-02750	New Diagnostic and Treatment	In Service	5			4
19 - Los Angeles	11810	LAC+USC Medical Center	Los Angeles	BLD-02751	Inpatient Tower	In Service	5			4
19 - Los Angeles	12831	Lakewood Regional Medical Center	Lakewood	BLD-00924	Main Hospital	In Service	2	1.39	1.06	2
19 - Los Angeles	12831	Lakewood Regional Medical Center	Lakewood	BLD-00925	Hospital Expansion	In Service	4			2
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-00654	Original Building & Additions	In Service	2	1.19	1.10	2
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-00655	Dietary Addition	In Service	2	0.42		2
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-03779	1st and 2nd Story Addition	In Service	1		3.96	2
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	Bellflower	BLD-00049	Bellflower Medical Center - Building 1	In Service	2		0.73	1
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	Bellflower	BLD-03011	Building 2	In Service	2	0.56		1
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	Bellflower	BLD-03012	Building 3	Not an Independent Building	N/A			N/A
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	Bellflower	BLD-05348	Bellflower Medical Center - Building 1 - South	In Service	2		0.62	1
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	Bellflower	BLD-05349	Bellflower Medical Center - Building 1 - North	In Service	2		1.13	1
19 - Los Angeles	12882	Los Angeles Metropolitan Medical Center	Los Angeles	BLD-00155	Hospital Building	In Service	2	1.07	1.07	1
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02047	Medical Records & Laundry	In Service	5			2
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02048	Central Plant Phase I	In Service	5			2
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02049	Central Plant Phase II	In Service	4			2
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02052	Pediatric Acute Care	In Service	3			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02053	Trauma Center	In Service	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02054	Hawkins Building (Augustus F Hawkins Building)	In Service	4			3
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05261	Central Plant 3	In Service	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05262	Central Plant 4	In Service	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05263	Pedestrian Tunnel	Tunnels	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05264	Ancillary Building	In Service	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05412	Central Plant Phase 1 Tunnel	Tunnels	N/A			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05413	Hawkins Building Tunnel	Tunnels	N/A			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05416	Trauma Center Connecting Tunnel	In Service	5			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05821	Bulk Medical Gas Equipment Yard	Equipment Yard	N/A			4
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05859	Main Drop Off Canopy	In Service	5			4
19 - Los Angeles	11843	Memorial Hospital of Gardena	Gardena	BLD-01778	Hospital	In Service	1		5.18	2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01789	2A-2C- Central Plant & Additions	In Service	2	0.31		2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01790	101- Miller's Children's Hospital	Not an Independent Building	N/A	0.53		N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01791	1E - Center for Health Education	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01792	03 - Memorial West - Nursing Unit	In Service	2	0.06		2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01793	4A 4B- Memorial West - Rehab Unit	In Service	2	0.13		2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01794	1B - Old Pathology	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01795	5 - X-Ray Addition	In Service	2	0.17		2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01796	6A-6C - Surgery & Addition	In Service	3			2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01797	1G -Doctor's Dining & Administration	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01798	1C - Original Coffee Shop	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01799	7A-7B - Outpatient Surgery	In Service	3			2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01800	8 - Cancer Prevention Center	In Service	4			2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-02637	10 - Emergency Power Area	In Service	3			2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03123	1A -1K Main Tower & Additions	In Service	1	9.81	9.81	2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03139	103- Miller Children's Clerical Add	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03523	102- Miller's Children's Hosp Entry	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03524	9 - ER Addition & Remodel	In Service	5			2
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03604	MCH - Central Plant	Not an Independent Building	N/A			N/A
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03605	MCH - 4 Story Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03899	101- Miller's Children's Hospital	In Service	2	0.53		2
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03900	102- Miller's Children's Hospital Entry	In Service	5			2
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03901	103- Miller Children's Clerical Addition	In Service	3			2
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03905	Central Plant	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03906	4 Story Addition	In Service	5			4
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-05883	Oxygen Farm	Equipment Yard	N/A			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00358	Main Hospital	In Service	2		0.81	2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00359	East Wing	In Service	1		1.96	2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00360	Utility Building / Central Plant	In Service	5			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00362	West Wing	In Service	1		9.12	2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00363	Main-North End	Not an Independent Building	N/A			N/A
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00364	Pavilion East & West	No Acute Care - OSHPD Bldg	N/A	1.81	3.47	2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00365	Hoefflin Wing	In Service	4			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00366	Surgical Wing	In Service	3s			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-00367	Patient Tower	In Service	5			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-03711	Electrical Equipment Building	In Service	4			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05461	North Tower	In Service	5s			4s
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05514	Tower Lobby	In Service	5s			2
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05634	Generator Building	In Service	5			4
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05635	Switchgear Building	In Service	5			4
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05636	Switchgear Shed	In Service	5			4
19 - Los Angeles	11858	Methodist Hospital of Southern California	Arcadia	BLD-05848	Berger Tower Patient Canopy	In Service	5			2
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00352	Building A - Tower	In Service	1		2.08	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00353	Building B - Ancillary Building	Under Construction	1s	0.87		N/A
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00354	Building C - Emergency Department B	In Service	2	0.87	0.87	2
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-03891	Building D - South Tower	In Service	5s			4
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05536	Building E - Psychiatric Unit	Under Construction	5s			4s
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05537	Building F - Psychiatric Administration	Under Construction	5s			4s
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05538	Building G - Lobby Clinical Lab	Under Construction	5s			4s
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05539	Building H - Canopy	Under Construction	5s			4s
19 - Los Angeles	11874	Monrovia Memorial Hospital	Monrovia	BLD-00377	Main Building	In Service	2	2.24		2
19 - Los Angeles	12878	Monterey Park Hospital	Monterey Park	BLD-00946	Original Building	In Service	2	0.08		2
19 - Los Angeles	12878	Monterey Park Hospital	Monterey Park	BLD-00947	Radiology Basement Addition	In Service	4			2
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-00379	Skilled Nursing Facility	Acute Psych / SNF only	N/A			2
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-00380	Administration Building	Acute Psych / SNF only	N/A		28.71	2
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-00381	Wings E, F, G, & H	Not an Independent Building	N/A			N/A
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-00382	Wings A, B, C, D	Acute Psych / SNF only	N/A		40.39	2
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-02740	Wings J & K with Wings E, F, G, & H	Acute Psych / SNF only	N/A		1.75	2
19 - Los Angeles	11887	Motion Picture & Television Hospital	Woodland Hills	BLD-02741	Utility Enclosure	Equipment Yard	N/A			
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00388	Farr Tower	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00389	D&T Building	In Service	5			4
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00390	Support Services Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00391	IFL Building	In Service	3s			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00392	Therapy Pool Building	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00393	Clinical Laboratory Bldg Expansion	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00394	F Tower - Main Tower	In Service	2		0.98	2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00395	G Tower	In Service	2	0.58		2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00396	Cancer Center	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03092	F Tower - Elevator Tower	Not an Independent Building	N/A	5.79		N/A
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03094	Linear Accelerator	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03095	Emergency Room Addition	In Service	3s			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03096	MRI Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03097	Outpatient Registration Building	Not an Independent Building	N/A			N/A
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03135	Clinical Laboratory Building (Original)	Not an Independent Building	N/A			N/A
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03136	Quiet/Dining	In Service	3			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03487	Service Elevator Tower	Under Construction	5s			4s
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03645	Electrical Equipment Room	In Service	4			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-05464	Clinical Laboratory Building (D&T Addition)	In Service	3s			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-06078	Gift Shop	In Service	4			2
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-06079	Admitting	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00397	Original Building	In Service	2	0.06		2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00398	Service Enclosure - East Side	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00399	Administration Addition	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00400	ICU Addition	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02690	Service Enclosure - West Side	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02691	Walk In Freezer	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02692	Boiler Room	In Service	2	0.12		2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02693	Engineering Building	In Service	2	0.12		2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03759	1956 Storage Building	In Service	2	0.12		2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03760	1983 Storage Addition	In Service	4			2
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03800	Original Building - South Wing	Not an Independent Building	N/A			N/A
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00368	North Wing	In Service	4			2
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00369	East Wing & Additions	In Service	1	2.67	5.22	2
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00370	West Wing & Additions	In Service	2		1.13	2
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00371	Pavilion / Addition	In Service	2		0.76	2
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00017	Building 1	In Service	1		18.94	2
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00018	Building 2	In Service	1		35.28	2
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00019	Building 3	In Service	1		18.94	2
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-05182	Main Building	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02203	Original Nursing Tower	In Service	1		18.96	2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02204	Original Surgery and Lab Building	In Service	2	0.61		2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02206	Pathology Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02207	Scanner Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02208	ER/Surgery Addition	In Service	4			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02209	ICU/CCU	In Service	4			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02210	Respiration Therapy Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02211	Cath Lab	In Service	4			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02212	36 Bed Addition	In Service	4			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02213	Building A, Mech. Equipment Bldg.	In Service	5			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02214	Building B	In Service	5			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02215	Building C	In Service	5			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02216	Radiology Addition	In Service	5			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-02217	ER Addition	In Service	5			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-03221	Generator #2 Building	In Service	4			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-06135	Original Mechanical Area	In Service	1			2
19 - Los Angeles	12235	PIH Health Hospital - Downey	Downey	BLD-06325	ICU / ER Connection Canopy	In Service	5s			4s
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-01156	Original Building Patient Tower	In Service	2	4.50	1.00	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-01158	Long Term Care	In Service	2	0.43		2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-01160	Power Plant	In Service	4s			2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-01162	1992 Pavilion	In Service	3			2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03151	Health Center (North Building)	In Service	3			2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03152	Health Center (East Building)	In Service	3			2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03272	ED Shannon Tower	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03273	Plaza Tower	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03666	1968 Generator Building	In Service	2	0.31		2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-03715	1992 Pavilion Bridge	In Service	3			2
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-05468	Central Plant Expansion	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-06460	Link Corridor	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-06465	Electrical/Mechanical/Compact r Segment	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-06466	Communication Room & Utility Tunnel Segment	In Service	5			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-06467	Cooling Tower Enclosure	Equipment Yard	N/A			4
19 - Los Angeles	11968	PIH Health Hospital-Whittier	Whittier	BLD-06473	Pump Room	In Service	5			4
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00411	1972 Building - ICU/Emergency	In Service	2	9.79	1.05	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00412	D&T Addition	In Service	3			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00413	Women's Center	In Service	3s			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00414	1913 Building	In Service	1		14.72	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00415	1928 Building	In Service	1		14.04	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00416	1953 Building	In Service	2		1.00	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00417	1961 Building	In Service	2	0.56		2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00418	1963 Building - Cafeteria	In Service	2		0.54	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00419	1963 Building - Lab/Peds	Not an Independent Building	N/A			N/A
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-02838	Building 01A	In Service	3s			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-02839	Building 01B Canopy	In Service	3s			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03468	Pitzer Bldg Admin/Marketing/Acct	No Acute Care - OSHPD Bldg	N/A			1
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03850	Boiler Building	In Service	2		0.42	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03877	1961 Dining Building	In Service	2		1.11	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05176	1958 Lobby Addition	In Service	1		11.33	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05202	1958 Building (Emergency Wing)	In Service	1		25.67	2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05669	2013 Vestibule	In Service	2			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05670	2013 Low Canopy	In Service	2			2
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05671	2013 High Canopy	In Service	2			2
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01984	Main Building	In Service	3s			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01985	ICU/CCU Building	In Service	4s			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01986	Cardiac Heart Center	In Service	3s			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01987	Central Plant Building	In Service	2			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01988	Utility Building	In Service	4s			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01989	Chapel Building	In Service	3s			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01991	New Equipment Shelter	In Service	3s			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-02714	Old Utility Tunnel	Tunnels	N/A			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-02715	New Utility Tunnel	Tunnels	N/A			3
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03628	South Addition	In Service	5			4
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03635	A-North Bldg-Outpatient/Office Bldg	Not an Independent Building	N/A			N/A
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03636	New Central Plant	In Service	5			4
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03637	Sub-Acute Building	Skilled Nursing Only	N/A			
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03638	Control Room	In Service	5			4
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05337	Generator Yard	Equipment Yard	N/A			
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05338	Transformer Yard	Equipment Yard	N/A			
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05339	Cooling Tower	Not a Building Structure	N/A			
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01215	Central Wing North	In Service	2		0.54	3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01216	West Wing & Entrance Canopy	In Service	1	7.80	13.24	3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01217	East Wing	In Service	3			3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01218	Laboratory Addition	In Service	4			3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01219	Conference Center	In Service	5			3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01220	ED Entry Canopy	Under Construction	5s			4s
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01221	Emergency Generator Enclosure	Proposed	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03147	Central Wing Tower	In Service	1	9.03	9.03	3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03148	Central Wing South	In Service	2	0.47		3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03149	Central Wing Stair Tower	In Service	2	0.44		3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03150	West Wing Elevator Tower	In Service	2	0.12		3
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-05177	Drop-Off Canopy	In Service	2		0.70	3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01727	Original Hospital	In Service	2		0.99	3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01731	11 Technology Center & Lab	In Service	5			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01733	Emergency Generator	Not a Building Structure	N/A			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01734	Liquid Oxygen Storage Tanks and Manifolds	Equipment Yard	N/A			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01735	West Tower Building	In Service	4			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01737	Radiation Therapy Building Walkway	In Service	5s			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01738	Dining Room Addition	In Service	4			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01739	Generator Building	In Service	5			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01741	ER/Cardiac Wing	In Service	2		1.02	3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-02625	Administrative Wing	In Service	2		0.54	3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03159	South Tower Addition	In Service	5			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03160	Earl Street Loading Dock Improvement	In Service	5			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03162	South Tower Building	In Service	4			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03340	Hazardous Material Storage	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03537	11 Central Plant	In Service	5			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03716	Dietary Loading Dock and Storage	In Service	5			4
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03717	Entrance Canopy	In Service	3s			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03718	Radiation Therapy Building	In Service	5s			3
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06195	Med Gas Storage	In Service	5			4
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-03700	North Pavilion Inpatient Tower	In Service	5s			4s
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-03703	New Central Plant	In Service	5s			4s
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-03704	Keck Center Diagnostic & Treatment	In Service	5s			4s
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-05271	Entry Canopy	In Service	5s			4s
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-05987	Equipment Yard	Equipment Yard	N/A			4
19 - Los Angeles	12006	Providence Saint John's Health Center	Santa Monica	BLD-05988	Flue Building	Not a Building Structure	N/A			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01185	Robertson Tower	In Service	3			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01186	Robertson Lobby	In Service	3			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01187	Robertson Canopy	In Service	3			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01188	East Building	In Service	2		1.20	2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01190	South Building	In Service	2	0.70		2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01191	ER/CCU Building	In Service	4			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01192	Laundry/Central Plant Building	In Service	4			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01193	Central Plant Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01194	P & E Building	In Service	3			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01195	MRI Building	In Service	4			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01197	Parking Structure 1A	In Service	4			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-03515	Northeast Building	In Service	5			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05355	Connector Corridor - 1	In Service	5			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05356	Connector Corridor - 2	In Service	5			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05357	Connector Corridor - 3	In Service	5			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05358	Connector Corridor - 4	In Service	5			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05359	Connector Corridor - 5	In Service	5s			4
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05360	Northeast Building Tunnel	Tunnels	N/A			
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05361	Central Plant Tunnel	Tunnels	N/A			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05362	East Building Tunnel	Tunnels	N/A			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05363	Cooling Towers	Not a Building Structure	N/A			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05549	South Building Tunnel	Tunnels	N/A			2
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-06412	Emergency Department	Proposed	5s			4s
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00169	Main Hospital	In Service	1		2.78	2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00170	Patient Tower	In Service	1		4.54	2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00171	Ancillary Wing	In Service	1		2.78	2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00172	Service Building	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00173	Cardiology Addition	In Service	3			2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00174	Admitting/Emergency	In Service	3			2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00175	Women's Pavilion	In Service	3			2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-00176	Mechanical Building	In Service	4			2
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-03423	Patient Wing	Under Construction	5s			4s
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-03424	Interim Canopy	Under Construction	5s			4s
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-06372	Hospital Main Lobby Building	Proposed	5s			4s
19 - Los Angeles	13085	Providence Tarzana Medical Center	Tarzana	BLD-06398	Emergency Cat Lab	In Service	4s			2
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	Los Angeles	BLD-02895	Ronald Reagan UCLA Medical Center	In Service	5			4
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	Los Angeles	BLD-02926	Emergency Services Building	In Service	5s			4s
19 - Los Angeles	12004	Saint Francis Medical Center	Lynwood	BLD-01177	Family Life Center	In Service	5			2
19 - Los Angeles	12004	Saint Francis Medical Center	Lynwood	BLD-01178	Health Services Pavilion	In Service	3			2
19 - Los Angeles	12004	Saint Francis Medical Center	Lynwood	BLD-01179	Central Plant	In Service	4			2
19 - Los Angeles	12004	Saint Francis Medical Center	Lynwood	BLD-01180	New Hospital Tower	In Service	5			2
19 - Los Angeles	12004	Saint Francis Medical Center	Lynwood	BLD-05791	Psychiatric Care Unit	Acute Psych / SNF only	N/A			
19 - Los Angeles	12014	Saint Vincent Medical Center	Los Angeles	BLD-01211	Main Hospital	In Service	1	4.56	11.34	2
19 - Los Angeles	12014	Saint Vincent Medical Center	Los Angeles	BLD-01212	Central Plant / Parking Garage	In Service	2		0.74	2
19 - Los Angeles	12014	Saint Vincent Medical Center	Los Angeles	BLD-01213	Doheny Wing	In Service	1	4.02	3.47	2
19 - Los Angeles	12014	Saint Vincent Medical Center	Los Angeles	BLD-01214	Cath Lab	In Service	5s			2
19 - Los Angeles	12014	Saint Vincent Medical Center	Los Angeles	BLD-03227	ER Ambulance and Entrance Cover	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00166	Main Hospital	In Service	2	0.05		3
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00167	CT Scan Addition	In Service	4			3
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00168	Boiler Room Addition	In Service	5			3
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00662	Pavilion Building	In Service	2	2.89	2.29	2
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00663	Cooling Tower	In Service	4			2
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00664	Radiology and Surgery Addition	In Service	3s			2
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00665	Surgery Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00666	Emergency Addition	In Service	3s			2
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00667	CCU Building	In Service	3s			2
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00668	Patient Tower	In Service	3s			2
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01225	Merle Norman Pavilion	In Service	3			2
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01230	New Central Plant	In Service	5s			4
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01231	New Southwest Building	In Service	5s			4s
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02774	New Central Wing	In Service	5s			4s
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02775	New North Wing	In Service	5			4
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02776	New Orthopedic Hospital	In Service	5			4
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01232	01 Orig Bldg Complex & 02 Addition	In Service	2	2.06	0.98	2
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01233	Addition Building Complex	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01234	Burn Center Building	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01235	1961 Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01236	Surgery Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01237	Laboratory Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01238	ER Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01239	Surgery Addition	Not an Independent Building	N/A			N/A
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01240	Chiller Room	Not an Independent Building	N/A			N/A
19 - Los Angeles	13225	Silver Lake Medical Center - Downtown Campus	Los Angeles	BLD-00055	Hospital and Medical Office	In Service	2	0.75	0.55	2
19 - Los Angeles	13225	Silver Lake Medical Center - Downtown Campus	Los Angeles	BLD-00056	Boiler & Emergency Generator	In Service	2	0.36		2
19 - Los Angeles	13225	Silver Lake Medical Center - Downtown Campus	Los Angeles	BLD-03826	Main Hospital - West	In Service	2	0.53		3
19 - Los Angeles	13225	Silver Lake Medical Center - Downtown Campus	Los Angeles	BLD-06178	Oxygen Storage Yard	Equipment Yard	N/A			3
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00355	Tower	In Service	1		10.52	2
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00356	Pavilion	In Service	1	10.70	1.00	2
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00357	Outpatient Building & Additions	In Service	2		0.91	2
19 - Los Angeles	11718	Southern California Hospital at Hollywood	Hollywood	BLD-01976	Original Building	In Service	2	20.55	1.14	2
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01205	Bauer Wing	In Service	2	4.86	1.16	2
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01206	MRI Building	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01207	West Wing	No Acute Care OSHPD Bldg	N/A		3.22	2
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01208	East Wing	In Service	2	0.69		2
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01209	South Wing	No Acute Care OSHPD Bldg	N/A	3.68	8.36	2
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01210	Emergency / Generator Building	In Service	4s			2
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02218	Original Hospital Building	In Service	2	0.75		2
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02219	Original Central Plant	In Service	2			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02220	East Wing	In Service	3			2
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02221	Lobby/Cath Lab Addition	In Service	3			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02222	Surgery Addition	In Service	5			2
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02223	Doctors' Dining/Medical Records	In Service	3			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02224	Admitting/Business	In Service	3			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02225	Linear Accelerator	In Service	5			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02226	Central Plant Addition	In Service	4			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02227	North Wing	In Service	3			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02228	Elevator Core (North Wing)	In Service	4			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02229	MRI Addition	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02230	Ambulatory Care	In Service	3			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02231	Gallery	In Service	3			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02232	Central Plant Expansion - A	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02233	Central Plant Expansion - B	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02234	Central Plant-South Wing Addition	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02235	East Wing Addition	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-03478	New Hospital Building	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-03848	MRI Addition Corridor	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05421	Bulk Medical Gas System	Equipment Yard	N/A			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05668	Emergency Generator Building	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05705	Surgery Addition West	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05733	Emergency Generators and Switchgear	Equipment Yard	N/A			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06132	Central Plant Elevator and Stair	In Service	5			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06133	Utility Tunnel	Tunnels	N/A			3
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06148	Central Plant Walkway Canopy	In Service	3			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06149	Lundquist North Wing Connector	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06150	Lundquist Tower Connector to Center Tower	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06211	Lundquist Connector Exit Corridor	In Service	5			4
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06295	Original Service Building	In Service	2			2
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	Los Angeles	BLD-00317	Cancer Research Institute (Ezralow Tower)	In Service	3			2
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	Los Angeles	BLD-03689	Topping Tower	In Service	5			2
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01025	Main Building - North Tower	In Service	2	3.16	0.70	2
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01026	Main Building - South Tower	In Service	2	4.31	0.52	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01027	West Addition	In Service	4			2
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01028	East Addition	In Service	3s			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02169	Base Building (Main Hospital)	In Service	2		1.13	2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02170	Service Building	In Service	2		1.09	2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02171	Administrative Expansion	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02172	Ancillary Inpatient East	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02174	Elevator Lobby East	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02175	Elevator Lobby West	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02638	Ancillary Inpatient West	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02789	Inpatient Tower	In Service	5			4
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-03124	Administrative Expansion (North)	In Service	4			2
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-05197	South Tower	In Service	2		0.82	2
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-02176	Hospital Building / Additions	In Service	1		4.67	2
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-03430	Medical Office Building	Not an Independent Building	N/A			N/A
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-06119	70 Bed Hospital Extension	Under Construction	5s			4s
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-06120	Pedestrian Bridge	Under Construction	5s			4s
19 - Los Angeles	12182	West Hills Hospital & Medical Center	West Hills	BLD-02181	Main Building	In Service	2	0.49		2
19 - Los Angeles	12182	West Hills Hospital & Medical Center	West Hills	BLD-02182	Purchasing / Central Supply	In Service	4			2
19 - Los Angeles	12182	West Hills Hospital & Medical Center	West Hills	BLD-03178	ED / ICU	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
19 - Los Angeles	12182	West Hills Hospital & Medical Center	West Hills	BLD-03179	Central Plant	In Service	5			4
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02196	Original Building	In Service	2		0.97	2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02197	Addition 1	In Service	2		0.39	2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02198	Addition 2	In Service	2		0.39	2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02199	Addition 3	In Service	2		0.51	2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02200	ER Addition	In Service	4			2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02201	OB Addition	In Service	3			2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02202	Pediatrics Addition	In Service	4			2
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-03422	ER Addition - West Portion	In Service	4s			2
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00436	Main & Mechanical Building	In Service	2	0.12		2
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00437	OB Wing Addition	In Service	4			2
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00438	Outpatient Building	In Service	5			2
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00439	ICU/ER Addition	In Service	5			2
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06092	Utility Canopy 1	In Service	5			4
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06093	Utility Canopy 2	In Service	5			4
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06094	Central Utility Plant	In Service	5			4
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06322	CT Addition	In Service	3s			
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-02518	Hospital (G Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-02650	Central Plant	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05429	Hospital (A Canopy)	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05430	Hospital (B Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05431	Hospital (C Porte-Cochere)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05432	Hospital (D Canopy)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05433	Hospital (E Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05434	Hospital (F Canopy)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05435	Hospital (H Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05436	Hospital (I Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05437	Hospital (J Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05438	Hospital (K Wing)	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05439	West Expansion - Canopy	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05440	West Expansion	In Service	5			4
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05441	Medical Waste Building	In Service	5s			4
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00441	General Services Building	In Service	2	0.02		2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00442	Hospital Building	In Service	2			2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00443	Medical Office Building 1	In Service	2		0.85	2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00444	Mechanical Equipment Building	In Service	2			2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00445	Support Services Building	In Service	5s			2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00446	Generator Switchgear Building	In Service	5			2
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-03283	Doctor's Sleep Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-03598	Medical Records Building Addition	Not an Independent Building	N/A			N/A
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05615	Emergency Department	In Service	5s			4s
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05616	Oxygen Storage	In Service	5s			4s
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05617	Mechanical Building - CUP	In Service	5s			4s
21 - Marin	10261	Kentfield Rehabilitation & Specialty Hospital	Kentfield	BLD-00440	Hospital Building	In Service	2	0.36		2
21 - Marin	10261	Kentfield Rehabilitation & Specialty Hospital	Kentfield	BLD-05922	New Main Canopy	Under Construction	5s			4s
21 - Marin	10261	Kentfield Rehabilitation & Specialty Hospital	Kentfield	BLD-05923	Covered Walkway	Under Construction	5s			4s
21 - Marin	10261	Kentfield Rehabilitation & Specialty Hospital	Kentfield	BLD-05924	Ambulance Canopy	Under Construction	5s			4s
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00447	01 - Original Building & Additions	In Service	2	1.55	1.01	1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00448	02 - Additions & Alterations	In Service	2			1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00449	03 - Cobalt Bomb Wing	In Service	2	0.15		1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00450	Laboratory Addition & Remodel	Not an Independent Building	N/A			N/A
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00451	04 - Medical Health Center (Mental Health Center)	In Service	1		2.47	1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00452	05 - Elevated Pedestrian Bridge	In Service	1		14.44	1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00453	06 - West Wing	In Service	3			1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00455	1A - Additions & Alterations	Not an Independent Building	N/A			N/A
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-00456	04A - Medical Records	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-03054	1C - East Canopy	Not an Independent Building	N/A			N/A
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-03055	West Canopy	Not an Independent Building	N/A			N/A
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-03056	Ambulance Entry Canopy	In Service	3			1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-03526	05A - Elevator	In Service	1		4.91	1
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-06250	Hospital Replacement Building	Under Construction	5s			4s
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-06251	Hospital Replacement Building - Loading Dock	Under Construction	5s			4s
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-06252	Oxygen Tank Enclosure	Equipment Yard	N/A			2
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-06433	West Wing Lobby	Proposed	5s			4s
21 - Marin	10273	Marin General Hospital	Greenbrae	BLD-06434	West Wing Canopy	Proposed	5s			4s
21 - Marin	17672	Novato Community Hospital	Novato	BLD-00457	Hospital	In Service	5			4
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-00458	Hospital Building	In Service	2	0.00		2
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-03808	Skilled Nursing Wing	Skilled Nursing Only	N/A			N/A
23 - Mendocino	18198	Adventist Health Howard Memorial	Willits	BLD-05319	Main Building	In Service	5			4
23 - Mendocino	18198	Adventist Health Howard Memorial	Willits	BLD-05320	Mechanical Yard	Equipment Yard	N/A			4
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00305	Main Building, North Wing	In Service	4			2
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00306	OB Addition	In Service	5			2
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00307	Central Plant	In Service	5			4
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-02959	Main Building, Central Wing	In Service	4			2
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-02960	Main Building, Ancillary	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-05704	Emergency Department Building	Under Construction	5s			4s
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06369	Support Building	Under Construction	5s			4s
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06370	Electrical Room	In Service	5s			4s
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-00469	Main Hospital	In Service	2	0.16		2
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-00470	Central Plant	In Service	2			2
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-00471	Emergency Addition - West	In Service	4			2
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-00472	X-Ray File Storage	In Service	5			4
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-02787	Respiratory Neurophysiology Lab	In Service	4			2
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-02788	Emergency Generator Shelter	In Service	4			3
23 - Mendocino	10301	Mendocino Coast District Hospital	Fort Bragg	BLD-03473	Emergency Addition - East	In Service	4			2
24 - Merced	10309	Memorial Hospital Los Banos	Los Banos	BLD-00029	Main Hospital	In Service	2	1.00	1.00	2
24 - Merced	10309	Memorial Hospital Los Banos	Los Banos	BLD-00030	Mechanical Building	In Service	2	1.21	1.19	2
24 - Merced	10315	Mercy Medical Center	Merced	BLD-03870	Hospital	In Service	5			4
24 - Merced	10315	Mercy Medical Center	Merced	BLD-03871	Power Plant	In Service	5			4
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05610	Radioactive Waste and Pathology Holding	In Service	5			4
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05611	Equipment Charging	In Service	5			4
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05612	ER Entrance Bridge	In Service	5			4
25 - Modoc	10322	Modoc Medical Center	Alturas	BLD-01627	Hospital Building	In Service	2		0.15	2
25 - Modoc	10322	Modoc Medical Center	Alturas	BLD-03330	Warnerview Skilled Nursing Facility	Skilled Nursing Only	N/A			N/A
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06279	Hospital - Building 100	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06288	Entrance Canopy	Under Construction	5s			4s
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01621	Main Hospital	In Service	2	0.00		2
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01622	Pump House Building	In Service	2	0.01		2
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01623	Heating and Storage Building	In Service	2		0.52	2
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01624	Generator Building	In Service	2		0.36	2
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01625	South Wing Addition	In Service	5s			2
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01626	Walk-in Box	In Service	5s			2
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-00267	Main Hospital	In Service	4			2
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-03697	New Wing	In Service	5			4
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-03698	New Wing Connecting Corridor - North	In Service	5			4
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-05561	New Wing Connecting Corridor - South	In Service	5			4
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01629	"A" Phase I - 1960 Wing	In Service	2			1
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01630	"B" Phase II - 1968 Wing	Not an Independent Building	N/A			N/A
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01631	"C" 1978 Addition	In Service	3			1
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01633	"E" 1998 Cancer Center Addition	In Service	5			1
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-03714	Parking Structure	In Service	5			1
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05554	"G" Utility Service Building	In Service	5s			4s
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05555	"H" Cardiac EP Lab	In Service	5s			4s
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05556	"J" South Pavilion	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05557	"K" Forest Pavilion	In Service	5s			4s
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-01634	Main Hospital	In Service	2	0.05		2
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03265	New Porte Cochere	In Service	5			2
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03266	New Hospital	In Service	5			2
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03328	Bottle Building	In Service	5			4
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02542	Extended Care Services (Bldg 100)	In Service	5			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02544	Food Service / Central Plant (Bldg 580) 580A	In Service	5			3
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02545	Acute Care (Building 500)	In Service	5			3
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03827	Material Management (Bldg 600)	In Service	4			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03828	Inpatient Mental Health (Bldg 940)	In Service	4			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03829	Generator Building (Bldg 980)	In Service	5			3
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03862	Kitchen & Associated Fac (Bldg 600)	In Service	2		0.81	2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03864	Canopy	In Service	5			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03865	Canopy	In Service	5			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03867	Canopy	In Service	5			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03868	Canopy	In Service	5			2
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-05986	Pediatric / Surgery (BLD 580) 580B	In Service	5			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01635	Original Building	In Service	2	0.28		2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01636	36 Bed Addition	In Service	2	0.35		2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01638	Dietary Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01639	Electrical and Mechanical Building	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01640	Central Sterile Supply	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01641	Cardiac Center North	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01642	Cardiac Center South	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01643	CCU Expansion	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01644	Outpatient Center	In Service	5			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01645	Cath Lab Expansion	In Service	5			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01646	Cath Lab Canopy	In Service	5			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01647	Cath Lab Stair Tower	In Service	5			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01648	Link	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-01649	Central Plant	In Service	5			4
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-03076	Administration Building	In Service	4			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-03455	Utility Tunnel	Under Construction	N/A			
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-03456	Drop-off Canopy	In Service	5			4
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-05201	Rotary UPS	In Service	2			2
27 - Monterey	10348	Salinas Valley Memorial Hospital	Salinas	BLD-05269	New Central Energy Plant	Under Construction	5s			4s
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01665	Smoking Porch Addition to Main Wing	Not an Independent Building	N/A			N/A
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01666	Main Wing & Smoking Porch Addition	In Service	2		0.30	2
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01667	East Wing	In Service	2		0.31	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01668	Ancillary Wing & (ICCU Add 5th Flr)	In Service	4			2
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-03031	Generator Building	In Service	4			2
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-03554	Health Center	In Service	2		1.13	2
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-05327	Chiller Plant	In Service	5s			4
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01650	Main Hospital	No Acute Care - OSHPD Bldg	N/A		7.94	2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01651	West Wing	No Acute Care - OSHPD Bldg	N/A		2.30	2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01652	West Tower	In Service	2			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01653	Conference Addition	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01654	Link Corridor	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01655	South Elevator Tower	In Service	4			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01656	South Nursing Wing	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01657	North Elevator Tower	In Service	4			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01658	North Nursing Wing	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01659	Maternity / Pediatrics	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01660	Admitting / Lobby	In Service	3			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01661	Radiology / Oncology Addition	In Service	4			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01662	MRI Building	In Service	5			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01663	Emergency Addition	In Service	5			2
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-01664	Emergency Canopy	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-02881	Canopy Addition	In Service	5			4
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-05309	North Acute Care Building	In Service	5			4
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-05323	North Acute Care Corridor	In Service	5			4
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-05462	Imaging Center Canopy	In Service	5			4
28 - Napa	10362	Queen Of The Valley Medical Center	Napa	BLD-05463	Women's Center	In Service	5			4
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01669	East Wing	In Service	2	0.00		2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01670	West Wing	In Service	4			2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01671	ICU Addition	In Service	4			2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01672	Pharmacy Addition	Not an Independent Building	N/A			N/A
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01673	West Wing Addition	In Service	4			2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01674	Outpatient Center	In Service	4s			2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01675	West Wing Addition #2	Not an Independent Building	N/A			N/A
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-03399	Entry Canopy West	In Service	5s			4s
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-03686	Central Plant	In Service	4			2
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-06080	Entry Canopy Center	In Service	5s			4s
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-06081	Entry Canopy East	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01676	1950 Building and 1966 Additions	In Service	2		0.44	1
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01677	1966 North Addition Building	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01678	1978 Building	In Service	4			1
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01679	1990 Building	In Service	4			1
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01680	1993 Building	In Service	4			1
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-02569	Med Gas Storage Building	In Service	4			1
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-03236	1986 Building	Skilled Nursing Only	N/A			
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-03897	Western Addition	Under Construction	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05249	2011 ED/SPD Addition	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05272	South Wing	Under Construction	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05273	South Wing Corridor	Under Construction	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05474	2002 Building	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05475	Generator Building	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05476	2008 Building	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05477	Central Plant	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05478	Modular Chiller Building	In Service	5s			4s
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05479	Chiller Building Cooling Tower	Not a Building Structure	N/A			
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05480	Skilled Nursing Facility Addition	Skilled Nursing Only	N/A			
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01684	Central Plant	In Service	2		0.90	2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01685	Main Hospital	In Service	2	0.36		2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01692	Phase IV/North Wing - South	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01693	Phase IV East Entrance	In Service	4			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01695	Main Entrance Building	In Service	5			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03658	Corridor No. 1	In Service	5			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03659	Porte Cochere	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03660	Corridor No. 2	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03661	Corridor No. 3	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03662	Corridor No. 4	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03663	Corridor No. 5	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03664	Arcade	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03665	Phase IV/North Wing - North	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03671	Phase IV East Entrance Addition - North	In Service	3			2
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03672	Phase IV East Entrance Addition - South	In Service	3			2
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01681	Original Building / Additions	In Service	2	0.39		1
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01682	ICU Addition	In Service	4			1
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01683	OB/Gyn	In Service	4			1
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-06268	Equipment Yard	Under Construction	N/A			
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-06269	Trash Enclosure	Equipment Yard	N/A			1
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00996	Psychiatric Treatment	In Service	2	0.09		2
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00997	Main Hospital Building	In Service	2	0.03		2
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00998	ICU / CCU Unit	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00999	ER Addition / Birthing Center	In Service	4			2
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-01000	Canopy Addition	In Service	4			2
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02346	Main Building	In Service	2	0.22		2
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02347	Entry Pavilion	In Service	4s			2
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02348	Mechanical Building	In Service	5			2
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02349	ICU/Admin Addition	In Service	4			2
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02350	Surgery Addition	In Service	5s			2
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-00271	CHOC North	In Service	4			3
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-00272	Research Building	In Service	4			3
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-00273	CHOC West	In Service	2		1.03	2
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-05243	Tower II	In Service	5s			4s
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-05335	CHOC Lobby	In Service	5s			4s
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-05672	Providence Tunnel	Tunnels	4s			3
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-05720	Le Veta Stairs and Bridge	In Service	5s			4s
30 - Orange	14370	Children's Hospital of Orange County	Orange	BLD-05721	5 Story Garage Elevator and Bridge	In Service	5s			4s
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-02351	Original Hospital Building	In Service	2	0.34		2
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-02352	Psychiatric Addition	In Service	4			2
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03102	Radiographic and Fluoroscopy Addn	In Service	4			2
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03417	Canopy 1	In Service	4			2
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03419	Canopy 3	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	16536	Encompass Health Rehabilitation Hospital Of Tustin	Tustin	BLD-00288	Acute Care Hospital	In Service	3			1
30 - Orange	16536	Encompass Health Rehabilitation Hospital Of Tustin	Tustin	BLD-02900	Generator Enclosure	In Service	4			1
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-01029	Original Building	In Service	2	0.02		2
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-01030	Classroom Addition	In Service	4s			2
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-02631	Mechanical Addition	In Service	4s			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00926	Main Hospital/Additions	In Service	2	0.01		2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00927	Women & Children's Hosp.	In Service	4			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00928	Dining Room Addition	In Service	4			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00929	Conference Room Addition	In Service	4			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00930	Living Care Center	Not an Independent Building	N/A			N/A
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-00931	ER Addition	In Service	4			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-03497	Emergency Power Building	In Service	5s			4s
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-03770	ER Addition - Phase 2	In Service	4			2
30 - Orange	12834	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-03771	ER Addition - Phase 3	In Service	5			2
30 - Orange	16234	Fountain Valley Regional Hospital And Medical Center	Fountain Valley	BLD-05195	Living Care Center	In Service	3			2
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02406	Patient Tower	In Service	4			2
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02407	Ancillary Building	In Service	4			2
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02408	Mechanical Building	In Service	4			2
30 - Orange	17438	Healthbridge Children's Hospital-Orange	Orange	BLD-05189	Main Building	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	18226	HealthSouth Rehabilitation Hospital of Tustin	Tustin	BLD-06151	West Building	Proposed	5s			4s
30 - Orange	18226	HealthSouth Rehabilitation Hospital of Tustin	Tustin	BLD-06152	East Building	Proposed	5s			4s
30 - Orange	18226	HealthSouth Rehabilitation Hospital of Tustin	Tustin	BLD-06448	Oxygen Tank Enclosure	Proposed	N/A			
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-00283	D & T	In Service	4			2
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-00284	Nursing	In Service	4			2
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-05852	ER Entrance Canopy	In Service	5			4
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-05853	Emergency Department	In Service	5			5
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06124	Main Entrance Canopy	In Service	4s			2
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06285	Ambulance Bay Canopy	In Service	5			4
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06286	NPC 5 Storage Area	Equipment Yard	N/A			5
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06297	Trellis Wheel Chair Storage	In Service	5			4
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06303	Patient Tower	Proposed	5s			4s
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06304	Central Utility Plant	Proposed	5s			4s
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06305	North Entry Canopy	Proposed	N/A			
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06306	South Entry Canopy	Proposed	5s			4s
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06307	Utility Tunnel	Proposed	N/A			
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06409	Main Entrance Canopy Extension	Proposed	5s			4s
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06410	UPS Room	Proposed	5s			4s
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06480	Vending Kiosk	In Service	5			4
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06481	Wheelchair Storage	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02360	Original Building	In Service	2	0.74		2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02361	Four-Story Building - 1957	In Service	2	1.71		2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02363	Old ICU - 1963	In Service	2	0.63		2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02364	Old Radiation Therapy - 1975	In Service	4			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02366	Power Plant - Boilers and Chillers	Not an Independent Building	N/A			N/A
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02368	Inpatient Tower - 1974	In Service	2	0.48		2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02369	Ancillary / Helistop / Power Plant	In Service	2		0.03	2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02370	Helistop - 1974	Not an Independent Building	N/A			N/A
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02371	Chemical Dependency - 1965	In Service	2	0.64		2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02373	Cancer Center	In Service	3			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02374	MRI / MRI Addition	In Service	3			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02375	South Entrance	In Service	3			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02376	ER East Waiting Room Addition	Not an Independent Building	N/A			N/A
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02377	MRI Addition	Not an Independent Building	N/A			N/A
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02378	Link Building	In Service	3			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02379	Emergency Department Addition	In Service	5			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03098	Cancer Center - Link Tower	In Service	3			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03332	Power Plant - MUSS & ATS	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03333	Emergency Generator Building	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03415	Energy Treatment Building	In Service	4			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03699	East Wing	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05442	Cogeneration Building	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05517	Cafe Building	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05518	Fire Pump Building	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05519	ECU Waiting Building	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05520	Original Building - North Portion	In Service	2			2
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05568	East Wing Canopy	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05900	ECU Waiting Walk-In Entry Canopy	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05901	ECU Waiting Drop-Off Area Canopy	In Service	5			4
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-06281	Elevator Tower (for Inpatient Tower)	In Service	5			2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02387	Hospital Tower	In Service	2	0.36		2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02388	Main Hospital	In Service	2	0.03		2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02389	ICU/CCU Addition	In Service	4s			2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02390	Emergency Expansion	In Service	3			2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02916	CT Scan Addition	In Service	4			2
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02917	X-Ray Addition	In Service	2	0.03		2
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-05274	Hospital	In Service	5			4
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-05275	Central Utility Plant	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-06224	Walk-in Refrigerator	Not a Building Structure	N/A			
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-03831	Main Building	In Service	5s			4s
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-03902	Central Plant	In Service	5s			4s
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02353	Building I: Original Building	In Service	2	0.59		2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02354	Building II	In Service	4			2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02355	Building III	In Service	4			2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02356	Building IV	In Service	4			2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02357	Building V	In Service	4			2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02358	Building VI	In Service	4			2
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02359	Building VII	In Service	4			2
30 - Orange	13068	Kindred Hospital Brea	Brea	BLD-02559	Main Building	In Service	3			2
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-01343	Patient Tower (Building I)	In Service	2	1.02	1.02	1
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03059	Entry/Lobby (Building II)	In Service	2	1.05	1.05	1
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03060	Critical Care (Building III)	In Service	2	1.05	1.05	1
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03061	Body Scanner Addition (Building IV)	In Service	4			1
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03479	Entry Canopy	In Service	2			3
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00982	Main Building	In Service	2	0.48		2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00983	Perinatal Building Addition	In Service	4			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00984	Pool Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00985	Service Building	In Service	4			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02758	Service Building	In Service	4s			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02759	Rehabilitation Department Expansion	In Service	4			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02760	Patient Room Expansion	In Service	4			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-05516	Oxygen Tank Yard	Equipment Yard	N/A			2
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-05782	Canopy	In Service	5			4
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-02395	Main Hospital/ICU - CCU/Nuclear Med	In Service	2	0.03		2
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-02396	OB South/ER/Lab	In Service	3			2
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-02397	Women's Center	In Service	5			2
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-02398	Linear Accelerator	In Service	5			2
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-06453	Central Utility Plant	Proposed	5s			4s
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-06477	Utility Bridge	Proposed	5s			4s
30 - Orange	10440	Los Alamitos Medical Center	Los Alamitos	BLD-06478	TES (Thermal Energy Storage)	Proposed	N/A			
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00323	Original Building	In Service	3			2
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00324	South Addition	In Service	3			2
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00325	Emergency Room Addition	In Service	3			2
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05472	Pedestrian Bridge	In Service	5			4
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05730	Patient Care Pavilion	Clinic - Local Jurisdiction	N/A			
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05731	Covered Walkway	In Service	4			2
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05873	Emergency Room Addition #2	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-06027	LDR	In Service	3			2
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-06231	LDR Canopy	In Service	3			2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01042	Main Hospital	In Service	2	0.20		2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01043	Women's Health Center	In Service	4			2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01044	Central Plant - Steel Portion	In Service	2	0.74		2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01045	Central Plant - Concrete Portion	In Service	2	0.06		2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-02738	Critical Care Pavilion	In Service	5			2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-03707	Central Plant Addition	In Service	4			2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-05981	Utility Tunnel	Tunnels	N/A			2
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-05989	Main Hospital Canopy	In Service	5			4
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-06020	CCP Canopy	In Service	5			4
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-06024	WHC Canopy	In Service	5			4
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02433	Original Building	In Service	2	0.08		2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02434	Nursing Tower	In Service	2		2.92	2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02435	Elevator Tower	In Service	2	0.13		2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02436	Radiographic	In Service	2	0.10		2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02437	Radiographic - South Addition	In Service	2	1.05	5.84	2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02438	Administration Building	In Service	2	0.06		2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02439	Mechanical / Central Plant	In Service	2	0.03		2
30 - Orange	10468	Mission Hospital Laguna Beach	Laguna Beach	BLD-02440	Linear Accelerator Suite (Treatment)	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00913	Pavilion - Building 1	In Service	2	0.01		2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00914	Pavilion - Building 2	In Service	5			2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00915	Pavilion - Building 3	In Service	4			2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00916	Pavilion - Building 4	In Service	4			2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00917	Pavilion - Building 5	In Service	5			2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-00918	Hospital Tower	In Service	4			2
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-03184	Tower 2	In Service	5			4
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-03185	Linear Accelerator	In Service	5			4
30 - Orange	12804	Mission Hospital Regional Medical Center	Mission Viejo	BLD-03186	Perioperative Pediatric Pavilion	In Service	5			4
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00295	Ancillary Building/ER Expansion	In Service	2	0.60		2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00296	Elevator Tower	In Service	2			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00297	Nursing Tower	In Service	2			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00298	Administration	In Service	2	1.97	0.67	2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00299	Shipping & Receiving	In Service	2			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00300	Mechanical Building	In Service	2			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00301	Radiation Therapy	In Service	2			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00302	Support Services	In Service	5s			2
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-05722	Entrance Canopy	In Service	2			2
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-00156	Main Hospital & Addition	In Service	2	0.03		2
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-00157	Patient Room Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-00158	OB Addition	In Service	4			2
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-00159	Classrooms & Additions	In Service	2	0.03		2
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-03742	GI Building Expansion	In Service	5			4
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-03743	GI Building Expansion Canopy	In Service	5			4
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-05701	Main Entry and Ambulance Canopy	In Service	5			4
30 - Orange	13077	Placentia Linda Hospital	Placentia	BLD-05718	Free-Standing Mechanical Platform	Under Construction	5s			4s
30 - Orange	13066	Saddleback Memorial Medical Center - San Clemente	San Clemente	BLD-01001	Original Hospital	In Service	2	0.14		2
30 - Orange	13066	Saddleback Memorial Medical Center - San Clemente	San Clemente	BLD-01002	ER Expansion	In Service	5s			2
30 - Orange	13059	South Coast Global Medical Center	Santa Ana	BLD-00994	Main Hospital and Additions	In Service	2	0.02		2
30 - Orange	13059	South Coast Global Medical Center	Santa Ana	BLD-00995	Nursing Wing Addition	In Service	4			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02414	Main Building (A)	In Service	2		15.48	2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02415	Central Plant	In Service	2			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02416	East/West Wing	In Service	2	0.59	13.47	2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02417	South Tower	In Service	2	0.63		2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02418	North Wing / Lobby	In Service	4			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02419	Main Hospital Building (B)	In Service	4			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02420	Main Hospital Building (C)	In Service	4			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02421	Regional Cancer Center	In Service	4			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02422	Emergency Department Expansion	In Service	5			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-02784	Generator Enclosure	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03013	ICU/CCU Addition	In Service	5			2
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03352	Patient Care Center/Plaza Tower	In Service	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03353	Facilities Services Building	In Service	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03354	PCC Lobby / Canopy	In Service	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03355	Underground Tunnel	Tunnels	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-03357	South Entry Canopy	In Service	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-06061	PCC West Canopy	In Service	5			4
30 - Orange	10457	St. Joseph Hospital	Orange	BLD-06435	Emergency Entrance Canopy	In Service	3s			
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02424	Main Building / Canopies / Boiler Room	In Service	1	0.87	2.24	2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02425	West Building	In Service	1		17.89	2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02426	North Building	In Service	2	0.24		2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02427	CT Scan Building	In Service	3			2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02428	Outpatient/Admitting Building	In Service	3			2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02429	Linear Accelerator	In Service	5			2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02431	Emergency Generator Enclosure	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02432	MRI and Surgery Building	In Service	3			2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02832	E.R. Waiting/Canopy	In Service	3			2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02833	Basement Expansion	In Service	1		8.14	2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-02834	Boiler Room Expansion / Chiller Rm	In Service	2	0.17		2
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-03190	Southwest Acute Care Bed Tower	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-03191	Central Utility Plant	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-03192	East Link	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-03193	West Link North	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-03194	Northwest Acute Care Bed Tower	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-05775	West Link South	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-05776	Trash Enclosure	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-05777	Medical Gas Enclosure	In Service	5			4
30 - Orange	10458	St. Jude Medical Center	Fullerton	BLD-05778	Main Entrance Canopy	In Service	5			4
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-02400	Medical Center Tower Building 1A	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-02401	Neuropsychiatric Center - West Wing	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-02402	Steam Plant Building 31	In Service	5			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-02403	Primary Electrical Facility Building 32	In Service	4			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-02404	Utility Tunnel	Tunnels	N/A			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-03017	Neuropsychiatric Center - East Wing (Acute Center East)	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-03412	Douglas Hospital	In Service	5			4
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-03416	Link Building	In Service	5			4
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05584	Medical Gas / Oxygen Tank Yard	Equipment Yard	N/A			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05585	Packaged Chilled Water Generator	Not a Building Structure	N/A			
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05586	Cooling Tower Yard	Equipment Yard	N/A			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05587	Generator Switchgear	In Service	5s			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05588	Emergency Generator Housing	Equipment Yard	N/A			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05683	Neuropsychiatric Center - East Wing (Acute Center South)	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05769	Neuropsychiatric Center - East Wing (Acute Center North)	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05770	Neuropsychiatric Center - East Wing (Acute Center Walkway North)	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-05771	Neuropsychiatric Center - East Wing (Acute Center Walkway South)	In Service	3			2
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-06008	Ambulance Canopy	Under Construction	5s			4s
30 - Orange	10446	University of California Irvine Medical Center	Orange	BLD-06239	Chiller Plant	Under Construction	5s			4s
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02441	Main Hospital	In Service	2	1.06	1.08	2
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02675	Phase I - Tower Addition	In Service	3			2
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02886	Phase I - 1 Story Addition	In Service	3			2
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-03118	Entry Canopy	In Service	3			2
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-03559	Oxygen Tank Yard	Equipment Yard	N/A			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00260	Hospital, Building 1	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00261	Hospital, Building 2	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00262	Hospital, Building 3	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00263	Hospital Tower	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00264	Hospital Tower North	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00265	Hospital Tower South	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00266	Central Plant Building	In Service	4			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05230	Emergency Department/Radiology	In Service	5s			4s
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05723	Central Plant Addition	In Service	5			4
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05724	EVS Building	In Service	5			4
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05725	Women & Children's Link	In Service	5			4
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05726	Women & Children's Center	In Service	5			4
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05727	Fire Pump Building	In Service	5			4
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06067	Entry Canopy	In Service	4s			2
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06388	MRI Entry Canopy	Under Construction	5s			4s
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01344	Original Hospital	In Service	2	0.00		2
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01345	Storage / Pharmacy Building	In Service	4			2
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01346	Dietary Addition	In Service	4			2
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01347	Emergency Addition	In Service	4			2
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01348	Medical Records Addition	In Service	4			2
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01349	Electrical Addition	In Service	5			4
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01350	Boiler Addition	In Service	5			4
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-02979	West Electrical Room	In Service	4			4
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05552	Cath Lab Addition	In Service	5s			4s
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05553	MRI Addition	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05779	Patient Drop Off Canopy	In Service	5s			4s
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05882	Emergency Generators Yard	Equipment Yard	N/A			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-00303	Main Hospital (General Hospital)	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-00304	Central Plant	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03248	Acute Rehabilitation - East	Not an Independent Building	N/A			N/A
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03249	Acute Rehabilitation - Pedestrian Walkway	In Service	5			4
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03580	General Hospital Pedestrian Walkway	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03581	Bed Tower South	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03582	Bed Tower North	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03583	Administration	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03584	MOB Pedestrian Walkway	In Service	5			2
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03585	Emergency Department Expansion	In Service	5			4
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03586	Bed Tower Expansion	In Service	5s			4s
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03587	Bed Tower Expansion Pedestrian Walkway	In Service	5s			4s
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03611	NICU	In Service	5			4
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03612	Acute Rehabilitation	In Service	5			4
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03613	Well Baby Nursery	Not an Independent Building	N/A			N/A
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03614	ICU Expansion	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06161	E.D. & Critical Care Expansion	Under Construction	5s			4s
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-01362	Main Hospital Building	In Service	2	0.00		2
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-01364	Boiler Plant Building	In Service	2		0.00	2
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-03655	SNF Addition	In Service	5			4
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-03656	Central Plant	In Service	5			4
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01351	Original Building	In Service	2	0.03		2
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01353	1976 Addition	In Service	4			2
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01354	South Addition	In Service	4			2
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01355	Main Hospital Building	In Service	2	0.08		2
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01356	Pump Building	In Service	2	0.01		2
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01358	Entrance Addition	Not an Independent Building	N/A			N/A
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01359	Extended Care Addn.	In Service	4			2
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01360	Storage Addition	In Service	4			2
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01361	Generator Building	In Service	5			4
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-03843	Boiler Room	In Service	2	0.06		2
33 - Riverside	10901	Acadia Behavioral Health Hospital	Indio	BLD-06336	Administration/Outpatient Clinic and Support Services	Proposed	N/A			
33 - Riverside	10901	Acadia Behavioral Health Hospital	Indio	BLD-06337	Connecting Corridor	Proposed	N/A			
33 - Riverside	10901	Acadia Behavioral Health Hospital	Indio	BLD-06338	Patient Wing	Proposed	N/A			
33 - Riverside	10901	Acadia Behavioral Health Hospital	Indio	BLD-06339	Main Entrance Canopy	Proposed	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01367	Original Hospital - Main	In Service	2	1.05	0.48	2
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01368	Ancillary - Main	In Service	4			2
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01369	Surgery & Delivery - Main	In Service	3			2
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-02996	Rehabilitation Hospital - Magnolia	Not an Independent Building	N/A			N/A
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-02997	ED Addition	In Service	5			4
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-03594	Generator Building (Electrical Panel Room)	In Service	4			4
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05887	Bulk Medical Gas Yard	Equipment Yard	N/A			4
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05888	Emergency Generator	Equipment Yard	N/A			4
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05889	Switchgear Yard	Equipment Yard	N/A			4
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05890	Modular MRI Building	Outpatient Only	N/A			
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-06298	Porte Cochere	In Service	5			4
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01393	Main Hospital & Additions	In Service	2	0.38		2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01395	Woman & Infants Hospital	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01396	North Wing	In Service	2	0.30		2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01397	Central Plant	In Service	4			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01398	Shipping/Receiving	In Service	4			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01399	Surgery Wing	In Service	4			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01400	West Tower	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01401	Lobby	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01402	Admitting	In Service	4			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01403	Elevator Tower	In Service	4			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01404	Dinah Shore Waiting Area	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-02932	East Tower	In Service	2	0.51		2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03720	West Tower - Corridor 1	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03721	West Tower - Corridor 2	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03722	West Tower - Corridor 3	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03723	West Tower - Corridor 4	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03725	West Tower - Corridor 5	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03741	Medical Records Building	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03764	Elevator Tower - Corridor 1	In Service	3			2
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03765	Elevator Tower - Corridor 2	In Service	3			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01056	North Addition	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01057	Eisenhower Wing (North)	Not an Independent Building	N/A	9.45	7.08	N/A
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01058	Gene Autry Wing	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01059	Surgery Expansion	In Service	5			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01060	Sinn Wing - Part A	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01061	Birthing Center Bridge	In Service	4s			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-02824	Engineering Department	In Service	2		0.64	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03003	Eisenhower Wing (South)	Not an Independent Building	N/A	9.45	7.08	N/A
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03004	Eisenhower Wing (Center)	In Service	2	4.89	0.92	2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03005	Sinn Wing - Part B (Amb. Canopy)	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03006	Sinn Wing - Part C	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03007	Sinn Wing - Part D	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03008	Sinn Wing - Part E	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03009	Sinn Wing - Part F	In Service	4			2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03540	(CP) Central Plant	In Service	5			4
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03541	Annenberg Pavilion	In Service	5			4
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03830	12 KV Switch Building	In Service	5			4
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-05500	Delivery Dock	In Service	2		0.21	2
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-05647	ED / Renker Pavilion	In Service	5			4
33 - Riverside	18213	HealthSouth Murrieta Rehabilitation Hospital	Murrieta	BLD-05790	Rehabilitation Hospital	Under Construction	5s			4s
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01405	Pre 1980 Emergency	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01406	Tower I	In Service	2		1.20	2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01407	1965 Mechanical Room	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01408	1948 Addition	In Service	2		0.95	2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01409	North Wing and Annex	In Service	1		15.11	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01410	Obstetrics I	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01411	1965 NW Addition	In Service	2		1.06	2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01412	Behavioral Health	In Service	2			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01413	Obstetrics II	In Service	4			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01414	Tower II Lower Levels	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01415	Tower II Upper Levels	In Service	3			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01416	1980 Entrance	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01417	Main Lobby and Entrance	In Service	3			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-01418	Area A	In Service	3			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-02857	Area B	In Service	3			2
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-02858	Area C	Not an Independent Building	N/A			N/A
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-05649	Emergency Department Addition	In Service	5			4
33 - Riverside	10541	Hemet Valley Medical Center	Hemet	BLD-06156	Canopy	In Service	4			2
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01370	Original Hospital Building	In Service	2	0.07		2
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01371	Central Plant	In Service	2	0.72		2
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01372	Central Plant Addition	In Service	4			2
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01373	North Wing/E.R. Expansion	In Service	4			2
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01374	West/South Wing	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01375	ICU - MED / Surgery Addition	In Service	5			4
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-03525	Canopy	In Service	5			4
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-00285	Patient Tower	In Service	4			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02918	Stair and Elevator Tower	In Service	4			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02919	Central Plant	In Service	3			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02920	Hospital Building	In Service	3			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02921	Waiting Room Addition	In Service	5			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-05418	Bulk Oxygen Tank	Equipment Yard	N/A			2
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-05732	Emergency Department Expansion	In Service	5s			4s
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-00274	Hospital Tower	In Service	3s			2
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-00275	Plant Service Building	In Service	4s			3
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05460	MRI Building	In Service	4s			
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05651	Switchgear Enclosure	Under Construction	5s			4s
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05652	Generator Enclosure - Number 1	Under Construction	5s			4s
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05653	Generator Enclosure - Number 2	Under Construction	5s			4s
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05654	Generator Enclosure - Number 3	Under Construction	5s			4s
33 - Riverside	13030	Kindred Hospital Riverside	Perris	BLD-00986	Main Hospital	In Service	2		0.24	2
33 - Riverside	13030	Kindred Hospital Riverside	Perris	BLD-03519	Storage	In Service	4s			2
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05595	Main Hospital Facility	In Service	5			4
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05596	Central Plant	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05800	Loading Dock Canopy	In Service	5			4
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05801	North Canopy	In Service	5			4
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05802	East Canopy	In Service	5			4
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05803	Emergency Department Canopy	In Service	5			4
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05804	Entrance Canopy	In Service	5			4
33 - Riverside	16148	Menifee Valley Medical Center	Sun City	BLD-00351	Hospital Building	In Service	4			2
33 - Riverside	16148	Menifee Valley Medical Center	Sun City	BLD-02897	Patient Tower	In Service	4			2
33 - Riverside	16148	Menifee Valley Medical Center	Sun City	BLD-02898	Stair and Elevator Tower	In Service	4			2
33 - Riverside	16148	Menifee Valley Medical Center	Sun City	BLD-02899	Central Plant	In Service	4			2
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01376	Building A	In Service	2		0.03	1
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01377	Building B	In Service	2	0.00		1
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01378	Building C	In Service	4			1
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01379	Building D	In Service	2		0.40	1
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01380	Building E	In Service	2		0.02	1
33 - Riverside	10554	Parkview Community Hospital Medical Center	Riverside	BLD-01381	Original Hospital Building and 1961 Additions	In Service	2	0.07		2
33 - Riverside	10554	Parkview Community Hospital Medical Center	Riverside	BLD-01382	1971 Tower	In Service	2	0.54		2
33 - Riverside	10554	Parkview Community Hospital Medical Center	Riverside	BLD-01383	Diagnostic & Treatment Wing & Addition	In Service	5s			2
33 - Riverside	10554	Parkview Community Hospital Medical Center	Riverside	BLD-03344	Utility Plant Building	Under Construction	5s			4s
33 - Riverside	10554	Parkview Community Hospital Medical Center	Riverside	BLD-05783	Emergency Department Addition	Under Construction	5s			4s
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01384	Building A (Main)	In Service	1		3.70	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01385	Building B	In Service	1	1.69	1.69	2
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01386	Building C (Inpatient Building)	In Service	3			2
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01387	Building D	In Service	2	0.08		2
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01388	Old Radiology Building	In Service	2	0.15		2
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-03107	Emergency Generator Enclosure	In Service	4			2
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-03421	Building G	In Service	5s			4s
33 - Riverside	18224	Riverside Psychiatric Hospital	Riverside	BLD-05952	North Building	Proposed	N/A			
33 - Riverside	18224	Riverside Psychiatric Hospital	Riverside	BLD-05960	South Building	Proposed	N/A			
33 - Riverside	18224	Riverside Psychiatric Hospital	Riverside	BLD-05961	Emergency Generator	Proposed	N/A			
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-02517	Main Building	In Service	3			2
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03488	Ancillary Building	In Service	3			2
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03489	Central Plant / Dining Building	In Service	3			2
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03490	Generator Building	In Service	3			2
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-05814	Co-Gen Yard	Equipment Yard	N/A			4
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-05906	MRI Trailer	Outpatient Only	N/A			
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-06352	Central Plant Yard	Equipment Yard	N/A			2
33 - Riverside	10559	San Geronio Memorial Hospital	Banning	BLD-01389	Original Building-OB Addition-'64 Addition	In Service	2	0.59		2
33 - Riverside	10559	San Geronio Memorial Hospital	Banning	BLD-01390	O.R. Addition	In Service	2	0.03		2
33 - Riverside	10559	San Geronio Memorial Hospital	Banning	BLD-01391	Addition (1980)	In Service	4			2
33 - Riverside	10559	San Geronio Memorial Hospital	Banning	BLD-01392	O.B. Addition	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-02947	Ambulance Canopy	In Service	5			4
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-02948	Entrance Canopy	In Service	5			4
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05235	ED / ICU	In Service	5			4
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05303	Central Plant	In Service	5			4
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05425	Oxygen Tank and Cooling Tower Yard	Equipment Yard	N/A			
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05576	Patient Tower	Under Construction	5s			4s
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05577	Lobby	Under Construction	5s			4s
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05578	Entry Canopy	Under Construction	5s			4s
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05579	Connecting Corridor	Under Construction	5s			4s
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-00331	Building A	In Service	3			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-00332	Building B & ER Addition	In Service	4			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-00333	Building C - Obstetrics Addition	In Service	3			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-00334	Radiology Addition	In Service	4			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-00335	OR/Amb. Care Addn - Bldg D, North	In Service	5s			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-02980	OR/Amb. Care Addn - Bldg D, South	In Service	5s			2
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-05228	ER, ICU & Radiology Expansion - Building G	In Service	5s			4s
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-05281	Bed Addition, Building "i"	In Service	5s			4s
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-05282	ER, ICU & Radiology Expansion - Building F	In Service	5s			4s
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-05284	ER, ICU & Radiology Expansion - Building H	In Service	5s			4s
33 - Riverside	15749	Southwest Healthcare System	Wildomar	BLD-05521	ER, ICU & Radiology Expansion - Building B1D	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
33 - Riverside	16681	Southwest Healthcare System	Murrieta	BLD-00290	Original Hospital Building & Conversions	In Service	4s			2
33 - Riverside	16681	Southwest Healthcare System	Murrieta	BLD-00291	Acute Care Addition	In Service	3s			2
33 - Riverside	16681	Southwest Healthcare System	Murrieta	BLD-05229	Women's Center and Emergency Room	In Service	5s			2
33 - Riverside	18167	Temecula Valley Hospital	Temecula	BLD-05259	Main Hospital	In Service	5s			4s
33 - Riverside	18167	Temecula Valley Hospital	Temecula	BLD-06130	D&T Expansion 2018	In Service	5s			4s
33 - Riverside	18162	Vibra Rehabilitation Hospital Of Rancho Mirage	Rancho Mirage	BLD-05443	Main Building	Under Construction	5s			4s
33 - Riverside	18162	Vibra Rehabilitation Hospital Of Rancho Mirage	Rancho Mirage	BLD-06095	Dining Addition	Under Construction	5s			4s
33 - Riverside	18162	Vibra Rehabilitation Hospital Of Rancho Mirage	Rancho Mirage	BLD-06096	Rehab Addition	Under Construction	5s			4s
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01419	Hospital	In Service	2	0.04		2
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01420	Hospital Addition Tower	In Service	2	0.01		2
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01421	3 - Hospital Addition Clinic	In Service	2	0.01		2
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01422	Camellia Building	In Service	2	0.00		2
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-03284	ATS Building	In Service	5			4
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-03557	Telephone Equipment Building	In Service	2			2
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-05469	Central Utility Building	In Service	5s			4s
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-05905	Camellia Utility Bridge	In Service	5			4
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-06474	ED Expansion	Proposed	5s			4s
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00319	Hospital, Building 1	In Service	4			2
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00320	Hospital, Building 2	In Service	4			2
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00321	Hospital Expansion	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00322	Central Plant	In Service	4			2
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03502	Communications Building	In Service	4			2
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03503	ER / Radiology Expansion	In Service	5s			4
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03608	Central Utility Plant (Chiller Plant)	In Service	5			4
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03609	Hospital Addition	In Service	5			4
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06109	ED Trauma Addition	In Service	5			4
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06128	Corridors	In Service	5			4
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06249	CUP Water Tank No. 2	Under Construction	5s			4s
34 - Sacramento	10022	Kaiser Permanente Railyards Medical Center	Sacramento	BLD-06442	Hospital	Proposed	5s			4s
34 - Sacramento	10022	Kaiser Permanente Railyards Medical Center	Sacramento	BLD-06443	Primary Energy Center	Proposed	5s			4s
34 - Sacramento	10022	Kaiser Permanente Railyards Medical Center	Sacramento	BLD-06444	Hospital Loading Dock	Proposed	5s			4s
34 - Sacramento	10022	Kaiser Permanente Railyards Medical Center	Sacramento	BLD-06445	Imaging Tech Dock Canopy	Proposed	5s			4s
34 - Sacramento	10022	Kaiser Permanente Railyards Medical Center	Sacramento	BLD-06446	Bulk Gas Storage	Proposed	5s			4s
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01423	South Wing / East Wing (South Wing)	In Service	2		0.26	2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01424	East Wing	No Acute Care - OSHPD Bldg	N/A			2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01425	Northeast Wing, Part A	In Service	2			2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01426	Northeast Wing, Part B	In Service	2			2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01427	North Wing	In Service	4s			2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03110	Northeast Wing, Part D	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03380	Heart Center	In Service	5			4
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03381	Equipment Yard	Equipment Yard	N/A			
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-05211	2 Story Corridor Structure	In Service	3			2
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-05212	4 Story Corridor Structure	Not an Independent Building	N/A			N/A
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-06125	Ambulance Canopy	In Service	5			4
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00078	South	In Service	4			2
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00079	West	In Service	4			2
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00080	East	In Service	4			2
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00081	Central Plant	In Service	4			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01428	Original Hospital	In Service	2	0.00		2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01429	Central Plant	In Service	2			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01430	CCU/Telemetry	In Service	4			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01431	New Central Plant	In Service	5s			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01432	New Hospital Wing	In Service	5s			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01433	Cath Lab Addition	In Service	4			2
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-03404	McAuley Tower	In Service	5			4
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-05784	McAuley Canopy	In Service	5s			4s
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-06461	Utility Tunnel	Tunnels	N/A			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00971	West Wing	In Service	2	0.01		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00972	East Wing	In Service	2			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00973	Central Plant	In Service	4			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00974	ER Addition	In Service	4			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00975	North Wing	In Service	5			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03216	ED Expansion	In Service	5			4
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03696	Medical Gas Building	In Service	4			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03705	East Wing Addition	In Service	5			3
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03706	East Wing Canopy	In Service	5			2
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06308	ED Upper South Canopy	In Service	5			4
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06309	ED Lower South Canopy	In Service	5			4
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06310	ED North Canopy	In Service	5			4
34 - Sacramento	14506	Shriners Hospitals For Children Northern California	Sacramento	BLD-02530	Main Hospital	In Service	4s			2
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-01446	Main Hospital	In Service	4			2
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03264	Radiation Oncology Center	Not an Independent Building	N/A			N/A
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03622	Sutter Capital Pavilion	In Service	5			4
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03629	Foot Bridge	In Service	2			2
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05216	Women's & Children's Center	In Service	5s			2
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05907	Sutter Capital Pavilion Utility Tunnel	Tunnels	N/A			
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05908	Main Hospital Utility Tunnel	Tunnels	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
34 - Sacramento	10025	UC Davis Rehabilitation Institute	Sacramento	BLD-06469	UC Davis Rehabilitation Institute	Proposed	5s			4s
34 - Sacramento	10025	UC Davis Rehabilitation Institute	Sacramento	BLD-06470	Emergency Generator Enclosure	Proposed	N/A			
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01434	North/South Wing	In Service	1		4.30	2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01435	University Surgery Center	Not an Independent Building	N/A			N/A
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01436	East Wing (Tower)	In Service	2	0.01		2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01437	East Wing (Radiology)	In Service	2	0.00		2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01438	East Wing (Laundry)	In Service	4			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01439	University Tower	In Service	4			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01440	MRI	In Service	4			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01443	Emergency Room Expansion	In Service	4s			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01444	Central Plant	In Service	5s			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01445	Davis Tower	In Service	5s			2
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-02840	Bulk Medical Gas	Equipment Yard	N/A			
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-02841	Surgery and Emergency Services Pavilion	In Service	5s			4
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-05815	CT Scan Building	In Service	5s			4s
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-03267	Main Building	In Service	5			4
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05493	Entry Canopy	In Service	5			4
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05494	Biowaste / Storage Building	In Service	5			4
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05495	Equipment Yard	Equipment Yard	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
34 - Sacramento	11326	Vibra Rehabilitation Hospital of Natomas	Sacramento	BLD-06365	Vibra Rehabilitation Hospital of Natomas	Proposed	5s			4s
34 - Sacramento	11326	Vibra Rehabilitation Hospital of Natomas	Sacramento	BLD-06397	Main Entry Drop Off Canopy	Proposed	5s			4s
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01458	Original Hospital Building	In Service	2	0.28		2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01459	ICU	In Service	4			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01460	Conference	In Service	4			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03063	Emergency Room	In Service	4			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03064	Reception	In Service	3s			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03065	Radiology	In Service	4			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03472	Entrance Canopy	In Service	3			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03761	Emergency Department Expansion	In Service	5s			4s
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03820	Radiology Wing	In Service	5			2
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-05467	Women's Center	In Service	5s			4s
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-05874	William and Inez Mabie SNF	Skilled Nursing Only	N/A			
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00071	Diagnostic & Treatment Bldg.	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00072	Nursing Tower	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00073	Clinics Building	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00074	Mental Health Building	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00075	Central Plant	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00076	MRI Building	In Service	5			5
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00077	Loading Dock	In Service	3			5

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	16877	Ballard Rehabilitation Hospital	San Bernardino	BLD-00293	Hospital	In Service	3			2
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05294	Main Hospital Tower - North	In Service	5s			4s
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05295	Main Hospital - South	In Service	5s			4s
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05296	Porte-Cochere	In Service	5s			4s
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05297	Entrance Canopy - East	In Service	5s			4s
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05298	Entrance Canopy - West	In Service	5s			4s
36 - San Bernardino	13035	Bear Valley Community Hospital	Big Bear Lake	BLD-00987	Main Hospital Building	In Service	2	0.02		2
36 - San Bernardino	13035	Bear Valley Community Hospital	Big Bear Lake	BLD-00988	Mechanical Building	In Service	2	0.44		2
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01003	Building 1 (Main Core)	In Service	2	0.54		2
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01004	Building Two	In Service	3s			2
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01005	Building Three	In Service	3s			2
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01006	Building Four	In Service	3s			2
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01007	Building Five	In Service	3s			2
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01471	Main Hospital, Wing A	In Service	2		0.00	2
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01472	Main Hospital, Wing B	In Service	2		0.00	2
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01473	Main Hospital, Wing C	In Service	2		0.01	2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01846	Original Hospital	No Acute Care OSHPD Bldg	N/A	4.54		2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01847	Storage Building	No Acute Care OSHPD Bldg	N/A	4.12		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01848	Physical Therapy	In Service	4			2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01849	South Hospital	In Service	3s			2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01850	North Hospital	In Service	3s			2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01851	Wings 700/800/900	In Service	2	0.02		2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01852	Utility/Central Plant 1/Service Buildings	In Service	2	1.20	1.20	2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01853	Central Plant #2	In Service	4s			2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01854	Central Plant #3	In Service	4s			2
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-03223	Telecom Building	In Service	5s			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01046	Main Hospital Building	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01047	Birthing Center	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01048	Emergency Addition	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-02612	Main Hospital Entrance Canopy	In Service	4			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-02613	Emergency Room Canopy	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05640	Outpatient Surgery Waiting & Connecting Corridor	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05641	Cath Lab and Surgery Addition	In Service	5			4
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05642	65 Bed Acute Care Addition	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-00245	Acute Care Hospital Building	In Service	5			2
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-00246	Emergency Department Addition	In Service	5			4
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05124	Continuing Care Center	Skilled Nursing Only	N/A			N/A
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05702	Perinatal Addition	In Service	5			4
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05703	Pedestrian Walkway	In Service	5			
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06062	Emergency Water Supply Pump Enclosure	Under Construction	5s			4s
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06105	Cooling Tower and Emergency Generator	Equipment Yard	N/A			2
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06106	Emergency Ambulance Canopy	In Service	5s			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01494	Phase 2	In Service	2		0.62	2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01495	Phase 1A3	Not an Independent Building	N/A			N/A
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01496	Central Plant	In Service	4			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01498	Phase 4 Building	In Service	3			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01499	Phase 5 Building	In Service	3			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01500	MRI Addition	In Service	4			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01501	Telecom Addition	In Service	4			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-03053	Parking Structure	In Service	5			2
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05250	Central Plant	In Service	5			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05251	Hospital Tower	In Service	5			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05512	Phase 3	In Service	2		0.52	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05564	Hospital Support Building	No Acute Care - OSHPD Bldg	N/A			N/A
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05602	Hospital Drop-off Canopy	No Acute Care - OSHPD Bldg	N/A			N/A
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05603	ED Drop-off Canopy	In Service	5			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05604	Loading Dock Storage	In Service	5			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05605	Central Plant Storage	In Service	5			4
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05606	Pedestrian Tunnel	Tunnels	5			4
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-05244	Main Hospital	In Service	5s			4s
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-05258	Central Utility Plant	In Service	5s			4s
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-01466	Building I	In Service	1	31.75	3.87	2
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-01467	Ambulance Canopy	In Service	4s			3
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05842	Building III (Patient Wing 5)	Under Construction	1s			2
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05843	Building IV (Support Services)	Under Construction	1s			2
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05844	Building V (Patient Wing 6)	Under Construction	1s			2
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05845	Building VI (Patient Wing 7)	Under Construction	1s			2
36 - San Bernardino	14102	Kindred Hospital Rancho	Rancho Cucamonga	BLD-03042	Original Building	In Service	5			2
36 - San Bernardino	14102	Kindred Hospital Rancho	Rancho Cucamonga	BLD-03043	Generator Enclosure	In Service	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01479	Main Hospital Tower - Area C	In Service	1		11.44	2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01480	Main Hospital Tower - Area B	In Service	2			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01481	Emergency Room Expansion - 1976	In Service	4			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01482	Northeast Wing - Schuman Pavilion	In Service	4			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01483	South Wing Phase 2	In Service	3			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01484	Emergency Room Expansion - 1987	Not an Independent Building	N/A			N/A
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01485	South Wing Phase I	In Service	3			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01486	Co-Generation Plant	In Service	4			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-02961	Chiller Facility	In Service	4			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03021	South Wing Phase I	In Service	3			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03022	South Wing Phase I	In Service	3			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03023	Main Hospital Tower - Area A	In Service	1		14.07	2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03024	South Wing Phase 2	In Service	3			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03025	Original Plant	In Service	1		7.34	2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05372	Utility Tunnel Expansion	Tunnels	N/A			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05373	Utility Tunnel	Tunnels	N/A			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05374	Cooling Tower	Not a Building Structure	N/A			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05375	Edison Yard	Equipment Yard	N/A			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05482	Emergency Generator Fuel Tank	Equipment Yard	N/A			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05488	South Tower Fuel Tank	Equipment Yard	N/A			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05489	South Tower Bulk Medical Gas	Equipment Yard	N/A			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05490	Emergency Generator	In Service	5			2
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05592	South Wing Tunnel Phase 1	Tunnels	N/A			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05878	New Replacement Hospital	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06022	Utility Tunnel – BLD 12B	Tunnels	N/A			4
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06028	Chiller Plant	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06032	CTP Generator Enclosure	Proposed	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06068	Unimed Switchgear	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06070	CTP Decontam Shower	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06071	CTP Loading Dock Canopy	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06072	CTP Entrance Canopy	Proposed	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06073	CTP Galleria	Proposed	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06074	CTP 7 & 8 Connector	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06075	CTP Grand Hallway Canopy	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06076	Schuman Addition	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06077	Schuman Bridge	Under Construction	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06395	Shop Canopy	Proposed	5s			4s
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06406	Bulk Medical Gas	Under Construction	N/A			
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01008	Hospital Ancillary	In Service	2	0.05		2
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01009	Nursing Wing	In Service	2	0.05		2
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01010	X-Ray Addition	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01011	Storage Addition	In Service	4s			2
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-02882	24 Bed Rehabilitation Hospital	In Service	5			4
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-03814	Telephone Building	In Service	2	0.09		2
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-05593	Mechanical Room	In Service	5			4
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-05793	24 Bed Rehabilitation Hospital - Covered Walkway	In Service	5			4
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-05939	OR Expansion	Under Construction	5s			4s
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	Redlands	BLD-05322	Heart and Surgical Hospital	In Service	5			4
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00963	Service Wing - Original Hospital	In Service	2	0.20		2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00965	Service Wing - Dining Room Addition	In Service	5s			2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00966	Service Wing - Medical Records Addition	In Service	5s			2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00967	North Wing - Original Hospital	In Service	2	0.20		2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00968	North Wing - Labor & Delivery Addition	In Service	5			2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00969	East Wing - Original Hospital	In Service	2	0.20		2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00970	Plant Services - Original Hospital	In Service	2	0.20		2
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-02737	Plant Services - Engineering Addition	In Service	5s			2
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01474	Main Building	In Service	2		3.73	1
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01475	Radiology/Lab and ER Addition	In Service	5			1
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01476	ER Addition	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01477	Emergency Generator Bldg	In Service	1			1
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01478	Oxygen Storage Bldg	In Service	1			1
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-03687	Emergency Generator Bldg II	In Service	5s			4s
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-05687	LOX Yard	Equipment Yard	N/A			4
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-06479	Skilled Nursing Building	Skilled Nursing Only	N/A			N/A
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01801	Original Main Hospital	In Service	2		0.96	2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01802	Part 1 Addition - Tower	In Service	2	0.30		2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01803	Part 2 Addition - Surgery	In Service	2	0.20		2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01804	Part 3 Addition - Admitting	In Service	2	0.27		2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01806	Central Plant	In Service	5			4
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01807	Radiology Addition	In Service	2		0.17	2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01808	Patient Tower	In Service	3			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01809	Central Supply	In Service	4			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01810	North Hallway	In Service	3			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01811	Radiotherapy Addition	In Service	5s			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01813	Emergency Building 2	In Service	4			4
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02812	Phase 2 Building Addition	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02813	1958 Radiology Building	In Service	2		0.77	2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02814	Electrical Utility Canopy	In Service	5			4
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-05892	Surgery Addition	Under Construction	5s			4s
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-05904	Oxygen Farm	Equipment Yard	N/A			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06299	Gift Shop Addition	Under Construction	5s			4s
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06327	North / South Utility Tunnel	Tunnels	N/A			2
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06328	East / West Utility Tunnel	Tunnels	N/A			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01833	Auditorium & Administration	In Service	2			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01834	Latimer Wing	In Service	2		1.16	2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01835	Maternity	Not an Independent Building	N/A			N/A
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01836	Power Plant	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01837	Laundry Building	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01838	Main Building	In Service	2	0.34		2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01839	Increment II, Phase 1 - East	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01840	Increment II	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01841	Maternity Addition	In Service	5			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01842	Mental Health - South	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01843	Increment II - Phase 2 East & Middle	In Service	3			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01844	Modular Unit	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01845	NICU Addition	In Service	5			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03020	Increment II - Phase 2 West Section	In Service	3			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03542	Mental Health - North	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03548	Increment II, Phase 1 - North	In Service	4			2
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-05253	Main Hospital Tower	In Service	5s			4s
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-05254	Central Plant	In Service	5s			4s
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06154	New Oxygen Service Area	Equipment Yard	N/A			4
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06377	East Canopy	In Service	5			4
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06378	West Canopy	In Service	5			4
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06385	Central Plant	In Service	5			4
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06386	Emergency Drive Canopy	In Service	3			3
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06387	Emergency Walkway Canopy	In Service	3			3
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01814	Main Hospital	In Service	1		36.74	2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01815	South Wing	No Acute Care - OSHPD Bldg	N/A	4.76		2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01816	Emergency Building	In Service	3s			3
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01817	Central Tower	In Service	1	4.22		2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01818	North Tower	In Service	3			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01819	Service Building	In Service	4			3
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01820	Ancillary Building	In Service	2	5.06	1.10	3
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-03363	Cooling Tower Yard	Equipment Yard	N/A			2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-05639	IT Services Building	In Service	5s			4s
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06229	CoGen Plant	Equipment Yard	N/A			
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06255	Loading Dock Canopy	In Service	1			2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06259	CCU Med Air and Vacuum Canopy	In Service	5s			2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06260	Medical Gas Canopy	Equipment Yard	N/A			2
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06287	Conference Center	In Service	3			3
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01821	Original Hospital & ER	In Service	2	0.53		2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01822	Transitional Care-CCU/ICU	In Service	2	0.09		2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01823	Combined W/Bldg1-Emergency Building	Not an Independent Building	N/A			N/A
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01824	Combined W/Bldg 2-CCU/ICU	Not an Independent Building	N/A			N/A
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01825	Boiler Building	In Service	2	0.13		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01826	Chiller Building	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01827	Surgery Addition	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01828	West Addition	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01829	East Wing	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01830	Obstetrics/Prenatal/LDR Addition	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01831	Medical/Surgical	In Service	4			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-01832	New Hospital Building	In Service	5			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-02928	MRI Building	In Service	2		0.79	3
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06087	Filter Building	In Service	5			2
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06088	South Building Connector	In Service	5			3
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06089	South Building West Canopy	In Service	5			3
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06090	South Building South Canopy	In Service	5			3
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06230	Inpatient MRI Building	In Service	5s			4s
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06404	Generator Yard	Under Construction	N/A			
36 - San Bernardino	10695	St. Mary Medical Center	Apple Valley	BLD-06405	Generator Distribution / Transfer Switch Building	Under Construction	5s			4s
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-04912	Subacute	Skilled Nursing Only	N/A			N/A
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-05483	Acute Care Building No. 1	In Service	5			4
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-05959	Emergency Generator	Equipment Yard	N/A			N/A
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-06126	Medical Gas Building	In Service	5s			4s
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-06127	Lighthouse Bulk Medical Gas Building	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01855	Medical / Surgical / Surgery Add	In Service	3			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01856	Radiology/Surgery/L&D/Emergency	In Service	2	2.18	0.27	2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01857	Equipment Shelter Pump House	In Service	2			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01858	Emergency Building	Not an Independent Building	N/A			N/A
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01859	Nursing Wing (BHU/PCU)	In Service	2	0.53		2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01860	Cath Lab/ICU/Outpatient Surgery	In Service	4			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01861	Emergency Generator Room	In Service	4			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01862	Urgent Care E.R. Expansion	In Service	3			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03131	O.B. Addition	Proposed	N/A			N/A
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03132	Canopy Addition	In Service	3s			2
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03134	Helistop	In Service	5			2
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-00935	Main Hospital	In Service	2	0.69		2
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-00936	Rehabilitation Hospital	Not an Independent Building	N/A			N/A
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-00937	Connecting Bridge	Not an Independent Building	N/A			N/A
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-00938	Service Building	In Service	2	0.15		2
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-00939	Fire Pump Building	In Service	4			2
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-03050	East Equipment Yard	Equipment Yard	N/A			2
37 - San Diego	12872	Alvarado Hospital Medical Center	San Diego	BLD-03453	ED Addition	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	16263	Alvarado Hospital Medical Center	San Diego	BLD-03910	Rehabilitation Hospital	In Service	4			2
37 - San Diego	16263	Alvarado Hospital Medical Center	San Diego	BLD-03911	Connecting Bridge	In Service	4			2
37 - San Diego	10024	Encompass Health Rehabilitation Hospital of Chula Vista	Chula Vista	BLD-06462	Support Building	Proposed	5s			4s
37 - San Diego	10024	Encompass Health Rehabilitation Hospital of Chula Vista	Chula Vista	BLD-06463	Patient Wing	Proposed	5s			4s
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02098	Emergency Generator Building	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02099	West Wing - West	In Service	2	0.12		2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02100	North Wing	In Service	2	0.03		2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02101	South Wing	In Service	2	0.09		2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02102	Central Plant & Cooling Plant Expansion	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02103	East Wing	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02104	Physical Rehabilitation Unit	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02105	Meeting Room Addition	In Service	3			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02622	Main Entry	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02829	Heart and Vascular Center	In Service	5			4
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02830	New Central Plant	In Service	5			4
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03678	Old Administration Building	In Service	2	0.00		2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03683	Womens Health Center	In Service	3			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03685	East Wing Addition	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03767	West Wing - East	In Service	2	0.09		2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03768	West Wing - North	In Service	2	0.15		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05312	Mental Health Building	Acute Psych Only	N/A			N/A
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05336	ED/CCU and ACNU Building	In Service	5			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05368	Physical Rehabilitation Utility Vault	In Service	4s			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05510	MRI / Angio Addition	In Service	4			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05678	Utility Tunnel	Tunnels	N/A			2
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05764	Emergency Generator 1	Not a Building Structure	N/A			4
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05765	Emergency Generator 2	Not a Building Structure	N/A			4
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-02943	Hospital	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-03552	Central Utility Plant	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-05690	Hospital Support Building	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06311	Main Entrance Canopy	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06312	Emergency Entry Canopy	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06313	Fire Pump Room	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06314	Tech Dock Canopy - Lower	In Service	5			5
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06315	Tech Dock Canopy - Upper	In Service	5			5
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00198	Hospital Tower	In Service	2			2
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00199	Hospital Tower Addition	In Service	3s			2
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00200	Clinic Tower Addition	In Service	3s			2
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00201	Central Plant	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00202	Emergency Generator Building	In Service	4			2
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00203	Cooling Tower	Not a Building Structure	N/A			2
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-03295	Med Gas Chain Link Fence Enclosure	In Service	5			4
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02106	Building I (Building A)	In Service	2			2
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02107	Building II (Building B)	In Service	2	0.67		2
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02108	Building III (Building C)	In Service	2	0.03		2
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02109	Building IV (Building D)	In Service	4			2
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02110	Building V (Building E)	In Service	4			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02126	McLeod Tower	In Service	2	0.17		2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02127	McLeod Tower East Extension	In Service	2	0.10		2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02128	Adams Wing	In Service	2	0.13		2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02129	West Wing	In Service	4s			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02130	South Wing	In Service	4s			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02131	Co-Generation Plant	In Service	4			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02761	Parking Garage with Helistop	In Service	2			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02762	Medical Records & Tumor Registry	In Service	4s			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02763	Linear Accelerator	Not an Independent Building	N/A			N/A
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02765	Rad Therapy Add/Linear Accelerator	In Service	4			2
37 - San Diego	12347	Palomar Health Downtown Campus	Escondido	BLD-02766	Cafeteria	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-05231	Hospital	In Service	5s			4s
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-05232	Central Plant	In Service	5s			4s
37 - San Diego	18230	Palomar Rehabilitation Institute	Escondido	BLD-06258	Palomar Rehabilitation Institute	Proposed	5s			4s
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02132	Main Tower	In Service	2	0.12		2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02133	West Wing	In Service	2	0.54		2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02134	East Wing	In Service	4			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02135	ER Expansion	In Service	4			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02136	Boiler Building	In Service	4			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02137	Pediatrics Wing	In Service	5s			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02138	Chiller Building	In Service	5s			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02139	Generator Building	In Service	5s			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02140	Medical Office Building	In Service	3s			2
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02141	Storage Building - BLD-06432 at 24384	Not an Independent Building	N/A	0.89		N/A
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-00255	Patient Tower	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-00256	Ancillary Building (East)	In Service	4s			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-00257	Central Plant	In Service	4			4
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-00258	Angio / Cath Lab Addition	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-00259	Emergency Room Addition	In Service	5			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-02896	Co-Generation Building	In Service	4			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03240	Entrance Canopy	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03241	Pedestrian Link	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03588	Villa Pomerado	Skilled Nursing Only	N/A			
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03589	Steam Plant	Equipment Yard	N/A			4
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03592	Patient Elevator Tower	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-03593	Lobby	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-06245	Ancillary Building (West)	In Service	4s			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-06246	Loading Dock/Electrical Room	In Service	4			2
37 - San Diego	14190	Pomerado Hospital	Poway	BLD-06451	Power Conditioning UPS/ATS Building	Proposed	5s			4s
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02063	Medical Wing - Original Hospital	In Service	2			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02066	Dining Room - Original Hospital	In Service	2	0.16		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02067	Gait Lab	In Service	2	0.05		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02068	Warehouse/Shop	In Service	2	0.02		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02069	Old Gait Analysis Lab	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02070	2nd Dining Room - Original Hospital	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02071	Intensive Care Unit	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02072	Co-Generation Plant	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02073	Clinical Lab	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02074	Medical Nursing Unit Expansion	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02076	Radiology Addition	In Service	3			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02079	Children's Way Pavilion (15A & 15B)	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02080	Children's Way Pavilion - Clock Tower	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02669	Surgical Unit	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02770	Gas Storage Building	Equipment Yard	N/A			4
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02772	Bridge to Acute Care Pavilion	In Service	5			4
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-02773	Emergency Generator Building	In Service	5			4
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03125	"A" Wing, Original Hospital	In Service	2	0.29		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03126	"B" Wing, Original Hospital	In Service	2	0.12		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03127	"C" Wing - Original Hospital	In Service	2	0.16		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03128	"D" Wing - Original Hospital	In Service	2	0.07		3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03129	Bridge to Sharp Hospital	Not an Independent Building	N/A			N/A
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03130	Trauma Room Addition	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03195	Intensive Care Unit	In Service	4			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03197	Passageway to NICU	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03198	Children's Way Pavilion - Bridge	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03199	Enclosed Passageway to MOB	In Service	3			3
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03647	Acute Care Pavilion	In Service	5			4
37 - San Diego	12285	Rady Children's Hospital - San Diego	San Diego	BLD-03896	Hahn Pavilion Loading Dock Canopy	In Service	3			3
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00250	Original Building - Phase I North Wing	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00251	Original Building - Phase I South Wing	In Service	4			2
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00253	Dining and Kitchen Addition	In Service	4			2
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00254	Storage & Maintenance Building	In Service	4			2
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-02662	Heart, Lung, Vascular Center	In Service	3s			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02085	Wood Building	In Service	2	0.02		2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02086	Masonry Building	In Service	2	0.60		2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02088	OSA Building	In Service	4			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02089	East Wing Addition - North	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02090	Emergency Room Addition	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02091	ICU Addition	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02586	Loading Dock	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03553	Central Energy Plant Service Yard	Equipment Yard	N/A			5
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03673	East Wing Addition - South	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03674	East Wing Addition - Center	In Service	3			2
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-05299	Critical Care Building	In Service	5			5
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-05301	Central Energy Plant	In Service	5			5
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01118	Building 1-3-4	In Service	2	0.57		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01119	Building 1-A	In Service	2	0.03		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01120	West Tower	In Service	2	0.23		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01121	Transition Tower (& 5A)	In Service	2	4.61	0.07	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01122	Addition to Women's Center	Not an Independent Building	N/A			N/A
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01123	East Tower	In Service	2	0.14		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01124	Building 7	In Service	2	0.05		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01125	Service Building (8, 8A, 8B)	In Service	2	2.81		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01126	Co-Generation Plant	In Service	4			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01127	Building 10	In Service	3s			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01128	Emergency Expansion	In Service	3s			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01129	Building 6A	In Service	2	0.44		2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02583	Dining Area Addition	In Service	3s			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02584	Mericos Building	In Service	3s			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02585	Outpatient Waiting Room	In Service	3s			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03051	Building 10A	In Service	4			2
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03549	Scripps Clinic La Jolla Medical Office Building	Clinic - Local Jurisdiction	N/A			
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03550	Emergency Department Canopy	In Service	5s			4s
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03551	Prebys Cardiovascular Institute Pedestrian Walkway	In Service	5			5
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-05266	Prebys Cardiovascular Institute	In Service	5			5
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-05267	Central Energy Plant	In Service	5			5
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-06436	New Tower	Proposed	5s			4s
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02114	Main Hospital Tower	In Service	2			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02115	Main Hospital Wing	In Service	2	0.13		2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02116	ICU Building	In Service	2	0.18		2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02119	ICU Addition	In Service	2	0.21		2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02120	Elevator Tower	Acute Psych Only	N/A			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02121	Ambulatory Addition	In Service	3			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02122	Ambulatory Add - Elevator Tower	In Service	3			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02123	Ambulatory Addition	In Service	3			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02124	Ambulatory Addition	Not an Independent Building	N/A			N/A
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02589	Mechanical Tunnel	Tunnels	N/A			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03543	Central Energy Plant	In Service	5			4
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03545	Canopy 1	In Service	5			4
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03546	Canopy 2	In Service	5			4
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03547	Canopy 3	In Service	5			4
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03712	Ambulatory Add - Canopy	In Service	3			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03713	Ambulatory Add - East Stair Add	In Service	3			2
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-05637	Emergency Department Addition	In Service	5			4
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-05638	Replacement Stair	Not an Independent Building	N/A			N/A
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06492	Replacement Hospital	Proposed	5s			4s
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06493	New Canopy 1	Proposed	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06494	New Canopy 2	Proposed	5s			4s
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02055	Original Building	In Service	2	0.34		2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02056	Tower Addition	In Service	2	0.16		2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02057	Emergency Room Addition	In Service	4			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02058	Hospital Expansion	In Service	5			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02060	Hospital Expansion - Emergency Dept	In Service	5			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02061	Mechanical Building	In Service	5			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03044	Hospital Expansion - Lobby	In Service	5			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03045	Hospital Expansion - ICU	In Service	5			2
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03842	Connector Building	Not an Independent Building	N/A	0.14		N/A
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03874	Modular Cath Lab	In Service	5			4
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03875	Cath Lab Canopy	In Service	5			4
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00227	East Tower - North Portion	In Service	2	0.03		2
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00228	East Tower - South Portion	In Service	2	0.56		2
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00229	West Tower - Lobby	In Service	5			2
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00230	Cardiac Operating Room Addition	In Service	4			2
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02717	West Tower - Administrative Wing	In Service	4			2
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02718	Emergency Generator Building	In Service	5			4
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02719	West Tower - Tower	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02828	Ocean View Tower	Under Construction	5s			4s
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05673	Entry Building	Under Construction	5s			4s
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05674	Chiller Plant	In Service	5s			4s
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05969	Birch Patrick Convalescent Center	Skilled Nursing Only	N/A			N/A
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06011	Loading Dock Canopy	In Service	5s			4s
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06238	Bulk O2 Yard	Under Construction	N/A			
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06394	Gas Bottle Storage	Not a Building Structure	N/A			4
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02081	Main Tower	In Service	2	0.22		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02082	ICU Building	In Service	2	0.07		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02083	Ancillary Building	In Service	2	0.07		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02827	Prospect Place Canopy	In Service	5s			4s
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03680	Morgue Building	In Service	2	0.08		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03681	Long Term Care Building	In Service	4D	0.08		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03682	Sub Acute Care II Building	In Service	2	0.02		2
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03895	Skilled Nursing Facility	Not an Independent Building	N/A			N/A
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-03892	Mary Birch Womens Center	In Service	3			2
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-03893	Corridor 1 - North	Not an Independent Building	N/A			N/A
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-03894	Corridor 1 - South	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01130	North Tower - East Building	In Service	2	0.05		2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01131	North Tower - Central Building	In Service	2			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01132	North Tower - West Building	In Service	2	0.16		2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01133	Inter-Hospital Passageway	In Service	2			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01134	South Tower	In Service	2	1.69	0.56	2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01135	Rehabilitation Center	In Service	3			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01136	Emergency / Radiology	In Service	2	0.04		2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01137	Dietary Building	In Service	2	0.06		2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01138	Service Building	In Service	2	0.23		2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01139	Long Term Care Building	In Service	2	0.76	0.76	2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01140	MRI Building	In Service	3			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01141	Mary Birch Womens Center	Not an Independent Building	N/A			N/A
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01142	New Central Plant	In Service	3			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-02835	New Acute Care Tower (Stephen Birch West Tower)	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-02836	Stephen Birch East Tower	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03753	Corridor 1 - North	In Service	2		0.54	2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03754	Corridor 1 - South	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03755	Corridor 2 - North	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03756	Corridor 2 - Middle	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03757	Corridor 2 - South	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03758	Corridor 2 - Long Term Care	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05526	Passageway Link	In Service	2		4.20	2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05527	Telephone Switch Building	In Service	5			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05534	Corridor 1 - North Segment B	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05535	Corridor 1 - North Segment C	In Service	4			2
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05540	Kitchen / Pharmacy Storage Building	Not an Independent Building	N/A		1.38	N/A
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05550	Outpatient Pavilion	Outpatient Only	N/A			
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05975	Emergency Canopy	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05976	Parking Structure Canopy	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05977	East Entrance Canopy	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05978	Main Front Canopy	In Service	5			4
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05979	Lower Level SB Connector	In Service	5			4
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01143	Center Tower	In Service	2	0.57		2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01144	North Wing	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01145	Center Complex - North	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01146	South Tower	In Service	2	0.71		2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01147	Electrical Building	In Service	4s			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01148	1976 Center Complex Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01149	Materials/Laboratory Building	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01150	1976 Radiology Addition	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01151	Emergency Room Addition	In Service	3			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01152	Administration Building	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01153	Pavilion Building Canopy	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01154	Pavilion Building	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01155	Ancillary Building	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02868	South Tower Stair Shaft	In Service	2		0.12	2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02869	Electrical Building Addition	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02870	Emergency Room Addition Canopy	In Service	3			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02871	Perinatal Unit/Women's Center	In Service	4s			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02872	Perinatal Unit/Women's Center Canopy 1	In Service	4s			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02873	Perinatal Unit/Women's Center Canopy 2	Not an Independent Building	N/A			N/A
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02874	Perinatal Unit/Women's Center Canopy 3	In Service	4s			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02875	Surgery Addition 1	In Service	3			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02876	Surgery Addition 2	In Service	3			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02877	Surgery Addition Canopy	In Service	3			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02878	Central Plant	In Service	4			2
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-03766	Center Complex - South	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-05487	Behavioral Health Unit	Acute Psych Only	N/A			N/A
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02142	Main Hospital Building	In Service	2			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02143	Ancillary & Support Services Facility	In Service	3			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02144	West Wing & Psychiatric Inpatient	Acute Psych Only	N/A			N/A
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02145	Central Plant	Not an Independent Building	N/A			N/A
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02146	Utility Line Bridge	In Service	2		0.71	2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02147	Telecommunications	In Service	5			4
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02148	Outpatient Clinic	In Service	2			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03304	Boiler House and Shops	In Service	4			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03853	OR Suite Expansion	In Service	4			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03854	Delivery / Surgery Expansion	In Service	4			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05175	Utility Line Bridge - South	In Service	2		1.14	2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05560	Chiller Building	In Service	5			2
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05846	Emergency Generator Building	In Service	5			4
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-02561	Main Hospital	In Service	3			4
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-02846	Main Hospital	In Service	3			4
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05315	UCSD Sulpizio Family Cardiovascular Center	In Service	5s			4s
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05419	Central Plant	In Service	5s			4s
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05420	Bed Tower	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05974	Emergency Preparedness Supplies Building	In Service	5s			4s
37 - San Diego	16703	Vibra Hospital of San Diego	San Diego	BLD-00292	Hospital and M.O.B.	In Service	3			2
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01108	East Wing	In Service	1		20.03	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01109	Building B	In Service	1		16.50	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01110	Building H	In Service	3s			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01111	Building A	In Service	1		27.10	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01112	Building A - Emergency Generator Building	In Service	4			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01113	NBICU	In Service	3			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01114	North Wing	In Service	1		32.71	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-01116	Boiler Room	In Service	1		2.16	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-02976	Outpatient Research Building	In Service	1		17.13	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05350	Radiation Therapy Building	In Service	1		6.54	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05383	Freight Elevator Building	In Service	4			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05384	Mechanical Room	In Service	4			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05385	Powerhouse	Not an Independent Building	N/A			N/A
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05386	Electrical Room	In Service	2		0.39	1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05387	NBICU Addition	In Service	3s			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-05388	Oxygen Tank	Equipment Yard	N/A			1
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-06121	North Wing (Building A)	Delicensed Clinic under OSHPD	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-06122	South Wing (Building B)	Delicensed Clinic under OSHPD	N/A			N/A
38 - San Francisco	12404	California Pacific Medical Center - California West Campus Hospital	San Francisco	BLD-06123	Center for Geriatrics Parking	Delicensed Clinic under OSHPD	N/A			N/A
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01100	North Tower	In Service	2			2
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01101	Link Building	In Service	1		7.99	2
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01102	South Tower	In Service	1		8.13	2
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01103	Rehabilitation Building	In Service	2		0.18	2
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01104	Emergency Systems Additions	In Service	5			2
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01105	MER Building	In Service	3			2
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	San Francisco	BLD-03810	New Hospital	Under Construction	5s			4s
38 - San Francisco	12482	California Pacific Medical Center - Pacific Campus Hospital	San Francisco	BLD-01017	Main Hospital	In Service	1		14.36	1
38 - San Francisco	12482	California Pacific Medical Center - Pacific Campus Hospital	San Francisco	BLD-01018	1965 Mental Health	Acute Psych Only	N/A			1
38 - San Francisco	18165	California Pacific Medical Center - Van Ness Campus	San Francisco	BLD-03801	New Acute Care Hospital	Under Construction	5s			4s
38 - San Francisco	14621	Chinese Hospital	San Francisco	BLD-00316	Comprehensive Health Care Building	In Service	3			2
38 - San Francisco	14621	Chinese Hospital	San Francisco	BLD-05688	Patient Tower	Under Construction	5s			4s
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01093	Main Hospital	In Service	2			2
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01094	East Wing	In Service	2			2
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01095	North Wing	In Service	4			2
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01096	MEE Building	In Service	4			2
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01097	Doctor's Sleep Annex	In Service	2			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-01089	Clarendon Hall	Skilled Nursing Only	N/A			1
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-01090	Clarendon Hall Additions	Skilled Nursing Only	N/A			1
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-03809	South Residence	In Service	5			4
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05918	North Residence	In Service	5			4
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05919	Pavilion Building	In Service	5s			4s
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05920	Generator Building	In Service	5s			4s
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01069	Main Hospital	In Service	1	14.47		2
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01070	M Wing	In Service	1			2
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01071	Service Building	In Service	5			2
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-03339	Replacement Hospital	In Service	5			4
38 - San Francisco	12457	Saint Francis Memorial Hospital	San Francisco	BLD-01079	Main Tower	In Service	2	1.25	1.15	2
38 - San Francisco	12457	Saint Francis Memorial Hospital	San Francisco	BLD-01080	1958 Building	In Service	2			2
38 - San Francisco	12457	Saint Francis Memorial Hospital	San Francisco	BLD-01081	Pierotti Pavilion	In Service	3s			2
38 - San Francisco	12460	St. Mary's Medical Center	San Francisco	BLD-01072	Main Tower	In Service	2	1.18	0.64	3
38 - San Francisco	12460	St. Mary's Medical Center	San Francisco	BLD-01073	McAuley Wing	In Service	2	17.37	0.90	2
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01012	Moffitt Hospital	In Service	2			3
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01013	Long Hospital	In Service	3			3
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01014	Emergency Entrance Structure	In Service	3			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01015	Magnetic Resonance Imaging Building	In Service	4			3
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01016	Central Utilities Plant	In Service	4			3
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	San Francisco	BLD-05445	UCSF Benioff Children's Hospital	In Service	5s			4s
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	San Francisco	BLD-05523	Energy Center	In Service	5			4
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01082	Building A	In Service	2			2
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01083	Building B	In Service	2			2
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01084	Building D	Not an Independent Building	N/A			N/A
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01085	Building R	In Service	4			2
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01876	Central (Main)/East Wing	In Service	2	0.05		2
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01877	West Wing	In Service	2	0.04		2
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01878	Central Plant	In Service	4s			4
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01879	North Wing	In Service	4			2
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01880	Emergency Addition	In Service	4s			2
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-02864	New Patient Tower	In Service	5s			4s
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-03624	New Central Plant	In Service	5			4
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01863	1987 Building - 87-A	In Service	4			2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01864	1987 Building - 87-B	In Service	4			2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01865	1975 Building - 75-A	In Service	4			2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01866	1967 Building - 67-A	In Service	2	0.12		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01867	1964 Building - 64-A	In Service	2		0.26	2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01868	1957 Building - 57-A	Not an Independent Building	N/A			N/A
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01869	Generator Building - Fuel Tank	Equipment Yard	N/A			
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01870	Generator Building - Cooling Tower	Not a Building Structure	N/A			
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01871	1932 Building - 32-A	In Service	2		0.97	2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-03615	Generator Building	In Service	5s			2
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-05397	Generator Building - Bulk Oxygen	Equipment Yard	N/A			
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01881	Main Hospital & Additions	In Service	2	0.00		2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01882	Outpatient/Administration	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01883	OR Addition/Meeting Room	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01884	East Patient Tower	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01885	Purchasing	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01886	Telephone Equipment Building	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01887	ER Addition	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01888	X-Ray Addition	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01889	Ultrasound/Storage	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01890	CT Scan	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01891	OB Addition	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01892	Mechanical Equip. Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01893	Entrance Canopy	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01894	OR Addition	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01895	LDR Addition	In Service	5			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01896	Mechanical Equip. Building	In Service	4			2
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01897	Freezer	Not an Independent Building	N/A			N/A
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-05831	Central Utility Plant	Under Construction	5s			4s
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00065	East Wing	In Service	4			2
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00066	West Wing	In Service	4			2
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00067	Tower	In Service	4			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01911	Main Hospital Building	In Service	4			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01912	Central Plant	In Service	5			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01913	OPD Building / Conference Center / Admin Wing	In Service	2		0.61	2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01914	OPD Emergency Generator Shed	In Service	1		2.97	2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01915	Dietary Building	In Service	2		0.27	2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01917	A & B Wings	In Service	1		3.47	2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03035	Loading Dock	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03171	Clinical Laboratory	In Service	5s			4s
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03172	Area F	Under Construction	5s			4s
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03726	Compacter / Sterilizer / Baler	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03727	Connecting Link - Part 1 - North	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03728	Connecting Link - Part 2 - North	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03729	Area D	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03730	Area E	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03731	Main Hospital Canopy	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03732	Connecting Link - Part 1 - West	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03733	Connecting Bridge - Part 1 - West	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03734	Connecting Bridge - Pylon	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03735	Connecting Link - Part 2 - West	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03736	Connecting Bridge - Part 2 - West	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03737	Connecting Bridge - Pylon 2	In Service	4s			2
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03738	Connecting Link - Part 3 - West	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01898	Main Wing	No Acute Care - OSHPD Bldg	N/A			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01899	North Wing	In Service	2	0.01		2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01900	South Wing	In Service	2	0.18		2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01901	West Wing	In Service	2	2.35	0.24	2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01902	East Wing	In Service	2			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01903	Administrative Wing	In Service	2			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01904	Southeast Wing	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01905	Cafeteria	In Service	4			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01906	Heart Center	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01907	Outpatient Surgery Building	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01908	Cancer Center	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01909	Hospital Main Entrance	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03367	Women & Children's Pavilion Building	In Service	5			4
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03369	LOX Yard	Equipment Yard	N/A			4
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03370	New Generator Building	In Service	5			4
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03371	Pedestrian Corridor	In Service	5			4
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03492	Elevator Addition	In Service	2	0.32		2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03493	Kitchen Remodel 1	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03494	Kitchen Remodel 2	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03495	Material Management Building	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03496	Utility Plant	In Service	4s			2
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03575	Generator Enclosure for Women and Children's Pavilion Building	Equipment Yard	N/A			4
39 - San Joaquin	18232	Stockton Rehabilitation Hospital	Stockton	BLD-06280	Stockton Rehabilitation Hospital	Proposed	5s			4s
39 - San Joaquin	18232	Stockton Rehabilitation Hospital	Stockton	BLD-06282	LOX Tank	Proposed	N/A			
39 - San Joaquin	18232	Stockton Rehabilitation Hospital	Stockton	BLD-06319	Porte Cochere	Proposed	5s			4s
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01918	Original Hospital Building / Additions	In Service	2	0.14		2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01919	Building Block No. 2	In Service	2	0.11		2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01920	1976 Alterations & Additions	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01921	Two Story Addition West	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03046	Mechanical Building	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03075	Central Plant	In Service	5			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03200	North Canopy	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03345	Northwest Canopy	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03346	One Story Addition	In Service	4			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03347	Northeast Canopy	In Service	4			3
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03348	West Canopy	In Service	4			3
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03903	Ambulatory Care Entrance Corridor	In Service	5			2
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03904	Ambulatory Care Addition	In Service	5			2
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00955	Main Hospital	In Service	2	0.00		2
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00956	Cath Lab Addition	In Service	4			2
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00957	Surgery Addition	In Service	4s			2
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-03600	Mechanical Building	In Service	4			2
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-05622	Electrical Room	In Service	5s			4s
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06242	Emergency Department Addition	Under Construction	5s			4s
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06458	Patient Tower Addition	Proposed	5s			4s
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06459	Canopy Addition	Proposed	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01922	Canopy	In Service	4			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01923	Kitchen Addition	In Service	5			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01924	Central Supply	In Service	4			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01925	Skilled Nursing	In Service	4			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01926	Corridor	In Service	3			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01927	Critical Care Unit	In Service	4			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01928	Corridor	In Service	3			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01929	Surgery, Emergency, Food Service	In Service	3			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01930	Canopy	In Service	3			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01931	Main Entrance	In Service	3			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01932	Storage and Service	In Service	4			2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01933	Nursing Unit, Admin, Laboratory	In Service	2	0.48		2
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-03310	Emergency Department Expansion	Under Construction	5s			4s
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-03312	Acute Rehab	In Service	5			4
40 - San Luis Obispo	10778	Sierra Vista Regional Medical Center	San Luis Obispo	BLD-00839	Main Hospital and Additions	In Service	2	0.37		2
40 - San Luis Obispo	10778	Sierra Vista Regional Medical Center	San Luis Obispo	BLD-00840	Patient Tower	In Service	2	0.01		2
40 - San Luis Obispo	10778	Sierra Vista Regional Medical Center	San Luis Obispo	BLD-00841	West Wing	In Service	3			2
40 - San Luis Obispo	10778	Sierra Vista Regional Medical Center	San Luis Obispo	BLD-00842	E. R. Addition	In Service	4			2
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-00241	Main Hospital	In Service	4			2
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-00242	Radiology Addition/Cath Lab	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-00243	E.R. Room	In Service	4			2
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-00244	Administrative Addition	In Service	4			2
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-03458	Diagnostic & Treatment Expansion	In Service	5			4
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-03459	West Nurse Addition	In Service	5			4
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-03460	Support Service Building	In Service	5			4
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-03461	Patient Tower Addition	In Service	5			4
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-05966	Entry Canopy	In Service	5			4
40 - San Luis Obispo	13999	Twin Cities Community Hospital	Templeton	BLD-05967	Main Entry Canopy	In Service	5			4
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-03280	Central Plant	In Service	5s			4s
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-05277	Replacement Hospital	In Service	5s			4s
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06063	Hospital	Delicensed Clinic under OSHPD	N/A			
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06064	Service Building 1	Delicensed Clinic under OSHPD	N/A			
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06065	Service Building 2	Delicensed Clinic under OSHPD	N/A			
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06066	Service Building 3	Delicensed Clinic under OSHPD	N/A			
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06356	Medical Office Building 2	Clinic - Local Jurisdiction	N/A			N/A
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00177	Hospital - Building 1	In Service	2	0.45		2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00178	Hospital - Building 2	In Service	2	0.45		2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00179	Hospital Tower - Building 3	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00180	Hospital - Building 4	In Service	2	0.61		2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00181	Hospital - Building 5	In Service	4D	0.61		2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00182	Hospital - Building 6	In Service	2	0.45		2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00183	Hospital - Building 7.1	In Service	3			2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00184	Hospital - Building 8	In Service	3			2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00185	Hospital - Building 9	In Service	3			2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03106	Ancillary Building	Not an Independent Building	N/A			N/A
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03475	Hospital - Building 6 Canopy	In Service	2			4
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03476	Hospital - Building 7.3	Not an Independent Building	N/A			N/A
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03477	Hospital - Building 7.2 Exhaust Hood	In Service	4			2
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-06030	Chiller Canopy	In Service	5s			4s
41 - San Mateo	16836	Menlo Park Surgical Hospital	Menlo Park	BLD-00024	Recovery Inn Acute Care Hospital	In Service	5			3
41 - San Mateo	10804	Mills-Peninsula Medical Center	Burlingame	BLD-03217	New Hospital	In Service	5s			4s
41 - San Mateo	10804	Mills-Peninsula Medical Center	Burlingame	BLD-03648	Walkway Canopy for Mobile CT Trailer	Under Construction	5s			4s
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00854	Original Hospital	In Service	2		0.98	2
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00856	Central Plant	In Service	5			4
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00857	Nursing Wing	In Service	5s			2
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00858	Nursing Wing Link	In Service	5s			2
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00859	North Addition	In Service	5s			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-02636	Diagnostic and Treatment Center	In Service	5			4
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-03317	1958 Building	Not an Independent Building	N/A			N/A
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-05788	Original Hospital - B1	In Service	2		0.54	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-05789	Original Hospital - B2	In Service	2		0.83	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-05792	Emergency Department Renovation and Addition (1988 Addition)	In Service	4			2
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00860	Building 1	In Service	2			3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00861	Building 2	In Service	2			3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00862	Building 3	In Service	2	1.39		3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00863	Building 4	In Service	2			3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00864	Building 5	In Service	2		0.81	3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00865	Building 6, 8, 9 and 10	In Service	2		1.00	3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00866	Building 7	In Service	2			3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05198	Building 1A	In Service	2			3
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05233	Pavilion	In Service	5			4
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05234	Dining Room	In Service	5			4
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00846	1963 Tower	In Service	1	2.29		2
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00847	Front Wing	In Service	1	2.24		3
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00848	Area A & B	In Service	3			2
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00849	Area C	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00850	Area D	In Service	3			2
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00851	Center Pod	In Service	3			3
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00852	South Pod	In Service	3			3
41 - San Mateo	10801	Seton Medical Center	Daly City	BLD-00853	Utilities Service Building	In Service	4			2
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01022	Hospital Building	In Service	2			3
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01023	Locker Building	In Service	5			4
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01024	Administration Building	In Service	5			4
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-02677	Breezeway Building	In Service	5			4
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-02678	Office Infill Building	In Service	5			4
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-03218	East Building	In Service	5			4
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05365	Bulk Oxygen Storage	Equipment Yard	N/A			4
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05935	Lobby	In Service	5			4
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05936	West Building	In Service	5			4
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05937	Porte Cochere	In Service	5			4
42 - Santa Barbara	10836	Lompoc Valley Medical Center	Lompoc	BLD-03028	Replacement Facility	In Service	5s			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00878	Main Hospital	In Service	2	0.43		2
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00879	Surgery Addition	In Service	3			2
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00881	Central Plant II - 1993	In Service	5			2
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00882	ER/CCU/Radiology Addition	In Service	4			2
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00883	Laboratory Addition	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-03385	Mechanical / Electrical Room Addition	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-03386	New Hospital Expansion	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05455	New Hospital Expansion - Section J	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05456	New Hospital Expansion - Section K	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05457	New Hospital Expansion - Main Entry Canopy	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05458	New Hospital Expansion - Emergency Department Entry Canopy	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05459	New Hospital Expansion - Ambulance Entry Canopy	In Service	5			4
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05623	Breezeway	In Service	5s			4s
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05994	Extended Care Center - Main Building	Skilled Nursing Only	N/A			N/A
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05996	Extended Care Center - Colonnade	Skilled Nursing Only	N/A			N/A
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05997	Extended Care Center - Adult Day Care	Skilled Nursing Only	N/A			N/A
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05998	Extended Care Center - Child Day Care	Skilled Nursing Only	N/A			N/A
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-06180	Extended Care Center - Day Care Connector	Skilled Nursing Only	N/A			N/A
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00901	South Wing (Building D) (Pueblo Pavilion)	In Service	2		0.93	2
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00902	East Wing (Building E) (Bath Pavilion)	In Service	2	0.58		3
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00904	Surgery Wing (Building G)	In Service	4			3
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00905	Building H	Not an Independent Building	N/A			N/A
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00906	Centennial Wing (Building I) (Arlington Pavilion)	In Service	4			2
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00907	Cancer Center (Building K)	In Service	5s			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05285	D & T Building (Junipero Pavilion)	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05286	D & T "B"	Not an Independent Building	N/A			N/A
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05287	Pavilion E (Wood-Claeysens Pavilion)	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05288	Pavilion F (Ridley-Tree Pavilion)	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05289	New Central Plant	In Service	5			4
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05292	Medical Gas Yard	Under Construction	N/A			
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06007	Knapp Building	Clinic - Local Jurisdiction	N/A			N/A
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06021	Link Building	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06402	Pavilion D (Compton Pavilion)	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06403	Treatment Pavilion (Arlington Pavilion)	Under Construction	5s			4s
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06447	Surgery Center of Santa Barbara	Clinic - Local Jurisdiction	N/A			N/A
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-00896	Hospital Building	In Service	2			2
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-00897	Emergency Services Building	In Service	4			4
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-03256	Patient Unit and Radiology Department	In Service	5			4
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05972	Emergency Entrance Porte Cochere (Entry Canopy)	In Service	5			4
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05973	Lobby Porte Cochere	In Service	5			4
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05980	CT Scanner Building	No Acute Care - OSHPD Bldg	N/A			
43 - Santa Clara	16713	Children's Healthcare Organization of Northern California - Pediatric Hospital	Campbell	BLD-03912	Main Building	In Service	5			2
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02254	1 - Orchard Pavilion	In Service	3s			1

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02255	2 - Willow Pavilion	In Service	3			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02256	4 - Laundry & Laboratory Addition	No Acute Care - OSHPD Bldg	N/A			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02257	5 - Unit A Expansion	No Acute Care - OSHPD Bldg	N/A			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02260	8 - Surgical Wing	No Acute Care - OSHPD Bldg	N/A			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02261	9 - Original Hospital	No Acute Care - OSHPD Bldg	N/A			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02262	10 - Central Plant	In Service	3s			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02263	11 - Psychiatric Wings	Acute Psych Only	N/A			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02264	13a - South Addition	Not an Independent Building	N/A			N/A
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-02265	14 - South Addition	Not an Independent Building	N/A			N/A
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-03529	12 - Psychiatric Wings	Not an Independent Building	N/A			N/A
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-03535	10 - Central Plant - Switchgear	In Service	5			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-03536	10 - Central Plant - Substation	In Service	5			1
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-03577	Slot Building	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-03578	New Main Hospital Building (West)	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05491	Make Ready Canopy	No Acute Care - OSHPD Bldg	N/A			
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05794	Behavioral Health Building	Under Construction	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05795	Behavioral Health Building - Entrance Canopy	Under Construction	N/A			
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05797	Utility Tunnel (East-West)	Tunnels	N/A			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05962	New Main Hospital/Women's Hospital Connector	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05963	New Main Hospital SE Vestibule	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05964	New Main Hospital SE Canopy	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-05965	New Main Hospital SW Canopy	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-06083	New Main Hospital Building - East	In Service	5			4
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-06084	North-South Utility Tunnel	Tunnels	N/A			
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-06085	New Main Hospital/Women's Hospital Tunnel	Tunnels	5s			4s
43 - Santa Clara	10883	El Camino Hospital	Mountain View	BLD-06086	New Main Hospital / Willow Pavilion Tunnel	Tunnels	5s			4s
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02243	Original Building / Outpatient	In Service	2	1.56	0.98	3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02244	Generator Building	In Service	2	1.24	0.92	3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02245	Unit 2 Addition / CCU Building	In Service	2	0.91	0.91	2
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02246	Surgery / Medical Center	In Service	2			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02247	Administration Building	In Service	2	0.22		3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02248	ICU Building	In Service	2			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02249	Emergency	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02250	Endoscopy	In Service	5			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02251	Entrance Canopy	In Service	5			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02252	O.B. Gyn / Cancer Center	In Service	2	0.13		3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03692	Rehabilitation Center	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03693	Emergency Generator Building	In Service	2	0.07		3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03694	Rehab Center Addition 1	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03695	Rehab Center Addition 2	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03821	Back-of-house addition (freezer)	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03822	Back-of-house Facility	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03823	Ambulatory Surgery Holding	In Service	4			3
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03824	Switch Gear Building	In Service	5			4
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-02267	Main Building	In Service	2			3
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-02268	MRI Building	In Service	3			3
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03445	Women's & Children's Center	In Service	5			4
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03446	Connection	In Service	5			4
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03447	Central Plant	In Service	5			4
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03448	Main Entrance Canopy	In Service	5			4
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	San Jose	BLD-00954	Hospital	In Service	2	0.59		3
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	San Jose	BLD-03599	ED Expansion	In Service	5s			4s
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-03701	Hospital - Phase I	In Service	5s			4
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-03702	Chiller Plant	In Service	5s			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-05951	Sanipak Cover	Not a Building Structure	N/A			4
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-00286	L.S. Packard Children's Hospital	In Service	3			2
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-02867	LPCH Generator Yard	Under Construction	N/A			
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05369	New LPCH Expansion Building	Under Construction	5s			4s
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05370	New LPCH Loading Dock	Under Construction	5s			4s
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05371	LPCH Tunnel	Tunnels	N/A			
43 - Santa Clara	10878	Mission Oaks Hospital	Los Gatos	BLD-02253	Main Building	In Service	3s			3
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02278	1953 Building	In Service	1		17.61	2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02279	1953 Boiler House / Laundry	In Service	1		27.80	2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02280	1969 Addition	In Service	2			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02281	Replacement Facility	In Service	4			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02282	Replacement Boiler House	In Service	4s			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03316	2005 Emergency Expansion	In Service	5			4
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03318	Linear Accelerator	In Service	4			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03319	Canopy 1	In Service	3			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03320	Canopy 2	In Service	3			2
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-05675	2005 Emergency Expansion Canopy	In Service	5			4
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-06234	Bulk Medical Gas	Equipment Yard	N/A			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02236	Main Tower and North Wing	In Service	1			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02237	South Wing	In Service	1			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02238	Obstetrics Wing	In Service	1			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02239	Emergency Department Building	In Service	4			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02240	Lab Building	In Service	3			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02241	Surgery Building	In Service	3			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02242	ICU/CCU Building	In Service	3			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02958	7A Outpatient Surgery Center	In Service	4s			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03387	East Patient Wing	In Service	5s			4s
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03388	ICU Expansion	In Service	5s			4s
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03389	West Wing	Under Construction	5s			4s
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03391	Emergency Department Addition	In Service	5s			4s
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03639	Central Plant	In Service	5s			4s
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06316	Bulk Oxygen Yard	Equipment Yard	N/A			2
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06396	West Wing Canopy	Under Construction	5s			4s
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02546	Ancillary B (6043)	In Service	2			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02547	Old Main Hospital C West (6001)	In Service	1		20.67	2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02548	Old Main Hospital C East (6001)	In Service	1		11.72	2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02550	Rehabilitation Center Str B (6004)	In Service	2			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02552	Rehabilitation Center Str C (6004)	In Service	2	3.37		2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02553	West Wing K Nursing (6006)	In Service	3			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02554	Main Hospital M (6009)	In Service	5			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02555	Energy Plant S1 - Boiler Room (6016)	In Service	4			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02556	Energy Plant S2 - Addition (6016)	In Service	4			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02557	Mech/Elec Bldg U (6017)	In Service	5			2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03654	M/E Chiller Addition	In Service	5s			4
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03860	Services Bldg N (Unit 5) (6002)	In Service	1		31.65	2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03861	Services Bldg S (Unit 4) (6002)	In Service	1		15.10	2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03869	Connecting Corridor	In Service	1		7.35	2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03907	Rehabilitation Center Str A (6004)	In Service	2	0.59		2
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05256	Replacement Bed Building (Sobrato Pavilion)	In Service	5s			4s
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05306	Barbara Arons Pavilion	Acute Psych Only	N/A			
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05677	West Wing K Nursing (6006) Air Intake	In Service	4			2
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02627	Hospital Building Area A	In Service	3			3
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02628	Hospital Building Area B/C	In Service	3			3
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02629	Central Plant	In Service	3			3
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02290	Edwards Building-Med School	In Service	1		33.58	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02291	Lane Building - Med School	In Service	1		17.15	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02292	Alway Building - Med School	In Service	1		8.59	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02293	Grant Building - Med School	In Service	1		10.13	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02294	Central Core	In Service	2			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02295	Central Core - East and West	In Service	1		28.15	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02296	Boswell Building	In Service	1		18.25	2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02297	West Pavilion	In Service	2			3
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02298	East Pavilion	In Service	2			3
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02299	Phase 1 Central Core Expansion	In Service	3s			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02300	Nursing Pod D	In Service	4			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02301	Nursing Pod E	In Service	4			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02302	Nursing Pod F	In Service	4			3
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02303	Diagnostic Treatment Center	In Service	3s			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02304	Atrium	In Service	3s			3
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02305	F Pod Extension	In Service	3s			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02754	L. S. Packard Childrens Hospital	Not an Independent Building	N/A			N/A
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02799	OSHPD Plant	In Service	5s			4s
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02800	OSHPD Electrical Equipment Yard	Equipment Yard	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02801	OSHPD Emergency Generator	Equipment Yard	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02802	OSHPD Cooling Towers	Equipment Yard	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02803	OSHPD Above Grade Fuel Tanks	Equipment Yard	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02865	New Stanford Hospital - Generator Building	Under Construction	5s			4s
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02866	Modular Steam Plant	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03435	Utility Substation	In Service	5s			4s
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03436	Emergency Generator	Equipment Yard	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03437	Utility Substation	Not a Building Structure	N/A			
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03805	Boiler Building - Office Portion	Not an Independent Building	N/A			N/A
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-05260	New Stanford Hospital	Under Construction	5s			4s
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-05867	North Feed Steam Tunnel (OSHPD)	Tunnels	N/A			2
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-05880	New Stanford Hospital - Elevator / Stair Enclosure	Under Construction	5s			4s
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-05881	New Stanford Hospital - Utility Tunnel	Under Construction	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02320	Main Hospital	In Service	2	0.35		2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02321	Boiler House/Original Corridor	In Service	2	0.17		2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02322	North Wing	In Service	3s			2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02323	Original East Wing	In Service	4			2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02324	Emergency Wing	In Service	4s			2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02325	Ancillary Building	In Service	4s			2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-03373	Generator #3	Equipment Yard	N/A			2
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-03527	Emergency Parking Deck	Not an Independent Building	N/A			N/A
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05749	Original Hospital	Delicensed Clinic under OSHPD	N/A			

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05750	North Wing	Not an Independent Building	N/A			N/A
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05751	3 Story Addition Tower	Not an Independent Building	N/A			N/A
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05752	Emergency Room Expansion	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05753	ICU / CCU Addition	Not an Independent Building	N/A			N/A
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05754	Emergency Generator Building	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05755	Electrical Building	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05756	Acute Rehabilitation Gym	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05757	Exterior Canopy	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05758	Connecting Structure	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-05759	Laboratory Expansion	Delicensed Clinic under OSHPD	N/A			
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	Santa Cruz	BLD-00240	Sutter Maternity	In Service	3			3
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	Santa Cruz	BLD-05910	Connector Building	In Service	4			2
44 - Santa Cruz	15019	Watsonville Community Hospital	Watsonville	BLD-00057	Main Hospital	In Service	5			4
44 - Santa Cruz	15019	Watsonville Community Hospital	Watsonville	BLD-00058	Central Plant	In Service	5			4
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02327	Original Hospital	In Service	1		2.73	2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02328	Long Term Beds Addition	In Service	4			2
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02329	Surgery/O.B. Addition	In Service	4			2
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02332	Pharmacy and 12 Bed Addition	In Service	4			2
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02333	Lobby/Business Addition	In Service	4			2
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02334	Emergency Addition	In Service	5			2
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-03566	Generator Building	In Service	1			2
45 - Shasta	11000	Mayers Memorial Hospital	Burney	BLD-05268	Skilled Nursing Building - Burney Campus	Skilled Nursing Only	N/A			
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-05334	Emergency Department Expansion	Under Construction	5s			4s
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06253	Connector	Under Construction	5s			4s
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06254	Drop-Off Canopy	Under Construction	5s			4s
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01502	Main Building	In Service	2			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01503	Pediatrics	In Service	2	0.00		2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01504	East Wing	In Service	2	0.10		2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01505	Radiology Addition	In Service	2	0.22		2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01506	Central Wing	In Service	2			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01507	Doctor's Lounge	Not an Independent Building	N/A			N/A
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01508	Cafeteria Addition	In Service	4			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01509	Third Floor L & D Addition	Not an Independent Building	N/A			N/A
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01510	West Tower	In Service	4s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01511	Engineering Addition	Not an Independent Building	N/A			N/A
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01512	Pediatrics Addition	In Service	4s			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01513	ER/ICU Addition	In Service	5			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01514	Radiology & Cafeteria Addition	In Service	4			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01515	Oncology Center Addition	In Service	5s			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01516	Generator Bunker	In Service	4			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03642	Corridor	In Service	3s			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03643	Oncology Canopy	In Service	3s			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03644	Emergency Canopy	In Service	3s			2
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-05354	MRI Addition	In Service	5s			4s
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-05618	Service Yard	Equipment Yard	N/A			2
45 - Shasta	16679	Patients' Hospital of Redding	Redding	BLD-00289	Hospital Building	In Service	5			2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02340	East Wing	In Service	2	0.10		2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02341	West Wing	In Service	2	0.00		2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02342	Surgery/Radiology/ICU	In Service	4			2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02343	ER Expansion	In Service	5			2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02344	Surgery/Cardiology/LDR	In Service	4			2
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02345	Expansion	In Service	4			2
45 - Shasta	16620	Vibra Hospital Of Northern California	Redding	BLD-00064	N. Ca. Rehabilitation Hosp. Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00082	Nursing Wing	In Service	5			4
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00083	D & T Wing	In Service	5			4
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00084	Med. Gas Shed	In Service	5			4
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00231	1973 Building	In Service	4			2
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00232	Administration Building	Not an Independent Building	N/A			N/A
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00233	Laboratory Addition	Not an Independent Building	N/A			N/A
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00234	Radiology Addition	Not an Independent Building	N/A			N/A
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00235	Skilled Nursing Facility & Maintenance Shop	In Service	4			2
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00236	Generator Enclosure	In Service	5s			2
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06101	Emergency Dept. Addition	Under Construction	5s			4s
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06118	1973 Nursing Wing	In Service	4			2
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06321	OPS Addition	In Service	5			4
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-03834	Hospital Building	In Service	5s			4
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-03835	Central Utility Plant Phase 2	In Service	5s			4
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00204	Central Plant East	In Service	4			2
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00205	Hospital Addition	In Service	3s			2
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00207	Central Plant West	In Service	2	0.08		2
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-02778	Central Plant	In Service	5s			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-02779	Hospital Tower	In Service	5s			4
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-03631	Central Plant East Storage / LOX	In Service	4			2
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01519	Central Plant	In Service	5			4
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01520	Phase 1 Replacement Building	In Service	5			4
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01521	Original Hospital Building A	In Service	4			2
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01522	Emergency Room Addition	In Service	5			4
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02681	Med/Surg Addition	In Service	4s			2
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02682	Original Hospital Building B	In Service	4			2
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02683	Original Hospital Building C	In Service	4			2
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-03029	Emergency Room Canopy	In Service	5			4
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-03030	Phase 1 Replacement Building Canopy	In Service	5s			4
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05345	Electrical Building	In Service	5			
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05875	New North Wing	Under Construction	5s			4s
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05876	Overhead Utility Support Structure	Not a Building Structure	N/A			
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-06335	Laboratory Building	In Service	5			
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00340	Nursing Wing	In Service	3			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00341	Main Entrance	In Service	5			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00342	Ancillary Wing	In Service	3			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00343	Administration Wing	In Service	5			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00344	Central Plant	In Service	5			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00345	Cafeteria Wing	In Service	5			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00347	Service Yard Canopy	In Service	3			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-05991	MRI Walkway	In Service	5			4
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-05993	Bulk Oxygen Tank	Equipment Yard	N/A			4
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01019	Original Hospital	In Service	2		0.47	2
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01020	One Story Addition	In Service	4			2
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01021	Tower Addition	In Service	3s			2
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-02969	Two Story Addition	In Service	4s			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-00919	Main Hospital Building	In Service	2			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-00920	Entrance Addition	In Service	5			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-00921	CT Scanner Addition	In Service	5s			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-00922	Mechanical/Electrical Addition	In Service	5			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-00923	Materials Management Addition	In Service	5s			2
49 - Sonoma	12823	Healdsburg District Hospital	Healdsburg	BLD-05449	ED Addition	In Service	5s			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00277	Hospital	In Service	3			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00278	Central Plant	In Service	4			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00279	Central Plant Addition	In Service	4			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00280	Electrical Building	In Service	4			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02780	Hospital, South	Not an Independent Building	N/A			N/A
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02781	Hospital, North	Not an Independent Building	N/A			N/A
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02782	Canopy, South	In Service	3			3
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02783	Canopy, North	In Service	3			3
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-03610	North Wing Expansion	In Service	5			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-03849	Generator Building	In Service	5			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-05699	Connecting Tunnel	In Service	5			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-05700	CUP / Boiler Room Expansion	In Service	5			4
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-06104	North Wing Expansion Canopy	In Service	5			4
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00311	Original Hospital - Southwest	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00312	Emergency Room Expansion	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00313	Power Plant Building	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00314	Switchgear Building	In Service	5			3
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00315	Power Plant Addition	In Service	5			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02579	Original Hospital - Northeast	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02580	Original Hospital - Northwest	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02581	Original Hospital - Southeast	In Service	3			2
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02757	Power Plant Addition	In Service	4			2
49 - Sonoma	11054	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01529	Original Hospital	In Service	2			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
49 - Sonoma	11054	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01530	Physical Therapy Addition	In Service	4			3
49 - Sonoma	11054	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01531	Psychiatric Addition	In Service	4			3
49 - Sonoma	11054	Santa Rosa Memorial Hospital	Santa Rosa	BLD-02755	Dietary Addition	In Service	4			3
49 - Sonoma	11054	Santa Rosa Memorial Hospital	Santa Rosa	BLD-02756	Social Services Addition	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01533	West Pavilion - North Wing	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01534	West Pavilion - West Wing	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01535	Service Building	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01536	West Pavilion - Entry Lobby and Canopy (Entry Lobby)	In Service	5			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01537	Emergency Wing	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01538	Center East - West Link	In Service	3			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01539	Center East Wing	In Service	2			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01540	East Wing and East Wing Link	In Service	2			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-01543	Emergency Wing-Entrance Canopy	In Service	4			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-03203	ED Expansion	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-03205	Ambulance Drop Off Canopy	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-03206	ED Addition	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-03207	Surgery Building and Cath Lab Infill	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-03208	Observation #3	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06270	Oxygen Tank - Generator - Underground Fuel Tank	Equipment Yard	N/A			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06275	West Pavilion - Entry Lobby and Canopy (West Canopy)	In Service	5			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06276	West Pavilion - Entry Lobby and Canopy (East Canopy)	In Service	5			3
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06277	Main Entrance Canopy	In Service	5			4
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06340	Water Treatment Structure	In Service	1s			2
49 - Sonoma	11059	Santa Rosa Memorial Hospital	Santa Rosa	BLD-06351	Bio-Hazard Holding	In Service	1s			3
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01523	Hospital Building	In Service	3			2
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01524	Entrance Canopy	In Service	3			2
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01525	Emergency Canopy	In Service	3			2
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01526	Mechanical Room	In Service	3			2
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01527	Radiology Addition	In Service	4			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01544	West Wing	In Service	2	0.48		2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01545	Central Wing	In Service	2		1.13	2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01546	East Wing North	In Service	4			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-02990	Central Wing Canopy	In Service	3s			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-02991	West Wing Canopy	In Service	3s			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03079	East Wing Center	In Service	3			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03080	East Wing South	In Service	4			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03873	Chiller Building	In Service	4			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05409	East Wing Loading Dock Canopy	In Service	5s			2
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05410	ED / OR	In Service	5s			4s
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05411	ED / OR Canopy	In Service	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05237	Hospital Building - West Wing	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05238	Hospital Building - Center Wing	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05239	Hospital Building - East Wing	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05240	Central Utility Plant	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05241	Water Treatment Building	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05242	Medical Gas Storage Building	In Service	5			4
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05364	Utility Building	In Service	5			4
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-01551	Orig Hospital Bldg & Add - Bldg III	In Service	1		13.80	1
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-01552	1978 Hospital Building - Bldg I	In Service	4			1
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-03534	Building II	In Service	2		0.52	1
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01579	Main Hospital & Additions	In Service	2	0.00		2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01580	South Tower	In Service	2	0.45		2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01581	North Tower	In Service	4			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01582	Cath Lab	In Service	4			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01583	Lobby Addition	In Service	4			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01584	Women & Children's Center	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01585	Central Mechanical Plant	In Service	4s			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01586	West Tower	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01587	ER/Lab	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01588	Cardiology	In Service	5s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01589	Endoscopy	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01590	Endoscopy	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01591	Endoscopy	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01592	Pharmacy Addition	In Service	4			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01593	Dining Room Addition	In Service	4s			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-03405	ER/LAB Connecting Corridor	In Service	5			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-06179	Women & Children's Center - Steam Generator Room	In Service	4s			2
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-06200	Entry Canopy	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01604	Main Building - East Wing	In Service	2	0.03		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01605	Main Building - West Wing	In Service	2	0.03		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01606	Mental Health Addition	In Service	2	0.02		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01607	Critical Care Addition	In Service	2	0.03		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01608	Diagnostic Imaging/ER Emergency	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01609	Nursing Unit Addition	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01610	Engineering Addition	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01611	Central Supply Addition	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01612	Central Plant Addition	In Service	4			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01613	O.R. / G.I. Addition	In Service	5			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01614	Walk-In Freezer	In Service	5			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01615	Dietary Addition	In Service	5			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01616	Surgery Addition	In Service	5			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01617	Utility Tunnel	Tunnels	N/A			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01618	Exit Passage Way	In Service	2	0.07		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03229	Cardio Vascular Surgery Addition	In Service	5			4
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03230	ED Addition - North West Tower	In Service	5s			4
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03231	Obstetrics Expansion	In Service	5s			4
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03232	Oxygen Tank Yard	Equipment Yard	N/A			2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03690	Exit Passage Way - Part II	In Service	2	0.07		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03691	Exit Passage Way - Part III	In Service	2	0.07		2
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03813	Exit Passage Way - Part IV	In Service	2	0.07		2
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05648	South Building	In Service	5s			4s
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05655	North Building	In Service	5s			4s
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05656	Emergency Generator Enclosure	Equipment Yard	N/A			
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05657	Bulk Oxygen Enclosure	In Service	5s			4s
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05183	Main Building	In Service	5s			4s
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05184	Central Plant	In Service	5s			4s
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05531	Central Utility Yard	Equipment Yard	N/A			
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01567	Connecting Corridor Infill	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01568	Physical Plant & Additions	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01569	G. I. Lab Addition	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01570	Emergency/Ancillary Services	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01571	West Expansion	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01572	Same Day Surgery	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01573	Advanced Medical Diagnostic	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01574	Radiation Oncology Addition	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01575	Original Hospital	In Service	2	0.34		2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01576	Obstetrics Expansion	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01577	Surgery/Emergency Expansion	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01578	Dietary/Dining	In Service	4s			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03140	ER Expansion	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03225	North Tower	In Service	5			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03226	Central Plant Expansion	In Service	5			4
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03837	North Tower	In Service	5			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03838	Family Birthing Center Addition	In Service	5			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03839	Surgery/Emergency Expansion - East	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03847	Original Hospital - South	In Service	2	0.24		2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05405	Corridor and Elevator Addition	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05406	Emergency/Ancillary Services Canopy	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05407	West Expansion - Labor and Delivery	In Service	4			2
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05408	West Expansion - Chapel	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05417	GI Lab	In Service	4			2
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00193	Original Building	In Service	2	0.00		2
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00194	ICU Addition	In Service	4			2
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00195	Emergency Dept. Addition	In Service	5			2
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00196	300 Wing Addition	In Service	5			2
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03243	Central Utility Plant	In Service	5			4
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03244	Replacement Hospital	In Service	5			4
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03245	Canopy #6	In Service	5			4
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03246	Canopy #7	In Service	5			4
50 - Stanislaus	17461	Stanislaus Surgical Hospital	Modesto	BLD-03242	Hospital Building	In Service	5			4
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	Yuba City	BLD-05179	Emergency Generator	Equipment Yard	N/A			
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	Yuba City	BLD-05344	Hospital	In Service	5s			4s
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01560	Main Hospital - North Wing	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01561	Six Bed Addition	Not an Independent Building	N/A			N/A
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01562	Surgery Addition	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01563	Patient Rooms Addition	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01564	Medical Records Addition	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01565	Surgery Expansion	Not an Independent Building	N/A			N/A

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01566	Administration Addition	Not an Independent Building	N/A			N/A
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-02977	Main Hospital - Southwest Wing	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-02978	Main Hospital - Southeast Wing	In Service	4			2
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-06031	Drop-off Canopy	In Service	5			4
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02523	Main Hospital Building	In Service	2	0.02		2
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02524	SNF Building	Skilled Nursing Only	N/A			1
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02525	Security Addition	In Service	1	10.49		2
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02526	16-Bed Addition	In Service	2	0.63		2
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02527	Lab and Radiology Addition	In Service	4			2
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02528	Emergency Generator Building	In Service	2		0.98	2
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02529	Connecting Corridor Addition	In Service	1		9.90	2
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00564	Original Structure & Additions	In Service	2	0.00		1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00569	Fifth Addition: Radiology Addition	In Service	4			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00570	Sixth Addition	Not an Independent Building	N/A			N/A
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00571	Sixth Add - 1.8	In Service	4			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00572	Sixth Add - 1.9	Not an Independent Building	N/A			N/A
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-02963	MRI Modular Building	Outpatient Only	N/A			
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-03517	First Addition	In Service	2	0.00		1

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-03518	Second Addition	In Service	2	0.00		1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05607	Tower 1	Under Construction	5s			4s
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05868	Generator Yard	Equipment Yard	N/A			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05869	Tower 1 Generator Yard	Under Construction	N/A			
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05870	Bulk Medical Gas and Water Tank Yard	Equipment Yard	N/A			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05871	CT Scan Building	Outpatient Only	N/A			N/A
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06041	Sixth Add - 1.8 - Lobby	In Service	4			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06042	Sixth Add - 1.7 - North Restroom Addition	In Service	4			1
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06043	Sixth Add - 1.7 - South Restroom Addition	In Service	4			1
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01031	Original Building	In Service	2	0.01		2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01032	1st. East Expansion	In Service	4			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01033	Cafeteria - Dining Unit	In Service	4			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01034	Special Services	In Service	4			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01035	Co-Gen. Building	In Service	3			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01036	Special Procedures	In Service	4			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01037	West Expansion	In Service	3			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-01038	East Expansion	In Service	3			2
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-02695	Cypress Rehabilitation Hospital	Not an Independent Building	N/A			N/A
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-02716	Cafeteria - Office Unit	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-03616	North Expansion	In Service	5			4
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-05218	Cypress Rehabilitation Hospital	Not an Independent Building	N/A			N/A
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-05219	Cypress Rehabilitation Hospital	Not an Independent Building	N/A			N/A
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-05583	Dietary Addition	In Service	5s			4s
54 - Tulare	12601	Kaweah Delta Medical Center	Visalia	BLD-06048	Emergency Department Addition	Under Construction	5s			4s
54 - Tulare	18179	Kaweah Delta Rehabilitation Hospital	Visalia	BLD-03749	Original Building - Part 1	In Service	5			2
54 - Tulare	18179	Kaweah Delta Rehabilitation Hospital	Visalia	BLD-03750	Original Building - Part 3	In Service	5			2
54 - Tulare	18179	Kaweah Delta Rehabilitation Hospital	Visalia	BLD-03751	Original Building - Part 2	In Service	5			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00556	Original Building	In Service	2	0.01		2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00557	Radiology Addition	In Service	4			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00558	Emergency Addition #1	In Service	4			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00560	3 Story Addition	In Service	4			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00561	4 Story Addition	In Service	4			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00562	Emergency Addition #2	In Service	5			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00563	Administration Addition #2	In Service	5			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-02696	Laboratory Addition	In Service	4			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-02697	Service Building	In Service	5			2
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-03239	Central Utility Plant	In Service	5s			4
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-05569	Emergency Department Electrical Room Addition	In Service	5s			4

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
55 - Tuolumne	11151	Adventist Health Sonora	Sonora	BLD-03833	OB Unit 9	In Service	2	0.00		2
55 - Tuolumne	18163	Adventist Health Sonora	Sonora	BLD-05178	Main Building	In Service	5			4
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01246	Original Building	In Service	2		1.14	2
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01249	Main Hospital Building	In Service	3			4
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01253	New Bridge/Elevator & Med. Gas Enclosure	In Service	4s			2
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-03335	North and South Patient Care Tower	In Service	5			4
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05217	Patient Care Tower Entrance	In Service	5			4
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05679	ED / Surgery Addition	Under Construction	5s			4s
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05680	ED / Surgery Addition Entrance	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00585	Goodyear Wing	In Service	1		10.52	2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00586	Main Building & Additions	In Service	1		16.58	2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00587	Gift Shop	In Service	1		22.48	2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00588	West Wing & Addition	In Service	1		13.22	2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00589	South Wing	In Service	4			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00590	North Wing & OB/Gyn Addition	In Service	4s			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00591	Ambulatory Surgery & OB/Gyn Addition	In Service	4s			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00592	E.R. Addition	In Service	4			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-00593	Emergency Generator Building	In Service	4			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03167	New Ambulance Entry	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03168	New 6 Story Hospital Tower - West	Under Construction	5s			4s

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03169	New 6 Story Hospital Tower - East	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03170	New 2 Story Hospital Tower	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03250	E.R. Addition Bridge	In Service	4s			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03251	Service Building	In Service	4			2
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03252	Bridge Addition	In Service	5s			4
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03253	Brent Street Bridge	In Service	5s			4
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05528	New ER Canopy	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05529	New Main Entry Canopy	Under Construction	5s			4s
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05530	New 1 Story Pedestrian Walkway	Under Construction	5s			4s
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00601	North Wing / Central Core	In Service	2	2.50	2.50	2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00602	South Wing	In Service	2	2.38		2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00603	West Wing	In Service	3			2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00604	New South Wing	In Service	3			2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00605	Emergency Generator Shed	In Service	4			2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-02950	Emergency Department Addition	In Service	5			2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-03108	ICU/CCU	In Service	5			2
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-03464	New Expansion	Under Construction	5s			4s
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-06341	Exit Discharge Area Expansion	Under Construction	5s			4s
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-06413	OR Expansion	Proposed	5s			4s
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02641	Building One	In Service	3s			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02642	Building Two - Dining/Kitchen	In Service	3s			2
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02643	Building Three	In Service	3s			2
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02644	Building Four - Gymnasium	In Service	4			2
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02645	Building Five	In Service	3s			2
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-06012	Outpatient Canopy	Under Construction	5s			4s
56 - Ventura	11169	Ojai Valley Community Hospital	Ojai	BLD-00606	Hospital Building	In Service	2	0.14		3
56 - Ventura	11169	Ojai Valley Community Hospital	Ojai	BLD-02994	Nursing Wing	In Service	4s			3
56 - Ventura	11169	Ojai Valley Community Hospital	Ojai	BLD-02995	Laboratory Addition	In Service	4s			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-00209	Main Hospital	In Service	1		26.04	2
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-00210	Central Plant/ Utilities Building	In Service	3			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-00211	Ancillary Building	In Service	3			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-00212	Ambulatory Surgery Center	In Service	3s			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-00213	ER Entrance Canopy	In Service	3			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-03257	Hospital Addition	Under Construction	5s			4s
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-03258	Chapel Addition	Proposed	N/A			
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-03845	Skilled Nursing Building	In Service	3			3
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-05209	ED Addition	In Service	5			4
56 - Ventura	13181	St Johns Pleasant Valley Hospital	Camarillo	BLD-06318	SNF Connection	Under Construction	5s			4s
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00607	Link Building 1	In Service	3			3
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00608	Hospital Building	In Service	3			3

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00612	Canopy and Entrance Bridge	In Service	4s			3
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02614	Patient Tower	In Service	3			3
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02615	Link Building 2	In Service	4			3
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02616	Central Plant	In Service	4			3
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-05872	MRI Building	In Service	5			4
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06160	Angiography Operating Suite Exterior Addition	Under Construction	5s			4s
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06174	New ED Expansion & Covered Entry	Under Construction	5s			4s
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06175	New Free-Standing Covered Walkway	Under Construction	5s			4s
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06176	New Free-Standing Covered Entry	Under Construction	5s			4s
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06464	Surgery Equipment Storage Exterior Addition	Proposed	5s			4s
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	Thousand Oaks	BLD-05186	Main Building	In Service	5s			4s
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00594	Main Hospital Building - Bldg 305	In Service	1			2
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00595	Fainer Wing - Building 304	In Service	4			2
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00596	Administration Building - Bldg 306	In Service	1			2
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00597	Mental Health Center - Building 399	In Service	5			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00598	Steam Plant - Building 328	In Service	1			2
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00599	Switch Building - Building 349	In Service	1			2
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00600	Generator Building - Building 366	In Service	4			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03341	Electrical Services Building 400	In Service	5			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03640	Administration Bldg Addition - #306	In Service	1			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03641	Medical Lab / Kitchen - Bldg 401	In Service	5			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05572	Cafeteria Building - Building 403	In Service	2			3
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05660	Med Gas Enclosure - Building 307	Equipment Yard	N/A			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05661	Fainer Wing Cooling Tower Enclosure - Building 308	Equipment Yard	N/A			
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05707	Hospital Replacement Wing	In Service	5s			4s
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05729	Interim LOX Tank	Equipment Yard	N/A			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-06225	Hospital Porte Cochere	In Service	4			4
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-06227	Ambulance and ED Porte Cochere	In Service	4			4
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01241	Main Building / East & North Addition	In Service	2		0.91	3
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01242	East Addition	Not an Independent Building	N/A			N/A
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01243	North Addition	Not an Independent Building	N/A			N/A
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01244	E.R. Addition	In Service	5			3
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01245	Storage Building & Storage Addition	In Service	4			2
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02647	Generator Building	In Service	5			2
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02648	I.C.U. Addition	In Service	2		0.91	3
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02724	Storage Addition	Not an Independent Building	N/A			N/A
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02929	Infectious Waste Sterilizer Bldg	In Service	5			3
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-01256	Main Hospital Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-01257	Central Plant	In Service	4			2
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-06114	Post Anesthesia Recovery Expansion	In Service	5			4
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01258	Building A	In Service	2	0.10		2
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01259	Building B	In Service	2	0.09		2
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01260	Building C	In Service	2	0.05		2
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01261	Building D	In Service	2	0.03		2
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01262	Building E, Ancillary Wing	In Service	4			2
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01263	Lobby	In Service	4			2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01264	Patient Tower/Cath Lab/4th Floor	In Service	4			2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01265	Patient Tower Cath Lab	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01266	Patient Tower 4th Floor Buildout	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01267	Central Plant (1960 & 1988)	In Service	2	0.34		2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01268	Central Plant CP-1 ('92 '98 & 2000)	In Service	4			2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01269	Central Plant CP-1 1998 Addition	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01270	Central Plant (1988)	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01271	Central Plant CP-1 2000 Addition	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01272	East Wing (1978)	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 5/16/2019

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	OSHPD NPC Rating *
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01273	West Wing (1960)	In Service	1	2.56		2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01274	North Wing (1925)	In Service	1	1.81		2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01275	North Wing N-1 ('74 '80 & '86)	In Service	4			2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01276	North Wing N-1 1980 Addition	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01277	North Wing N-1 1986 Addition	Not an Independent Building	N/A			N/A
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-02785	New Patient Tower	In Service	5s			4s
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-03485	North Wing N-2 (1960)	In Service	2	0.34		2
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-03769	Registration Building	In Service	4			2

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail