

**Advisory
Guide
Series**

A13

**NPC UPGRADE
CONSTRUCTION
PROCESS FOR
EXISTING CEILINGS
AND ABOVE-CEILING
UTILITIES**

Office of Statewide Hospital Planning and Development

**Department of Health Care Access and Information
Office of Statewide Hospital Planning and Development**

Headquarters and Northern California
(916) 440-8300

Southern California
(213) 897-0166

<https://hcai.ca.gov>

TABLE OF CONTENTS

TABLE OF CONTENTS.....	i
SECTION 1 Purpose and Scope	1
SECTION 2 Assessing Existing Conditions	1
SECTION 3 Preparation of Construction Documents.....	2
SECTION 4 Existing Braces	5
SECTION 5 ACD versus NMA	6
SECTION 6 NPC Upgrade Request.....	7

SECTION 1

PURPOSE AND SCOPE

Purpose

The nonstructural components and systems are the lifelines of hospital operations and must be anchored and braced to ensure the continued function of the hospital after an earthquake. HCAI has developed Nonstructural Performance Category (NPC) classifications to indicate the degree to which these components and systems are anchored and braced in each hospital building. For buildings not constructed under an OSHPD permit (or pre-1982/83), the determination of visible equipment anchorage status is straight forward, however, information regarding the layout and bracing conditions of utilities and equipment anchorage above ceilings can be difficult to verify. Surveys of these utilities are disruptive to hospital operations, and the subsequent upgrade construction causes further disruption. Repeatedly accessing ceilings to perform work increases project costs. The purpose of this Advisory Guide is to minimize disruption and expedite NPC upgrade construction for components and systems at or above ceilings.

Scope

The focus of this Advisory Guide is solely on the NPC upgrade of existing components and systems at or above ceilings. Examples of these components and systems include ceiling components, light fixtures, ducts, conduits, pipes, inline HVAC units, hung medical equipment, wall bracing, etc. This Advisory Guide does not address wall-mounted equipment, equipment mounted on top of floor or roof, new equipment, new systems and utilities, or deferred item submittals as these shall follow standard HCAI review and approval process.

Tenant Improvement (TI) projects shall follow the standard HCAI review and approval process. Deferred item submittals might be utilized to upgrade the above-ceiling items per a typical TI project process. A13 Guide is recommended to be used for building-wide ceiling and above-ceiling NPC upgrades. Deferred item submittals are not permitted under the A13 guide process.

SECTION 2

ASSESSING EXISTING CONDITIONS

More upfront planning and investigation will reduce unknowns and project delays once construction begins. The Design Professional of Record (DPOR) should review record Architectural, Structural, and MEP drawings along with the facility's historic documentation and archives. Additionally, DPOR may request drawings from state archives through the HCAI Records Management to ensure a comprehensive understanding of the existing documentation.

Where possible, the DPOR is required to visit the site to observe and verify existing drawings/conditions in various locations with clear photographs.

It is also important to identify significant potential abatement issues such as asbestos, lead, and mold by qualified professionals. The abatement scope may be in another project.

SECTION 3

PREPARATION OF CONSTRUCTION DOCUMENTS

Construction drawings should include typical bracing schedule(s) and attachment details. While above-ceiling utility layout drawings are recommended, they are not required for plan approval or permit. Bracing details must be specific to the building construction and tailored to site seismicity. Non-applicable details, such as including concrete over metal deck details for a wood building, should not be included.

The construction documents must include the following:

- An architectural floor plan showing the room function and clearly defined boundaries of the NPC upgrade. This floor plan will be used and updated to show seismic bracing upgrade locations and installed details during construction. Please see the following sections in this guide for further info.
- The SRU project number under which the NPC evaluation report was reviewed
- A statement on the cover sheet that all above-ceiling existing components will meet NPC-4/NPC-4D requirements for the area identified
- A statement requiring detailed photographs of each above-ceiling location, subject to review by the DPOR and HCAI (when requested)
- Bracing schedules and details based on the building-specific survey
- A statement requiring utility consequential damage and relative displacement per ASCE 7 Section 13.2.3 to be addressed during the construction phase in discussion with HCAI field staff

Use of Pre-approved Details

In addition to project-specific typical details, the construction drawings may include relevant OPM and OPD details. It is acceptable to use more than one OPM in a project.

These pre-approved and supporting details shall be shown on the drawings; simply referring to a preapproval number or detail page is not acceptable. See “ACD vs NMA” Section below and CAN 1-7-153(b) for further information about NMAs.

Application and Plan Review

Plan review will be performed at the corresponding HCAI region, following the typical plan approval and permitting process. Clearly indicate the scope of work and include "NPC 4 upgrade" or "NPC 4D Level 1 / 2 / 3" in the project description and title sheet of the project. If the scope does not cover all required areas to achieve NPC upgrade, then include a note that this is a "partial" upgrade, and completing this scope is not sufficient for NPC approval by itself. Since the construction cost is unknown, the project review cost will be billed hourly by HCAI.

Testing, Inspections and Observation (TIO)

Milestones in TIO form should clearly identify phases/stages/areas on the approved plans or on reference plans included as reference documents for the TIO. The scope of work should be divided into manageable phases/stages/areas to allow incremental sign-off by the HCAI field staff. If the scope has a large area, multiple milestones are recommended.

The first milestone shall be reserved for On-Site First Assessment (OSFA). When the first phase/stage/area is prepared for upgrade, DPOR will assess the existing conditions for code compliance. For non-conforming conditions, DPOR will select applicable details from the approved drawings. See discussion in "ACD vs NMA" section below for discovered conditions. Notify HCAI field staff at least one week prior to OSFA.

To clear each subsequent milestones, HCAI field staff may conduct spot-checks based on the up-to-date Bracing Layout Plan for areas covered under each milestone to observe completion of the work. Spot checks may also include verification of existing braces that were assumed to be compliant. Spot check locations will be chosen to minimize disruption to operations. Physical site visit by HCAI staff and the DPOR is required for OSFA. Subsequent milestone clearance by HCAI staff may be done in-person or remotely.

Milestones must be cleared with the HCAI staff in a timely manner. Contact HCAI field staff when a milestone is complete.

Pre-Construction Meeting

After HCAI plan approval and building permit is issued, the DPOR must coordinate a pre-construction meeting with the DPOR, SEOR, HCAI CO/DSE, IOR, Contractor(s), Inspection Agencies, and Facility Representatives. HCAI staff will address issues and concerns to clarify the construction TIO process.

Construction TIO Process

The first phase/stage/area identified in the TIO form will be completed with HCAI staff presence, where possible, to provide critical feedback. HCAI field staff will sign off on the OSFA prior to contractor starting work in other areas.

Construction in each phase/stage/area shall be documented, photographed and maintained by the DPOR. No area shall be closed before photographing and documentation are complete. If the area did not require any work for NPC compliance, photograph the area, from multiple angles, where possible. These photos shall be made available to HCAI staff, upon request, and added to the photographic records.

Site Verification

The contractor or licensed professional is permitted to perform site verification but the licensed architect, licensed structural engineer, or a licensed civil engineer who is listed as a design professional of record for the project shall take responsibility for the attachment detail and shall document bracing locations and dimensions on the bracing layout plans. Decisions for the adequacy of the approved details compared to the existing conditions shall be made only by a licensed professional listed in the project professionals. The braces that are added during construction should be noted on the bracing layout plans with accurate locations identified by the DPOR. It is the responsibility of the DPOR to present the layout drawings to the HCAI field staff when requested. Bracing information for each area shall be added to the bracing layout plans before closing out the area.

Bracing Layout Plans

The DPOR shall submit a bracing layout plan (similar to as-builts) to HCAI field staff showing the locations of all new braces and existing verified braces. Final project close-out shall not be done before HCAI receiving the Bracing Layout Plan. The Bracing Layout Plan shall be maintained by the DPOR at all phases.

The bracing layout plan is a mechanical/plumbing/electrical plan overlaid on an architectural floor plan showing the utility runs and the room function inside the scope of the project with the seismic bracing locations (existing and new) and detail callouts (new and verified). The bracing layout plan needs to be updated every time a new location is opened, showing the layout of the existing utility lines.

The DPOR shall submit bracing layout plans showing the locations of any new work required to meet NPC requirements. Existing bracing should be verified as explained under the sections below.

Utilities that require no added bracing, either because existing bracing is adequate, or because the utility is exempt from bracing requirements, may be noted for each room on

the bracing layout plans. The transition from where bracing is required to where bracing is not required should be clearly shown and noted. For example, note where a pipe size is reduced so it becomes exempt (and then may not be shown on the bracing layout plan, but photographs showing the utility lines in the area are required to be made available upon request).

The Final Bracing Layout Plans shall be submitted to HCAI prior to requesting the Construction Final from the HCAI field staff. The Bracing Layout Plans are not required to be approved prior to closing the ceilings in an area. Any work that has been performed and is later changed due to a HCAI review on the Bracing Layout Plans to achieve code compliance may be subject to destructive investigation.

SECTION 4 EXISTING BRACES

Existing braces, whether documented in a previous project or not, may be used to meet NPC requirements under the following conditions.

Existing Braces With Existing Drawings:

For non-OSHPD projects (plan submittal to the Office prior to 1982/1983) with bracing layout, the DPOR shall implement an onsite verification process that shall be described on the construction documents. The DPOR shall establish verification criteria throughout the area of work. Verification can be through various methods, including torque testing, pull testing, visual inspections, etc. The details from the original project are required to either be duplicated in the approved construction document or provided as a reference document, with a clear indication of which details are applicable, in order that the construction and inspection team can visually verify the existing work. Any observed deviation shall be evaluated by the design professional of record.

Existing fire sprinkler bracing verification under 1987, 1989, 1991, and 1994 NFPA 13:

1. Buildings where fire sprinklers are designed under the 1994 edition of NFPA 13 (plan submittal date after 4/30/1996): There is no need to evaluate or upgrade the fire sprinklers.
2. Buildings where fire sprinklers are designed under the 1991 edition of NFPA 13: The design team is required to add missing end-of-line restraints only.
3. Buildings where fire sprinklers are designed under the 1987 and 1989 editions of NFPA 13: Design team to perform a site visit and verify the existence of branch line bracing and end-of-line restraints. The design team is required to add missing end of branch line restraints, missing longitudinal sway bracing for feed and cross mains, and missing lateral sway bracing for feed and cross mains.
4. Buildings where fire sprinklers are designed under the 1985 and earlier editions of NFPA 13: All fire sprinkler piping shall be evaluated.

Existing Braces Without Documentation:

For conditions where existing braces are discovered without any known existing documentation, the DPOR shall verify the bracing details and spacing and evaluate for conformance. The DPOR shall provide calculations to justify existing conditions if asked by the HCAI field staff. The DPOR shall include a sketch of existing bracing details on the bracing layout drawings. Similar to existing braces with documentation above, the DPOR shall establish a verification criteria throughout the area of work.

Utility Bracing Exceptions

For NPC 4D Level 1, 2, or 3 upgrades, the 1995 California Building Code (CBC) code shall be used to determine which components need seismic bracing. For NPC 4D upgrade scope, bracing exceptions in the 1995 CBC or later editions of the CBC are acceptable and this CBC year selected should be consistent throughout the entire project. The seismic force level for NPC 4D is per 1998 CBC or later code. (See current version of California Administrative Code (CAC) Chapter 6 Table 11.1 for further details)

For NPC 4, all architectural, mechanical, electrical systems, components, and equipment shall meet the 1998 CBC or later code. For NPC 4 scope, exceptions in 1998 CBC or later, are acceptable, such as minimum pipe diameter for bracing, etc. Abandoned utilities within the scope of work must be restrained to prevent excessive movement or removed. Exceptions that apply to NPC 3, such as 300 sq ft for ceilings, are not acceptable under NPC 4; therefore, these areas need to also be upgraded per 1998 CBC or later code versions.

Where existing utilities cross seismic joints without flex joints, the DPOR shall evaluate if the installation of bracing might have an adverse effect on the seismic performance of the utilities. The best performance will result from installing flexible joints and bracing. Where installing flexible joints is not possible, provide justification that the existing condition is adequate to HCAI for review. Existing utilities with flex joints need not be evaluated.

SECTION 5 ACD VERSUS NMA

Bracing locations and utility layout based on discovered conditions will be incorporated into the Bracing Layout Plans and would not be classified as either an NMA (Non-Material Alteration) or an ACD (Approved Changed Documents).

If a condition is discovered that can be accommodated by using another detail in the selected OPM, this will be incorporated into the construction documents and would be classified as an NMA. For projects outside of the A13 Guide, please note that HCAI does not allow new details from an OPM not previously referenced to be brought into a project through the NMA process, they must be ACD. This NMA process is an exception, as it only applies to this guide. The OPM detail is required to be shown on the drawings per current version of CAC Section 7-115(d)2. These details will be incorporated into the construction documents before closeout.

If a condition is discovered that requires a minor non-material modification to a project approved detail that would generally be considered a non-material alteration, construction can commence based on stamped and signed sketch provided by a licensed professional approved for the project. Work may commence under this direction, however, the DPOR shall prepare and issue an NMA to HCAI field staff within one business day.

If a condition is discovered that requires a minor modification to an OPM detail, such as slightly increasing the allowable brace angle range, this may follow the same NMA process described above. Make such changes with notes outside the border of the OPM detail so it is clear how the detail is modified. If the change requires a calculation where determination cannot be made by inspection, it must be submitted as an ACD.

If a material alteration is required, then an ACD must be prepared and approved by HCAI. If the DPOR can provide a stamped sketch to the construction team before the space must be closed, then construction may proceed with inspection performed to the stamped detail. DPOR shall issue the ACD to HCAI within five business days. Please note, any work performed in this manner is subject to the Office's review and possible destructive investigation.

Final Closeout

Bracing layout drawings must be submitted to HCAI prior to project closeout.

The DPOR shall clearly state on the bracing layout drawings that all conditions in the area are compliant with the NPC requirements of the current version of CAC.

Photographs need not be uploaded to the eSP HCAI project portal. The photographs with proper documentation are required to be kept with the facility and the design professional until the NPC 5 upgrade (which also includes NPC 4 or NPC 4D upgrade) is approved. Please note that this documentation storage duration may be many years after completion of the project.

The DPOR shall request that HCAI field staff review the project for Construction Final when all work is complete and the bracing layout drawings have been submitted to the Office. Photographs shall be available for review. All ACDs must be approved and all NMAs must be concurred with. Test, Special Inspection reports and IOR Daily Field Records shall be presented to HCAI field staff for sign off/acceptance for each item on the TIO.

SECTION 6 NPC UPGRADE REQUEST

After completing all NPC 4 or NPC-4D construction projects, submit an updated reconciliation report under the previously accepted SRU project. If deviations from the previously submitted evaluation report are observed during construction, these shall be clearly identified and reported as part of the reconciliation report. The reconciliation report shall include the list of all relevant projects completed as part of the NPC

upgrade. SCU may ask for additional photographic verification of any area for confirmation when necessary. Therefore, it is critical to establish the custody of past photographs by the facility owner. SCU will review and approve the reconciliation report, then change the rating and send an upgrade approval letter to the facility contact.