

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
01 - Alameda	11210	Alameda Hospital	BLD-01278	Original Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied								N/A				
01 - Alameda	11210	Alameda Hospital	BLD-01279	Stephens Wing	OSHPD 1-In Service	2	Denied				Withdrawn				2	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 06/25/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11210	Alameda Hospital	BLD-01280	West Wing	OSHPD 1-In Service	2	Denied								2	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 06/25/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11210	Alameda Hospital	BLD-01281	South Wing	OSHPD 1-In Service	3s									2	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 06/25/2024		
01 - Alameda	11210	Alameda Hospital	BLD-01282	Radiology Addition	OSHPD 1-In Service	4									2	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 06/25/2024		
01 - Alameda	11210	Alameda Hospital	BLD-01283	Medical Gas Storage	OSHPD 1-In Service	3									2	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted		
01 - Alameda	11210	Alameda Hospital	BLD-02630	Compactor Shed	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
01 - Alameda	11210	Alameda Hospital	BLD-03120	Emergency Room Relocation	OSHPD 1-In Service	3s									2	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 06/25/2024		
01 - Alameda	11210	Alameda Hospital	BLD-05597	LOX Tank	OSHPD 1-Equipment Yard	N/A									4		Rpt: Not Submitted		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00695	Ehman Building	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00696	North Wing	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00698	East Wing	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00699	Original West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00700	West Service Wing - Building 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00701	Physio-Therapy Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00702	Original Emergency Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00703	Special Procedures Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00704	Emergency Department Expansion	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/31/2023		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00705	Cogeneration Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/31/2023		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00706	Emergency Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00707	Transformer Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03431	South Wing - Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023		
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03433	West Service Wing - Building 2 - Structurally connected to BLD-00699	OSHPD 1-Not an Independent Building	N/A								N/A					
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03434	Orig Emergency Wing - East Wing - Structurally connected to BLD-00702	OSHPD 1-Not an Independent Building	N/A								N/A					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-05300	Patient Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-06010	New LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-06060	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-00708	Main Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-03443	Main Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-03444	Bridge at Link	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01285	Admin.	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01286	Laundry/Hall of Health	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01287	Boiler	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01288	1968 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01289	1975 Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01290	1985 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01291	Electric Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Not Submitted	
01 - Alameda	11214	Alta Bates Summit Medical Center- Alta Bates Campus	BLD-01292	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	18180	Eden Medical Center	BLD-05340	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	18180	Eden Medical Center	BLD-05341	Chiller Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	18180	Eden Medical Center	BLD-05342	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
01 - Alameda	18180	Eden Medical Center	BLD-05343	Emergency Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
01 - Alameda	11268	Fairmont Hospital	BLD-01311	Building B	OSHPD 2-Skilled Nursing Only	N/A								N/A				
01 - Alameda	11268	Fairmont Hospital	BLD-01312	Building H	OSHPD 1R-Delicensed Clinic under OSHPD	N/A	Withdrawn					7/1/2019 Risk Bsd Replace		N/A				
01 - Alameda	11288	Highland Hospital	BLD-01315	Critical Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
01 - Alameda	11288	Highland Hospital	BLD-02957	New Acute Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
01 - Alameda	11288	Highland Hospital	BLD-06256	Critical Care Parking Structure	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
01 - Alameda	11288	Highland Hospital	BLD-06880	Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02489	Hospital Patient Wing North	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02490	Hospital Patient Wing South	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02491	Hospital North	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02492	Hospital South	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02493	Central Plant	OSHPD 1-In Service	5								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02494	General Services Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07247	Entry Canopy	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Not Submitted		
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-02986	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/08/2023		
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-02987	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/08/2023		
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-05716	Loading Dock and Plaza	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/08/2023		
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	BLD-03481	Templated Hospital Project	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023		
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	BLD-03482	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023		
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00692	Original Building	OSHPD 1-In Service	2						1/1/2015 Com Acc Retrofit		3		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00693	Outpatient Diag. & Treat. Center	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00694	Boiler Enclosure	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023		
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-03083	Surgery Addition - Structurally connected to BLD-00692	OSHPD 1-Not an Independent Building	N/A								N/A					
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-05427	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023		
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-05428	Liquid Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023		
01 - Alameda	11256	San Leandro Hospital	BLD-01300	Main/Original Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
01 - Alameda	11256	San Leandro Hospital	BLD-02709	Emergency Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
01 - Alameda	11256	San Leandro Hospital	BLD-07123	Aboveground Fuel Storage Tank	OSHPD 1-Under Construction	N/A								4s					
01 - Alameda	11256	San Leandro Hospital	BLD-07270	SPD Addition	OSHPD 1-Proposed	5s								4s					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
01 - Alameda	11344	St Rose Hospital	BLD-00709	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Awaiting review 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11344	St Rose Hospital	BLD-00710	Engineering/Boiler Building - Structurally connected to BLD-00709	OSHPD 1-Not an Independent Building	N/A								N/A					
01 - Alameda	11344	St Rose Hospital	BLD-00711	Emergency and Critical Care Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Awaiting review 12/13/2023		
01 - Alameda	11344	St Rose Hospital	BLD-00712	Chiller/Generator Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Awaiting review 12/13/2023		
01 - Alameda	11344	St Rose Hospital	BLD-03084	Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A								N/A					
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-00005	Hospital Building	OSHPD 1-In Service	2						3/31/2013 Risk Bsd Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-00006	Boiler Building	OSHPD 1-In Service	2						1/1/2015 Risk Bsd Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-00007	Emergency Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-00008	Hospital Building-1967 Addition - Structurally connected to BLD-00005	OSHPD 1-Not an Independent Building	N/A								N/A					
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-00009	Hospital Building - 1977 Addition - Structurally connected to BLD-00005	OSHPD 1-Not an Independent Building	N/A								N/A					
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-02992	Lobby Addition to Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
01 - Alameda	11363	Stanford Health Care Tri-Valley	BLD-03085	Building D: Service Building	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02532	Hospital Ambulatory Care & Inc. II	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023		
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02533	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023		
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02534	Valleycare (New) Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/27/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02699	Arcade - Phase I - Portion 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02700	Arcade - Phase II - Portion 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02701	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: In Review 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02901	Arcade - Phase I - Portion 2	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02902	Arcade - Phase I - Portion 3	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02903	Arcade - Phase II - Portion 2	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: In Review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-06430	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-06566	Emergency Generator Set	OSHPD 1-Under Construction	N/A								4s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07315	East Wing Hospital Addition	OSHPD 1-Proposed	5s								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07316	Canopy	OSHPD 1-Proposed	5s								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07317	NPC-5 Potable Water Storage Tank Enclosure	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01293	Cardiac Cath Lab - MPOE	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01294	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01295	West Site Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01296	Cafeteria Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01297	Diagnostic & Treatment Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01298	B/C Wing	OSHPD 1-In Service	1					1/1/2020 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01299	A/B Wing	OSHPD 1-In Service	1					1/1/2020 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-03121	Loading Dock	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Not Submitted	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05214	Western Expansion Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05822	Outpatient Clinic	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05837	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05856	Outpatient Center 2	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-06714	Walkway	Unknown-Outpatient Only	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07163	Medical Gas Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07178	Above Grade Fuel Tank	OSHPD 1-Under Construction	N/A								4s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07184	New Hospital Building	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07188	Site Support Building	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11366	Washington Hospital	BLD-00713	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00714	South Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	11366	Washington Hospital	BLD-00715	Emergency Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00716	Areas No. 1 and 2 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00717	Area No. 3 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00718	Area No. 4 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00719	Area No. 5 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00720	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03561	Center for Joint Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03562	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03563	Center for Joint Replacement - Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03564	Interim Loading Dock	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03565	Underground Service Passage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05627	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
01 - Alameda	11366	Washington Hospital	BLD-05628	Canopy #1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-05629	Canopy #2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-05630	Canopy #3	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-05632	Pedestrian Walkway #1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-05633	Pedestrian Walkway #2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-06563	Pedestrian Bridge	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-06840	Emergency Room Addition	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-07118	Center for Joint Replacement - Hallway	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-07139	Pedestrian Walkway #2A	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
01 - Alameda	11366	Washington Hospital	BLD-07140	Pedestrian Walkway #2B	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
03 - Amador	17490	Sutter Amador Hospital	BLD-00089	Hospital Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/27/2023		
03 - Amador	17490	Sutter Amador Hospital	BLD-05532	Emergency Department Entry Porte Cochere - Low	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
03 - Amador	17490	Sutter Amador Hospital	BLD-05533	Emergency Department Entry Porte Cochere - High	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
03 - Amador	17490	Sutter Amador Hospital	BLD-07058	Entry Canopy	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Not Submitted		
04 - Butte	10013	Enloe Health	BLD-00110	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00111	O.B. First Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
04 - Butte	10013	Enloe Health	BLD-00112	O.B. Second Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00113	Administration Third Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00114	Surgery Wing	OSHPD 1-In Service	2				Denied				2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00115	Corridor No. 1	OSHPD 1-In Service	2				1/1/2016 Com Acc Retrofit				2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00116	South Wing - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00117	Trauma	OSHPD 1-In Service	2				1/1/2015 Com Acc Replace				2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00118	Pharmacy	OSHPD 1-In Service	2				1/1/2015 Com Acc Remove GAC				2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00119	Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00120	Cath Lab No. 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00121	Radiology - Oncology - Structurally connected to BLD-02935	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00122	Cath Lab No. 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00123	Surgery Addition	OSHPD 1-In Service	4				Denied				2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00124	Waiting Area/Corridor No. 2	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
04 - Butte	10013	Enloe Health	BLD-02934	Magnolia Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
04 - Butte	10013	Enloe Health	BLD-02935	O.R. Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-02936	E.R. Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-07192	Angiography Room 5 Suite	OSHPD 1-Proposed	5s								4s				
04 - Butte	16464	Enloe Rehabilitation Center	BLD-00086	Rehabilitation Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/07/2013	Rpt: Not Submitted	
04 - Butte	10006	Orchard Hospital	BLD-00090	Main Hospital Building & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	BLD-00091	East Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00092	North Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00094	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	BLD-00095	Warehouse Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00096	18 Bed Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00097	Surgical Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00098	X-Ray Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00099	Entry Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00100	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10006	Orchard Hospital	BLD-02933	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00134	1960 Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
04 - Butte	10019	Oroville Hospital	BLD-00135	1963 Structural Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00136	1968 36 Bed Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00137	1971 X-Ray Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00138	1972 ICU Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00139	1974 ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00140	1978 Pathology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00141	1979 Business/Lobby Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00142	1979 Nuclear Medicine Addition - Structurally connected to BLD-00140	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00143	1989 South Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/11/2024	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00144	1997 Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-03175	1979 Kitchen/Dining Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-03844	1989 South Wing Addition - 1 story	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-06111	Orohealth Hospital New Patient Tower	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-06789	Orohealth Hospital Chiller Enclosure	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-06790	Orohealth Hospital Generator Enclosure	OSHPD 1-Under Construction	5s								5s				
05 - Calaveras	10029	Mark Twain Medical Center	BLD-00131	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
05 - Calaveras	10029	Mark Twain Medical Center	BLD-00132	South Wing	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Review Completed 12/26/2023	
05 - Calaveras	10029	Mark Twain Medical Center	BLD-06006	South Wing - Link Corridor	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Review Completed 12/26/2023	
05 - Calaveras	10029	Mark Twain Medical Center	BLD-07009	Steam Boilers Shed	OSHPD 1-Proposed	5s								4s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
06 - Colusa	10032	Colusa Medical Center	BLD-00133	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
06 - Colusa	10032	Colusa Medical Center	BLD-06329	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
06 - Colusa	10032	Colusa Medical Center	BLD-06475	Skilled Nursing Building	Local-Proposed	N/A								N/A				
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-02468	1 - Main Hospital	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Awaiting review 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-02469	16 - Main Entrance Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Awaiting review 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-03719	2 - Clinical Lab	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Awaiting review 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-03852	Cafeteria	OSHPD 1-In Service	2					Denied			3		Rpt: Review Completed 12/27/2023	Rpt: Awaiting review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-05505	Lower Generator Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/27/2023	Rpt: Awaiting review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-06510	Mechanical Shed	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Awaiting review 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07280	Walkway	OSHPD 1-In Service	5s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02472	Original Hospital (Elevator Tower)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02473	C Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02474	Elevator/Stair Tower - Structurally connected to BLD-02472	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02475	C Wing-East Wing-North West Element - Structurally connected to BLD-02476	OSHPD 1-Not an Independent Building	N/A								N/A					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02476	D Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						7/1/2019 Com Acc Rebuild		N/A					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02477	D Wing-North Wing-Infill - Structurally connected to BLD-02473	OSHPD 1-Not an Independent Building	N/A								N/A					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02478	C Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02479	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02480	B Wing / Surgery Equipment Room	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02481	Surgery Equipment Room - Structurally connected to BLD-02480	OSHPD 1-Not an Independent Building	N/A								N/A					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02482	Cancer Center	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02483	Emergency Room	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02484	Canopy - Structurally connected to BLD-02483	OSHPD 1-Not an Independent Building	N/A								N/A					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02485	A Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02486	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02487	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02488	Boiler Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02939	Canopy 1	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02940	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02941	Canopy 2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02946	Canopy 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05223	E Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05921	E-1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05971	HVAC Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-06886	LOX Yard	OSHPD 1-Proposed	N/A								4s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00478	Original Hospital (Tower & Low Rise)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00479	Phase 2 Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00480	Phase 2 Cafeteria / Cardiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00481	Phase 2 ER / Radiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00482	Phase 3 West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00484	MRI Addition - Structurally connected to BLD-00478	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-02944	Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-05222	Phase 4 Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-05308	Phase 3 West Wing - East Portion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-03744	Hospital Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Awaiting review 12/08/2023		
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-03745	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/08/2023		
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-02453	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 04/20/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-02454	Central Service Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-07211	Hospital Addition - 2005	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-07212	Tech Dock	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02447	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 08/14/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02448	North Addition (Hospital Tower)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/14/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02449	Phase 1 Hospital - Utility Expansion	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02450	Phase II Hospital	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02451	Generator Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02452	Waste, Gas Farm Enclosure	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-03504	Phase II Link Corridor	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-07034	Drop Off Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/06/2023		
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-00276	Main Hospital	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023		
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-05620	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-05621	OR Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-06290	New Pharmacy	OSHPD 1-Proposed	5s								4s				
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-06829	Infrastructure Yard	OSHPD 1-Proposed	5s								4s				
07 - Contra Costa	16166	San Ramon Regional Medical Center South Building	BLD-03688	Rehabilitation Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02461	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02462	ER / Lab Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02466	Nursing Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02467	Ambulatory Services	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03032	Mechanical Building - Structurally connected to BLD-02461	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03033	OR Storage Expansion	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03034	Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Not Submitted	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03484	Womens Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03667	Nursing Tower - Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03668	Nursing Tower - Dining Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03669	Nursing Tower - Admin Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice	
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**						
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03670	Nursing Tower - Lobby Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023		
08 - Del Norte	12784	Sutter Coast Hospital	BLD-01054	Hospital Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/30/2023		
08 - Del Norte	12784	Sutter Coast Hospital	BLD-01055	Special Care Unit	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023		
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00485	Original and Nursing Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00486	Two Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Review Completed 12/18/2023		
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00487	Mechanical Plant and Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Not Submitted		
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00488	MRI Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
09 - El Dorado	10109	Barton Memorial Hospital	BLD-05600	New Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
09 - El Dorado	10109	Barton Memorial Hospital	BLD-06620	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Not Submitted		
09 - El Dorado	10112	Marshall Medical Center	BLD-00489	Original Building (Bldg I)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
09 - El Dorado	10112	Marshall Medical Center	BLD-00490	1971 Addition No. 1 (Bldg II)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
09 - El Dorado	10112	Marshall Medical Center	BLD-00491	1971 Addition No. 2 (Bldg III) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A								N/A					
09 - El Dorado	10112	Marshall Medical Center	BLD-00492	1974 Addition (Bldg IV)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023		
09 - El Dorado	10112	Marshall Medical Center	BLD-00493	1981 Addition No. 1 (Bldg V)	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
09 - El Dorado	10112	Marshall Medical Center	BLD-00494	1981 Addition No. 2 (Bldg VI)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-00495	1988 Addition (Bldg VII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-00496	1991 Addition (Bldg VIII) - Structurally connected to BLD-00494	OSHPD 1-Not an Independent Building	N/A								N/A				
09 - El Dorado	10112	Marshall Medical Center	BLD-00497	1964 Addition (Bldg IX) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A								N/A				
09 - El Dorado	10112	Marshall Medical Center	BLD-05594	2012 Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06515	2012 Addition - Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06516	2012 Addition - Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06517	2012 Addition - South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06518	2012 Addition - Center Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06519	2012 Addition - North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06617	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06982	Ambulance Canopy	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	10162	Adventist Health Reedley	BLD-00513	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-00514	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	10162	Adventist Health Reedley	BLD-00515	Rec. Room & Office Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-00516	Lab & Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-00517	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-00518	Birthing Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-02949	LDR Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-05522	ER / Radiology / Clinic Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-05681	Generator Shed	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-06036	Lobby Remodel & Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06037	Corridor Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06038	Mechanical & Electrical Building Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06039	Main Entrance Canopy Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06040	ER Canopy Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
10 - Fresno	10160	Adventist Health Selma	BLD-00507	Medical / Surgical / Birthing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	10160	Adventist Health Selma	BLD-00508	Maintenance Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00509	Nursing Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00510	Emergency / Laboratory	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	
10 - Fresno	10160	Adventist Health Selma	BLD-00511	Multi-Use Facility	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00512	Warehouse	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	16116	Clovis Community Medical Center	BLD-00020	Nursing Unit	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00021	Diagnosis and Treatment	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00022	Administration and Support	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00023	Central Plant	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05376	Central Plant Expansion	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05377	Bed Tower	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05378	Diagnostic & Treatment Expansion	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
10 - Fresno	16116	Clovis Community Medical Center	BLD-05379	Support Expansion 1	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05380	Support Expansion 2	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05381	Canopy 1	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-06051	North Bed Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06052	Support Expansion 3A	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06053	Support Expansion 3B	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06054	Diagnostic & Treatment Expansion 3A	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06055	Diagnostic & Treatment Expansion 3B	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06056	Utility Racks	OSHPD 1-Not a Building Structure	N/A								5s	1/1/2030		Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-06556	Bottle Storage	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06591	Front Entry	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06694	Entry Canopy-North	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06695	Entry Canopy-South	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-07148	Emergency Entry Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	10122	Coalinga Regional Medical Center	BLD-00498	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
10 - Fresno	10122	Coalinga Regional Medical Center	BLD-06696	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
10 - Fresno	10127	Community Regional Medical Center	BLD-00003	West Wing / East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02535	Radiology Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02536	Aa - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	10127	Community Regional Medical Center	BLD-02537	Ab - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02538	Ac - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02539	Ad - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02540	Ae - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02541	Angiography Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02951	Trauma & Critical Care Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02952	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02953	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-03513	D/P Skilled Nursing Facility	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-05190	MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-05208	Data Center Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-06508	Trauma Center Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	10127	Community Regional Medical Center	BLD-06509	Trauma Center Utility Tunnel	OSHDP 1-Tunnels	5								4		Rpt: Review Completed 12/20/2023		
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05187	Main Hospital	OSHDP 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023		
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05188	Central Plant	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/21/2023		
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05278	Wing A	OSHDP 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023		
10 - Fresno	16878	Fresno Surgical Hospital	BLD-00294	Recovery Center	OSHDP 1-In Service	4								4		Rpt: Review Completed 12/28/2023		
10 - Fresno	16878	Fresno Surgical Hospital	BLD-03748	Expansion	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
10 - Fresno	16878	Fresno Surgical Hospital	BLD-05252	New Tower	OSHDP 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
10 - Fresno	16878	Fresno Surgical Hospital	BLD-05366	Equipment Yard	OSHDP 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/28/2023		
10 - Fresno	16878	Fresno Surgical Hospital	BLD-07246	New Tower Support	OSHDP 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Not Submitted		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00976	Sequoia Mall	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00977	Hospital Tower North	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00978	Hospital Tower South	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00979	Ancillary/Yosemite Building	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00980	Ancillary Building Addition	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00981	Utility/Grapevine Building	OSHDP 1-In Service	5								4		Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06468	Cooling Tower Yard	OSHDP 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/01/2023	Rpt: Review Completed 11/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06499	Medical Gas Storage	OSHPD 1-In Service	4s								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06502	Medical Waste Enclosure	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06503	Med Gas Cylinder Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06633	Emergency Department Expansion	OSHPD 1-Under Construction	5s								5s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06922	Entrance Canopy	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06923	Utility Shaft	OSHPD 1-Not a Building Structure	N/A								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06924	Fuel Pump House	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06925	Connecting Corridor	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06926	Utility Tunnel	OSHPD 1-Tunnels	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07049	Carpenter Shop	OSHPD 1-In Service	2s								2s	Rpt: Not Submitted	Rpt: Review Completed 11/21/2023		
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07171	Medical Waste Enclosure	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00500	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00501	West Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00502	Cogeneration Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00503	Chapel	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00504	Northwest Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00505	East Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00506	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-03307	Cath Recovery Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-03308	North Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-05548	Canopy and Bridges	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	BLD-05877	UPS Flywheel Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-06564	21 KV Switchgear Building	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-06600	Fire Pump / Chiller Building	OSHPD 1-Under Construction	5s								5s				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07077	North Addition Auditorium	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07078	North Addition Canopy #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07080	North Addition Canopy #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07175	Incinerator Canopy	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	16404	San Joaquin Valley Rehabilitation Hospital	BLD-02531	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/27/2023	Rpt: Open - Returned 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
11 - Glenn	10175	Glenn Medical Center	BLD-00519	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00520	Garage Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00521	600 Wing (Accounting) Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00522	Nurses Locker Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
11 - Glenn	10175	Glenn Medical Center	BLD-03773	Main Building - ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
11 - Glenn	10175	Glenn Medical Center	BLD-03774	Main Building - Dietary / Purchasing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03775	Main Building - 700 Wing South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03776	Main Building - 700 Wing North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03777	Main Building - 800 Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03778	Main Building - Medical / Surgery	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
11 - Glenn	10175	Glenn Medical Center	BLD-03825	Shop & Maint. Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-00751	Main Building and Additions	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Not Submitted	Rpt: Review Completed 09/08/2016	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-03334	ER Addition	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Not Submitted	Rpt: Review Completed 09/08/2016	
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-05453	Clinic Building and Additions	OSHPD 3-Outpatient Only	N/A								N/A				
12 - Humboldt	13087	Mad River Community Hospital	BLD-00186	Main Hospital	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	13087	Mad River Community Hospital	BLD-00187	Central Plant	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	13087	Mad River Community Hospital	BLD-00188	Administration/Urgent Care	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-00189	Short Stay Surgery	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-00190	Obstetrics Addition	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-05471	AHU Platform	OSHPD 1-Under Construction	5s								4s				
12 - Humboldt	13087	Mad River Community Hospital	BLD-05715	Conference Room Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/31/2023	Rpt: Review Completed 12/31/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00529	Original Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00530	O.B. Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00531	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00532	East Wing Expansion	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00533	E. Wing Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-03890	Surgery Department - Structurally connected to BLD-00529	OSHPD 1-Not an Independent Building	N/A								N/A				
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-05824	Rehab. Addition	OSHPD 1-Under Construction	5s								5s				
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00535	Original Hospital and Central Plant	OSHPD 1-In Service	1			Withdrawn		12/31/2019 Com Acc Replace	11/29/2024 AB 2190 Rebuild		2	1/1/2024	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00536	Linear Accelerator (Phase II)	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00537	Phase III Addition Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00538	Emergency Entrance Vestibule	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00539	Radiation Oncology Addition	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00540	Heart Center	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00541	East Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00542	Emergency Entrance Vestibule Addition	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-02735	Emergency Generator #1 CMU Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-02736	Emergency Generator #2 Enclosure Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03375	Northeast Building Entry Link	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03376	Fire Pump House	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03625	Northeast Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-05767	Northeast Building Ambulance Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-05768	Northeast Building Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06703	Hospital	OSHPD 1-Proposed	5s								5s					
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06704	Entry Canopy	OSHPD 1-Proposed	5s								5s					
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06705	ED Canopy	OSHPD 1-Proposed	5s								5s					
12 - Humboldt	10180	The General Hospital	BLD-00523	Original Hospital Building	OSHPD 1-In Service	1						7/1/2019 Com Acc Replace	12/31/2024 AB 2190 Rebuild	2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-00524	1950 Addition Building	OSHPD 1-In Service	1						7/1/2019 Com Acc Replace	12/31/2024 AB 2190 Rebuild	2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-00525	1955 Addition Building	OSHPD 1-In Service	1						7/1/2019 Com Acc Replace	12/31/2024 AB 2190 Rebuild	2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-00526	Center Building - 1957 Addition	OSHPD 1-In Service	1						7/1/2019 Com Acc Replace	12/31/2024 AB 2190 Rebuild	2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-02651	West Side Building - 1957 Addition	OSHPD 1-In Service	1						7/1/2019 Com Acc Replace	12/31/2024 AB 2190 Rebuild	2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-02652	Stair #1	OSHPD 1-In Service	4								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-02653	Nursery	OSHPD 1-In Service	4								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		
12 - Humboldt	10180	The General Hospital	BLD-02654	Stair #2	OSHPD 1-In Service	4								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
12 - Humboldt	10180	The General Hospital	BLD-02655	Stair #3	OSHPD 1-In Service	4								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC	
12 - Humboldt	10180	The General Hospital	BLD-02656	Radiology Wing	OSHPD 1-In Service	4								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC	
12 - Humboldt	10180	The General Hospital	BLD-02657	Lobby	OSHPD 1-In Service	3								2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00752	South Wing	OSHPD 1-In Service	1	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00753	L/D Bldg	OSHPD 1-In Service	1	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Not Submitted	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00754	Central Wing	OSHPD 1-In Service	1	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00755	West Addition - Structurally connected to BLD-00754	OSHPD 1-Not an Independent Building	N/A	01/01/2020							N/A				
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00756	Central Plant	OSHPD 1-In Service	1	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00757	North Wing	OSHPD 1-In Service	1	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00758	ICU Addition - Structurally connected to BLD-00757	OSHPD 1-Not an Independent Building	N/A								N/A				
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00759	Admin Bldg	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00760	OB Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00761	Radiology Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00762	Rad Annex	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00763	Lab Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-00764	Annex	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-02685	East Wing - South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-02686	New Wing	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
13 - Imperial	10190	El Centro Regional Medical Center	BLD-02687	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
13 - Imperial	10190	El Centro Regional Medical Center	BLD-02887	Admin Bldg Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-02888	East Wing - North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Not Submitted		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-03219	Electrical Room	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-03331	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-05694	Ancillary Services Building	OSHPD 1-Under Construction	5s								4s					
13 - Imperial	10190	El Centro Regional Medical Center	BLD-05940	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06098	Data Center Building	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06389	Entrance Lobby	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06390	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06391	Driveway Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06392	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06408	Utility Canopy	OSHPD 1-Under Construction	5s								5s					
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06419	North ASB Utility Canopy	OSHPD 1-Under Construction	5s								4s					
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06420	South ASB Utility Canopy	OSHPD 1-Under Construction	5s								4s					
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06421	ASB Covered Link	OSHPD 1-Under Construction	5s								4s					
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06427	Central Plant Shed	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06428	Hazardous Waste Storage	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10190	El Centro Regional Medical Center	BLD-06429	Pharmacy Expansion	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00765	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Review Completed 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00766	Original Power Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Review Completed 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00767	Administration Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Review Completed 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00768	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00769	Outpatient Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00770	Women's Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00771	ER	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00772	New Power Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-00773	Dietary	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-02892	Link between 05B and 01A	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-02893	Link between 05B and 05C	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-05909	Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Healthcare District	BLD-06240	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Review Completed 10/31/2024	
14 - Inyo	10200	Northern Inyo Hospital	BLD-00775	Main Hosp Bldg/Existing Central Plant	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
14 - Inyo	10200	Northern Inyo Hospital	BLD-00776	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-00777	Central Plant Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-00778	Emergency Generator Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-02922	New Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
14 - Inyo	10200	Northern Inyo Hospital	BLD-05321	New Central Plant Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-06524	Covered Walkway - West	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
14 - Inyo	10200	Northern Inyo Hospital	BLD-06525	Covered Walkway - North	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-06526	Corridor Connection	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00779	Main Hospital Building	OSHPD 1-In Service	2						1/1/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00780	Maintenance Building	OSHPD 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00781	Entrance Addition - Structurally connected to BLD-00779	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00782	East Wing Addition	OSHPD 1-In Service	2						7/1/2019 Risk Bsd Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00783	West Wing Addition - Structurally connected to BLD-00779	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00784	Diagnostics & Treatment Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00785	Patient Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00786	Storage Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00787	Boiler Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00788	Boiler Room 2 Addition - Structurally connected to BLD-00787	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00789	Laundry Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00790	Storage Building	OSHPD 1-In Service	2						7/1/2019 Risk Bsd Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12881	Adventist Health Bakersfield	BLD-00948	Original Building (Main Hospital)	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
15 - Kern	12881	Adventist Health Bakersfield	BLD-00949	Emergency Department Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00951	Emergency Generator Enclosure	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00952	Fire Pump Enclosure	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00953	Bulk Medical Storage Facility	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-06018	Tower Number 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-06555	New Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-07024	Tank Storage	OSHPD 1-In Service	2s								2s		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01049	Main Building	OSHPD 1-In Service	2	Withdrawn							2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12765	Adventist Health Delano	BLD-01050	Radiology Addition	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01051	ICU/TCU Facility	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01052	Med Gases Ancillary	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01053	Med Gases	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-05953	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
15 - Kern	12765	Adventist Health Delano	BLD-06162	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-06618	Switchgear Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
15 - Kern	12765	Adventist Health Delano	BLD-06622	Hospital Entry Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	17358	Adventist Health Specialty Bakersfield	BLD-00085	Bakersfield Heart Hospital	OSHDP 1-In Service	5								4		Rpt: Review Completed 06/06/2024		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-03237	Main Entrance Building	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05541	Medical / Surgical Facility Building	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05542	Obstetrical Facilities Building	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05543	D & T Building	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05544	Main Entrance Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05545	ED Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05546	CT Trailer Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05547	Water Tank	OSHDP 1-Not a Building Structure	N/A								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06624	Main Entrance High Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06625	ED High Canopy	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06626	Trash Enclosure	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/22/2023		
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06627	Mechanical Yard	OSHDP 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/22/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00791	Main Hospital / Lobby / Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00792	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00793	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00794	Main Hospital West Wing / Business Office	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00795	Maternity Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00796	Labor & Delivery	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00797	Labor & Delivery II	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00798	Main Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00799	New Cath Lab & Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00800	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00801	Main Hospital East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03377	Endoscopy Building	OSHPD 1-In Service	2									2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03378	Main Tower - Connecting Corridor	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03379	Laundry / Warehouse Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A									N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05215	Entrance Pavilion	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05659	Endoscopy Corridor	OSHPD 1-In Service	2									2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05896	Cardiac Rehab	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A									N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05897	Physical Therapy / Regional Human Resources	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A									N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05902	Ambulance Porte Cochere	OSHPD 1-In Service	5s									2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06326	Kitchen / Shell Bldg.	OSHPD 1-In Service	5s									4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06357	Pediatric Pavilion for Emergency Care	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06373	Lobby Expansion	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06497	Utility Tunnel	OSHPD 1-Tunnels	N/A									2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06330	Vibra Rehabilitation Hospital of Bakersfield	OSHPD 1-In Service	5									5				Earthquake Resilient
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06332	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A									5				
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06333	O2 Yard	OSHPD 1-Equipment Yard	N/A									5				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06334	Main Entry Drop Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-00281	East Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/27/2023		
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-00282	West Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/27/2023		
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05565	20 Bed Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023		
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05566	Emergency Power Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023		
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05567	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023		
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07088	Generator Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023		
15 - Kern	10219	Good Samaritan Hospital	BLD-00811	Original Hospital & Additions	OSHPD 1-In Service	2						1/1/2014 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10219	Good Samaritan Hospital	BLD-00812	Pediatrics Wing & Additions	OSHPD 1-In Service	2						1/1/2015 Fin Hdsp Replace		2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10219	Good Samaritan Hospital	BLD-00813	Patient Wing	OSHPD 1-In Service	2						1/1/2014 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10219	Good Samaritan Hospital	BLD-00814	Intensive Care Unit Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
15 - Kern	10208	Kern Medical Center	BLD-00803	Wing B/C - North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10208	Kern Medical Center	BLD-00804	Wing D	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
15 - Kern	10208	Kern Medical Center	BLD-00805	Wing E	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-00806	Infill at E Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-00807	Wing G / Laundry / Boiler Room	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2018 Com Acc Rebuild			N/A				
15 - Kern	10208	Kern Medical Center	BLD-00808	Wing G/Dietary	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10208	Kern Medical Center	BLD-00809	Central Utilities Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-03806	Wing B/C - South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	BLD-00810	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	BLD-02964	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02965	Surgical Suite Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02966	Service Facility Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02967	Skilled Nursing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-07133	Connecting Corridor	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
15 - Kern	10214	Mercy Hospital	BLD-00827	Main Wing/Courtyard Infill	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	BLD-00828	Addition to the Main Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00829	Patient Tower (T & D Stair No. 3)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00830	Treatment and Diagnostic Building (Central Plant and Emergency Generator Enclosure)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00831	T & D Admitting Wing (Boiler Building and Mezzanine)	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	BLD-00832	T & D Stair No. 1 (Laundry Building)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	BLD-00833	T & D Stair No. 2 (Treatment and Diagnostic Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00834	T & D Stair No. 3 (T & D Stair No. 4)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00835	T & D Stair No. 4 (Patient Tower)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00836	Boiler Building and Mezzanine (T&D Stair Number 1)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00837	Central Plant and Emergency Generator Enclosure (T&D Admitting Wing)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-03315	Corridor - Northwest Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-05203	Boiler Building and Mezzanine (T&D Stair Number 2)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06181	Porte Cochere	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06182	Corridor - Northeast Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06196	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06207	Emergency Generator and Aboveground Fuel Tank	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	17632	Mercy Southwest Hospital	BLD-02623	Main Hospital Building 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
15 - Kern	17632	Mercy Southwest Hospital	BLD-02624	Main Hospital Building 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
15 - Kern	17632	Mercy Southwest Hospital	BLD-06359	New Four Story Patient Tower	OSHPD 1-Under Construction	5s								5s					
15 - Kern	17632	Mercy Southwest Hospital	BLD-06360	New Two Story East Addition	OSHPD 1-Under Construction	5s								5s					
15 - Kern	17632	Mercy Southwest Hospital	BLD-06361	New One Story West Addition	OSHPD 1-Under Construction	5s								5s					
15 - Kern	17632	Mercy Southwest Hospital	BLD-06362	New Central Utility Plant	OSHPD 1-Under Construction	5s								5s					
15 - Kern	17632	Mercy Southwest Hospital	BLD-06363	Main Entry Canopy	OSHPD 1-Under Construction	5s								5s					
15 - Kern	17632	Mercy Southwest Hospital	BLD-06364	Loading Dock Canopy	OSHPD 1-Under Construction	5s								5s					
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00815	Main Core	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00817	B Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00818	C Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00819	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00820	D Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00821	E Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-03483	Addition to Existing Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-03619	Cafeteria / Dining Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06578	Entrance Canopy 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06579	New Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06580	Electrical Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06582	Entrance Canopy 2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-05346	Main Hospital - West Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/26/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-05347	Main Hospital - East Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/26/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-05570	Womens Center	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/26/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-05571	Energy Center	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/26/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-06785	Trellis	OSHPD 1-Not a Building Structure	N/A								4		Rpt: Review Completed 12/26/2023		
16 - Kings	18194	Adventist Health Hanford	BLD-07179	Cath Lab	OSHPD 1-Proposed	5s								5s				
17 - Lake	10247	Adventist Health Clearlake	BLD-00431	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 10/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
17 - Lake	10247	Adventist Health Clearlake	BLD-00432	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-00434	Central Supply/Maintenance	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-05509	Chiller Platform	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-06023	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-07026	ED Department	OSHPD 1-In Service	5								4			Rpt: Review Completed 10/27/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
17 - Lake	10247	Adventist Health Clearlake	BLD-07131	ED Department Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 10/27/2023		
17 - Lake	10247	Adventist Health Clearlake	BLD-07145	Med Gas Storage	OSHPD 1-In Service	5								4		Rpt: Review Completed 10/27/2023		
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00268	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00269	Hospital Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00270	CT Scanner	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-02981	Conference Room - Structurally connected to BLD-00268	OSHPD 1-Not an Independent Building	N/A								N/A				
17 - Lake	14345	Sutter Lakeside Hospital	BLD-02982	LDRP Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-03052	Purchasing Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
17 - Lake	14345	Sutter Lakeside Hospital	BLD-03558	Surgery & Emergency Department	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-06296	Pharmacy Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-06486	ED Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-07254	MRI Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
18 - Lassen	17940	Banner Lassen Medical Center	BLD-05185	Main Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
18 - Lassen	17940	Banner Lassen Medical Center	BLD-06331	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01940	Rehabilitation Wing	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01941	Mental Health Building	OSHPD 5-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01942	Main Building - North East - Structurally connected to BLD-03263	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01943	Main Building - South	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01944	Main Building - West (SICU)	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01945	Main Building - Stair Tower #5	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01946	Wilson Parking Structure	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01949	Link Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01950	Link Building - West	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01951	Link Building - East	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01952	TCU	OSHPD 1-In Service	2					7/16/2013 Risk Bsd Retrofit			4D-L1		Rpt: Review Completed 12/28/2023		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01953	D & T / D & T Plant	OSHPD 1-In Service	2								4D-L1		Rpt: Review Completed 12/28/2023		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03015	Womens Pavilion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03016	Mental Health Bldg South Addition	OSHPD 5-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03263	Main Building - North East	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03439	West Tower Phase 2 / 3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03440	West Tower Phase 1	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03441	West Tower Link to Main Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03762	Main Building - Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03913	Main Building - North	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-05932	Exhaust Stack	OSHPD 1-Not a Building Structure	N/A								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-06399	Compounding Pharmacy Building	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07021	Addition #1	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07022	Addition #2	OSHPD 1-In Service	4s								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07023	Addition #3	OSHPD 1-In Service	4s								3		Rpt: Already Approved 12/20/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02187	D & T Building (North Tower)	OSHPD 1R-Delicensed Clinic under OSHPD	N/A								N/A				
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02188	East Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02189	Chiller Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02191	East Building North Addition (B-1)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02192	South Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02193	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03157	East Building South Addition (B-2)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03287	Shop Building Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03288	Boiler Building Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03290	Service Tunnel Replacement	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03291	Specialty Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03859	Entry Concourse Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06511	Entry Concourse Building (South)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06512	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06513	Stair / Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06514	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06520	Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00613	Service Building & Additions (Block I)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00614	Home Health (Block II) Nursing & Lab	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00615	Nursing Administration (Block III)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00616	Accounting & Respiratory Therapy (IV)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00617	Emerson Wing - Nursing Unit (V) - Structurally connected to BLD-00614	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00618	Main Building North (Block VI)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00619	Canopy (Block VII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00620	OB Addition (Block VIII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00621	MRI Facility (Block IX)	OSHPD 1-In Service	5				Denied				2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-03872	Main/Utility/Tower (Block VI)	OSHPD 1-In Service	2				12/1/2016 Com Acc Retrofit				2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-05504	Central Plant and Ambulance Area	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-06415	Equipment Yard – Hot Water System	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-06729	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11386	Alhambra Hospital Medical Center	BLD-00722	Hospital	OSHPD 1-In Service	2	Denied				1/1/2015 Risk Bsd Retrofit			3		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00737	Original Hospital	OSHPD 1-In Service	2			01/01/2015		12/31/2019 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00738	Storeroom Addition	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00739	East Wing Addition	OSHDP 1-In Service	2			01/01/2015			12/31/2019 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00740	Dining Room Addition	OSHDP 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00741	Cobalt Addition	OSHDP 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00742	Hospital Addition	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00743	Central Plant	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00744	Emergency Room Addition - Structurally connected to BLD-00746	OSHDP 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00745	Storage Building	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00746	Hospital Tower Addition	OSHDP 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00747	Central Plant Addition	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00748	Entrance Addition - Structurally connected to BLD-00742	OSHDP 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00749	Kitchen and Dining Additions (west side addition) - Structurally connected to BLD-02621	OSHDP 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00750	Storeroom & Dock Addition - Structurally connected to BLD-00738	OSHDP 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02621	Kitchen Addition	OSHDP 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02804	New Women's and Children's Hospital	OSHDP 1-In Service	5								4			Rpt: Review Completed 01/02/2024	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02805	New WCH Central Plant	OSHDP 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-03486	Northeast Canopy	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05484	Kitchen and Dining Additions (east side addition) - Structurally connected to BLD-02621	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05708	New Women's and Children's Hospital Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05709	New Women's and Children's Hospital Electrical Room	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05711	New Women's and Children's Hospital LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06091	Central Plant Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06107	Entrance Canopy	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06108	Central Plant Addition - West	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06501	Prefabricated ED Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06646	Replacement Hospital	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06647	Main Entry Canopy	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06648	Emergency Entrance Canopy	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06650	Central Utility Plant	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00730	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00731	Dining/Kitchen Building & Additions (1902)	OSHPD 1-In Service	2			01/01/2015					3		Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00732	1927 Addition (Original Building)	OSHPD 1-In Service	2			01/01/2015					2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00733	1974 Addition "A"	OSHPD 1-In Service	2			01/01/2015					2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-02707	1974 Addition "B"	OSHPD 1-In Service	2			01/01/2015					3		Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-02708	1974 Addition "C"	OSHPD 1-In Service	2			01/01/2015					3		Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-03010	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06457	Utility Building	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06489	Entry Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06490	Rear Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06717	Emergency Generator Yard	OSHPD 1-Proposed	N/A								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06718	Above Ground Water Tank	OSHPD 1-Proposed	N/A								4s				
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00622	Tibbitts Tower A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00623	Tibbitts Tower B	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00625	D & T Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00626	1963 Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00627	1969 Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice	
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**						
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00628	1964 Tower	OSHPD 1-In Service	1						7/1/2019 Com Acc Rebuild	1/1/2025 AB 2190 Rebuild		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03122	Lobby	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03212	Emergency Department and Women's Services	OSHPD 1-Under Construction	5s									5s				
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03213	Stair Tower	OSHPD 1-Under Construction	5s									5s				
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03214	Entry Canopy	OSHPD 1-Under Construction	5s									4s				
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-06543	Cooling Tower Platform	OSHPD 1-Not a Building Structure	N/A									2		Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-00940	Main Hospital	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-02910	LOX Yard	OSHPD 1-Equipment Yard	N/A									4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-03876	Trigen Central Plant	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-03908	Central Plant Expansion 3	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-05781	Drop Off Canopy	OSHPD 1-In Service	5s									4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-02885	New Replacement Hospital	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05310	Medical Surgical Addition and 31 Bed Hospital	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05311	Electrical Building	OSHPD 1-In Service	5									4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05473	Mechanical Yard Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	11496	Casa Colina Hospital	BLD-06219	Welcome Gallery	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	11496	Casa Colina Hospital	BLD-06220	Imaging Connector	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
19 - Los Angeles	10095	Catalina Island Medical Center	BLD-07226	Hospital	OSHPD 1-Proposed	5s								5s					
19 - Los Angeles	10095	Catalina Island Medical Center	BLD-07227	ER Canopy	OSHPD 1-Proposed	5s								5s					
19 - Los Angeles	11410	Catalina Island Medical Center	BLD-00725	Original Building	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11410	Catalina Island Medical Center	BLD-00726	East Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01039	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01040	CCU Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01041	Outpatient Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06232	Pharmacy Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06366	Hospital	OSHPD 1-Under Construction	5s								5s					
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06367	Central Utility Plant (Energy Center)	OSHPD 1-Under Construction	5s								5s					
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06368	Gas Yard	OSHPD 1-Under Construction	N/A								5s					
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06418	Hospital Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06572	Loading Dock	OSHPD 1-Under Construction	5s								5s					
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06730	MRI/CT Trailers Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07187	Hospital Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00384	Main Medical Center	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/13/2023	Rpt: Review Completed 03/15/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00385	Harvey Morse Conference Center - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00386	Becker Building - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02806	Imaging Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024		
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02807	Saperstein Critical Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024		
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02808	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024		
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-03438	Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-05255	Thalians Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-05265	Comprehensive Cancer Center	OSHPD 3-Outpatient Only	N/A								N/A					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-05304	Advanced Health Sciences Pavilion	OSHPD 3-Outpatient Only	N/A								N/A					
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00633	West Wing/ER Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00634	North Wing/Day Surgery	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00635	Dietary Storage	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00636	East Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00637	West Tower	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00638	Engineering	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00639	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00640	Central Plant Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-00641	Nursery Addition	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-03466	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-05404	Electrical Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-06894	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinel Hospital Medical Center	BLD-07248	Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00643	Duque Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00644	Page Tower	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00645	McAllister Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00646	Page Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00647	Weingart Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00648	McDonald's Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 09/14/2023	Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-02847	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-02848	DWP Substation	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03292	Central Plant/Anderson Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03293	Subterranean Parking Structure	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03294	Cooling Tower - Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03531	Surgery Center/Anderson Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-05279	Anderson Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023		
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-07000	Duque Building Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00650	Northwest	OSHPD 1-In Service	2	Denied							3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00652	Main Medical	OSHPD 1-In Service	2	Denied							3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00653	ICU	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02575	Wing 1	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02576	Wing 5	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02577	Wing 6	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02578	Food Service Facility	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-03091	Chiller Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-03851	Helford Clinical Research Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06155	Helford Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06683	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06779	Main Medical Stair Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06953	Cogeneration Building	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06956	TES Tank	OSHPD 1-Not a Building Structure	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02151	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02670	Lobby & Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02671	X-ray Entry	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02672	OR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-03646	Telephone Equipment Building	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00402	North and East Wings	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00404	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2025	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00405	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11927	College Medical Center	BLD-00406	Engineering	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2025	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00410	Admin/West Entry Lobby - Structurally connected to BLD-00402	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11927	College Medical Center	BLD-02822	Assembly	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2025	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-06635	North Wing Addition	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11549	Community Hospital Of Huntington Park	BLD-00669	Main Hospital	OSHPD 1-In Service	2					2/1/2016 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11549	Community Hospital Of Huntington Park	BLD-03426	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12024	Docs Surgical Hospital	BLD-01224	Main Hospital - Structurally connected to BLD-05236	OSHPD 1-Not an Independent Building	N/A						Withdrawn		N/A				
19 - Los Angeles	12024	Docs Surgical Hospital	BLD-06601	New Hospital	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00670	Original Building	OSHPD 1-In Service	2	Withdrawn					2/1/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00671	East Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A	Withdrawn					Denied		N/A				
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00672	North Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A	Withdrawn					Denied		N/A				
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00673	South Addition	OSHPD 1-In Service	2	Withdrawn					1/1/2015 Risk Bsd Retrofit		2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00674	South Addition - Structurally connected to BLD-00673	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-00191	Original Building	OSHPD 1-In Service	2								3R		Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-00192	Gift Shop Addition	OSHPD 1-In Service	3								4D-L1			Rpt: Not Submitted	
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-03840	Emergency Dept.	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02019	Original Building	OSHPD 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02020	East Wing Addition	OSHPD 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02021	West Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02022	Psychiatric Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02023	Lobby Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02024	Generator Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02025	Power Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02026	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02027	Conference Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02028	Surgery Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-05422	CCU Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-05423	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-06673	ER Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01163	Main Building	OSHPD 1-In Service	2						1/1/2018 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01164	Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01165	South Wing Addition	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01166	1968 West Wing Addition	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01167	Outpatient Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01168	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01169	1983 Lobby Addition - Structurally connected to BLD-01163	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01171	Chiller Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01172	Cardiac Cath Lab Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01173	Maternal & Child Health Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-03409	Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-05424	Bridge Connector	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06654	ED & ICU Addition Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06655	Connecting Corridor	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06665	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 06/25/2024	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06727	Main Switchgear Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06728	MRI / CT Connecting Corridor	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06796	MRI / CT Pedestrian Walkway	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06815	Pump Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00675	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00676	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00677	Main Tower / Basement / Mech Bldg	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-07165	Lab Extension	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 08/05/2024	Rpt: Not Submitted	
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-07166	Engineering Shop	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 08/05/2024	Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01934	Main Hospital	OSHPD 1-In Service	2	Denied							3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	BLD-01935	Nursery/Post Partum	OSHPD 1-In Service	2	Denied							3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11658	Garfield Medical Center	BLD-01936	Emergency Wing	OSHPD 1-In Service	2	Denied								3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	BLD-01937	O.B. Pavilion	OSHPD 1-In Service	4									4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01938	O.B. Addition	OSHPD 1-In Service	4									4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01939	Cath Lab	OSHPD 1-In Service	3									4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03427	ER Addition	OSHPD 1-In Service	5									4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03428	Extended Service Canopy	OSHPD 1-In Service	4									3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03429	Service Canopy	OSHPD 1-In Service	4									3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-06302	Medical Gas Enclosure	OSHPD 1-Equipment Yard	N/A									4			Rpt: Not Submitted	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01779	Original Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2016 Fin Hdsp Remove GAC			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01780	1942 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2016 Fin Hdsp Replace			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01781	Radiology Addition A - Structurally connected to BLD-01780	OSHPD 1-Not an Independent Building	N/A						Withdrawn			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01782	Radiology Addition B	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2016 Fin Hdsp Remove GAC			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01783	South Tower	OSHPD 1-In Service	2						7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01784	Juncture Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A						7/1/2019 Fin Hdsp Retrofit			N/A	1/1/2030			
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01785	Patient Tower	OSHPD 1-In Service	2						7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01786	Heart and Emergency Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01787	Central Plant	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01788	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-03382	Administration Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	13224	Greater El Monte Community Hospital	BLD-00214	Main Hospital/Radiology Addition	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13224	Greater El Monte Community Hospital	BLD-00215	Nursery & LDR Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00216	Main Hospital - Original Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00217	Main Hospital - Administration Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00218	Main Hospital - Emergency Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00219	Main Hospital - Main Lobby Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00222	Central Plant Building	OSHPD 1-In Service	4								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00223	Pavilion - Main Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00224	Pavilion - Adult Day Health Care	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00225	Pavilion - Pavilion Plant Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-02862	Main Hospital - Emergency Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-02863	Main Hospital- Main Entrance Canopy	OSHPD 1-In Service	4								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03259	Patient Tower	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/14/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03309	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03338	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03413	Loading Dock	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03414	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-05854	Basement Lab Expansion	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-05855	Connecting Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07255	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07321	Radiology Department Expansion	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01977	North Wing	OSHPD 1-In Service	1	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01978	South Wing	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01979	D & T Tower	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01980	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01981	Kitchen Addition	OSHPD 1-In Service	1	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01982	Emergency Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01983	Linear Accelerator Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03505	Chalet Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03506	New Service Yard (Medical Gas Storage)	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03507	Acute Care Services Replacement Building	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-06293	2nd Floor Pedestrian Walkway	OSHPD 1-Under Construction	5s								4s					
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-06723	Switchgear Building	OSHPD 1-Under Construction	5s								4s					
19 - Los Angeles	11733	Huntington Hospital	BLD-02000	East Tower (3 story)	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02001	West Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02002	La Vina Building	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02003	Della Martin Center - Psychiatric B	OSHPD 5-Acute Psych Only	N/A								N/A					
19 - Los Angeles	11733	Huntington Hospital	BLD-02004	Energy Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02005	Chiller Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02008	Cooling Towers	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-02010	Valentine Building - Structurally connected to BLD-02014	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A					
19 - Los Angeles	11733	Huntington Hospital	BLD-02011	Wingate / Hahn Building	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit			3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11733	Huntington Hospital	BLD-02012	Hahn Building - Structurally connected to BLD-02011	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11733	Huntington Hospital	BLD-02013	Service Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A					
19 - Los Angeles	11733	Huntington Hospital	BLD-02014	1938 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Replace			N/A					
19 - Los Angeles	11733	Huntington Hospital	BLD-02015	1921 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11733	Huntington Hospital	BLD-02017	North Parking Structure - Structurally connected to BLD-02000	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02018	Electrical Switchgear Vault	OSHPD 1-In Service	4								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-03301	East Tower (7 story)	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-03302	East Tower Main Lobby	OSHPD 1-In Service	3								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-03303	New Boiler Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05497	ED Addition	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05498	Ambulance Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05796	West Tower Tunnel	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05955	South Campus Utility Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05956	East Tower Utility Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05957	ED Utility Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05970	East Tower Pedestrian Tunnel	OSHPD 1-Tunnels	4								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-05990	Bulk Oxygen Storage	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	11733	Huntington Hospital	BLD-06058	Bulk Oxygen	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/31/2023		
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02519	Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02520	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/05/2022	Rpt: Review Completed 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02521	Clinic Wing	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/05/2022	Rpt: Review Completed 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02522	MRI Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/05/2022	Rpt: Review Completed 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-03509	Clinic - MRI Connector	OSHPD 1-In Service	3								4			Rpt: Review Completed 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-06883	ED Expansion	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-06905	Canopy #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-07295	MRI Addition	OSHPD 1-In Service	5s								4			Rpt: Not Submitted	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05180	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05181	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05914	Canopy 01	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05915	Canopy 02	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05916	Main Building - Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06157	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06158	Main Building - Tower Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06159	ED Drop-Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06323	ED Walk-in Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06324	ED Entry Vestibule	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/19/2023		
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-01707	Centrex Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Review Completed 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-02792	LAMC Hospital - Phase I	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-02793	Central Utility Plant - 1550 Edgemont	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-07038	Pedestrian and Utility Passageway	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/15/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-01698	East MOB	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-02794	New Hospital Replacement Project	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-02795	New Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-05676	South Specialty Medical Office Building	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-06967	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-06968	ER Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02037	South Hospital - Ancillary Wing	OSHPD 1-In Service	3								3		Rpt: Review Completed 07/20/2023	Rpt: Review Completed 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02038	South Hospital - Patient Tower	OSHPD 1-In Service	3								3		Rpt: Review Completed 07/20/2023	Rpt: Review Completed 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02039	South Hospital - Elevator Tower	OSHPD 1-In Service	3								3		Rpt: Review Completed 07/20/2023	Rpt: Review Completed 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02040	South Hospital - Central Plant	OSHPD 1-In Service	4								3		Rpt: Review Completed 07/20/2023	Rpt: Review Completed 12/13/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03086	Boiler House - Structurally connected to BLD-02040	OSHPD 1-Not an Independent Building	N/A									N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03276	Vermont Pavilion	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03277	Annex Connecting Corridor (North)	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-05247	Annex Building	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-05248	Replacement Hospital	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06482	Emergency Department Addition	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06483	Emergency Department Ambulance Canopy	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06687	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06688	Electrical Building	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06689	Emergency Generator Enclosure #1	OSHPD 1-Not a Building Structure	N/A									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06690	Emergency Generator Enclosure #2	OSHPD 1-Not a Building Structure	N/A									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06971	South Hospital - Central Plant Expansion	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07036	Replacement Hospital Corridor #1	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07037	Replacement Hospital Corridor #2	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07051	Annex Connecting Corridor (Center)	OSHPD 1-In Service	5									4		Rpt: Review Completed 12/13/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07052	Annex Connecting Corridor (South)	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07053	Vermont Pavilion Corridor #1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07054	Vermont Pavilion Corridor #2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07055	Vermont Pavilion Corridor #3	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07056	Stair #3	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07059	Water Tank Service Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07060	South Hospital - Generator Cage	OSHPD 1-In Service	4								2	Rpt: Review Completed 07/27/2023	Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07062	South Hospital - Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								2	Rpt: Review Completed 07/27/2023	Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07063	South Hospital - Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07159	Canopy #1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07160	Canopy #2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07161	Pet Scan Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/13/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00327	Medical Center Tower	OSHPD 1-In Service	3								3	Rpt: Review Completed 06/13/2023	Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00328	Plant Services Building	OSHPD 1-In Service	4								3	Rpt: Review Completed 06/13/2023	Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00329	Nursing Tower II	OSHPD 1-In Service	3								2	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 11/17/2023	1/1/2030	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00330	MRI Building	OSHPD 1-In Service	3								3	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05847	Chiller / Generator Support Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05879	Service MSB Yard - Normal Power	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05984	Emergency Department Expansion	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05985	ED Patient Drop-off Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06129	Ambulance/Tech Dock Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06221	Canopy No. 2	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06222	Canopy No. 1	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06452	Tank Farm	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07005	Decontamination Showers	OSHPD 1-In Service	5								4		Rpt: Review Completed 11/17/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00941	Center Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 03/28/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00942	North Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/28/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00943	South Tower	OSHPD 1-In Service	3								3		Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00944	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-03275	West Wing Tower	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-03539	Generator Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06843	24 Hour Outpatient Pharmacy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06844	Covered Walkway #1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06845	West Wing Tower Bridge	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06946	Covered Walkway #2	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06947	Covered Walkway #3	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06948	Covered Walkway #4	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06949	Covered Walkway #5	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07001	Canopy	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07267	MRI 2	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-03163	Main Hospital	OSHPD 1-In Service	4								3	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/20/2023		
19 - Los Angeles	16483	Keck Hospital of USC	BLD-06993	Acute Care Tower	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/20/2023		
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07176	Entry Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07177	Entry Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07231	Infill Building	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11768	Kindred Hospital - La Mirada	BLD-01710	Building I	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Kindred Hospital - La Mirada	BLD-03469	Building II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
19 - Los Angeles	11768	Kindred Hospital - La Mirada	BLD-03470	Building III	OSHPD 1-In Service	2				1/1/2016 Risk Bsd Retrofit				2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Kindred Hospital - La Mirada	BLD-06112	Soiled Linen Storage	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	11768	Kindred Hospital - La Mirada	BLD-06113	Bio-Hazard Storage	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00727	Original Building - Building I	OSHPD 1-In Service	2				1/1/2015 Com Acc Retrofit				2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00728	Southeast Addition - Building III	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00729	Power Service Station - Building IV	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-03027	Addition - Building II	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-03066	Storage / Maintenance - Building V	OSHPD 1-In Service	2				7/1/2017 Com Acc Retrofit				3		Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-05829	Entrance Canopy	OSHPD 1-In Service	2				7/1/2017 Com Acc Retrofit				2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-01722	Building I (Acute Care Facility)	OSHPD 1-In Service	2						7/1/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-05840	Building II (Acute Care Support Services)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-05841	Building III (Acute Care Facility)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03708	Main Hospital	OSHPD 1-In Service	2						3/31/2013 Risk Bsd Retrofit		2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03709	Main Hospital Addition	OSHPD 1-In Service	2						3/31/2013 Risk Bsd Retrofit		2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03710	ICU Addition	OSHPD 1-In Service	2						3/31/2013 Risk Bsd Retrofit		2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-06115	Emergency Generator #2 Yard	OSHPD 1-Under Construction	N/A								4s				
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-00909	Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-00910	Emergency Room	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 03/08/2024	
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-06652	Liquid Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-06653	Emergency Generator	OSHPD 1-Under Construction	N/A								4s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00658	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00659	South Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00660	North Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00661	Laboratory Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-06614	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-06615	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-00055	Hospital and Medical Office	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-00056	Boiler & Emergency Generator	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-03826	Main Hospital - West	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-06178	Oxygen Storage Yard	OSHPD 1-Equipment Yard	N/A								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01759	Main Hospital Building - Patient Tower	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01760	Main Hospital Building - North Wing	OSHPD 1-In Service	2								2	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01761	Main Hospital Building - South Wing	OSHPD 1-In Service	2				1/1/2017 Com Acc Retrofit				2	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01762	Main Hospital Building - Cafeteria	OSHPD 1-In Service	4								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01763	Main Hospital Building - FCLC	OSHPD 1-In Service	2								2	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01764	PCDC Building	OSHPD 1-In Service	3								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01765	Central Plant Building	OSHPD 1-In Service	4								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01766	Central Plant West Expansion	OSHPD 1-In Service	4								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01767	Communications Building 2 East	OSHPD 1-In Service	4								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05316	Surgery / Emergency	OSHPD 1-In Service	5								4		Rpt: Open - Returned 11/26/2024		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05317	Emergency Generator Building	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05318	Tunnel	OSHPD 1-Tunnels	N/A								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05884	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05885	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								2	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06025	Surgery / Emergency Lower Entrance Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06026	Surgery / Emergency Upper Entrance Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06029	Surgery / Emergency Elevator Tower	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06498	12KV Building	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06876	Interim Helipad	OSHPD 1-Proposed	5s								4s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06950	Inpatient Tower	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06954	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07072	Temporary Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07164	Chiller Building	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07217	12kV General Access Power (GAP) Switchgear Building	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00337	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00338	Central Plant	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00339	Cooling Tower	OSHPD 1-In Service	4s								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-03620	Emergency Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-03621	Tuberculosis Isolation Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-05912	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06033	Canopy 05B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06034	Canopy 04B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06035	Canopy 04C	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06168	Emergency Generator	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06684	Emergency Generator Enclosure #1	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06685	Emergency Generator Enclosure #2	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06686	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02502	Bldg 100 Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A					
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02503	Bldg 101/102 Main Hosp Expansion	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02504	Outpatient Entrance Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A					
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02506	JPI Bldg South Wing	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02507	JPI Bldg North Wing	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02508	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02509	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02511	Safety Police Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02514	Building 500	OSHPD 1-In Service	1	01/01/2020						Yes	2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02516	JPI Bldg West Wing	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02924	JPI Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02925	JPI Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-05943	JPI Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 04/21/2021	Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06145	NPC-5 Domestic Water Storage Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06146	NPC-5 Sewer Storage Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/18/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06147	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06643	JPI Bldg Loading Dock	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-00654	Original Building & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-00655	Dietary Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-03779	1st and 2nd Story Addition	OSHPD 1-In Service	2					1/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-06645	Oxygen Farm	OSHPD 1-Proposed	N/A								4s				
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	BLD-00049	Bellflower Medical Center - Building 1	OSHPD 1-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	BLD-03011	Building 2	OSHPD 1-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	BLD-05348	Bellflower Medical Center - Building 1 - South	OSHPD 1-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11428	Los Angeles Community Hospital at Bellflower	BLD-05349	Bellflower Medical Center - Building 1 - North	OSHPD 1-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02749	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02750	New Diagnostic and Treatment	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02751	Inpatient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02047	Medical Records & Laundry (Hospital Service Building (HSB))	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02048	Central Plant Phase I	OSHPD 1-In Service	5	Withdrawn							4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02049	Central Plant Phase II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/23/2015	Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02052	Pediatric Acute Care (Main Lobby and Admitting (MLA))	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02053	Trauma Center (Hospital (IPT))	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02054	Hawkins Building (Augustus F Hawkins Building)	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05261	Central Plant 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05262	Central Plant 4	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05263	Pedestrian Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05264	Ancillary Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05412	Central Plant Phase 1 Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05413	Hawkins Building Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05416	Trauma Center Connecting Tunnel	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05821	Bulk Medical Gas Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05859	Main Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11843	Memorial Hospital of Gardena	BLD-01778	Hospital	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01789	2A-2C- Central Plant & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01791	1E - Center for Health Education - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01792	03 - Memorial West - Nursing Unit	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01793	4A 4B- Memorial West - Rehab Unit	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01794	1B - Old Pathology - Structurally connected to BLD-03123	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01795	5 - X-Ray Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01796	6A-6C - Surgery & Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023		
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01797	1G -Doctor's Dining & Administration - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01798	1C - Original Coffee Shop - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01799	7A-7B - Outpatient Surgery	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/20/2023	Rpt: Review Completed 12/20/2023		
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01800	8 - Cancer Prevention Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/02/2023	Rpt: Review Completed 12/20/2023		
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-02637	10 - Emergency Power Area	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/20/2023		
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-03123	1A -1K Main Tower & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-03524	9 - ER Addition & Remodel	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-07096	ER Addition Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03899	101- Miller's Children's Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03900	102- Miller's Children's Hospital Entry	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Open - Returned 10/11/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03901	103- Miller Children's Clerical Addition	OSHPD 1-In Service	3							4D-L1				Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03905	Central Plant	OSHPD 1-In Service	5							4				Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03906	4 Story Addition	OSHPD 1-In Service	5							4				Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-05883	Oxygen Farm	OSHPD 1-Equipment Yard	N/A							4				Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-07082	Central Plant Pump Room	OSHPD 1-In Service	5							4				Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11847	Mission Community Hospital	BLD-00352	Building A - Tower	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11847	Mission Community Hospital	BLD-00353	Building B - Ancillary Building	OSHPD 1-In Service	2					Denied		2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11847	Mission Community Hospital	BLD-00354	Building C - Emergency Department B	OSHPD 1-In Service	2							2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11847	Mission Community Hospital	BLD-03891	Building D - South Tower	OSHPD 1-In Service	5							4			Rpt: Review Completed 05/06/2024		
19 - Los Angeles	11847	Mission Community Hospital	BLD-05536	Building E - Psychiatric Unit	OSHPD 1-Under Construction	5s							4s					
19 - Los Angeles	11847	Mission Community Hospital	BLD-05537	Building F - Psychiatric Administration	OSHPD 1-Under Construction	5s							4s					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11847	Mission Community Hospital	BLD-05538	Building G - Lobby Clinical Lab	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11847	Mission Community Hospital	BLD-05539	Building H - Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11874	Monrovia Memorial Hospital	BLD-00377	Main Building	OSHPD 1-In Service	2				1/1/2017 Risk Bsd Retrofit				3	Rpt: Review Completed 12/14/2022	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12878	Monterey Park Hospital	BLD-00946	Original Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12878	Monterey Park Hospital	BLD-00947	Radiology Basement Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00388	Farr Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00389	D&T Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00390	Support Services Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00391	IFL Building	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00392	Therapy Pool Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00393	Clinical Laboratory Bldg Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00394	F Tower - Main Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00395	G Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00396	Cancer Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03092	F Tower - Elevator Tower - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A				01/01/2015				N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03094	Linear Accelerator	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03095	Emergency Room Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03096	MRI Addition - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03097	Outpatient Registration Building - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03135	Clinical Laboratory Building (Original) - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A				Withdrawn				N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03136	Quiet/Dining	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03487	Service Elevator Tower	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03645	Electrical Equipment Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-05464	Clinical Laboratory Building (D&T Addition)	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-06078	Gift Shop	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-06079	Admitting	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-07027	IFL Bridge	OSHPD 1-In Service	3s								2		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-07028	Addition #1	OSHPD 1-In Service	2s								2s		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00397	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00398	Service Enclosure - East Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00399	Administration Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00400	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02690	Service Enclosure - West Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02691	Walk In Freezer	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02692	Boiler Room	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02693	Engineering Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03759	1956 Storage Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03760	1983 Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/08/2025		
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03800	Original Building - South Wing - Structurally connected to BLD-00397	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11863	Olympia Medical Center	BLD-00368	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11863	Olympia Medical Center	BLD-00369	East Wing & Additions	OSHPD 1-In Service	2						1/1/2020 Fin Hdsp Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	BLD-00370	West Wing & Additions	OSHPD 1-In Service	2						1/1/2015 Risk Bsd Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	BLD-00371	Pavilion / Addition	OSHPD 1-In Service	2						1/1/2015 Risk Bsd Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	BLD-06983	West Wing	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06984	Bridge	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06985	Porte Cochere	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06986	Generator Enclosure	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-07048	Utility Enclosure	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	12841	Pacific Gardens Medical Center	BLD-00932	Main Hospital Building	OSHPD 1-In Service	2						Denied		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12841	Pacific Gardens Medical Center	BLD-06472	Medical Gas Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00017	Building 1	OSHPD 1-In Service	1	Withdrawn					7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit	2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00018	Building 2	OSHPD 1-In Service	1	Withdrawn					7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit	2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00019	Building 3	OSHPD 1-In Service	1	Withdrawn					7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit	2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-06541	Cafeteria	OSHPD 1-In Service	4D								2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-06542	Central Plant	OSHPD 1-In Service	4D								2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-05182	Main Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 09/13/2024		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-06852	Employee Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07329	West Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07330	East Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07331	Main Entrance Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07336	Outpatient Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01993	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024		
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01994	ICU / CCU Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024		
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01995	Mechanical Plant	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024		
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01996	MRI Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024		
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01997	1927 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01998	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01999	Linear Accelerator Addition - Structurally connected to BLD-01998	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-03322	Radiation Oncology Building	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06749	Witmer Street Expansion Loading Dock	OSHPD 1-Proposed	5s								4s					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06750	Bridge Connecting BLD-01993 and BLD-01995	OSHPD 1-Proposed	5s								4s					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06917	Tunnel Connecting BLD-01993 to BLD-06918	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06918	1953 Bldg. (Low-Height Portion)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02203	Original Nursing Tower	OSHPD 1-In Service	2	Denied					6/30/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02204	Original Surgery and Lab Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02206	Pathology Addition - Structurally connected to BLD-02203	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02207	Scanner Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02208	ER/Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02209	ICU/CCU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02210	Respiration Therapy Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02211	Cath Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02212	36 Bed Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02213	Building A, Mech. Equipment Bldg.	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02214	Building B	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02215	Building C	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02216	Radiology Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-02217	ER Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-03221	Generator #2 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-06135	Original Mechanical Area	OSHPD 1-In Service	4D					7/1/2019 Com Acc Replace			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-06325	ICU / ER Connection Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Hospital - Downey	BLD-06735	New Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 07/08/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01156	Original Building Patient Tower	OSHPD 1-In Service	2					1/1/2016 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01158	Long Term Care	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01160	Power Plant	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01162	1992 Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03151	Health Center (North Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03152	Health Center (East Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03272	ED Shannon Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03273	Plaza Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03666	1968 Generator Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03715	1992 Pavilion Bridge	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-05468	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06460	Link Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06465	Electrical/Mechanical/Compactor Segment	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06466	Communication Room & Utility Tunnel Segment	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06467	Cooling Tower Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06473	Pump Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00411	1972 Building - ICU/Emergency	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00412	D&T Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Open - Returned 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00413	Women's Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Open - Returned 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00414	1913 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						12/31/2019 Com Acc Replace		N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00415	1928 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						12/31/2019 Com Acc Replace		N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00416	1953 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00417	1961 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00418	1963 Building - Cafeteria	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00419	1963 Building - Lab/Peds - Structurally connected to BLD-00411	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-02838	Building 01A	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-02839	Building 01B Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03468	Pitzer Bldg Admin/Marketing/Acct	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03850	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03877	1961 Dining Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05176	1958 Lobby Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05202	1958 Building (Emergency Wing)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05669	2013 Vestibule	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05670	2013 Low Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05671	2013 High Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00170	Patient Tower	OSHPD 1-In Service	1					12/27/2019 Com Acc Retrofit	12/31/2023 AB 2190 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00171	Ancillary Wing	OSHPD 1-In Service	4D					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00172	Service Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00173	Cardiology Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00174	Admitting/Emergency	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00175	Women's Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00176	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-03423	Patient Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-03424	Interim Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06372	Hospital Main Lobby Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06398	Emergency Cat Lab	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06691	D&T Expansion	OSHPD 1-Under Construction	5s								5s					
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06692	D&T Canopy	OSHPD 1-Under Construction	5s								5s					
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01984	Main Building	OSHPD 1-In Service	3s								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01985	ICU/CCU Building	OSHPD 1-In Service	4s								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01986	Cardiac Heart Center	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01987	Central Plant Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01988	Utility Building	OSHPD 1-In Service	4s								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01989	Chapel Building	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01991	New Equipment Shelter	OSHPD 1-In Service	3s								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-02714	Old Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-02715	New Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03628	South Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03636	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03637	Sub-Acute Building	OSHPD 2-Skilled Nursing Only	N/A								N/A					
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03638	Control Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05337	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05338	Transformer Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05339	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01215	Central Wing North	OSHPD 1-In Service	2								3R	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01216	West Wing & Entrance Canopy	OSHPD 1-In Service	2				7/1/2019 Com Acc Retrofit				3R	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01217	East Wing	OSHPD 1-In Service	3								3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01218	Laboratory Addition	OSHPD 1-In Service	4								3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01219	Conference Center	OSHPD 1-In Service	5								3	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01220	ED Entry Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03147	Central Wing Tower	OSHPD 1-In Service	2				7/1/2019 Com Acc Retrofit				3R	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03148	Central Wing South	OSHPD 1-In Service	2								3R	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03149	Central Wing Stair Tower	OSHPD 1-In Service	2								3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03150	West Wing Elevator Tower	OSHPD 1-In Service	2								3R	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-05177	Drop-Off Canopy	OSHPD 1-In Service	2				1/1/2015 Risk Bsd Retrofit				3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-06496	Emergency Generator Enclosure	OSHPD 1-Under Construction	5s								4s					
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-06841	West Wing Stair Tower	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01727	Original Hospital	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01731	11 Technology Center & Lab	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01733	Emergency Generator	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01734	Liquid Oxygen Storage Tanks and Manifolds	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01735	West Tower Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01737	Radiation Therapy Building Walkway	OSHPD 1-In Service	5s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01738	Dining Room Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01739	Generator Building	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01741	ER/Cardiac Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-02625	Administrative Wing	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03159	South Tower Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03160	Earl Street Loading Dock Improvement	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03162	South Tower Building	OSHPD 1-In Service	4								3	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03340	Hazardous Material Storage	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03537	11 Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03716	Dietary Loading Dock and Storage	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03717	Entrance Canopy	OSHPD 1-In Service	3s								3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03718	Radiation Therapy Building	OSHPD 1-In Service	4								3	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06195	Med Gas Storage	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06574	Mobile CT Canopy	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06929	North Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06930	East Canopy - Low	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06931	East Canopy - High	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06932	South Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01185	Robertson Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01186	Robertson Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01187	Robertson Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01188	East Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01190	South Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01191	ER/CCU Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01192	Laundry/Central Plant Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01193	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01194	P & E Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01195	MRI Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01197	Parking Structure 1A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-03515	Northeast Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05355	Connector Corridor - 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05356	Connector Corridor - 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05357	Connector Corridor - 3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05358	Connector Corridor - 4	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05359	Connector Corridor - 5	OSHPD 1-In Service	5s								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05360	Northeast Building Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05361	Central Plant Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05362	East Building Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05363	Cooling Towers	OSHPD 1-Not a Building Structure	N/A								2		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05549	South Building Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-06412	Emergency Department	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-06575	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-07094	Urgent Care	OSHPD 3-Proposed	N/A								N/A				
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-07296	Water Tank Pump House	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	BLD-02895	Ronald Reagan UCLA Medical Center	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	BLD-02926	Emergency Services Building	Local-Proposed	5s								1				
19 - Los Angeles	12006	Saint John's Health Center	BLD-03700	North Pavilion Inpatient Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-03703	New Central Plant	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-03704	Keck Center Diagnostic & Treatment	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-05271	Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	12006	Saint John's Health Center	BLD-05987	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12006	Saint John's Health Center	BLD-05988	Flue Building	OSHPD 1-Not a Building Structure	N/A								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00166	Main Hospital	OSHPD 1-In Service	2								3R	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00167	CT Scan Addition	OSHPD 1-In Service	4								3	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023		
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00168	Boiler Room Addition	OSHPD 1-In Service	5								3	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023		
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00662	Pavilion Building	OSHPD 1-In Service	2	Withdrawn			Withdrawn				2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00663	Cooling Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00664	Radiology and Surgery Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00665	Surgery Addition - Structurally connected to BLD-00664	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00666	Emergency Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00667	CCU Building	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00668	Patient Tower	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01225	Merle Norman Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/15/2022	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01230	New Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01231	New Southwest Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02774	New Central Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02775	New North Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02776	New Orthopedic Hospital	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-06557	Loading Dock Annex Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01232	01 Orig Bldg Complex & 02 Addition	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01233	Addition Building Complex - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01234	Burn Center Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01235	1961 Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01236	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01237	Laboratory Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01238	ER Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01239	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01240	Chiller Room - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00355	Tower	OSHPD 1-In Service	1	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice				
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**									
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00356	Pavilion	OSHPD 1-In Service	2	Withdrawn								7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00357	Outpatient Building & Additions	OSHPD 1-In Service	2	Withdrawn								1/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-06640	Ambulance Canopy	OSHPD 1-Under Construction	5s												4s				
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-06641	ED Drop-off Canopy	OSHPD 1-Under Construction	5s												4s				
19 - Los Angeles	11718	Southern California Hospital at Hollywood	BLD-01976	Original Building	OSHPD 1-In Service	2									3/31/2013 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/23/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01177	Family Life Center	OSHPD 1-In Service	5												2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01178	Health Services Pavilion	OSHPD 1-In Service	3												2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01179	Central Plant	OSHPD 1-In Service	4												2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01180	New Hospital Tower	OSHPD 1-In Service	5												2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-05791	Psychiatric Care Unit	OSHPD 5-Acute Psych / SNF only	N/A												N/A				
19 - Los Angeles	12004	St. Francis Medical Center	BLD-06904	Generator Yard	OSHPD 5-Under Construction	N/A												N/A				
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01205	Bauer Wing	OSHPD 1-In Service	2									Denied			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01206	MRI Building	OSHPD 1-In Service	4s												2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01207	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						7/1/2019 Com Acc Remove GAC						
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01208	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01209	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						7/1/2019 Com Acc Remove GAC						
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01210	Emergency / Generator Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02218	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02219	Original Central Plant	OSHPD 1-In Service	2								3R		Rpt: Proposed Retrofit Acceptable 09/21/2022	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02220	East Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02221	Lobby/Cath Lab Addition	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02222	Surgery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02223	Doctors' Dining/Medical Records	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02224	Admitting/Business	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02225	Linear Accelerator	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02226	Central Plant Addition	OSHPD 1-In Service	4								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02227	North Wing	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02228	Elevator Core (North Wing)	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02229	MRI Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02230	Ambulatory Care	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02231	Gallery	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02232	Central Plant Expansion - A	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02233	Central Plant Expansion - B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02234	Central Plant-South Wing Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02235	East Wing Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-03478	New Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-03848	MRI Addition Corridor	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05421	Bulk Medical Gas System	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05668	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05705	Surgery Addition West	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05733	Emergency Generators and Switchgear	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06132	Central Plant Elevator and Stair	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06133	Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06148	Central Plant Walkway Canopy	OSHPD 1-In Service	3								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06149	Lundquist North Wing Connector	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06150	Lundquist Tower Connector to Center Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06211	Lundquist Connector Exit Corridor	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06295	Original Service Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12831	UCI Health-Lakewood	BLD-00924	Main Hospital	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 02/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12831	UCI Health-Lakewood	BLD-00925	Hospital Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 02/28/2024	
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-02181	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-02182	Purchasing / Central Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-03178	ED / ICU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-03179	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00358	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00359	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00360	Utility Building / Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00362	West Wing	OSHPD 1-In Service	2						1/1/2019 Com Acc Rebuild		2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00363	Main-North End - Structurally connected to BLD-00358	OSHPD 1-Not an Independent Building	N/A								N/A					
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00364	Pavilion East & West	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						7/1/2019 Com Acc Replace		N/A					
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00365	Hoefflin Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00366	Surgical Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00367	Patient Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-03711	Electrical Equipment Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05461	North Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05514	Tower Lobby	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05634	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05635	Switchgear Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05636	Switchgear Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05848	Berger Tower Patient Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024		
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-07349	Electrical Room	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted		
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-00317	Cancer Research Institute (Ezralow Tower)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/07/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-03689	Topping Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01025	Main Building - North Tower	OSHPD 1-In Service	2						4/1/2016 Risk Bsd Retrofit		3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01026	Main Building - South Tower	OSHPD 1-In Service	2						1/1/2015 Risk Bsd Retrofit		3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01027	West Addition	OSHPD 1-In Service	4								3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01028	East Addition	OSHPD 1-In Service	3s								3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-07073	Medical Office Building	OSHPD 3-Proposed	N/A								N/A				
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02169	Base Building (Main Hospital)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02170	Service Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02171	Administrative Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02172	Ancillary Inpatient East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02174	Elevator Lobby East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02175	Elevator Lobby West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02638	Ancillary Inpatient West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02789	Inpatient Tower	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/20/2023		
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-03124	Administrative Expansion (North)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-05197	South Tower	OSHPD 1-In Service	2	Denied				5/1/2014 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07205	Stair Tower #1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07206	Stair Tower #2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07209	Low Roof Area	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07210	Mechanical Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12180	West Covina Medical Center	BLD-02176	Hospital Building / Additions	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12180	West Covina Medical Center	BLD-03430	Medical Office Building	OSHPD 1-Under Construction	1								1s				
19 - Los Angeles	12180	West Covina Medical Center	BLD-06612	Skilled Nursing	OSHPD 1R-Skilled Nursing Only	N/A								N/A				
19 - Los Angeles	12180	West Covina Medical Center	BLD-06943	HVAC Tower and Enclosure	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12180	West Covina Medical Center	BLD-07083	Psych Addition	OSHPD 5-Proposed	N/A								N/A				
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02196	Original Building	OSHPD 1-In Service	2	Withdrawn					1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02197	Addition 1	OSHPD 1-In Service	2	Withdrawn					1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02198	Addition 2	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02199	Addition 3	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02200	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02201	OB Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02202	Pediatrics Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-03422	ER Addition - West Portion	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10075	HealthBridge Central Valley Children's Center	BLD-06945	Children's Hospital	OSHPD 1-Proposed	5s								5s				
20 - Madera	10257	Madera Community Hospital	BLD-00436	Main & Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
20 - Madera	10257	Madera Community Hospital	BLD-00437	OB Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-00438	Outpatient Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-00439	ICU/ER Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-06092	Utility Canopy 1	OSHPD 1-In Service	5								4				Rpt: Not Submitted
20 - Madera	10257	Madera Community Hospital	BLD-06093	Utility Canopy 2	OSHPD 1-In Service	5								4				Rpt: Not Submitted
20 - Madera	10257	Madera Community Hospital	BLD-06094	Central Utility Plant	OSHPD 1-In Service	5								4				Rpt: Not Submitted
20 - Madera	10257	Madera Community Hospital	BLD-06322	CT Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	17124	Valley Children's Hospital	BLD-02518	Hospital (G Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-02650	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05429	Hospital (A Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05430	Hospital (B Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05431	Hospital (C Porte-Cochere)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05432	Hospital (D Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05433	Hospital (E Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05434	Hospital (F Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05435	Hospital (H Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05436	Hospital (I Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05437	Hospital (J Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05438	Hospital (K Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05439	West Expansion - Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05440	West Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
20 - Madera	17124	Valley Children's Hospital	BLD-05441	Medical Waste Building	OSHPD 1-In Service	5								5			Earthquake Resilient	
20 - Madera	17124	Valley Children's Hospital	BLD-06697	On-Site Well	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-06698	Sewer Lift Station	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-06699	Waste Water Plant	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-07119	Giraffe Photovoltaic Array	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07120	Switchgear Yard	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07121	Microgrid	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07122	Fuel Cell Yard	OSHPD 1-Under Construction	N/A								4s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00441	General Services Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00442	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/14/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00443	Medical Office Building 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/22/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00444	Mechanical Equipment Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00445	Support Services Building	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00446	Generator Switchgear Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-03283	Doctor's Sleep Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/14/2023	Rpt: Review Completed 12/05/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-03598	Medical Records Building Addition - Structurally connected to BLD-00443	OSHPD 1-Not an Independent Building	N/A								N/A					
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05615	Emergency Department	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/05/2023			
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05616	Oxygen Storage	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/05/2023			
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05617	Mechanical Building - CUP	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/05/2023			
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-06848	Electrical Yard	OSHPD 1-Equipment Yard	N/A								2	Rpt: Not Submitted	Rpt: Review Completed 12/05/2023			
21 - Marin	10261	Kentfield Hospital	BLD-00440	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
21 - Marin	10273	Marinhealth Medical Center	BLD-00447	01 - Original Building & Additions	OSHPD 1-In Service	2	Denied	Denied		Denied				2	Intent to Remove GAC	Intent to Remove GAC		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
21 - Marin	10273	Marinhealth Medical Center	BLD-00448	02 - Additions & Alterations	OSHPD 1-In Service	2		Denied						2	Intent to Remove GAC	Intent to Remove GAC		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
21 - Marin	10273	Marinhealth Medical Center	BLD-00449	03 - Cobalt Bomb Wing	OSHPD 1-In Service	2	Denied	Denied		1/1/2015 Fin Hdsp Rebuild				2	Intent to Remove GAC	Intent to Remove GAC		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
21 - Marin	10273	Marinhealth Medical Center	BLD-00450	Laboratory Addition & Remodel - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-00451	04 - Medical Health Center (Mental Health Center)	OSHPD 1R-Acute Psych Only	N/A	Denied	Denied		7/1/2019 Com Acc Rebuild				N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-00452	05 - Elevated Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied	Denied		7/1/2019 Com Acc Rebuild				N/A					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
21 - Marin	10273	Marinhealth Medical Center	BLD-00453	06 - West Wing	OSHPD 1-In Service	3		Denied						2		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted		
21 - Marin	10273	Marinhealth Medical Center	BLD-00455	1A - Additions & Alterations - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-00456	04A - Medical Records - Structurally connected to BLD-00451	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-03054	1C - East Canopy - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-03056	Ambulance Entry Canopy	OSHPD 1-In Service	3		Denied						2		Rpt: Not Submitted	Rpt: Not Submitted		
21 - Marin	10273	Marinhealth Medical Center	BLD-03526	05A - Elevator	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied	Denied			7/1/2019 Com Acc Replace			N/A					
21 - Marin	10273	Marinhealth Medical Center	BLD-06250	Hospital Replacement Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
21 - Marin	10273	Marinhealth Medical Center	BLD-06251	Hospital Replacement Building - Loading Dock	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
21 - Marin	10273	Marinhealth Medical Center	BLD-06252	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
21 - Marin	10273	Marinhealth Medical Center	BLD-07233	Behavioral Health Emergency Generator	OSHPD 5-Proposed	N/A								N/A					
21 - Marin	17672	Novato Community Hospital	BLD-00457	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023		
21 - Marin	17672	Novato Community Hospital	BLD-07325	New Generator Yard	OSHPD 1-Proposed	N/A								4s					
21 - Marin	17672	Novato Community Hospital	BLD-07326	Mechanical Yard	OSHPD 1-Proposed	N/A								4s					
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-00458	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-03808	Skilled Nursing Wing	OSHPD 2-Skilled Nursing Only	N/A								N/A					
23 - Mendocino	18198	Adventist Health Howard Memorial	BLD-05319	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/05/2023		
23 - Mendocino	18198	Adventist Health Howard Memorial	BLD-05320	Mechanical Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/05/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00469	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00470	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00471	Emergency Addition - West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00472	X-Ray File Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-02787	Respiratory Neurophysiology Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-02788	Emergency Generator Shelter	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-03473	Emergency Addition - East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-06731	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/18/2023		
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-06732	Medical Air System Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00305	Main Building, North Wing	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00306	OB Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00307	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-02959	Main Building, Central Wing	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-02960	Main Building, Ancillary	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/19/2019	Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-05704	Emergency Department Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06369	Support Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06370	Electrical Room	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06877	OB Porte Cochere	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06878	Main Entry Canopy	OSHPD 1-In Service	4								4		Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06879	Entry Canopy	OSHPD 1-In Service	4								4		Rpt: Review Completed 12/04/2023		
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06955	East Patient Wing Expansion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/04/2023		
24 - Merced	10309	Memorial Hospital Los Banos	BLD-00029	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	BLD-00030	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	BLD-07015	Addition #1	OSHPD 1-In Service	2s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
24 - Merced	10309	Memorial Hospital Los Banos	BLD-07016	Mechanical Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
24 - Merced	10315	Mercy Medical Center	BLD-03870	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-03871	Power Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-05610	Radioactive Waste and Pathology Holding	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
24 - Merced	10315	Mercy Medical Center	BLD-05611	Equipment Charging	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
24 - Merced	10315	Mercy Medical Center	BLD-05612	ER Entrance Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
24 - Merced	10315	Mercy Medical Center	BLD-07020	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
25 - Modoc	18231	Modoc Medical Center	BLD-06279	Hospital - Building 100	OSHPD 1-In Service	5								5				Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	BLD-06288	Entrance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	BLD-06784	Warnerview Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
25 - Modoc	18231	Modoc Medical Center	BLD-06895	Patient Room Expansion	OSHPD 1-Under Construction	5s								5s					
25 - Modoc	18231	Modoc Medical Center	BLD-06896	Skilled Nursing Pedestrian Walkway	OSHPD 2-Under Construction	N/A								N/A					
25 - Modoc	18231	Modoc Medical Center	BLD-06897	Skilled Nursing Building	OSHPD 2-Under Construction	N/A								N/A					
25 - Modoc	18231	Modoc Medical Center	BLD-06898	Skilled Nursing Entrance Canopy	OSHPD 2-Under Construction	N/A								N/A					
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01621	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01622	Pump House Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01623	Heating and Storage Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01624	Generator Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01625	South Wing Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/21/2023		
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01626	Walk-in Box	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/21/2023		
26 - Mono	14304	Mammoth Hospital	BLD-00267	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
26 - Mono	14304	Mammoth Hospital	BLD-03697	New Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
26 - Mono	14304	Mammoth Hospital	BLD-03698	New Wing Connecting Corridor - North	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
26 - Mono	14304	Mammoth Hospital	BLD-05561	New Wing Connecting Corridor - South	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
26 - Mono	14304	Mammoth Hospital	BLD-06859	North Wing	OSHDP 1-Proposed	5s								5s				
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01629	A Phase I - 1960 Wing	OSHDP 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01630	B Phase II - 1968 Wing - Structurally connected to BLD-01629	OSHDP 1-Not an Independent Building	N/A								N/A				
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01631	C 1978 Addition	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01633	E 1998 Cancer Center Addition	OSHDP 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-03714	Parking Structure	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05554	G Utility Service Building	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05555	H Cardiac EP Lab	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05556	J South Pavilion	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05557	K Forest Pavilion	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-07228	Electrical Bunker	OSHDP 1-In Service	5								2		Rpt: Not Submitted	Rpt: Not Submitted	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-07300	Switchgear Yard	OSHDP 1-Under Construction	N/A								4s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-01634	Main Hospital	OSHDP 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Review Completed 11/16/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03265	New Porte Cochere	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03266	New Hospital	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03328	Bottle Building	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	17353	Natividad Medical Center	BLD-02542	Extended Care Services (Bldg 100)	OSHDP 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-02544	Food Service / Central Plant (Bldg 580) 580A	OSHDP 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
27 - Monterey	17353	Natividad Medical Center	BLD-02545	Acute Care (Building 500)	OSHPD 1-In Service	5								3	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03827	Material Management (Bldg 600)	OSHPD 1-In Service	4								2	1/1/2030 Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03828	Inpatient Mental Health (Bldg 940)	OSHPD 1-In Service	4								2	1/1/2030 Intent to Remove GAC	Intent to Remove GAC		
27 - Monterey	17353	Natividad Medical Center	BLD-03829	Generator Building (Bldg 980)	OSHPD 1-In Service	5								3	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03862	Kitchen & Associated Fac (Bldg 600)	OSHPD 1-In Service	2								2	1/1/2030 Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
27 - Monterey	17353	Natividad Medical Center	BLD-03864	Canopy	OSHPD 1-In Service	5								2	1/1/2030 Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03865	Canopy	OSHPD 1-In Service	5								2	1/1/2030 Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03867	Canopy	OSHPD 1-In Service	5								2	1/1/2030 Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-03868	Canopy	OSHPD 1-In Service	5								2	1/1/2030 Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	17353	Natividad Medical Center	BLD-05986	Pediatric / Surgery (BLD 580) 580B	OSHPD 1-In Service	5								2	1/1/2030 Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01635	Original Building	OSHPD 1-In Service	2								2	1/1/2030 Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01636	36 Bed Addition	OSHPD 1-In Service	2								2	1/1/2030 Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01638	Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030 Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01639	Electrical and Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01640	Central Sterile Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01641	Cardiac Center North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01642	Cardiac Center South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01643	CCU Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01644	Outpatient Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/05/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01645	Cath Lab Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/22/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01646	Cath Lab Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01647	Cath Lab Stair Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01648	Link	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01649	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03076	Administration Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03455	Utility Tunnel	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03456	Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-05201	Rotary UPS	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
28 - Napa	10366	Adventist Health St. Helena	BLD-01665	Smoking Porch Addition to Main Wing - Structurally connected to BLD-01666	OSHPD 1-Not an Independent Building	N/A								N/A				
28 - Napa	10366	Adventist Health St. Helena	BLD-01666	Main Wing & Smoking Porch Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-01667	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-01668	Ancillary Wing & (ICCU Add 5th Flr)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
28 - Napa	10366	Adventist Health St. Helena	BLD-03031	Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
28 - Napa	10366	Adventist Health St. Helena	BLD-03554	Health Center	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-05327	Chiller Plant	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/29/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01650	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01651	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01652	West Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01653	Conference Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01654	Link Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01655	South Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01656	South Nursing Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01657	North Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01658	North Nursing Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01659	Maternity / Pediatrics	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01660	Admitting / Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01661	Radiology / Oncology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01663	Emergency Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01664	Emergency Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-02881	Canopy Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05309	North Acute Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05323	North Acute Care Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05463	Women's Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01669	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01670	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01671	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01673	West Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01674	Outpatient Center	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01675	West Wing Addition #2 - Structurally connected to BLD-01670	OSHPD 1-Not an Independent Building	N/A								N/A				
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-03399	Entry Canopy West	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-03686	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-06080	Entry Canopy Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-06081	Entry Canopy East	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-07344	Pharmacy Addition	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 12/19/2023	Rpt: Not Submitted	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01676	1950 Building and 1966 Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Documents Uploaded 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01677	1966 North Addition Building - Structurally connected to BLD-01676	OSHPD 1-Not an Independent Building	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01678	1978 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/26/2022	Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01679	1990 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/26/2022	Rpt: Open - Documents Uploaded 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01680	1993 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/26/2022	Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-02569	Med Gas Storage Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/26/2022	Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-03236	1986 Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-03897	Western Addition	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05249	2011 ED/SPD Addition	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05272	South Wing	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05273	South Wing Corridor	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05474	2002 Building	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05475	Generator Building	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05476	2008 Building	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05477	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05478	Modular Chiller Building	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05479	Chiller Building Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Documents Uploaded 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05480	Skilled Nursing Facility Addition	OSHPD 2-Skilled Nursing Only	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-06666	Western Addition - Porte-Cochere	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01684	Central Plant	OSHPD 1-In Service	2						1/1/2015 Risk Bsd Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01685	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01692	Phase IV/North Wing - South	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01693	Phase IV East Entrance	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01695	Main Entrance Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03658	Corridor No. 1	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03659	Porte Cochere	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03660	Corridor No. 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03661	Corridor No. 3	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03662	Corridor No. 4	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03663	Corridor No. 5	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03664	Arcade	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03665	Phase IV/North Wing - North	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03671	Phase IV East Entrance Addition - North	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03672	Phase IV East Entrance Addition - South	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01681	Original Building / Additions	OSHPD 1-In Service	2								2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01682	ICU Addition	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC		
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01683	OB/Gyn	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-06268	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-06269	Trash Enclosure	OSHPD 1-Equipment Yard	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
30 - Orange	13061	Anaheim Global Medical Center	BLD-00996	Psychiatric Treatment	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	BLD-00997	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	BLD-00998	ICU / CCU Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	13061	Anaheim Global Medical Center	BLD-00999	ER Addition / Birthing Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	13061	Anaheim Global Medical Center	BLD-01000	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02346	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10400	Chapman Global Medical Center	BLD-02347	Entry Pavilion	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02348	Mechanical Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02349	ICU/Admin Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02350	Surgery Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-00271	CHOC North	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	14370	Children's Hospital of Orange County	BLD-00272	Research Building	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
30 - Orange	14370	Children's Hospital of Orange County	BLD-00273	CHOC West	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	14370	Children's Hospital of Orange County	BLD-05243	Tower II	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	14370	Children's Hospital of Orange County	BLD-05335	CHOC Lobby	OSHPD 1-In Service	3s								2s		Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	14370	Children's Hospital of Orange County	BLD-05672	Providence Tunnel	OSHPD 1-Tunnels	4								3		Rpt: Review Completed 12/19/2023	Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-05720	La Veta Stairs	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-05721	Garage Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-07297	La Veta Stair Transition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-07298	La Veta Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Children's Hospital of Orange County	BLD-07313	Garage Elevator Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10036	City of Hope National Medical Center Orange County	BLD-06670	Main Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10036	City of Hope National Medical Center Orange County	BLD-06671	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10036	City of Hope National Medical Center Orange County	BLD-06672	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10405	College Hospital Costa Mesa	BLD-02351	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: In Review 11/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-02352	Psychiatric Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: In Review 11/08/2024	
30 - Orange	10405	College Hospital Costa Mesa	BLD-03102	Radiographic and Fluoroscopy Addn	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: In Review 11/08/2024	
30 - Orange	10405	College Hospital Costa Mesa	BLD-03417	Canopy 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Not Submitted	
30 - Orange	10405	College Hospital Costa Mesa	BLD-03419	Canopy 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10405	College Hospital Costa Mesa	BLD-07142	Storage Building	OSHPD 1-Proposed	2								2				This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-07143	Utility Building	OSHPD 1-Proposed	2								2				This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-07144	Utility Yard	OSHPD 1-Equipment Yard	N/A								2	Rpt: Review Completed 09/17/2024	Rpt: In Review 11/08/2024		
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06151	West Building	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/31/2023		
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06152	East Building	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/31/2023		
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06448	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								4		Rpt: Not Submitted		
30 - Orange	12573	Foothill Regional Medical Center	BLD-01029	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Awaiting review 01/24/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12573	Foothill Regional Medical Center	BLD-01030	Classroom Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	
30 - Orange	12573	Foothill Regional Medical Center	BLD-02631	Mechanical Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02406	Patient Tower	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02407	Ancillary Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02408	Mechanical Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
30 - Orange	17438	Healthbridge Children's Hospital-Orange	BLD-05189	Main Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-00283	D & T	OSHPD 1-In Service	4								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	16319	Hoag Hospital Irvine	BLD-00284	Nursing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-05852	ER Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-05853	Emergency Department	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	16319	Hoag Hospital Irvine	BLD-06124	Main Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06285	Ambulance Bay Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06286	NPC 5 Storage Area	OSHPD 1-Equipment Yard	N/A								5				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06297	Trellis Wheel Chair Storage	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06409	Main Entrance Canopy Extension	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06480	Vending Kiosk	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06481	Wheelchair Storage	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06656	East Wing Addition	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06658	E-Generator Yard (E Generator Enclosure)	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06660	Dock Receiving Enclosure (Basement Connecting Corridor)	OSHPD 1-Under Construction	5s								4s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06661	Front Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06662	Front Entrance Expansion	OSHPD 1-Under Construction	5s								4s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06663	East Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06677	North-West Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06678	North Hospital - West Wing	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06680	North Hospital - East Wing	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06681	North-East Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06682	East Tunnel Connector	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06938	South-East Pedestrian Canopy	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
30 - Orange	16319	Hoag Hospital Irvine	BLD-06939	South-West Pedestrian Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07116	Emergency Generator Enclosure #1	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07117	Emergency Generator Enclosure #2	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02360	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: In Review 11/16/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02361	Four-Story Building - 1957	OSHPD 1-In Service	2					7/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02363	Old ICU - 1963	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 11/08/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02364	Old Radiation Therapy - 1975	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02366	Power Plant - Boilers and Chillers - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02368	Inpatient Tower - 1974	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02369	Ancillary / Helistop / Power Plant	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02370	Helistop - 1974 - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02371	Chemical Dependency - 1965	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 11/13/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02373	Cancer Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02374	MRI / MRI Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 07/10/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02375	South Entrance	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 05/31/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02376	ER East Waiting Room Addition - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02377	MRI Addition - Structurally connected to BLD-02374	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02378	Link Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/10/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02379	Emergency Department Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/10/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03098	Cancer Center - Link Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03332	Power Plant - MUSS & ATS	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/18/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03333	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03415	Energy Treatment Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 09/18/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03699	East Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05442	Cogeneration Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05517	Cafe Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05518	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05519	ECU Waiting Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05520	Original Building - North Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/01/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05568	East Wing Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05900	ECU Waiting Walk-In Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05901	ECU Waiting Drop-Off Area Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-06281	Elevator Tower (for Inpatient Tower)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07102	Utility Tunnel	OSHPD 1-Tunnels	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02387	Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	BLD-02388	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	BLD-02389	ICU/CCU Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02390	Emergency Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02916	CT Scan Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02917	X-Ray Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-05274	Hospital	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/07/2023		
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-05275	Central Utility Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/07/2023		
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-06224	Walk-in Refrigerator	OSHPD 1-Not a Building Structure	N/A								4		Rpt: Review Completed 12/07/2023		
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-06944	Fire Pump Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/07/2023		
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-03831	Main Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/19/2023		
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-03902	Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/19/2023		
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02353	Building I: Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02354	Building II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02355	Building III	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02356	Building IV	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02357	Building V	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02358	Building VI	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02359	Building VII	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	13068	Kindred Hospital Brea	BLD-02559	Main Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10476	Kindred Hospital Westminster	BLD-01343	Patient Tower (Building I)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03059	Entry/Lobby (Building II)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03060	Critical Care (Building III)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03061	Body Scanner Addition (Building IV)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	
30 - Orange	10476	Kindred Hospital Westminster	BLD-03479	Entry Canopy	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00982	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00983	Perinatal Building Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00984	Pool Building	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00985	Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02758	Service Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02759	Rehabilitation Department Expansion	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02760	Patient Room Expansion	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-05516	Oxygen Tank Yard	OSHDP 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-05782	Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00323	Original Building	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00324	South Addition	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00325	Emergency Room Addition	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 05/22/2023	Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05472	Pedestrian Bridge	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05730	Patient Care Pavilion	OSHDP 3-Clinic - Local Jurisdiction	N/A								N/A				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05731	Covered Walkway	OSHDP 1-In Service	4								4			Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05873	Emergency Room Addition #2	OSHDP 1-Under Construction	5s								5s				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-06027	LDR	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-06231	LDR Canopy	OSHDP 1-In Service	3								4			Rpt: Not Submitted	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01042	Main Hospital	OSHDP 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01043	Women's Health Center	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: In Review 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01044	Central Plant - Steel Portion	OSHDP 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/27/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01045	Central Plant - Concrete Portion	OSHPD 1-In Service	2								4D-L1		Rpt: In Review 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-02738	Critical Care Pavilion	OSHPD 1-In Service	5								4		Rpt: In Review 12/20/2023		
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-03707	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-05981	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/07/2023	Rpt: In Review 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-05989	Main Hospital Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-06020	CCP Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-06024	WHC Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07141	Central Plant	OSHPD 1-Proposed	5s								5s				
30 - Orange	18007	Orange County Global Medical Center	BLD-00295	Ancillary Building/ER Expansion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00296	Elevator Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00297	Nursing Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00298	Administration	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00299	Shipping & Receiving	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	18007	Orange County Global Medical Center	BLD-00300	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00301	Radiation Therapy	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00302	Support Services	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	18007	Orange County Global Medical Center	BLD-05722	Entrance Canopy	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-06693	New Cooling Tower Yard	OSHPD 1-Under Construction	N/A								4s				
30 - Orange	12804	Providence Mission Hospital	BLD-00913	Pavilion - Building 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12804	Providence Mission Hospital	BLD-00914	Pavilion - Building 2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-00915	Pavilion - Building 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-00916	Pavilion - Building 4	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-00917	Pavilion - Building 5	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-00918	Hospital Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-03184	Tower 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-03185	Linear Accelerator	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	12804	Providence Mission Hospital	BLD-03186	Perioperative Pediatric Pavilion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
30 - Orange	12804	Providence Mission Hospital	BLD-06715	Tower 2 Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
30 - Orange	12804	Providence Mission Hospital	BLD-07234	Hospital Tower 3	OSHPD 1-Proposed	5s								5s				
30 - Orange	12804	Providence Mission Hospital	BLD-07235	Canopy	OSHPD 1-Proposed	5s								5s				
30 - Orange	12804	Providence Mission Hospital	BLD-07236	Lobby Infill	OSHPD 1-Proposed	5s								5s				
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02433	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02434	Nursing Tower	OSHPD 1-In Service	2			Withdrawn		7/1/2019 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02435	Elevator Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02436	Radiographic	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02437	Radiographic - South Addition	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02438	Administration Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02439	Mechanical / Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02440	Linear Accelerator Suite (Treatment)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02414	Main Building (A)	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02415	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02416	East/West Wing	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02417	South Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02418	North Wing / Lobby	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02419	Main Hospital Building (B)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02420	Main Hospital Building (C)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02421	Regional Cancer Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02422	Emergency Department Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02784	Generator Enclosure	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03013	ICU/CCU Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03352	Patient Care Center/Plaza Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03353	Facilities Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03354	PCC Lobby / Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03355	Underground Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03357	South Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-06061	PCC West Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10457	Providence St. Joseph Hospital	BLD-06435	Emergency Entrance Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02424	Main Building / Canopies / Boiler Room	OSHPD 1-In Service	1			Withdrawn		7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02425	West Building	OSHPD 1-In Service	1			Withdrawn		7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02426	North Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02427	CT Scan Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02428	Outpatient/Admitting Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02429	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02431	Emergency Generator Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02432	MRI and Surgery Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02832	E.R. Waiting/Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02833	Basement Expansion	OSHPD 1-In Service	1			Withdrawn			7/1/2019 Com Acc Rebuild	Yes	2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02834	Boiler Room Expansion / Chiller Rm	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03190	Southwest Acute Care Bed Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03191	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03192	East Link	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03193	West Link North	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03194	Northwest Acute Care Bed Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05775	West Link South	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05776	Trash Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05777	Medical Gas Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05778	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023		
30 - Orange	10458	Providence St. Jude Medical Center	BLD-06581	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	13059	South Coast Global Medical Center	BLD-00994	Main Hospital and Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13059	South Coast Global Medical Center	BLD-00995	Nursing Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10062	UCI Health Rehabilitation Hospital	BLD-06919	Rehab Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10062	UCI Health Rehabilitation Hospital	BLD-06920	Generator Enclosure / Exit Stair Room / Trash Enclosure	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00926	Main Hospital/Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00927	Women & Children's Hosp.	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00928	Dining Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00929	Conference Room Addition	OSHPD 1-In Service	4				Denied				2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00931	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03497	Emergency Power Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03498	Surgery Addition	OSHPD 1-Under Construction	5s								4s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03770	ER Addition - Phase 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03771	ER Addition - Phase 3	OSHPD 1-In Service	5								2	1/1/2030	Rpt: NPC 4 error 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-06644	Switchgear Building	OSHPD 1-In Service	1								2s		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	16234	UCI Health-Fountain Valley	BLD-05195	Living Care Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02395	Main Hospital/ICU - CCU/Nuclear Med	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02396	OB South/ER/Lab	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02397	Women's Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02398	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00156	Main Hospital & Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00157	Patient Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00158	OB Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00159	Classrooms & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13077	UCI Health-Placentia Linda	BLD-03742	GI Building Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-03743	GI Building Expansion Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-05701	Main Entry and Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-05718	Free-Standing Mechanical Platform	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/18/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-02400	Medical Center Tower Building 1A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10446	University of California Irvine Medical Center	BLD-02401	Neuropsychiatric Center - West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-02402	Steam Plant Building 31	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 07/03/2009	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-02403	Primary Electrical Facility Building 32	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-02404	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-03017	Neuropsychiatric Center - East Wing (Acute Center East)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-03412	Douglas Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-03416	Link Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05584	Medical Gas / Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05587	Generator Switchgear	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05588	Emergency Generator Housing	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05683	Neuropsychiatric Center - East Wing (Acute Center South)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05769	Neuropsychiatric Center - East Wing (Acute Center North)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05770	Neuropsychiatric Center - East Wing (Acute Center Walkway North)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-05771	Neuropsychiatric Center - East Wing (Acute Center Walkway South)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	University of California Irvine Medical Center	BLD-06008	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
30 - Orange	10446	University of California Irvine Medical Center	BLD-06239	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06720	Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06721	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06884	ED Canopy No 1	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06885	ED Canopy No 2	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06889	Utility Tunnel	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06911	Electrical Yard	OSHPD 1-Equipment Yard	N/A								5				
30 - Orange	10039	University of California Irvine Medical Center - Irvine	BLD-06912	Main Switchgear	OSHPD 1-Not a Building Structure	N/A								5				
30 - Orange	10475	West Anaheim Medical Center	BLD-02441	Main Hospital	OSHPD 1-In Service	2					8/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10475	West Anaheim Medical Center	BLD-02675	Phase I - Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-02886	Phase I - 1 Story Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-03118	Entry Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-03559	Oxygen Tank Yard (Service Yard)	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00260	Hospital, Building 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00261	Hospital, Building 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00262	Hospital, Building 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00263	Hospital Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00264	Hospital Tower North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00265	Hospital Tower South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00266	Central Plant Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05230	Emergency Department/Radiology	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05723	Central Plant Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05724	EVS Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05725	Women & Children's Link	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05726	Women & Children's Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05727	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06067	Entry Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06388	MRI Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06786	Cart Wash and Compactor Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06832	Equipment Holding	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06856	Hospital Entry Canopy	OSHPD 1-Proposed	5s								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06857	Hospital Tower West	OSHPD 1-Under Construction	5s								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06858	ED Entry Canopy	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06940	Switchgear and IT Building	OSHPD 1-Proposed	5s								4s					
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06941	Generator Yard	OSHPD 1-Proposed	N/A								4s					
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06987	PRV Building	OSHPD 1-Under Construction	5s								4s					
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07124	Sanipak Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/13/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01344	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01345	Storage / Pharmacy Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01346	Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01347	Emergency Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01348	Medical Records Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01349	Electrical Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01350	Boiler Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-02979	West Electrical Room	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05552	Cath Lab Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05553	MRI Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05779	Patient Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05882	Emergency Generators Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07011	Addition #1	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023		
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07012	Addition #2	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07013	Addition #3	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07014	Covered Walkway	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-00303	Main Hospital (General Hospital)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-00304	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03248	Acute Rehabilitation - East - Structurally connected to BLD-03612	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03249	Acute Rehabilitation - Pedestrian Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03580	General Hospital Pedestrian Walkway	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03581	Bed Tower South	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03582	Bed Tower North	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03583	Administration	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03584	MOB Pedestrian Walkway	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03585	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03586	Bed Tower Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03587	Bed Tower Expansion Pedestrian Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03611	NICU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03612	Acute Rehabilitation	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03613	Well Baby Nursery - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03614	ICU Expansion - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06161	E.D. & Critical Care Expansion	OSHPD 1-In Service	5								5s		Rpt: Review Completed 12/31/2023		
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06753	Bed Tower Expansion - Walkway 2	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06754	Bed Tower Expansion - Walkway 3	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06758	Porte-Cochere	OSHPD 1-In Service	5								4s	Rpt: Not Submitted	Rpt: Not Submitted		
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06759	Gas Cylinder Enclosure	OSHPD 1-In Service	5								4s	Rpt: Not Submitted	Rpt: Not Submitted		
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-01362	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-01364	Boiler Plant Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-03655	SNF Addition	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-03656	Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
32 - Plumas	10512	Plumas District Hospital	BLD-01351	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10512	Plumas District Hospital	BLD-01353	1976 Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	
32 - Plumas	10512	Plumas District Hospital	BLD-01354	South Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
32 - Plumas	10512	Plumas District Hospital	BLD-06957	Skilled Nursing Facility	OSHDP 2-Under Construction	N/A								N/A				
32 - Plumas	10513	Seneca District Hospital	BLD-01355	Main Hospital Building	OSHDP 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-01356	Pump Building	OSHDP 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-01358	Entrance Addition - Structurally connected to BLD-01355	OSHDP 1-Not an Independent Building	N/A								N/A				
32 - Plumas	10513	Seneca District Hospital	BLD-01359	Extended Care Addn.	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-01360	Storage Addition	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-01361	Generator Building	OSHDP 1-In Service	5								4			Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-03843	Boiler Room	OSHDP 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-06811	New Hospital	OSHDP 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06812	New ED Canopy	OSHDP 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06813	New Entrance Canopy	OSHDP 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06814	New SNF	OSHDP 2-Under Construction	N/A								N/A				
32 - Plumas	10513	Seneca District Hospital	BLD-07110	New Ambulance Canopy	OSHDP 1-Under Construction	5s								5s				
33 - Riverside	10529	Corona Regional Medical Center	BLD-01367	Original Hospital - Main	OSHDP 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Awaiting review 02/26/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10529	Corona Regional Medical Center	BLD-01368	Ancillary - Main	OSHDP 1-In Service	4	Denied							2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Awaiting review 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-01369	Surgery & Delivery - Main	OSHDP 1-In Service	3	Denied							2	1/1/2030	Rpt: Awaiting review 02/21/2025	Rpt: Awaiting review 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-02997	ED Addition	OSHDP 1-In Service	5								4			Rpt: Awaiting review 02/26/2025	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
33 - Riverside	10529	Corona Regional Medical Center	BLD-03594	Generator Building (Electrical Panel Room)	OSHPD 1-In Service	4	Denied							4			Rpt: Awaiting review 02/26/2025		
33 - Riverside	10529	Corona Regional Medical Center	BLD-05887	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 02/26/2025		
33 - Riverside	10529	Corona Regional Medical Center	BLD-05888	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 02/26/2025		
33 - Riverside	10529	Corona Regional Medical Center	BLD-05889	Switchgear Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 02/26/2025		
33 - Riverside	10529	Corona Regional Medical Center	BLD-05890	Modular MRI Building	OSHPD 3-Outpatient Only	N/A								N/A					
33 - Riverside	10529	Corona Regional Medical Center	BLD-06298	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/26/2025		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01393	Main Hospital & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01395	Woman & Infants Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01396	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01397	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01398	Shipping/Receiving	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01399	Surgery Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01400	West Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01401	Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01402	Admitting	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted		
33 - Riverside	10537	Desert Regional Medical Center	BLD-01403	Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	10537	Desert Regional Medical Center	BLD-01404	Dinah Shore Waiting Area	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-02932	East Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	BLD-03720	West Tower - Corridor 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03721	West Tower - Corridor 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03722	West Tower - Corridor 3	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03723	West Tower - Corridor 4	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03725	West Tower - Corridor 5	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03741	Medical Records Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03764	Elevator Tower - Corridor 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03765	Elevator Tower - Corridor 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-06628	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01381	Original Hospital Building and 1961 Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01382	1971 Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01383	Diagnostic & Treatment Wing & Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	Com Acc						
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-03344	Utility Plant Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-05783	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-01056	North Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-01057	Eisenhower Wing (North) - Structurally connected to BLD-03004	OSHPD 1-Not an Independent Building	N/A			Withdrawn			7/1/2019 Com Acc Retrofit		N/A					
33 - Riverside	12662	Eisenhower Medical Center	BLD-01058	Gene Autry Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-01059	Surgery Expansion	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-01060	Sinn Wing - Part A	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-01061	Birthing Center Bridge	OSHPD 1-In Service	3								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-02824	Engineering Department	OSHPD 1-In Service	2			Withdrawn			1/1/2015 Com Acc Replace		4D-L1			Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03003	Eisenhower Wing (South) - Structurally connected to BLD-03004	OSHPD 1-Not an Independent Building	N/A			Withdrawn			7/1/2019 Com Acc Retrofit		N/A					
33 - Riverside	12662	Eisenhower Medical Center	BLD-03004	Eisenhower Wing (Center)	OSHPD 1-In Service	2			Withdrawn			7/1/2019 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03005	Sinn Wing - Part B (Amb. Canopy)	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03006	Sinn Wing - Part C	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03007	Sinn Wing - Part D	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03008	Sinn Wing - Part E	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03009	Sinn Wing - Part F	OSHPD 1-In Service	4								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03540	(CP) Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03541	Annenberg Pavilion	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-03830	12 KV Switch Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-05500	Delivery Dock	OSHPD 1-In Service	2						1/1/2015 Com Acc Retrofit		4D-L1			Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	12662	Eisenhower Medical Center	BLD-05647	ED / Renker Pavilion	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
33 - Riverside	12662	Eisenhower Medical Center	BLD-06760	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Not Submitted		
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	BLD-05790	Rehabilitation Hospital	OSHPD 1-In Service	5s								5s			Rpt: Awaiting review 12/31/2023		
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	BLD-06553	Admin	OSHPD 1-In Service	5s								5s			Rpt: Awaiting review 12/31/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice	
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**						
33 - Riverside	10541	Hemet Global Medical Center	BLD-01405	Pre 1980 Emergency - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A									N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01406	Tower I	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01407	1965 Mechanical Room - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A									N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01408	1948 Addition	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01409	North Wing and Annex	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01410	Obstetrics I - Structurally connected to BLD-01409	OSHPD 1-Not an Independent Building	N/A									N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01411	1965 NW Addition	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01412	Behavioral Health	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01413	Obstetrics II	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-01414	Tower II Lower Levels - Structurally connected to BLD-01415	OSHPD 1-Not an Independent Building	N/A									N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01415	Tower II Upper Levels	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-01416	1980 Entrance - Structurally connected to BLD-01417	OSHPD 1-Not an Independent Building	N/A									N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01417	Main Lobby and Entrance	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-01418	Area A	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-02857	Area B	OSHPD 1-In Service	3									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	10541	Hemet Global Medical Center	BLD-02858	Area C - Structurally connected to BLD-02857	OSHPD 1-Not an Independent Building	N/A								N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-05649	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-06156	Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01370	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01371	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01372	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01373	North Wing/E.R. Expansion	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01374	West/South Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01375	ICU - MED / Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-03261	Admitting Building / Hospital Front Entrance	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-03525	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06500	MRI	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06583	Emergency Department Addition	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06584	Chiller Building	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06585	Pump House	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06587	CT#2 Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-00285	Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02918	Stair and Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02919	Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02920	Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02921	Waiting Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-05418	Bulk Oxygen Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-05732	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06545	Diagnostic and Treatment Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06546	Energy Center (CUP)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06547	Booster Pump House	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06548	Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06873	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06874	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-00274	Hospital Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-00275	Plant Service Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05460	MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05651	Switchgear Enclosure	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05652	Generator Enclosure - Number 1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023		
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05653	Generator Enclosure - Number 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023		
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05654	Generator Enclosure - Number 3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023		
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06761	Bed Tower	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06762	Rotunda	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06763	North Canopy	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06764	South Canopy	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06868	Fire Pump Room	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06869	Tech Dock Building	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06890	Generator Enclosure - Number 4	OSHPD 1-Under Construction	5s								5s					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06891	Propane Tank and Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/12/2023		
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06973	Hospital Tower Basement	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/14/2022	Rpt: Review Completed 12/12/2023		
33 - Riverside	13030	Kindred Hospital Riverside	BLD-00986	Main Hospital	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/07/2024	Rpt: Review Completed 03/07/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	13030	Kindred Hospital Riverside	BLD-03519	Storage	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 03/07/2024	Rpt: Review Completed 03/07/2024		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05595	Main Hospital Facility	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05596	Central Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05800	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05801	North Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05802	East Canopy	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/28/2023		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05803	Emergency Department Canopy	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/28/2023		
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05804	Entrance Canopy	OSHPD 1-In Service	5								4		Rpt: Awaiting review 12/28/2023		
33 - Riverside	16148	Menifee Global Medical Center	BLD-00351	Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02897	Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02898	Stair and Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02899	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	10553	Palo Verde Hospital	BLD-01376	Building A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01377	Building B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01378	Building C	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Not Submitted	
33 - Riverside	10553	Palo Verde Hospital	BLD-01379	Building D	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01380	Building E	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-05443	Main Building	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-06095	Dining Addition	OSHPD 1-Under Construction	5s								4s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-06096	Rehab Addition	OSHPD 1-Under Construction	5s								4s					
33 - Riverside	10556	Riverside Community Hospital	BLD-01384	Building A (Main)	OSHPD 1-In Service	1						9/1/2017 Com Acc Rebuild	Yes	2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
33 - Riverside	10556	Riverside Community Hospital	BLD-01385	Building B	OSHPD 1-In Service	2						2/1/2018 Com Acc Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	10556	Riverside Community Hospital	BLD-01386	Building C (Inpatient Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/15/2023		
33 - Riverside	10556	Riverside Community Hospital	BLD-01387	Building D	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	10556	Riverside Community Hospital	BLD-01388	Old Radiology Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
33 - Riverside	10556	Riverside Community Hospital	BLD-03107	Emergency Generator Enclosure	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/15/2023		
33 - Riverside	10556	Riverside Community Hospital	BLD-03421	Building G	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023		
33 - Riverside	10556	Riverside Community Hospital	BLD-07245	Building H	OSHPD 1-Proposed	5s								5s					
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-02517	Main Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Awaiting review 12/08/2023		
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03488	Ancillary Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Awaiting review 12/08/2023		
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03489	Central Plant / Dining Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Awaiting review 12/08/2023		
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03490	Generator Building	OSHPD 1-In Service	3								4			Rpt: Awaiting review 12/08/2023		
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-05814	Co-Gen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/08/2023		
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-05906	MRI Trailer	OSHPD 3-Outpatient Only	N/A								N/A					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06352	Central Plant Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06830	Exterior Canopy 1	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06831	Exterior Canopy 2	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01389	Original Building-OB Addition-'64 Addition	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 02/13/2025	Rpt: Awaiting review 02/06/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01390	O.R. Addition	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Open - Returned 02/13/2025	Rpt: Awaiting review 02/06/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01391	Addition (1980)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01392	O.B. Addition	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-02947	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-02948	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05235	ED / ICU	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05303	Central Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05425	Oxygen Tank and Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-06816	Pedestrian Walkway Canopy	OSHPD 1-In Service	5								4			Rpt: Awaiting review 02/06/2025	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00331	Building A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00332	Building B & ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00334	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00335	OR/Amb. Care Addn - Bldg D, North	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-02980	OR/Amb. Care Addn - Bldg D, South	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05228	ER, ICU & Radiology Expansion - Building G	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05281	Bed Addition, Building "i"	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05282	ER, ICU & Radiology Expansion - Building F	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05284	ER, ICU & Radiology Expansion - Building H	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05521	ER, ICU & Radiology Expansion - Building B1D	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06605	Replacement Hospital	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06606	Central Plant	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06776	Main Entry Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06777	Loading Dock Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06807	Service Building	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-00290	Original Hospital Building & Conversions	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-00291	Acute Care Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-05229	Women's Center and Emergency Room	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-06770	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-06828	Hospital and Women's Center Generator	OSHPD 1-Equipment Yard	N/A								2s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	18167	Temecula Valley Hospital	BLD-05259	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
33 - Riverside	18167	Temecula Valley Hospital	BLD-06130	D&T Expansion 2018	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
33 - Riverside	18167	Temecula Valley Hospital	BLD-07279	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
34 - Sacramento	10027	California Northstate University Medical Center	BLD-06522	CNU Medical Center	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-06523	Central Plant	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07308	Open Parking Garage (North)	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07309	Open Parking Garage (South)	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01419	Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01420	Hospital Addition Tower	OSHDP 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01421	3 - Hospital Addition Clinic	OSHDP 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01422	Camellia Building	OSHDP 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-03284	ATS Building	OSHDP 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-03557	Telephone Equipment Building	OSHDP 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-05469	Central Utility Building	OSHDP 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-05905	Camellia Utility Bridge	OSHDP 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-06474	ED Expansion	OSHDP 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00319	Hospital, Building 1	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00320	Hospital, Building 2	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00321	Hospital Expansion	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/18/2022	Rpt: Review Completed 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00322	Central Plant	OSHDP 1-In Service	4								4			Rpt: Review Completed 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03502	Communications Building	OSHDP 1-In Service	4								4			Rpt: Review Completed 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03503	ER / Radiology Expansion	OSHDP 1-In Service	5s								4			Rpt: Review Completed 12/11/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03608	Central Utility Plant (Chiller Plant)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/11/2023		
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03609	Hospital Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/11/2023		
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06109	ED Trauma Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/11/2023		
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06128	Corridors	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/11/2023		
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06249	CUP Water Tank No. 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/11/2023		
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06602	ED Expansion	OSHPD 1-Under Construction	5s								5s					
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06603	ED Entry Canopy	OSHPD 1-Under Construction	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06442	Hospital	OSHPD 1-Proposed	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06443	Energy Center	OSHPD 1-Proposed	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06444	Entry Canopy	OSHPD 1-Proposed	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06446	Ambulance Canopy	OSHPD 1-Proposed	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07266	Fire Pump House	OSHPD 1-Proposed	5s								5s					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07269	Oxygen Yard	OSHPD 1-Proposed	N/A								5s					
34 - Sacramento	10606	Mercy General Hospital	BLD-01423	South Wing / East Wing (South Wing)	OSHPD 1-In Service	2						7/1/2017 Risk Bsd Retrofit		2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
34 - Sacramento	10606	Mercy General Hospital	BLD-01424	East Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
34 - Sacramento	10606	Mercy General Hospital	BLD-01425	Northeast Wing, Part A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
34 - Sacramento	10606	Mercy General Hospital	BLD-01426	Northeast Wing, Part B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
34 - Sacramento	10606	Mercy General Hospital	BLD-01427	North Wing	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
34 - Sacramento	10606	Mercy General Hospital	BLD-03110	Northeast Wing, Part D	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/08/2023	Rpt: Review Completed 12/22/2023		
34 - Sacramento	10606	Mercy General Hospital	BLD-03380	Heart Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
34 - Sacramento	10606	Mercy General Hospital	BLD-03381	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
34 - Sacramento	10606	Mercy General Hospital	BLD-05211	2 Story Corridor Structure	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
34 - Sacramento	10606	Mercy General Hospital	BLD-05212	4 Story Corridor Structure - Structurally connected to BLD-01427	OSHPD 1-Not an Independent Building	N/A								N/A					
34 - Sacramento	10606	Mercy General Hospital	BLD-06125	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00078	South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/07/2024	Rpt: Review Completed 08/05/2024		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00079	West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/07/2024	Rpt: Review Completed 08/05/2024		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00080	East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/07/2024	Rpt: Review Completed 08/05/2024		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00081	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/07/2024	Rpt: Review Completed 08/05/2024		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06990	Central Plant Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 08/05/2024		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06991	Ambulance Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06992	Emergency Department	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 08/05/2024		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01428	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01429	Central Plant	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01430	CCU/Telemetry	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01431	New Central Plant	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01432	New Hospital Wing	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01433	Cath Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-03404	McAuley Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-05784	McAuley Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06461	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06988	McAuley Canopy - Low	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06989	Lobby and Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07284	Emergency Shower	OSHPD 1-In Service	5								2		Rpt: Review Completed 09/05/2024	Rpt: Not Submitted	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07285	Vehicular Emergency Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07286	Emergency Entry	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00971	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00972	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00973	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/23/2007	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00974	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00975	North Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03216	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03696	Medical Gas Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03705	East Wing Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03706	East Wing Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06308	ED Upper South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06309	ED Lower South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06310	ED North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	BLD-06365	Vibra Rehabilitation Hospital of Natomas	OSHPD 1-In Service	5								5				Earthquake Resilient
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	BLD-06397	Main Entry Drop Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
34 - Sacramento	14506	Shriners Hospitals For Children Northern California	BLD-02530	Main Hospital	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 01/11/2024	Rpt: Not Submitted	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-01446	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03264	Radiation Oncology Center - Structurally connected to BLD-05216	OSHPD 1-Not an Independent Building	N/A								N/A				
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03622	Sutter Capital Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03629	Foot Bridge	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05216	Women's & Children's Center	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05907	Sutter Capital Pavilion Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05908	Main Hospital Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06469	UC Davis Rehabilitation Institute	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06470	Emergency Generator Enclosure	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06664	Porte-Cochere	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01434	North/South Wing	OSHPD 1-In Service	1	Denied					12/31/2019 Com Acc Replace	1/1/2025 AB 2190 Rebuild	2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01435	University Surgery Center - Structurally connected to BLD-01434	OSHPD 1-Not an Independent Building	N/A	Denied							N/A				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01436	East Wing (Tower)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01437	East Wing (Radiology)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01438	East Wing (Laundry)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01439	University Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01440	MRI	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01443	Emergency Room Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01444	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01445	Davis Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-02840	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-02841	Surgery and Emergency Services Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-05815	CT Scan Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06783	California Tower	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06825	Interim Ambulance Canopy	OSHPD 1-Proposed	5s								4s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06826	Interim Drop-off Canopy	OSHPD 1-Proposed	5s								4s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07203	CUP Annex	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07261	Surgery and Emergency Services Pavilion - West	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07262	Loading Dock Canopy	OSHPD 1-In Service	5								2		Rpt: Review Completed 11/04/2024	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07263	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07264	Vestibule Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07265	Mechanical Room	OSHPD 1-In Service	5								2	Intent to Remove GAC	Intent to Remove GAC			
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07281	Gas Bottle Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07324	University Tower Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-03267	Main Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/27/2023		
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05493	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05494	Biowaste / Storage Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05495	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01458	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01459	ICU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01460	Conference	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03063	Emergency Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03064	Reception	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03065	Radiology	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03472	Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted		
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03761	Emergency Department Expansion	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03820	Radiology Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-05467	Women's Center	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-05874	William and Inez Mabie SNF	OSHPD 2-Skilled Nursing Only	N/A								N/A				
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00071	Diagnostic & Treatment Bldg.	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00072	Nursing Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00073	Clinics Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00074	Mental Health Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00075	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00076	MRI Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00077	Loading Dock	OSHPD 1-In Service	3								5				
36 - San Bernardino	16877	Ballard Rehabilitation Hospital	BLD-00293	Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Open - Returned 12/27/2023	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05294	Main Hospital Tower - North	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05295	Main Hospital - South	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05296	Porte-Cochere	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05297	Entrance Canopy - East	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05298	Entrance Canopy - West	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	13035	Bear Valley Community Hospital	BLD-00987	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13035	Bear Valley Community Hospital	BLD-00988	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01003	Building 1 (Main Core)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01004	Building Two	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01005	Building Three	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01006	Building Four	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01007	Building Five	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07250	Main Entrance Canopy	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07251	Ambulance Canopy	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07252	Nuclear Medicine	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07253	Storage	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01471	Main Hospital, Wing A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01472	Main Hospital, Wing B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01473	Main Hospital, Wing C	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01846	Original Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				01/01/2015				N/A				
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01847	Storage Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				01/01/2015				N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01848	Physical Therapy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01849	South Hospital	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01850	North Hospital	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01851	Wings 700/800/900	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01852	Utility/Central Plant 1/Service Buildings	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01853	Central Plant #2	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01854	Central Plant #3	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-03223	Telecom Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01046	Main Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01047	Birthing Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01048	Emergency Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-02612	Main Hospital Entrance Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-02613	Emergency Room Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05640	Outpatient Surgery Waiting & Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05641	Cath Lab and Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05642	65 Bed Acute Care Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-07204	ED Addition	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-00245	Acute Care Hospital Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-00246	Emergency Department Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05124	Continuing Care Center	OSHPD 2-Skilled Nursing Only	N/A								N/A				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05702	Perinatal Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05703	Pedestrian Walkway	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06062	Emergency Water Supply Pump Enclosure	OSHPD 1-Not a Building Structure	N/A								5				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06105	Cooling Tower and Emergency Generator	OSHPD 1-Equipment Yard	N/A								5				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06106	Emergency Ambulance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06576	Electrical Building	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06577	Generator Enclosure	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01494	Phase 2	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01495	Phase 1A3 - Structurally connected to BLD-01489	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01496	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Review Completed 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01498	Phase 4 Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01499	Phase 5 Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Review Completed 12/06/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01500	MRI Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01501	Telecom Addition	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-03053	Parking Structure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05250	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05251	Hospital Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05512	Phase 3	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Rebuild			2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05564	Hospital Support Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05602	Hospital Drop-off Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05603	ED Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05604	Loading Dock Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05605	Central Plant Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05606	Pedestrian Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-06933	MRI Addition #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-06981	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/06/2023		
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07182	Phase 2 Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Intent to Remove GAC	Intent to Remove GAC		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07183	Phase 5 Utility Tunnel	OSHDP 1-Tunnels	N/A								2		Rpt: Review Completed 09/25/2024	Rpt: Not Submitted	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-05244	Main Hospital	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-05258	Central Utility Plant	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06958	Tech Dock Canopy 1	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06959	Tech Dock Canopy 2	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06960	Tech Dock Canopy 3	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06961	Tech Dock Canopy 4	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06962	E.D. Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06963	Medical Storage Building	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06964	CUP Expansion	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06965	IT Admin	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06966	IT Plant	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-01466	Building I	OSHDP 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-01467	Ambulance Canopy	OSHDP 1-In Service	4s								3		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05842	Building III (Patient Wing 5)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05843	Building IV (Support Services)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05844	Building V (Patient Wing 6)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05845	Building VI (Patient Wing 7)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-03042	Original Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/20/2024	Rpt: Review Completed 03/20/2024	
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-03043	Generator Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/20/2024	Rpt: Review Completed 03/20/2024	
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-07010	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/20/2024	
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07345	Loma Linda Rehabilitation Hospital	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07346	Porte-Cochere	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07347	Trash Enclosure	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07348	Generator Yard	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01479	Main Hospital Tower - Area C	OSHPD 1-In Service	1	Denied							2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01480	Main Hospital Tower - Area B	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01481	Emergency Room Expansion - 1976	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01482	Northeast Wing - Schuman Pavilion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01483	South Wing Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01484	Emergency Room Expansion - 1987 - Structurally connected to BLD-01481	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01485	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01486	Co-Generation Plant	OSHPD 1-In Service	4								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-02961	Chiller Facility	OSHPD 1-In Service	4								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03021	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03022	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03023	Main Hospital Tower - Area A	OSHPD 1-In Service	1	Denied							2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03024	South Wing Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03025	Original Plant	OSHPD 1-In Service	4D	Denied							4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05372	Utility Tunnel Expansion	OSHPD 1-Tunnels	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05373	Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05375	Edison Yard (Underground Vault)	OSHPD 1-In Service	N/A								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05482	Emergency Generator Fuel Tank	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05488	South Tower Fuel Tank	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05489	South Tower Bulk Medical Gas	OSHDP 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05490	Emergency Generator	OSHDP 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05592	South Wing Tunnel Phase 1	OSHDP 1-Tunnels	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05878	New Replacement Hospital	OSHDP 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06022	Utility Tunnel – BLD 12B	OSHDP 1-Tunnels	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06028	Chiller Plant	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06032	CTP Generator Enclosure	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06068	Unimed Switchgear	OSHDP 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06070	CTP Decontam Shower	OSHDP 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06071	CTP Loading Dock Canopy	OSHDP 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06072	CTP Entrance Canopy	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06073	CTP Galleria	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06074	CTP 7 & 8 Connector	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06075	CTP Grand Hallway Canopy	OSHDP 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06076	Schuman Addition	OSHDP 1-Under Construction	5s								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06077	Schuman Bridge	OSHDP 1-Under Construction	5s								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06395	Shop Canopy	OSHDP 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06406	Bulk Medical Gas	OSHDP 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06740	TES Generator	OSHDP 1-Under Construction	5s								4s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06791	CTP Emergency Generator No. 1	OSHDP 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06792	CTP Emergency Generator No. 2	OSHDP 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06793	CTP Emergency Generator No. 3	OSHDP 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06794	CTP Emergency Generator No. 4	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06839	P3 Canopy	OSHPD 1-Proposed	5s								4s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01008	Hospital Ancillary	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01009	Nursing Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01010	X-Ray Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01011	Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-02882	24 Bed Rehabilitation Hospital	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-03814	Telephone Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Awaiting review 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-05593	Mechanical Room	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-05793	24 Bed Rehabilitation Hospital - Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/27/2023	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-05322	Heart and Surgical Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07186	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00963	Service Wing - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00965	Service Wing - Dining Room Addition	OSHPD 1-In Service	5s								4D-L1			Rpt: Review Completed 12/14/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00966	Service Wing - Medical Records Addition	OSHPD 1-In Service	4								4D-L1		Rpt: Review Completed 12/14/2023		
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00967	North Wing - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00968	North Wing - Labor & Delivery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00969	East Wing - Original Hospital	OSHPD 1-In Service	2								4D-L1		Rpt: Review Completed 12/14/2023		This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00970	Plant Services - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-02737	Plant Services - Engineering Addition	OSHPD 1-In Service	4								4D-L1		Rpt: Review Completed 12/14/2023		
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-06936	Monochloramine Generating Station	OSHPD 1-Proposed	5s								4s				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01474	Main Building	OSHPD 1-In Service	2	Denied							2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01475	Radiology/Lab and ER Addition	OSHPD 1-In Service	5								2		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01476	ER Addition - Structurally connected to BLD-01475	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01477	Emergency Generator Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01478	Oxygen Storage Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-03687	Emergency Generator Bldg II	OSHPD 1-In Service	5								2		Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	10681	Mountains Community Hospital	BLD-05687	LOX Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
36 - San Bernardino	10681	Mountains Community Hospital	BLD-06479	Skilled Nursing Building	OSHPD 1R-Skilled Nursing Only	N/A								N/A					
36 - San Bernardino	10681	Mountains Community Hospital	BLD-07304	Med/Surg and ED Addition	OSHPD 1-Proposed	5s								5s					
36 - San Bernardino	10681	Mountains Community Hospital	BLD-07305	Porte-Cochere	OSHPD 1-Proposed	5s								5s					
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01821	Original Hospital & ER	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01822	Transitional Care-CCU/ICU	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01823	Emergency Addition - Structurally connected to BLD-01821	OSHPD 1-Not an Independent Building	N/A								N/A					
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01824	CCU/ICU Addition - Structurally connected to BLD-01822	OSHPD 1-Not an Independent Building	N/A								N/A					
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01825	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01826	Chiller Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023		
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01827	Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023		
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01828	West Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023		
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01829	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023		
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01830	Obstetrics/Prenatal/LDR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023		
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01831	Medical/Surgical	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01832	New Hospital Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-02928	MRI Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06087	Filter Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06088	South Building Connector	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06089	South Building West Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06090	South Building South Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06230	Inpatient MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06404	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06405	Generator Distribution / Transfer Switch Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01801	Original Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01802	Part 1 Addition - Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01803	Part 2 Addition - Surgery	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01804	Part 3 Addition - Admitting	OSHDP 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01806	Central Plant	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01807	Radiology Addition	OSHDP 1-In Service	2						1/1/2015 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01808	Patient Tower	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01809	Central Supply	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/12/2023	Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01810	North Hallway	OSHDP 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01811	Radiotherapy Addition	OSHDP 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01813	Emergency Building 2	OSHDP 1-In Service	4								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02812	Phase 2 Building Addition	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02813	1958 Radiology Building	OSHDP 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02814	Electrical Utility Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-05892	Surgery Addition	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-05904	Oxygen Farm	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06299	Gift Shop Addition	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/26/2023		
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06327	North / South Utility Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/26/2023		
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06328	East / West Utility Tunnel	OSHPD 1-Tunnels	N/A								4		Rpt: Review Completed 12/26/2023		
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01833	Auditorium & Administration	OSHPD 1-In Service	2			01/01/2015					2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01834	Latimer Wing	OSHPD 1-In Service	2			01/01/2015		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01835	Maternity - Structurally connected to BLD-01834	OSHPD 1-Not an Independent Building	N/A			01/01/2015		Withdrawn			N/A				
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01836	Power Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01837	Laundry Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01838	Main Building	OSHPD 1-In Service	2			Denied					2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01839	Increment II, Phase 1 - East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01840	Increment II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01841	Maternity Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01842	Mental Health - South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01843	Increment II - Phase 2 East & Middle	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Awaiting review 12/14/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01845	NICU Addition	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03020	Increment II - Phase 2 West Section	OSHDP 1-In Service	3								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03542	Mental Health - North	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03548	Increment II, Phase 1 - North	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-05253	Main Hospital Tower	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06154	New Oxygen Service Area	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06377	East Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06378	West Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06385	Central Plant	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06386	Emergency Drive Canopy	OSHDP 1-In Service	3								3		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06387	Emergency Walkway Canopy	OSHDP 1-In Service	3								3		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06604	Main Electrical Switchgear Building	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06619	New Tower - Pedestrian Corridor	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01814	Main Hospital	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01815	South Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A													
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01816	Emergency Building	OSHDP 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01817	Central Tower	OSHDP 1-In Service	4D								2	1/1/2024	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01818	North Tower	OSHDP 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01819	Service Building	OSHDP 1-In Service	4								3		Rpt: Review Completed 10/25/2016	Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01820	Ancillary Building	OSHDP 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-03363	Cooling Tower Yard	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-05639	IT Services Building	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06229	CoGen Plant	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06255	Loading Dock Canopy	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06259	CCU Med Air and Vacuum Canopy	OSHDP 1-In Service	5								4			Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06260	Medical Gas Canopy	OSHDP 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023		
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06287	Conference Center	OSHDP 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023		
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-04912	Subacute	OSHDP 2-Skilled Nursing Only	N/A								N/A					

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-05483	Acute Care Building No. 1	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-05959	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/15/2023		
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-06126	Medical Gas Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-06127	Lighthouse Bulk Medical Gas Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01855	Medical / Surgical / Surgery Add	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01856	Radiology/Surgery/L&D/Emergency	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01857	Equipment Shelter Pump House	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01858	Emergency Building - Structurally connected to BLD-01856	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01859	Nursing Wing (BHU/PCU)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01860	Cath Lab/ICU/Outpatient Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01861	Emergency Generator Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01862	Urgent Care E.R. Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03131	O.B. Addition	OSHPD 1-Under Construction	N/A	Denied							N/A				
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03132	Canopy Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/10/2024	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03134	Helistop	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/10/2024	Rpt: Not Submitted	
37 - San Diego	12322	Grossmont Hospital	BLD-02098	Emergency Generator Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02099	West Wing - West	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02100	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02101	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02102	Central Plant & Cooling Plant Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/03/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02103	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02104	Physical Rehabilitation Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12322	Grossmont Hospital	BLD-02105	Meeting Room Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02622	Main Entry	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-02829	Heart and Vascular Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02830	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-03678	Old Administration Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
37 - San Diego	12322	Grossmont Hospital	BLD-03683	Womens Health Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-03685	East Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-03767	West Wing - East	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-03768	West Wing - North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-05312	Mental Health Building	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12322	Grossmont Hospital	BLD-05336	ED/CCU and ACNU Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05368	Physical Rehabilitation Utility Vault	OSHPD 1-In Service	4s								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-05510	MRI / Angio Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-05678	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05764	Emergency Generator 1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05765	Emergency Generator 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-06787	Neuro ICU Addition	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12322	Grossmont Hospital	BLD-06788	PCU Addition	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12322	Grossmont Hospital	BLD-06867	Main Entry Canopy	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-07007	South Loading Dock	OSHPD 1-In Service	4D								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07008	Utility Trellis	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12322	Grossmont Hospital	BLD-07070	Tunnel / Storage Room	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/15/2023		
37 - San Diego	12322	Grossmont Hospital	BLD-07071	ER Substation	OSHPD 1-In Service	5s								4		Rpt: Review Completed 12/15/2023		
37 - San Diego	12322	Grossmont Hospital	BLD-07153	Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/15/2023		
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-02943	Hospital	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-03552	Central Utility Plant	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-05690	Hospital Support Building	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06311	Main Entrance Canopy	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06312	Emergency Entry Canopy	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06313	Fire Pump Room	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06314	Tech Dock Canopy - Lower	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06315	Tech Dock Canopy - Upper	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06531	Hospital Building	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06532	Central Plant	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06533	Entry Canopy	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06534	ED Canopy	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06536	Garden Canopy	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07097	Tech Dock Canopy West	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07098	Tech Dock Canopy East	OSHPD 1-In Service	5								5			Earthquake Resilient	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07100	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								5				
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07101	Bunker Fire Pump Rooms	OSHPD 1-In Service	5								5			Earthquake Resilient	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00198	Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 06/05/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00199	Hospital Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00200	Clinic Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00201	Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 06/05/2023	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00202	Emergency Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00203	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								2		Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-03295	Med Gas Chain Link Fence Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02106	Building I (Building A)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02107	Building II (Building B)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02108	Building III (Building C)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02109	Building IV (Building D)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02110	Building V (Building E)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	18173	Palomar Medical Center	BLD-05231	Hospital	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	18173	Palomar Medical Center	BLD-05232	Central Plant	OSHDP 1-In Service	5s								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	14190	Palomar Medical Center Poway	BLD-00255	Patient Tower	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-00256	Ancillary Building (East)	OSHDP 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-00257	Central Plant	OSHDP 1-In Service	4								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	14190	Palomar Medical Center Poway	BLD-00258	Angio / Cath Lab Addition	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-00259	Emergency Room Addition	OSHDP 1-In Service	5								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	14190	Palomar Medical Center Poway	BLD-02896	Co-Generation Building	OSHDP 1-In Service	4								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03240	Entrance Canopy	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03241	Pedestrian Link	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03588	Villa Pomerado	OSHDP 2-Skilled Nursing Only	N/A								N/A				
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03589	Steam Plant	OSHDP 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/29/2023		
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03592	Patient Elevator Tower	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-03593	Lobby	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-06245	Ancillary Building (West)	OSHDP 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	14190	Palomar Medical Center Poway	BLD-06246	Loading Dock/Electrical Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar Medical Center Poway	BLD-06451	Power Conditioning UPS/ATS Building	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	14190	Palomar Medical Center Poway	BLD-06808	Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	18230	Palomar Rehabilitation Institute	BLD-06258	Palomar Rehabilitation Institute	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12348	Paradise Valley Hospital	BLD-02132	Main Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12348	Paradise Valley Hospital	BLD-02133	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12348	Paradise Valley Hospital	BLD-02134	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02135	ER Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02136	Boiler Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02137	Pediatrics Wing	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02138	Chiller Building	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02139	Generator Building	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02140	Medical Office Building	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02141	Storage Building - BLD-06432 at 24384	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02063	Medical Wing - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02066	Dining Room - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02067	Gait Lab	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02068	Warehouse/Shop	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02069	Old Gait Analysis Lab	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02070	2nd Dining Room - Original Hospital	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02071	Intensive Care Unit	OSHPD 1-In Service	4								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02072	Co-Generation Plant	OSHPD 1-In Service	4								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02073	Clinical Lab	OSHPD 1-In Service	3								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02074	Medical Nursing Unit Expansion	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02076	Radiology Addition	OSHPD 1-In Service	3								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02079	Children's Way Pavilion (15A & 15B)	OSHPD 1-In Service	3								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02080	Children's Way Pavilion - Clock Tower	OSHPD 1-In Service	4								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02669	Surgical Unit	OSHPD 1-In Service	4								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02770	Gas Storage Building	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02772	Bridge to Acute Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-02773	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03125	A Wing, Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03126	B Wing, Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03127	C Wing - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03128	D Wing - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03129	Bridge to Sharp Hospital - Structurally connected to BLD-03128	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03130	Trauma Room Addition	OSHPD 1-In Service	3								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03195	Intensive Care Unit	OSHPD 1-In Service	4								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03197	Passageway to NICU	OSHPD 1-In Service	3								3		Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03198	Children's Way Pavilion - Bridge	OSHPD 1-In Service	3								3	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023		
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03199	Enclosed Passageway to MOB	OSHPD 1-In Service	3								3	Intent to Remove GAC	Intent to Remove GAC		
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03647	Acute Care Pavilion	OSHPD 1-In Service	5								4		Rpt: Review Completed 03/23/2023		
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-03896	Hahn Pavilion Loading Dock Canopy	OSHPD 1-In Service	3								3	Rpt: Open - Returned 12/22/2023	Rpt: Review Completed 03/23/2023		
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06800	ICU/ES Pavilion	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06801	Campus Connector	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06802	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06803	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06804	Ambulance Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital - San Diego	BLD-06805	Bulk Medical Gas Yard	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	14181	Scripps Green Hospital	BLD-00250	Original Building - Phase I North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00251	Original Building - Phase I South Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00253	Dining and Kitchen Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00254	Storage & Maintenance Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-02662	Heart, Lung, Vascular Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02085	Wood Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02086	Masonry Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02088	OSA Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02089	East Wing Addition - North	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/20/2023	Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02090	Emergency Room Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02091	ICU Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02586	Loading Dock	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03553	Central Energy Plant Service Yard	OSHPD 1-Equipment Yard	N/A								5				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03673	East Wing Addition - South	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/20/2023	Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03674	East Wing Addition - Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/20/2023	Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-05299	Critical Care Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-05301	Central Energy Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06537	Acute Care Building	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06538	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06539	Loading Dock	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01118	Building 1-3-4	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01119	Building 1-A	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01120	West Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01121	Transition Tower (& 5A)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01122	Addition to Women's Center - Structurally connected to BLD-01121	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01123	East Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01124	Building 7	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01125	Service Building (8, 8A, 8B)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01126	Co-Generation Plant	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01127	Building 10	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01128	Emergency Expansion	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01129	Building 6A	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02583	Dining Area Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02584	Mericos Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02585	Outpatient Waiting Room	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03051	Building 10A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03549	Scripps Clinic La Jolla Medical Office Building	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03550	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03551	Prebys Cardiovascular Institute Pedestrian Walkway	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-05266	Prebys Cardiovascular Institute	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-05267	Central Energy Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06436	New Tower	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06747	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06927	Pedestrian Tunnel	OSHPD 1-Proposed	5s								4s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07213	RA/Chem Storage	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07214	Bio Hazard Storage	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02114	Main Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02115	Main Hospital Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02116	ICU Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02119	ICU Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02120	Elevator Tower	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02121	Ambulatory Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02122	Ambulatory Add - Elevator Tower	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02123	Ambulatory Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02124	Ambulatory Addition - Structurally connected to BLD-02121	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02589	Mechanical Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02590	Clinic Building	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03543	Central Energy Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03545	Canopy 1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03546	Canopy 2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03547	Canopy 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03712	Ambulatory Add - Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03713	Ambulatory Add - East Stair Add	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-05637	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-05638	Replacement Stair - Structurally connected to BLD-02119	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06492	Replacement Hospital	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06493	New Canopy 1	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06806	Pedestrian Access Bridge	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06853	Canopy 2	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06854	Pedestrian Access Canopy	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06855	Canopy 3	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02055	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02056	Tower Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02057	Emergency Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02058	Hospital Expansion	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02060	Hospital Expansion - Emergency Dept	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02061	Mechanical Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03044	Hospital Expansion - Lobby	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03045	Hospital Expansion - ICU	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03842	Connector Building - Structurally connected to BLD-02056	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03874	Modular Cath Lab	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03875	Cath Lab Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	16703	Select Specialty Hospital - San Diego	BLD-00292	Hospital and M.O.B.	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/21/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00227	East Tower - North Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Awaiting review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00228	East Tower - South Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Awaiting review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00229	West Tower - Lobby	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Awaiting review 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00230	Cardiac Operating Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02717	West Tower - Administrative Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Awaiting review 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02718	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02719	West Tower - Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Awaiting review 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02828	Ocean View Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05673	Entry Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05674	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05969	Birch Patrick Convalescent Center	OSHPD 2-Skilled Nursing Only	N/A								N/A				
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06011	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06238	Bulk O2 Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06394	Gas Bottle Storage	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02081	Main Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02082	ICU Building (Emergency Department Building)	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02083	Ancillary Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02827	Prospect Place Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03680	Morgue Building	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03681	Long Term Care Building (Outpatient Pavilion Building)	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03682	Sub Acute Care II Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-03892	Mary Birch Womens Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/12/2022	Rpt: Not Submitted	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06769	Mary Birch Expansion	OSHPD 1-Proposed	5s								5s				
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06900	Loading Dock Canopy	OSHPD 1-Proposed	5s								4s				
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06903	Temporary Dietary Exit Canopy	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01130	North Tower - East Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01131	North Tower - Central Building	OSHPD 1-In Service	2			01/01/2014					2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01132	North Tower - West Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01133	Inter-Hospital Passageway	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01134	South Tower	OSHPD 1-In Service	2			01/01/2014					2	1/1/2030	Rpt: Review Completed 01/09/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01135	Rehabilitation Center	OSHPD 1-In Service	3								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01136	Emergency / Radiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01137	Dietary Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01138	Service Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01139	Long Term Care Building	OSHPD 1-In Service	2								4D-L1			Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01140	MRI Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01142	New Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-02835	New Acute Care Tower (Stephen Birch West Tower)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-02836	Stephen Birch East Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03753	Corridor 1 - North	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03754	Corridor 1 - South	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03755	Corridor 2 - North	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03756	Corridor 2 - Middle	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03757	Corridor 2 - South	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03758	Corridor 2 - Long Term Care	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05526	Passageway Link	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05527	Telephone Switch Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05534	Corridor 1 - North Segment B	OSHPD 1-In Service	4					Denied			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05535	Corridor 1 - North Segment C	OSHPD 1-In Service	4					Denied			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice	
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**						
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05540	Kitchen / Pharmacy Storage Building - Structurally connected to BLD-01134	OSHDP 1-Not an Independent Building	N/A													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05550	Outpatient Pavilion	OSHDP 3-Outpatient Only	N/A													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05551	Shop Building	OSHDP 1-In Service	2s										Intent to Remove GAC	Intent to Remove GAC		
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05976	Parking Structure Canopy	OSHDP 1-In Service	5												Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05977	East Entrance Canopy	OSHDP 1-In Service	5												Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05978	Main Front Canopy	OSHDP 1-In Service	5												Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05979	Lower Level SB Connector	OSHDP 1-In Service	5												Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06596	Campus Connector (Center)	OSHDP 1-Under Construction	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06755	New Central Energy Plant	OSHDP 1-Under Construction	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06756	ED Expansion	OSHDP 1-Under Construction	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06757	New Oxygen Yard	OSHDP 1-Under Construction	N/A													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06768	New Tower	OSHDP 1-Proposed	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06810	Electrical Yard	OSHDP 1-Proposed	N/A													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06851	ED Canopy	OSHDP 1-Under Construction	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06901	Campus Connector - North	OSHDP 1-Under Construction	5s													
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06902	Campus Connector - South	OSHDP 1-Under Construction	5s													
37 - San Diego	12372	Tri-City Medical Center	BLD-01143	Center Tower	OSHDP 1-In Service	2	Denied									1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01144	North Wing	OSHDP 1-In Service	4	Denied									1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01145	Center Complex - North	OSHDP 1-In Service	4	Denied									1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12372	Tri-City Medical Center	BLD-01146	South Tower	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 10/14/2024	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01147	Electrical Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01148	1976 Center Complex Addition	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-01149	Materials/Laboratory Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-01150	1976 Radiology Addition	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01151	Emergency Room Addition	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01152	Administration Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-01153	Pavilion Building Canopy	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-01154	Pavilion Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01155	Ancillary Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02868	South Tower Stair Shaft - Structurally connected to BLD-01146	OSHPD 1-Not an Independent Building	N/A	Denied				6/28/2013 Risk Bsd Retrofit			N/A	1/1/2030			
37 - San Diego	12372	Tri-City Medical Center	BLD-02869	Electrical Building Addition	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-02870	Emergency Room Addition Canopy	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Not Submitted	
37 - San Diego	12372	Tri-City Medical Center	BLD-02871	Perinatal Unit/Women's Center	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02872	Perinatal Unit/Women's Center Canopy 1	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice	
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**						
37 - San Diego	12372	Tri-City Medical Center	BLD-02873	Perinatal Unit/Women's Center Canopy 2 - Structurally connected to BLD-02872	OSHPD 1-Not an Independent Building	N/A	Denied								N/A				
37 - San Diego	12372	Tri-City Medical Center	BLD-02874	Perinatal Unit/Women's Center Canopy 3	OSHPD 1-In Service	4	Denied								2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02875	Surgery Addition 1	OSHPD 1-In Service	3	Denied								2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02876	Surgery Addition 2	OSHPD 1-In Service	3	Denied								2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02877	Surgery Addition Canopy	OSHPD 1-In Service	3	Denied								2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02878	Central Plant	OSHPD 1-In Service	4	Denied								2	1/1/2030	Rpt: Awaiting review 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-03766	Center Complex - South	OSHPD 1-In Service	3	Denied								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-05487	Behavioral Health Unit	OSHPD 5-Acute Psych Only	N/A									N/A				
37 - San Diego	12372	Tri-City Medical Center	BLD-06565	Utility Tunnel	OSHPD 1-Tunnels	N/A									2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00935	Main Hospital	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 11/21/2023	Rpt: Review Completed 11/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00938	Service Building	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 11/21/2023	Rpt: Review Completed 11/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00939	Fire Pump Building	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 11/21/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-03050	East Equipment Yard - Structurally connected to BLD-00938	OSHPD 1-Not an Independent Building	N/A									N/A	1/1/2030			
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-03453	ED Addition	OSHPD 1-In Service	5									4			Rpt: Review Completed 11/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-06631	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-07193	Rehabilitation Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/20/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-07194	Connecting Bridge	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/20/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02142	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02143	Ancillary & Support Services Facility	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02144	West Wing & Psychiatric Inpatient	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02145	Central Plant - Structurally connected to BLD-03304	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02146	Utility Line Bridge	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02147	Telecommunications	OSHPD 1-In Service	5								4			Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02148	Outpatient Clinic	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03304	Boiler House and Shops	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03853	OR Suite Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03854	Delivery / Surgery Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05175	Utility Line Bridge - South	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05560	Chiller Building	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05846	Emergency Generator Building	OSHPD 1-In Service	5								4			Intent to Remove GAC		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-02561	Main Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-02846	Main Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05315	UCSD Sulpizio Family Cardiovascular Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05419	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05420	Bed Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05974	Emergency Preparedness Supplies Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023		
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-07320	MRI Suite Expansion	OSHPD 1-Proposed	5s								4s					
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01100	North Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01101	Link Building	OSHPD 1R-Acute Psych / SNF only	N/A								N/A					
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01102	South Tower	OSHPD 1R-Acute Psych / SNF only	N/A								N/A					
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01103	Rehabilitation Building	OSHPD 1R-Acute Psych / SNF only	N/A								N/A					
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01104	Emergency Systems Additions	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023		
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01105	MER Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023		
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	BLD-03810	New Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
38 - San Francisco	18165	California Pacific Medical Center - Van Ness Campus	BLD-03801	New Acute Care Hospital	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/30/2023	
38 - San Francisco	14621	Chinese Hospital	BLD-00316	Comprehensive Health Care Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	
38 - San Francisco	14621	Chinese Hospital	BLD-05688	Patient Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01093	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2022	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01094	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2022	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01095	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/19/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01096	MEE Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/19/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01097	Doctor's Sleep Annex	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 01/17/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-06935	Loading Dock Extension	OSHPD 1-In Service	4								3		Rpt: Review Completed 09/07/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-03809	South Residence	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05918	North Residence	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05919	Pavilion Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05920	Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06623	Connecting Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06772	Knuckle Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06773	North Knuckle - SRB Connecting Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06774	South Knuckle - SRB Connecting Building	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06775	Loading Dock	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06781	Water Tank #1	OSHPD 1-Not a Building Structure	N/A								3s	Rpt: Not Submitted	Rpt: Not Submitted		
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06782	Water Tank #2	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01069	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01070	M Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01071	Service Building	OSHPD 1-In Service	5			Withdrawn					2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-03339	Replacement Hospital	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
38 - San Francisco	12457	UCSF Health - Saint Francis Hospital	BLD-01079	Main Tower	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health - Saint Francis Hospital	BLD-01080	1958 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health - Saint Francis Hospital	BLD-01081	Pierotti Pavilion	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/26/2023	
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	BLD-01072	Main Tower	OSHPD 1-In Service	2								3R		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	BLD-01073	McAuley Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
38 - San Francisco	12476	UCSF Medical Center	BLD-01012	Moffitt Hospital	OSHPD 1-In Service	2								3R	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
38 - San Francisco	12476	UCSF Medical Center	BLD-01013	Long Hospital	OSHPD 1-In Service	4								3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/21/2023		
38 - San Francisco	12476	UCSF Medical Center	BLD-01014	Emergency Entrance Structure	OSHPD 1-In Service	3								3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/21/2023		
38 - San Francisco	12476	UCSF Medical Center	BLD-01016	Central Utilities Plant	OSHPD 1-In Service	4								3	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023		
38 - San Francisco	12476	UCSF Medical Center	BLD-06771	Helen Diller Hospital	OSHPD 1-Under Construction	5s								5s				
38 - San Francisco	12476	UCSF Medical Center	BLD-06928	Oxygen Yard	OSHPD 1-Under Construction	N/A								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-06994	Pump House	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-07135	Electrical Building	OSHPD 1-Proposed	5s								4s				
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	BLD-05445	UCSF Benioff Children's Hospital	OSHPD 1-In Service	5								5			Earthquake Resilient	
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	BLD-05523	Energy Center	OSHPD 1-In Service	5								5			Earthquake Resilient	
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01082	Building A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01083	Building B	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01084	Building D - Structurally connected to BLD-01083	OSHPD 1-Not an Independent Building	N/A				01/01/2015				N/A				
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01085	Building R	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01876	Central (Main)/East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01877	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01878	Central Plant	OSHPD 1-In Service	4s								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01879	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01880	Emergency Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-02864	New Patient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-03624	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-07232	New Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
39 - San Joaquin	10729	Dameron Hospital	BLD-01863	1987 Building - 87-A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01864	1987 Building - 87-B	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01865	1975 Building - 75-A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01866	1967 Building - 67-A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	BLD-01867	1964 Building - 64-A	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
39 - San Joaquin	10729	Dameron Hospital	BLD-01868	1957 Building - 57-A - Structurally connected to BLD-01871	OSHPD 1-Not an Independent Building	N/A									N/A				
39 - San Joaquin	10729	Dameron Hospital	BLD-01869	Generator Building - Fuel Tank	OSHPD 1-Equipment Yard	N/A									4s	Rpt: Open - Returned 12/29/2023	Rpt: Review Completed 12/29/2023		
39 - San Joaquin	10729	Dameron Hospital	BLD-01870	Generator Building - Cooling Tower	OSHPD 1-Not a Building Structure	N/A									4s	Rpt: Open - Returned 12/29/2023	Rpt: Review Completed 12/29/2023		
39 - San Joaquin	10729	Dameron Hospital	BLD-01871	1932 Building - 32-A	OSHPD 1-In Service	2	Denied								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	BLD-03615	Generator Building	OSHPD 1-In Service	5s									2	1/1/2030	Rpt: Open - Returned 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-05397	Generator Building - Bulk Oxygen	OSHPD 1-Equipment Yard	N/A									4s	Rpt: Open - Returned 12/29/2023	Rpt: Review Completed 12/29/2023		
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01881	Main Hospital & Additions	OSHPD 1-In Service	2									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01882	Outpatient/Administration	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01883	OR Addition/Meeting Room	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01884	East Patient Tower	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01885	Purchasing	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01886	Telephone Equipment Building	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01887	ER Addition	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01888	X-Ray Addition	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01889	Ultrasound/Storage	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01890	CT Scan	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01891	OB Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01892	Mechanical Equip. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01893	Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01894	OR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01895	LDR Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01896	Mechanical Equip. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01897	Freezer - Structurally connected to BLD-01881	OSHPD 1-Not an Independent Building	N/A								N/A				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00065	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Review Completed 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00066	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Review Completed 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00067	Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Review Completed 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07075	Emergency Department Expansion	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07273	Emergency Department Canopy A	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07274	Emergency Department Canopy B	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07275	Emergency Department Canopy C	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07276	Emergency Department Canopy D	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07277	MRI Canopy A	OSHPD 1-Proposed	5s								5s					
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07278	MRI Canopy B	OSHPD 1-Proposed	5s								5s					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01911	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01912	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01913	OPD Building / Conference Center / Admin Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01914	OPD Emergency Generator Shed	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn							N/A					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01915	Dietary Building	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01917	A & B Wings	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn							N/A					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03035	Loading Dock	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03171	Clinical Laboratory	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03172	Area F	OSHPD 1-In Service	5s								5s			Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03726	Compacter / Sterilizer / Baler	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03727	Connecting Link - Part 1 - North	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03728	Connecting Link - Part 2 - North	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024		
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03729	Area D	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03730	Area E	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03731	Main Hospital Canopy	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03732	Connecting Link - Part 1 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03733	Connecting Bridge - Part 1 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03734	Connecting Bridge - Pylon	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03735	Connecting Link - Part 2 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03736	Connecting Bridge - Part 2 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03737	Connecting Bridge - Pylon 2	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03738	Connecting Link - Part 3 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01898	Main Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01899	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01900	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01901	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01902	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01903	Administrative Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01904	Southeast Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01905	Cafeteria	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01906	Heart Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01907	Outpatient Surgery Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01908	Cancer Center	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01909	Hospital Main Entrance	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03367	Women & Children's Pavilion Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03369	LOX Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03370	New Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03371	Pedestrian Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03492	Elevator Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03493	Kitchen Remodel 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03494	Kitchen Remodel 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03495	Material Management Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03496	Utility Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03575	Generator Enclosure for Women and Children's Pavilion Building	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07237	Ambulance Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07238	Stair Tower	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07239	ED Lobby Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07240	Linear Accelerator Building	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07241	Arcade	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07242	OSB Canopy	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07243	Main Entrance Canopy	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07244	Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07343	North Tower	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06280	Stockton Rehabilitation Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06282	LOX Tank	OSHPD 1-Equipment Yard	N/A								5				
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06319	Porte Cochere	OSHPD 1-In Service	5								5				Earthquake Resilient
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01918	Original Hospital Building / Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01919	Building Block No. 2	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01920	1976 Alterations & Additions	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01921	Two Story Addition West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03046	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03075	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03200	North Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03345	Northwest Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03346	One Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03347	Northeast Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03348	West Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03903	Ambulatory Care Entrance Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03904	Ambulatory Care Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00839	Main Hospital and Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00840	Patient Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00841	West Wing	OSHPD 1-In Service	3				Withdrawn				2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00842	E. R. Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00241	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00242	Radiology Addition/Cath Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00243	E.R. Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00244	Administrative Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03458	Diagnostic & Treatment Expansion	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03459	West Nurse Addition	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03460	Support Service Building	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03461	Patient Tower Addition	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-05966	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-05967	Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-06611	MEP Equipment Room	OSHPD 1-Proposed	5s								4s				
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	BLD-07154	Dignity Health Central Coast Rehabilitation Hospital	OSHPD 1-Proposed	5s								5s				
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	BLD-07155	Porte-Cochere	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00955	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00956	Cath Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00957	Surgery Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-03600	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-05622	Electrical Room	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06242	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06458	Patient Tower Addition	OSHPD 1-Proposed	5s								5s					
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06630	Chapel	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06642	Generator Yard	OSHPD 1-Proposed	N/A								4s					
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06675	Bell Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06745	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06746	Patient Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01922	Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01923	Kitchen Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/18/2023		
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01924	Central Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/18/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01925	Skilled Nursing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01926	Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01927	Critical Care Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01928	Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01929	Surgery, Emergency, Food Service	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01930	Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01931	Main Entrance	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01932	Storage and Service	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01933	Nursing Unit, Admin, Laboratory	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-03310	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-03312	Acute Rehab	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00846	1963 Tower	OSHPD 1-In Service	2	Withdrawn							3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00847	Front Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn							N/A				
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00848	Area A & B	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00849	Area C	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00850	Area D	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00851	Center Pod	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00852	South Pod	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00853	Utilities Service Building	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-03280	Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-05277	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-06356	Medical Office Building 2	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00177	Hospital - Building 1	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00178	Hospital - Building 2	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00179	Hospital Tower - Building 3	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00180	Hospital - Building 4	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00181	Hospital - Building 5	OSHPD 1-In Service	4D								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00182	Hospital - Building 6	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00183	Hospital - Building 7.1	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00184	Hospital - Building 8	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00185	Hospital - Building 9	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-03475	Hospital - Building 6 Canopy	OSHPD 1-In Service	2								4			Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-03477	Hospital - Building 7.2 Exhaust Hood	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Review Completed 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-06030	Chiller Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/15/2023	
41 - San Mateo	10804	Mills-Peninsula Medical Center	BLD-03217	New Hospital	OSHPD 1-In Service	5s								5s			Rpt: Review Completed 12/28/2023	
41 - San Mateo	10804	Mills-Peninsula Medical Center	BLD-03648	Walkway Canopy for Mobile CT Trailer	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00856	Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00857	Nursing Wing	OSHPD 1-In Service	5s								2	1/1/2024	Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00858	Nursing Wing Link	OSHPD 1-In Service	5s								2	1/1/2024	Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00859	North Addition	OSHPD 1-In Service	5s								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-02636	Diagnostic and Treatment Center	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-03317	1958 Building - Structurally connected to BLD-00854	OSHPD 1-Not an Independent Building	N/A								N/A				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07103	Soiled Storage Canopy	OSHPD 1-Under Construction	5s								4s				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07104	Med Gas Storage Shed	OSHPD 1-Under Construction	5s								4s				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07195	Central Plant Loading Dock Canopy	OSHPD 1-Under Construction	5s								4s				
41 - San Mateo	10811	Sequoia Hospital	BLD-00860	Building 1	OSHPD 1-In Service	4D			07/01/2015 per AB 2557					3		Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
41 - San Mateo	10811	Sequoia Hospital	BLD-00861	Building 2	OSHPD 1-In Service	2			07/01/2015 per AB 2557					3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
41 - San Mateo	10811	Sequoia Hospital	BLD-00862	Building 3	OSHPD 1-In Service	2							3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-00863	Building 4	OSHPD 1-In Service	2							3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-00864	Building 5	OSHPD 1-In Service	2							3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-00865	Building 6, 8, 9 and 10	OSHPD 1-In Service	2			09/01/2015 per AB 2557				3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-00866	Building 7	OSHPD 1-In Service	2							3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-05198	Building 1A	OSHPD 1-In Service	2			01/01/2015				3	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		
41 - San Mateo	10811	Sequoia Hospital	BLD-05233	Pavilion	OSHPD 1-In Service	5							4		Rpt: Review Completed 12/26/2023			
41 - San Mateo	10811	Sequoia Hospital	BLD-05234	Dining Room	OSHPD 1-In Service	5							4		Rpt: Review Completed 12/26/2023			
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01022	Hospital Building	OSHPD 1-In Service	2							3	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01023	Locker Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01024	Administration Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-02677	Breezeway Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-02678	Office Infill Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-03218	East Building	OSHPD 1-In Service	5			Denied					4			Rpt: Not Submitted	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05365	Bulk Oxygen Storage	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05935	Lobby	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05936	West Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05937	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10836	Lompoc Valley Medical Center	BLD-03028	Replacement Facility	OSHPD 1-In Service	5s								4			Rpt: Awaiting review 03/06/2025	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00878	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00879	Surgery Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00881	Central Plant II - 1993	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00882	ER/CCU/Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00883	Laboratory Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-03385	Mechanical / Electrical Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-03386	New Hospital Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05455	New Hospital Expansion - Section J	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05456	New Hospital Expansion - Section K	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023		
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05457	New Hospital Expansion - Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023		
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05458	New Hospital Expansion - Emergency Department Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023		
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05459	New Hospital Expansion - Ambulance Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023		
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05623	Breezeway	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/19/2023		
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05994	Extended Care Center - Main Building	OSHPD 2-Skilled Nursing Only	N/A								N/A					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05996	Extended Care Center - Colonnade	OSHPD 2-Skilled Nursing Only	N/A								N/A					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05997	Extended Care Center - Adult Day Care	OSHPD 2-Skilled Nursing Only	N/A								N/A					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05998	Extended Care Center - Child Day Care	OSHPD 2-Skilled Nursing Only	N/A								N/A					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-06180	Extended Care Center - Day Care Connector	OSHPD 2-Skilled Nursing Only	N/A								N/A					
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00901	South Wing (Building D) (Pueblo Pavilion)	OSHPD 1-In Service	2			01/01/2015			3/31/2013 Risk Bsd Retrofit		3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00902	East Wing (Building E) (Bath Pavilion)	OSHPD 1-In Service	2			Denied					3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00904	Surgery Wing (Building G)	OSHPD 1-In Service	4			Denied					3		Rpt: Not Submitted	Rpt: Not Submitted		
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00905	Building H - Structurally connected to BLD-00902	OSHPD 1-Not an Independent Building	N/A			Denied					N/A					
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00906	Centennial Wing (Building I) (Arlington Pavilion)	OSHPD 1-In Service	4			Denied					4			Rpt: Not Submitted		
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00907	Cancer Center (Building K)	OSHPD 1-In Service	5s			Denied					3		Rpt: Not Submitted	Rpt: Not Submitted		
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05285	D & T Building (Junipero Pavilion)	OSHPD 1-In Service	5								4			Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05286	D & T "B" - Structurally connected to BLD-05285	OSHPD 1-Not an Independent Building	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05287	Pavilion E (Wood-Claeysens Pavilion)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05288	Pavilion F (Ridley-Tree Pavilion)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05289	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05292	Medical Gas Yard	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06007	Knapp Building	OSHPD 3-Clinic - Local Jurisdiction	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06021	Link Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06402	Pavilion D (Compton Pavilion)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06403	Treatment Pavilion (Arlington Pavilion)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06447	Surgery Center of Santa Barbara	OSHPD 3-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06748	Cottage Center For Advanced Imaging	OSHPD 3-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06836	Cloister Garden	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06837	Main Lobby Canopy - High	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06838	Main Lobby Canopy - Low	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-07033	Pediatric Medical Office Building	OSHPD 3-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-07114	Cottage Heart Center	OSHPD 3-Proposed	N/A								N/A				
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-00896	Hospital Building	OSHPD 1-In Service	4D			07/31/2015 per AB 2557		Withdrawn			2	1/1/2030	Rpt: Awaiting review 09/20/2024	Rpt: Not Submitted	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-00897	Emergency Services Building	OSHPD 1-In Service	4			Denied					4			Rpt: Not Submitted	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-03256	Patient Unit and Radiology Department	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05972	Emergency Entrance Porte Cochere (Entry Canopy)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05973	Lobby Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05980	CT Scanner Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
43 - Santa Clara	16713	Children's Healthcare Organization of Northern California - Pediatric Hospital	BLD-03912	Main Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-02254	1 - Orchard Pavilion	OSHPD 1-In Service	3s								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-02255	2 - Willow Pavilion	OSHPD 1-In Service	3								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-02262	10 - Central Plant	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-02264	13a - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-02265	14 - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-03529	12 - Psychiatric Wings - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-03535	10 - Central Plant - Switchgear	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-03536	10 - Central Plant - Substation	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-03577	Slot Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-03578	New Main Hospital Building (West)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-05794	Behavioral Health Building	OSHPD 5-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-05795	Behavioral Health Building - Entrance Canopy	OSHPD 5-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-05797	Utility Tunnel (East-West)	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-05962	New Main Hospital/Women's Hospital Connector	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-05963	New Main Hospital SE Vestibule	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
43 - Santa Clara	10883	El Camino Health	BLD-05964	New Main Hospital SE Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-05965	New Main Hospital SW Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-06083	New Main Hospital Building - East	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-06084	North-South Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-06085	New Main Hospital/Women's Hospital Tunnel	OSHPD 1-Tunnels	5s								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-06086	New Main Hospital / Willow Pavilion Tunnel	OSHPD 1-Tunnels	5								2		Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-06570	New Canopy at Women's Hospital	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10883	El Camino Health	BLD-07189	Wing J	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10883	El Camino Health	BLD-07190	BHS Link	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10883	El Camino Health	BLD-07322	Bulk Gas - Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02243	Original Building / Outpatient	OSHPD 1-In Service	2			Withdrawn	01/01/2015				3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02244	Generator Building	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02245	Unit 2 Addition / CCU Building	OSHPD 1-In Service	2			Denied					2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02246	Surgery / Medical Center	OSHPD 1-In Service	2								3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02247	Administration Building	OSHPD 1-In Service	2			Denied					3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02248	ICU Building	OSHPD 1-In Service	2								3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02249	Emergency	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02250	Endoscopy	OSHPD 1-In Service	5								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02251	Entrance Canopy	OSHPD 1-In Service	5								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02252	O.B. Gyn / Cancer Center	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03692	Rehabilitation Center	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03693	Emergency Generator Building	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03694	Rehab Center Addition 1	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03695	Rehab Center Addition 2	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03821	Back-of-house addition (freezer)	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03822	Back-of-house Facility	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03823	Ambulatory Surgery Holding	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03824	Switch Gear Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07112	Rehabilitation Hospital	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07113	Trash Enclosure	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07249	Emergency Generator Enclosure	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-02267	Main Building	OSHPD 1-In Service	2								3	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-02268	MRI Building	OSHPD 1-In Service	3								3	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03445	Women's & Children's Center	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03446	Connection	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03447	Central Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03448	Main Entrance Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07291	New Main Hospital	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07292	EMS Canopy	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07293	ED Canopy	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07294	New Central Plant	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07126	Replacement Hospital	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07127	Energy Center	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07128	ED Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07129	Main Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07130	West Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	BLD-00954	Hospital	OSHPD 1-In Service	2								3	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	BLD-03599	ED Expansion	OSHPD 1-In Service	5s								4s	Intent to Remove GAC	Intent to Remove GAC		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-03701	Hospital - Phase I	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/12/2023		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-03702	Chiller Plant	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/12/2023		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-05951	Sanipak Cover	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07197	Hospital Phase IIA	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07198	Hospital Phase IIB	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07199	Hospital Phase IIC	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07200	Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07201	Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07202	Water Treatment Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-00286	L.S. Packard Children's Hospital	OSHPD 1-In Service	3								4			Rpt: Awaiting review 12/26/2023		
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-02867	LPCH Generator Yard	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Awaiting review 12/26/2023		
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05369	New LPCH Expansion Building	OSHPD 1-In Service	5								5				Earthquake Resilient	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05370	New LPCH Loading Dock	OSHPD 1-In Service	5								5				Earthquake Resilient	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05371	LPCH Tunnel	OSHPD 1-In Service	5								5				Earthquake Resilient	
43 - Santa Clara	10878	Mission Oaks Hospital	BLD-02253	Main Building	OSHPD 1-In Service	3s								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023		
43 - Santa Clara	10919	O'Connor Hospital	BLD-02278	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
43 - Santa Clara	10919	O'Connor Hospital	BLD-02279	1953 Boiler House / Laundry	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A					
43 - Santa Clara	10919	O'Connor Hospital	BLD-02280	1969 Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
43 - Santa Clara	10919	O'Connor Hospital	BLD-02281	Replacement Facility	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-02282	Replacement Boiler House	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03316	2005 Emergency Expansion	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03318	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03319	Canopy 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03320	Canopy 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10919	O'Connor Hospital	BLD-05675	2005 Emergency Expansion Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10919	O'Connor Hospital	BLD-06234	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-07318	Medical Gas Canopy	OSHPD 1-Proposed	5s								4s				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02236	Main Tower and North Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02237	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02238	Obstetrics Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02239	Emergency Department Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02240	Lab Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02241	Surgery Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02242	ICU/CCU Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02958	7A Outpatient Surgery Center	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03387	East Patient Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03388	ICU Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03389	West Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03391	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03639	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06316	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06396	West Wing Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023		
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06551	Connecting Corridor - Structurally connected to BLD-02241	OSHPD 1-Not an Independent Building	N/A								N/A					
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06980	ED Waiting Expansion	OSHPD 1-Under Construction	5s								4s					
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02546	Ancillary B (6043)	OSHPD 1-In Service	2			01/01/2015			1/1/2015 Com Acc Retrofit		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02547	Old Main Hospital C West (6001)	OSHPD 1-In Service	1			01/01/2015			12/31/2019 Com Acc Retrofit	7/1/2026 AB 1471 Rebuild	2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02548	Old Main Hospital C East (6001)	OSHPD 1-In Service	1			01/01/2015			12/31/2019 Com Acc Retrofit	7/1/2026 AB 1471 Rebuild	2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02550	Rehabilitation Center Str B (6004)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02552	Rehabilitation Center Str C (6004)	OSHPD 1-In Service	2			01/01/2015			1/1/2015 Com Acc Retrofit		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02553	West Wing K Nursing (6006)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02554	Main Hospital M (6009)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02555	Energy Plant S1 - Boiler Room (6016)	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02556	Energy Plant S2 - Addition (6016)	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02557	Mech/Elec Bldg U (6017)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03654	M/E Chiller Addition (6017)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03860	Services Bldg N (Unit 5) (6002)	OSHPD 1-In Service	1						7/1/2019 Com Acc Retrofit	7/1/2025 AB 1471 Retrofit	2	1/1/2030	Rpt: Review Completed 12/29/2023	Intent to Remove GAC	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03861	Services Bldg S (Unit 4) (6002)	OSHPD 1-In Service	1						7/1/2019 Com Acc Retrofit	7/1/2025 AB 1471 Retrofit	2	1/1/2030	Rpt: Review Completed 12/29/2023	Intent to Remove GAC	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03869	Connecting Corridor (6002)	OSHPD 1-In Service	1						7/1/2019 Com Acc Retrofit	7/1/2025 AB 1471 Retrofit	2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03907	Rehabilitation Center Str A (6004)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05256	Replacement Bed Building (Sobrato Pavilion) (6011)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05306	Barbara Arons Pavilion (0914)	OSHPD 5-Acute Psych Only	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05677	West Wing K Nursing (6006) Air Intake	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06589	Receiving and Support Center (6008)	OSHPD 1-In Service	2							12/31/2025 AB 1471 RSC Tier 2	2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06590	Receiving and Support Center Tunnel (6008)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06702	Link Building	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06733	BHSC Building	OSHPD 5-Under Construction	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06734	BHSC Tunnel	OSHPD 5-Under Construction	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06833	ED Addition (6006)	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06834	ED Addition - North Side (6006)	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06835	ED Addition - East Side (6006)	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06850	Stair Tower #10	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06899	Subgrade Water Tank/Pump Enclosure	OSHPD 1-Not a Building Structure	N/A								3s	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02627	Hospital Building Area A	OSHPD 1-In Service	3								3	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02628	Hospital Building Area B/C	OSHPD 1-In Service	3								3	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02629	Central Plant	OSHPD 1-In Service	3								3	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023		
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-06892	Above Ground Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07332	Canopy	OSHPD 1-Proposed	5s								4s				
43 - Santa Clara	10035	Stanford Health Care	BLD-02865	New Stanford Hospital - Generator Building	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	BLD-05260	New Stanford Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	BLD-05880	New Stanford Hospital - Elevator / Stair Enclosure	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	BLD-05881	New Stanford Hospital - Utility Tunnel	OSHPD 1-Tunnels	N/A								5				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/CF**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
43 - Santa Clara	10943	Stanford Health Care	BLD-02290	Edwards Building-Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02291	Lane Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Replace			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02292	Alway Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02293	Grant Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02294	Central Core	OSHPD 1-In Service	2									3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02295	Central Core - East and West	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Rebuild			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02296	Boswell Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A						1/1/2020 Com Acc Rebuild			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02297	West Pavilion	OSHPD 1-In Service	2									3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02298	East Pavilion	OSHPD 1-In Service	2									3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02299	Phase 1 Central Core Expansion	OSHPD 1-In Service	3s									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02300	Nursing Pod D	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02301	Nursing Pod E	OSHPD 1-In Service	4									2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Awaiting review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
43 - Santa Clara	10943	Stanford Health Care	BLD-02302	Nursing Pod F	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02303	Diagnostic Treatment Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/27/2016	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02304	Atrium	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02305	F Pod Extension	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/27/2016	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02799	OSHPD Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02800	OSHPD Electrical Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02801	OSHPD Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02802	OSHPD Cooling Towers	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02803	OSHPD Above Grade Fuel Tanks	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02866	Modular Steam Plant	OSHPD 1-In Service	5								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03435	Utility Substation	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03436	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03437	Utility Substation	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03805	Boiler Building - Office Portion - Structurally connected to BLD-02309	OSHPD 1-Not an Independent Building	N/A				Withdrawn				N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-05867	North Feed Steam Tunnel (OSHPD)	OSHPD 1-Tunnels	N/A								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-06567	Nursing Pod DX	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10943	Stanford Health Care	BLD-06568	Nursing Pod EX	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10943	Stanford Health Care	BLD-06849	Pediatric ED Canopy	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10943	Stanford Health Care	BLD-06995	Breezeway Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-06996	Liquid Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Awaiting review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
43 - Santa Clara	10943	Stanford Health Care	BLD-07004	Waste Management Building	OSHPD 1-In Service	4								4			Rpt: Awaiting review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-07288	300P Fire Pump House	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10943	Stanford Health Care	BLD-07289	300P Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Not Submitted	
44 - Santa Cruz	10972	Dominican Hospital	BLD-02320	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
44 - Santa Cruz	10972	Dominican Hospital	BLD-02321	Boiler House/Original Corridor	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
44 - Santa Cruz	10972	Dominican Hospital	BLD-02322	North Wing	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-02323	Original East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-02324	Emergency Wing - Structurally connected to BLD-02323	OSHPD 1-Not an Independent Building	N/A								N/A	1/1/2030			
44 - Santa Cruz	10972	Dominican Hospital	BLD-02325	Ancillary Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-03373	Generator #3	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-03527	Emergency Parking Deck - Structurally connected to BLD-02320	OSHPD 1-Not an Independent Building	N/A								N/A				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07299	Utility Tunnel	OSHPD 1-Tunnels	N/A								2s		Rpt: Not Submitted	Rpt: Not Submitted	
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	BLD-00240	Sutter Maternity	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/30/2023	
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	BLD-05910	Connector Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Not Submitted	
44 - Santa Cruz	15019	Watsonville Community Hospital	BLD-00057	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Open - Returned 02/20/2023	
44 - Santa Cruz	15019	Watsonville Community Hospital	BLD-00058	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 02/20/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02327	Original Hospital	OSHPD 1-In Service	2	Withdrawn											This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02328	Long Term Beds Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02329	Surgery/O.B. Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02332	Pharmacy and 12 Bed Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-05268	Skilled Nursing Building - Burney Campus	OSHPD 2-Skilled Nursing Only	N/A								N/A				
45 - Shasta	11000	Mayers Memorial Hospital	BLD-05334	Emergency Department Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06253	Connector	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06254	Drop-Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06969	Water Tank	OSHPD 1-Not a Building Structure	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06970	Water Tank Pump Enclosure	OSHPD 1-Not a Building Structure	N/A								5				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01502	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01503	Pediatrics	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01504	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01505	Radiology Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01506	Central Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01507	Doctor's Lounge - Structurally connected to BLD-01504	OSHDP 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01508	Cafeteria Addition	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01509	Third Floor L & D Addition - Structurally connected to BLD-01502	OSHDP 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01510	West Tower	OSHDP 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01511	Engineering Addition - Structurally connected to BLD-01502	OSHDP 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01512	Pediatrics Addition	OSHDP 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01513	ER/ICU Addition	OSHDP 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01514	Radiology & Cafeteria Addition	OSHDP 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01515	Oncology Center Addition	OSHDP 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01516	Generator Bunker	OSHDP 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03642	Corridor	OSHDP 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03643	Oncology Canopy	OSHDP 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03644	Emergency Canopy	OSHDP 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-05354	MRI Addition	OSHDP 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-05618	Service Yard	OSHDP 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
45 - Shasta	16679	Patients' Hospital of Redding	BLD-00289	Hospital Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Open - Returned 12/31/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02340	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02341	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02342	Surgery/Radiology/ICU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02343	ER Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02344	Surgery/Cardiology/LDR	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02345	Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	16620	Vibra Hospital Of Northern California	BLD-00064	N. Ca. Rehabilitaion Hosp. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Open - Returned 12/27/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00082	Nursing Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00083	D & T Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00084	Med. Gas Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07087	Emergency Department Waiting Room Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07093	Bulk O2 and Propane Yard	OSHPD 1-Under Construction	5s								4s				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07156	Emergency Department Expansion	OSHPD 1-Under Construction	5s								5s				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07157	Generator Yard	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07158	Patient Drop-Off Canopy	OSHPD 1-Under Construction	5s								4s					
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00231	1973 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023		
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00232	Administration Building - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A					
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00233	Laboratory Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A					
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00234	Radiology Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A					
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00235	Skilled Nursing Facility & Maintenance Shop	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023		
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00236	Generator Enclosure	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023		
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06101	Emergency Dept. Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023		
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06118	1973 Nursing Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023		
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06321	OPS Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023		
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00204	Central Plant East	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/06/2023		
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00205	Hospital Addition	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/06/2023		
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00207	Central Plant West	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-02778	Central Plant	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/06/2023		
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-02779	Hospital Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-03631	Central Plant East Storage / LOX	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07215	Central Plant North-West	OSHPD 1-In Service	2								2		Rpt: Review Completed 08/20/2024	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07216	Central Plant East Pathway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-03834	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-03835	Central Utility Plant Phase 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-06842	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01519	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01520	Phase 1 Replacement Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01521	Original Hospital Building A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01522	Emergency Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02681	Med/Surg Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02682	Original Hospital Building B	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02683	Original Hospital Building C	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-03029	Emergency Room Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
48 - Solano	11019	Northbay Medical Center	BLD-03030	Phase 1 Replacement Building Canopy	OSHPD 1-In Service	5s								4		Rpt: Review Completed 12/29/2023		
48 - Solano	11019	Northbay Medical Center	BLD-05345	Electrical Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/29/2023		
48 - Solano	11019	Northbay Medical Center	BLD-05875	New North Wing	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/29/2023		
48 - Solano	11019	Northbay Medical Center	BLD-05876	Overhead Utility Support Structure	OSHPD 1-Not a Building Structure	N/A								4		Rpt: Review Completed 12/29/2023		
48 - Solano	11019	Northbay Medical Center	BLD-06335	Laboratory Building	OSHPD 1-In Service	5								4s	Rpt: Not Submitted	Rpt: Review Completed 12/29/2023		
48 - Solano	11019	Northbay Medical Center	BLD-07340	Med Gas Storage Canopy	OSHPD 1-Proposed	5s								4s				
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00340	Nursing Wing	OSHPD 1-In Service	3								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00341	Main Entrance	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00342	Ancillary Wing	OSHPD 1-In Service	3								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00343	Administration Wing	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00344	Central Plant	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00345	Cafeteria Wing	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00347	Service Yard Canopy	OSHPD 1-In Service	3								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-05991	MRI Walkway	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-05993	Bulk Oxygen Tank	OSHPD 1-Equipment Yard	N/A								4		Rpt: Open - Returned 12/29/2023		
48 - Solano	12525	Sutter Solano Medical Center	BLD-01019	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	12525	Sutter Solano Medical Center	BLD-01020	One Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-01021	Tower Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
48 - Solano	12525	Sutter Solano Medical Center	BLD-02969	Two Story Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-07017	Addition #1 (Chiller Building)	OSHPD 1-In Service	5s								4s		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-07018	Medical Gas Yard	OSHPD 1-Under Construction	N/A								4s				
49 - Sonoma	12823	Healdsburg Hospital	BLD-00919	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	12823	Healdsburg Hospital	BLD-00920	Entrance Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-00921	CT Scanner Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-00922	Mechanical/Electrical Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-00923	Materials Management Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-05449	ED Addition	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/28/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00277	Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00278	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00279	Central Plant Addition	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00280	Electrical Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02780	Hospital, South - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A								N/A				
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02781	Hospital, North - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02782	Canopy, South	OSHPD 1-In Service	3								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02783	Canopy, North	OSHPD 1-In Service	3								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-03610	North Wing Expansion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-03849	Generator Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-05699	Connecting Tunnel	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-05700	CUP / Boiler Room Expansion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-06104	North Wing Expansion Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/18/2023		
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00311	Original Hospital - Southwest	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00312	Emergency Room Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00313	Power Plant Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00314	Switchgear Building	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00315	Power Plant Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02579	Original Hospital - Northeast	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02580	Original Hospital - Northwest	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02581	Original Hospital - Southeast	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02757	Power Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01529	Original Hospital	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01530	Physical Therapy Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01531	Psychiatric Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-02755	Dietary Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-02756	Social Services Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01533	West Pavilion - North Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01534	West Pavilion - West Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01535	Service Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01536	West Pavilion - Entry Lobby and Canopy (Entry Lobby)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01537	Emergency Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01538	Center East - West Link	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01539	Center East Wing	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.

NPC 5 Status: This column shows NPC 5 evaluation report submittal status.

Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.

Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.

Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.

Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01540	East Wing and East Wing Link	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01543	Emergency Wing-Entrance Canopy	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03203	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03205	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03206	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03207	Surgery Building and Cath Lab Infill	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03208	Observation #3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06270	Oxygen Tank - Generator - Underground Fuel Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06275	West Pavilion - Entry Lobby and Canopy (West Canopy)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06276	West Pavilion - Entry Lobby and Canopy (East Canopy)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06277	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023		
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06340	Water Treatment Structure	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06351	Bio-Hazard Holding	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01523	Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01524	Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01525	Emergency Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01526	Mechanical Room	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01527	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01544	West Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01545	Central Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01546	East Wing North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-02990	Central Wing Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-02991	West Wing Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03079	East Wing Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03080	East Wing South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03873	Chiller Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05409	East Wing Loading Dock Canopy	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05410	ED / OR	OSHPD 1-In Service	5s							4s			Rpt: Not Submitted	Rpt: Review Completed 12/29/2023		
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05411	ED / OR Canopy	OSHPD 1-In Service	5s							4s			Rpt: Not Submitted	Rpt: Review Completed 12/29/2023		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05237	Hospital Building - West Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05238	Hospital Building - Center Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05239	Hospital Building - East Wing	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05240	Central Utility Plant	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05241	Water Treatment Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05242	Medical Gas Storage Building	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05364	Utility Building	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-06549	Expansion Wing	OSHPD 1-In Service	5								5			Earthquake Resilient	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-07019	Medical Waste	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-01551	Orig Hospital Bldg & Add - Bldg III	OSHPD 1-In Service	1					7/1/2019 Com Acc Retrofit	7/1/2022 AB 2190 Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-01552	1978 Hospital Building - Bldg I	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-03534	Building II	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01579	Main Hospital & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01580	South Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01581	North Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01582	Cath Lab	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01583	Lobby Addition	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
50 - Stanislaus	11085	Doctors Medical Center	BLD-01584	Women & Children's Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01585	Central Mechanical Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01586	West Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01587	ER/Lab	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01588	Cardiology	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01589	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01590	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01591	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01592	Pharmacy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01593	Dining Room Addition - Structurally connected to BLD-01579	OSHPD 1-Not an Independent Building	N/A								N/A	1/1/2030			
50 - Stanislaus	11085	Doctors Medical Center	BLD-03405	ER/LAB Connecting Corridor	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-06179	Women & Children's Center - Steam Generator Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-06200	Entry Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-07074	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01604	Main Building - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01605	Main Building - West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01606	Mental Health Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01607	Critical Care Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01608	Diagnostic Imaging/ER Emergency	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01609	Nursing Unit Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01610	Engineering Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01611	Central Supply Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01612	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01613	O.R. / G.I. Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01614	Walk-In Freezer	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01615	Dietary Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01616	Surgery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01617	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01618	Exit Passage Way	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03229	Cardio Vascular Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03230	ED Addition - North West Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03231	Obstetrics Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03232	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03690	Exit Passage Way - Part II	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03691	Exit Passage Way - Part III	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03813	Exit Passage Way - Part IV	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07191	North West Tower Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/15/2023	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05648	South Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05655	North Building	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/21/2023		
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05656	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4		Rpt: Review Completed 12/21/2023		
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05657	Bulk Oxygen Enclosure	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/21/2023		
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05183	Main Building	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/12/2023		
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05184	Central Plant	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/12/2023		
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05531	Central Utility Yard	OSHPD 1-Equipment Yard	N/A								4s	Rpt: Not Submitted	Rpt: Review Completed 12/12/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-01567	Connecting Corridor Infill	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01568	Physical Plant & Additions	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01569	G. I. Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01570	Emergency/Ancillary Services	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01571	West Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01572	Same Day Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01573	Advanced Medical Diagnostic	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01574	Radiation Oncology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
50 - Stanislaus	11111	Memorial Medical Center	BLD-01575	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01576	Obstetrics Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-01577	Surgery/Emergency Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-01578	Dietary/Dining	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03140	ER Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03225	North Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03226	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03837	North Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03838	Family Birthing Center Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03839	Surgery/Emergency Expansion - East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-03847	Original Hospital - South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
50 - Stanislaus	11111	Memorial Medical Center	BLD-05405	Corridor and Elevator Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		
50 - Stanislaus	11111	Memorial Medical Center	BLD-05406	Emergency/Ancillary Services Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted		
50 - Stanislaus	11111	Memorial Medical Center	BLD-05407	West Expansion - Labor and Delivery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
50 - Stanislaus	11111	Memorial Medical Center	BLD-05408	West Expansion - Chapel	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-05417	GI Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/31/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00193	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00194	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00195	Emergency Dept. Addition	OSHPD 1-In Service	5								4D-L1			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00196	300 Wing Addition	OSHPD 1-In Service	5								4D-L1			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03243	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03244	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03245	Canopy #6	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03246	Canopy #7	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	17461	Stanislaus Surgical Hospital	BLD-03242	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	BLD-05179	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Not Submitted	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	BLD-05344	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01560	Main Hospital - North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01561	Six Bed Addition - Structurally connected to BLD-02977	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01562	Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01563	Patient Rooms Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01564	Medical Records Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01565	Surgery Expansion - Structurally connected to BLD-01562	OSHPD 1-Not an Independent Building	N/A								N/A				
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01566	Administration Addition - Structurally connected to BLD-01560	OSHPD 1-Not an Independent Building	N/A								N/A				
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-02977	Main Hospital - Southwest Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-02978	Main Hospital - Southeast Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-06031	Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
53 - Trinity	11125	Trinity Hospital	BLD-02523	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02524	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
53 - Trinity	11125	Trinity Hospital	BLD-02525	Security Addition	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02526	16-Bed Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02527	Lab and Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
53 - Trinity	11125	Trinity Hospital	BLD-02528	Emergency Generator Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02529	Connecting Corridor Addition	OSHPD 1R-Skilled Nursing Only	N/A								N/A	1/1/2030			
54 - Tulare	11145	Adventist Health Tulare	BLD-00564	Original Structure & Additions	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-00569	Fifth Addition: Radiology Addition	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-00570	Sixth Addition - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-00571	Sixth Add - 1.8	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-00572	Sixth Add - 1.9 - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-02963	MRI Modular Building	OSHPD 3-Outpatient Only	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-03517	First Addition	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-03518	Second Addition	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-05607	Tower 1	OSHPD 1-Under Construction	5s								5s				
54 - Tulare	11145	Adventist Health Tulare	BLD-05868	Generator Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-05869	Tower 1 Generator Yard	OSHPD 1-Under Construction	N/A								5s				
54 - Tulare	11145	Adventist Health Tulare	BLD-05870	Bulk Medical Gas and Water Tank Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-05871	CT Scan Building	OSHPD 3-Outpatient Only	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-06041	Sixth Add - 1.8 - Lobby	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
54 - Tulare	11145	Adventist Health Tulare	BLD-06042	Sixth Add - 1.7 - North Restroom Addition	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-06043	Sixth Add - 1.7 - South Restroom Addition	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
54 - Tulare	11145	Adventist Health Tulare	BLD-06887	Canopy #1	OSHPD 1-Proposed	5s								4s				
54 - Tulare	11145	Adventist Health Tulare	BLD-06888	Canopy #2	OSHPD 1-Proposed	5s								4s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01031	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01032	1st. East Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01033	Cafeteria - Dining Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01034	Special Services	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01035	Co-Gen. Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01036	Special Procedures	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01037	West Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01038	East Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-02716	Cafeteria - Office Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-03616	North Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-05583	Dietary Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-06048	Emergency Department Addition	OSHPD 1-In Service	5								5s			Rpt: Review Completed 12/13/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03749	Original Building - Part 1	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03750	Original Building - Part 3	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03751	Original Building - Part 2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00556	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11140	Sierra View Medical Center	BLD-00557	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00558	Emergency Addition #1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00560	3 Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00561	4 Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00562	Emergency Addition #2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00563	Administration Addition #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-02696	Laboratory Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-02697	Service Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-03239	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-05569	Emergency Department Electrical Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
54 - Tulare	11140	Sierra View Medical Center	BLD-06706	CT Building	OSHPD 1-In Service	3								3	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/28/2023		
54 - Tulare	11140	Sierra View Medical Center	BLD-06707	Cath Lab	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/28/2023		
54 - Tulare	11140	Sierra View Medical Center	BLD-06819	Skilled Nursing Facility	OSHPD 2-Proposed	N/A								N/A				
55 - Tuolumne	11151	Adventist Health Sonora	BLD-03833	OB Unit 9	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
55 - Tuolumne	18163	Adventist Health Sonora	BLD-05178	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
55 - Tuolumne	18163	Adventist Health Sonora	BLD-06910	O.R. – Admin. Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01246	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01249	Main Hospital Building	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01253	New Bridge/Elevator & Med. Gas Enclosure	OSHPD 1-In Service	4s								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-03335	North and South Patient Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05217	Patient Care Tower Entrance	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05679	ED / Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05680	ED / Surgery Addition Entrance	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-07115	Central Utility Plant	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building’s GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-00606	Hospital Building	OSHPD 1-In Service	2								3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-02994	Nursing Wing	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-02995	Laboratory Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03167	New Ambulance Entry	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03168	New 6 Story Hospital Tower - West	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/30/2023		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03169	New 6 Story Hospital Tower - East	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/30/2023		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03170	New 2 Story Hospital Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/30/2023		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05528	New ER Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05529	New Main Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05530	New 1 Story Pedestrian Walkway	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	10040	Harvest Medical Complex	BLD-06934	Hospital	OSHPD 1-Proposed	5s								5s					
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00601	North Wing / Central Core	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00602	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00603	West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/22/2023		
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00604	New South Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023		
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00605	Emergency Generator Shed	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023		
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-02950	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-03108	ICU/CCU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-03464	New Expansion	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-06341	Exit Discharge Area Expansion	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-06413	OR Expansion	OSHPD 1-Under Construction	5s								5s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07111	ED Waiting Room Expansion	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07172	ED Entry Canopy	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07319	Dietary Expansion	OSHPD 1-Proposed	5s								5s				
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02641	Building One	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02642	Building Two - Dining/Kitchen	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02643	Building Three	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02644	Building Four - Gymnasium	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02645	Building Five	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-06012	Outpatient Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00607	Link Building 1	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00608	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00612	Canopy and Entrance Bridge	OSHPD 1-In Service	4s								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02614	Patient Tower	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02615	Link Building 2	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02616	Central Plant	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-05872	MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06160	Angiography Operating Suite Exterior Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06174	New ED Expansion & Covered Entry	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06175	New Free-Standing Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06176	New Free-Standing Covered Entry	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07032	Canopy #1	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00209	Main Hospital	OSHPD 1-In Service	1					7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00210	Central Plant/ Utilities Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00211	Ancillary Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00212	Ambulatory Surgery Center	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-03257	Hospital Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-03258	Chapel Addition	Adjacent -No Gen Acute Care - OSHPD Bldg	N/A								N/A				
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-03845	Skilled Nursing Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 3/20/2025

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-05209	ED Addition	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/25/2023		
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06318	SNF Connection	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/25/2023		
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06870	Recycle Enclosure	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/25/2023		
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06871	Water Pump Yard	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/25/2023		
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06872	Dietary Canopy	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/25/2023		
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-05186	Main Building	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023		
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07180	Entry Canopy	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07181	Porte-Cochere	OSHPD 1-In Service	5s								4s	Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11162	Ventura County Medical Center	BLD-00594	Main Hospital Building - Bldg 305	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-00595	Fainer Wing - Building 304	OSHPD 1-In Service	4								4		Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-00596	Administration Building - Bldg 306	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-00597	Mental Health Center - Building 399	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-03341	Electrical Services Building 400	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-03640	Administration Bldg Addition - #306	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-03641	Medical Lab / Kitchen - Bldg 401	OSHPD 1-In Service	5								4		Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-05572	Cafeteria Building - Building 403	OSHPD 1-In Service	2								3	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							CO/Ct**	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status							
56 - Ventura	11162	Ventura County Medical Center	BLD-05660	Med Gas Enclosure - Building 307	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-05661	Fainer Wing Cooling Tower Enclosure - Building 308	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-05707	Hospital Replacement Wing	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-05729	Interim LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-06225	Hospital Porte Cochere	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/21/2023		
56 - Ventura	11162	Ventura County Medical Center	BLD-06227	Ambulance and ED Porte Cochere	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/21/2023		
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01241	Main Building / East & North Addition	OSHPD 1-In Service	2	Withdrawn					1/1/2017 Com Acc Retrofit		3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01242	East Addition - Structurally connected to BLD-01241	OSHPD 1-Not an Independent Building	N/A								N/A					
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01243	North Addition - Structurally connected to BLD-01241	OSHPD 1-Not an Independent Building	N/A								N/A					
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01244	E.R. Addition	OSHPD 1-In Service	5								3R		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01245	Storage Building & Storage Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted		
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02647	Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted		
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02648	I.C.U. Addition	OSHPD 1-In Service	2	Withdrawn					1/1/2017 Com Acc Retrofit		3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02724	Storage Addition - Structurally connected to BLD-01245	OSHPD 1-Not an Independent Building	N/A								N/A					
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02929	Infectious Waste Sterilizer Bldg	OSHPD 1-In Service	5								3		Rpt: Not Submitted	Rpt: Not Submitted		
57 - Yolo	17725	Sutter Davis Hospital	BLD-01256	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/31/2023		
57 - Yolo	17725	Sutter Davis Hospital	BLD-01257	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/31/2023		

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/Ct**					
57 - Yolo	17725	Sutter Davis Hospital	BLD-06114	Post Anesthesia Recovery Expansion	OSHPD 1-In Service	5								4		Rpt: Review Completed 12/31/2023		
57 - Yolo	17725	Sutter Davis Hospital	BLD-06528	Birthing Department Expansion	OSHPD 1-In Service	5s								5s		Rpt: Review Completed 12/31/2023		
57 - Yolo	17725	Sutter Davis Hospital	BLD-06529	Emergency Department Expansion	OSHPD 1-In Service	5s								5s		Rpt: Review Completed 12/31/2023		
57 - Yolo	17725	Sutter Davis Hospital	BLD-06530	Ambulance Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
57 - Yolo	17725	Sutter Davis Hospital	BLD-07307	MRI Canopy	OSHPD 1-In Service	5								4		Rpt: Not Submitted		
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01258	Building A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01259	Building B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01260	Building C	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01261	Building D	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01262	Building E, Ancillary Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01263	Lobby	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Review Completed 12/26/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01264	Patient Tower/Cath Lab/4th Floor	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01265	Patient Tower Cath Lab - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01266	Patient Tower 4th Floor Buildout - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	AB 2190 Extension Status	CO/CF**					
58 - Yuba	11205	Adventist Health And Rideout	BLD-01267	Central Plant (1960 & 1988)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
58 - Yuba	11205	Adventist Health And Rideout	BLD-01268	Central Plant CP-1 ('92 '98 & 2000)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01269	Central Plant CP-1 1998 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01270	Central Plant (1988) - Structurally connected to BLD-01267	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01271	Central Plant CP-1 2000 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01272	East Wing (1978)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01273	West Wing (1960)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				1/1/2018 Com Acc Rebuild			N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01276	North Wing N-1 1980 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01277	North Wing N-1 1986 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-02785	New Patient Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-03769	Registration Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-07207	North Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
58 - Yuba	11205	Adventist Health And Rideout	BLD-07208	South Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
 Fin Hdsp = Financial Hardship based SB 90 extension
 Com Acc = Community Access based SB 90 extension
 GAC = General Acute Care

Retrofit = Building will be retrofitted
 Rebuild = GAC services will be moved to new building/s
 Replace = GAC services will be moved to existing SPC 2 or higher building/s
 Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
 * 1s is a temporary rating assigned to seismically separate buildings created by retrofits
 ** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating