HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions						CO/CF **	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status						
01 - Alameda	11210	Alameda Hospital	BLD-01278	Original Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				12/1/2019 Com Acc Replace	7/30/2030 AB 869		N/A				
01 - Alameda	11210	Alameda Hospital	BLD-01279	Stephens Wing	OSHPD 1-In Service	2	Denied			Withdrawn	12/1/2019 Com Acc Retrofit	7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11210	Alameda Hospital	BLD-01280	West Wing	OSHPD 1-In Service	2	Denied					7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11210	Alameda Hospital	BLD-01281	South Wing	OSHPD 1-In Service	3s						7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-01282	Radiology Addition	OSHPD 1-In Service	4						7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-01283	Medical Gas Storage	OSHPD 1-In Service	3						7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-02630	Compactor Shed	OSHPD 1-In Service	4						7/30/2030 AB 869		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-03120	Emergency Room Relocation	OSHPD 1-In Service	3s						7/30/2030 AB 869		2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-05597	LOX Tank	OSHPD 1-Equipment Yard	N/A						7/30/2030 AB 869		4			Rpt: Proposed Retrofit Acceptable 06/25/2024	
01 - Alameda	11210	Alameda Hospital	BLD-07777	WT-01 Water Tank	OSHPD 1-Proposed	N/A						7/30/2030 AB 869		5s				
01 - Alameda	11210	Alameda Hospital	BLD-07778	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A						7/30/2030 AB 869		5s				
01 - Alameda	11210	Alameda Hospital	BLD-07779	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A						7/30/2030 AB 869		5s				
01 - Alameda	11210	Alameda Hospital	BLD-07780	Booster Pump Canopy	OSHPD 1-Proposed	5s						7/30/2030 AB 869		5s				
01 - Alameda	11210	Alameda Hospital	BLD-07781	Ionization Unit/UV Lamp Canopy	OSHPD 1-Proposed	5s						7/30/2030 AB 869		5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00695	Ehman Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00696	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00698	East Wing	OSHPD 1-In Service	2					9/1/2016 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00699	Original West Wing	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00700	West Service Wing - Building 1	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00701	Physio-Therapy Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00702	Original Emergency Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00703	Special Procedures Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00704	Emergency Department Expansion	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/31/2023	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00705	Cogeneration Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00706	Emergency Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-00707	Transformer Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03431	South Wing - Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/31/2023	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03433	West Service Wing - Building 2 - Structurally connected to BLD-00699	OSHPD 1-Not an Independent Building	N/A					7/1/2019 Com Acc Retrofit			N/A				
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-03434	Orig Emergency Wing - East Wing - Structurally connected to BLD-00702	OSHPD 1-Not an Independent Building	N/A								N/A				
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-05300	Patient Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-06010	New LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	11322	Alta Bates Summit Medical Center	BLD-06060	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-00708	Main Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-03443	Main Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	BLD-03444	Bridge at Link	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/30/2023	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01285	Admin.	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01286	Laundry/Hall of Health	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01287	Boiler	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01288	1968 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01289	1975 Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01290	1985 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/27/2023	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01291	Electric Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Not Submitted	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	BLD-01292	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
01 - Alameda	18180	Eden Medical Center	BLD-05340	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	18180	Eden Medical Center	BLD-05341	Chiller Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	18180	Eden Medical Center	BLD-05342	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	18180	Eden Medical Center	BLD-05343	Emergency Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
01 - Alameda	11268	Fairmont Hospital	BLD-01311	Building B	OSHPD 2-Skilled Nursing Only	N/A								N/A				
01 - Alameda	11268	Fairmont Hospital	BLD-01312	Building H	OSHPD 1R-Delicensed Clinic under OSHPD	N/A	Withdrawn				7/1/2019 Risk Bsd Replace			N/A				
01 - Alameda	11288	Highland Hospital	BLD-01315	Critical Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11288	Highland Hospital	BLD-02957	New Acute Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
01 - Alameda	11288	Highland Hospital	BLD-06256	Critical Care Parking Structure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
01 - Alameda	11288	Highland Hospital	BLD-06880	Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02489	Hospital Patient Wing North	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02490	Hospital Patient Wing South	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02491	Hospital North	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02492	Hospital South	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02493	Central Plant	OSHPD 1-In Service	5								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-02494	General Services Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 05/03/2023	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07247	Entry Canopy	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Review Completed 12/04/2023	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07613	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07614	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07615	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-07616	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	BLD-08060	CUP Yard Canopy	OSHPD 1-Proposed	5s								4s				
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-02986	Hospital	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/08/2023	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-02987	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/08/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-05716	Loading Dock and Plaza	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/08/2023	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	BLD-07422	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	BLD-03481	Templated Hospital Project	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/04/2023	
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	BLD-03482	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/04/2023	
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	BLD-07441	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00692	Original Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			3		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00693	Outpatient Diag. & Treat. Center	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-00694	Boiler Enclosure	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-03083	Surgery Addition - Structurally connected to BLD-00692	OSHPD 1-Not an Independent Building	N/A								N/A				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-05427	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-05428	Liquid Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-08088	Pump House	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-08089	Water Tank #1	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-08090	Wastewater Tank #1	OSHPD 1-Proposed	N/A								5s				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-08091	Fuel Tank #1	OSHPD 1-Proposed	N/A								5s				
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	BLD-08092	Fuel Tank #2	OSHPD 1-Tanks	N/A								N/A				
01 - Alameda	11256	San Leandro Hospital	BLD-01300	Main/Original Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/03/2025	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11256	San Leandro Hospital	BLD-02709	Emergency Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 01/12/2026	Rpt: Review Completed 12/22/2023	
01 - Alameda	11256	San Leandro Hospital	BLD-07123	Aboveground Fuel Storage Tank	OSHPD 1-Tanks	N/A								N/A				
01 - Alameda	11256	San Leandro Hospital	BLD-07270	SPD Addition	OSHPD 1-Under Construction	5s								4s				
01 - Alameda	11344	St Rose Hospital	BLD-00709	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11344	St Rose Hospital	BLD-00710	Engineering/Boiler Building - Structurally connected to BLD-00709	OSHPD 1-Not an Independent Building	N/A								N/A				
01 - Alameda	11344	St Rose Hospital	BLD-00711	Emergency and Critical Care Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	
01 - Alameda	11344	St Rose Hospital	BLD-00712	Chiller/Generator Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	
01 - Alameda	11344	St Rose Hospital	BLD-03084	Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A								N/A				
01 - Alameda	11344	St Rose Hospital	BLD-07831	Pump House	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11344	St Rose Hospital	BLD-07832	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
01 - Alameda	11344	St Rose Hospital	BLD-07833	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
01 - Alameda	11344	St Rose Hospital	BLD-07834	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02532	Hospital Ambulatory Care & Inc. II	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02533	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02534	Valleycare (New) Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02699	Arcade - Phase I - Portion 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02700	Arcade - Phase II - Portion 1	OSHPD 1-In Service	2								4			Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02701	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02901	Arcade - Phase I - Portion 2	OSHPD 1-In Service	2								4			Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02902	Arcade - Phase I - Portion 3	OSHPD 1-In Service	2								4			Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-02903	Arcade - Phase II - Portion 2	OSHPD 1-In Service	2								4			Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-06430	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-06566	Emergency Generator Set	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07315	East Wing Hospital Addition	OSHPD 1-Proposed	5s								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07316	Canopy	OSHPD 1-Under Construction	5s								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07317	NPC-5 Potable Water Storage Tank Enclosure (WT-01)	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07539	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07540	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07541	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07542	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	16632	Stanford Health Care Tri-Valley	BLD-07543	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01293	Cardiac Cath Lab - MPOE	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01294	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01295	West Site Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01296	Cafeteria Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01297	Diagnostic & Treatment Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01298	B/C Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Replace			N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-01299	A/B Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Replace			N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-03121	Loading Dock	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Not Submitted	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05214	Western Expansion Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05822	Outpatient Clinic	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05837	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-05856	Outpatient Center 2	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-06714	Walkway	Adjacent Building - Local Jurisdiction-Outpatient Only	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07163	Medical Gas Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07178	Above Grade Fuel Tank (FT-01)	OSHPD 1-Tanks	N/A								N/A				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07184	New Hospital Building	OSHPD 1-Under Construction	5s								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07188	Site Support Building	OSHPD 1-Under Construction	5s								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07635	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07636	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-07637	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	BLD-08128	WT Water Tanks	OSHPD 1-Under Construction	N/A								5s				
01 - Alameda	11366	Washington Hospital	BLD-00713	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00714	South Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00715	Emergency Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00716	Areas No. 1 and 2 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00717	Area No. 3 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00718	Area No. 4 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00719	Area No. 5 Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	BLD-00720	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11366	Washington Hospital	BLD-03561	Center for Joint Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03562	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03563	Center for Joint Replacement - Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03564	Interim Loading Dock	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-03565	Underground Service Passage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05627	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05628	Canopy #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05629	Canopy #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05630	Canopy #3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05632	Pedestrian Walkway #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-05633	Pedestrian Walkway #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-06563	Pedestrian Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-06840	Emergency Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-07118	Center for Joint Replacement - Hallway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-07139	Pedestrian Walkway #2A	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
01 - Alameda	11366	Washington Hospital	BLD-07140	Pedestrian Walkway #2B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
01 - Alameda	11366	Washington Hospital	BLD-07394	Expansion Building	OSHPD 1-Proposed	5s								5s				
01 - Alameda	11366	Washington Hospital	BLD-07395	Underground Service Passage	OSHPD 1-Proposed	5s								5s				
03 - Amador	17490	Sutter Amador Hospital	BLD-00089	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
03 - Amador	17490	Sutter Amador Hospital	BLD-05532	Emergency Department Entry Porte Cochere - Low	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
03 - Amador	17490	Sutter Amador Hospital	BLD-05533	Emergency Department Entry Porte Cochere - High	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
03 - Amador	17490	Sutter Amador Hospital	BLD-07058	Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
04 - Butte	10013	Enloe Health	BLD-00110	Original Hospital	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00111	O.B. First Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00112	O.B. Second Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00113	Administration Third Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00114	Surgery Wing	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00115	Corridor No. 1	OSHPD 1-In Service	2					1/1/2016 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00116	South Wing - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
04 - Butte	10013	Enloe Health	BLD-00117	Trauma	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00118	Pharmacy	OSHPD 1-In Service	2					1/1/2015 Com Acc Remove GAC			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	BLD-00119	Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00120	Cath Lab No. 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00121	Radiology - Oncology - Structurally connected to BLD-02935	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10013	Enloe Health	BLD-00122	Cath Lab No. 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00123	Surgery Addition	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-00124	Waiting Area/Corridor No. 2	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
04 - Butte	10013	Enloe Health	BLD-02934	Magnolia Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-02935	O.R. Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-02936	E.R. Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
04 - Butte	10013	Enloe Health	BLD-07192	Angiography Room 5 Suite	OSHPD 1-Proposed	5s								4s				
04 - Butte	16464	Enloe Rehabilitation Center	BLD-00086	Rehabilitation Center	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
04 - Butte	10006	Orchard Hospital	BLD-00090	Main Hospital Building & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	BLD-00091	East Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00092	North Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
04 - Butte	10006	Orchard Hospital	BLD-00094	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	BLD-00095	Warehouse Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00096	18 Bed Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00097	Surgical Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00098	X-Ray Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00099	Entry Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10006	Orchard Hospital	BLD-00100	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10006	Orchard Hospital	BLD-02933	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00134	1960 Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10019	Oroville Hospital	BLD-00135	1963 Structural Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00136	1968 36 Bed Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00137	1971 X-Ray Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00138	1972 ICU Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00139	1974 ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00140	1978 Pathology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00141	1979 Business/Lobby Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
04 - Butte	10019	Oroville Hospital	BLD-00142	1979 Nuclear Medicine Addition - Structurally connected to BLD-00140	OSHPD 1-Not an Independent Building	N/A								N/A				
04 - Butte	10019	Oroville Hospital	BLD-00143	1989 South Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/11/2024	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-00144	1997 Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-03175	1979 Kitchen/Dining Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-03844	1989 South Wing Addition - 1 story	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
04 - Butte	10019	Oroville Hospital	BLD-06111	Orohealth Hospital New Patient Tower	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-06789	Orohealth Hospital Chiller Enclosure	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-06790	Orohealth Hospital Generator Enclosure	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-07641	Pump House	OSHPD 1-Under Construction	5s								5s				
04 - Butte	10019	Oroville Hospital	BLD-07642	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
04 - Butte	10019	Oroville Hospital	BLD-07643	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
05 - Calaveras	10029	Mark Twain Medical Center	BLD-00131	North Wing	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
05 - Calaveras	10029	Mark Twain Medical Center	BLD-00132	South Wing	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/08/2023	Rpt: Review Completed 12/26/2023	
05 - Calaveras	10029	Mark Twain Medical Center	BLD-06006	South Wing - Link Corridor	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/08/2023	Rpt: Review Completed 12/26/2023	
05 - Calaveras	10029	Mark Twain Medical Center	BLD-07009	Steam Boilers Shed	OSHPD 1-Proposed	5s								4s				
06 - Colusa	10032	Colusa Medical Center	BLD-00133	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
06 - Colusa	10032	Colusa Medical Center	BLD-06329	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-02468	1 - Main Hospital	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-02469	16 - Main Entrance Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-03719	2 - Clinical Lab	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-03852	Cafeteria	OSHPD 1-In Service	2					Denied			3		Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-05505	Lower Generator Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-06510	Mechanical Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07280	Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07388	Ward E	OSHPD 1-In Service	1								1		Rpt: Not Submitted	Rpt: Not Submitted	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07589	Cafeteria South Wing	OSHPD 1-Proposed	5s								5s				
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07784	Loading Dock A	OSHPD 1-Proposed	5s								5s				
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07894	Pump House	OSHPD 1-Proposed	5s								5s				
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07895	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10049	Contra Costa Regional Medical Center	BLD-07896	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02472	Original Hospital (Elevator Tower)	OSHPD 1-In Service	2					8/1/2019 Com Acc Rebuild			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02473	C Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02474	Elevator/Stair Tower - Structurally connected to BLD-02472	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02475	C Wing-East Wing-North West Element - Structurally connected to BLD-02476	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02476	D Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Rebuild			N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02477	D Wing-North Wing-Infill - Structurally connected to BLD-02473	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02478	C Wing Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02479	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02480	B Wing / Surgery Equipment Room	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02481	Surgery Equipment Room - Structurally connected to BLD-02480	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02482	Cancer Center	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02483	Emergency Room	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02484	Canopy - Structurally connected to BLD-02483	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02485	A Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02486	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02487	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02488	Boiler Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Open - Returned 08/01/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02939	Canopy 1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02940	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02941	Canopy 2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-02946	Canopy 3	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05223	E Tower	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05921	E-1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-05971	HVAC Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Open - Returned 08/01/2025	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	BLD-06886	LOX Yard	OSHPD 1-Proposed	N/A								4s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00478	Original Hospital (Tower & Low Rise)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00479	Phase 2 Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 08/01/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00480	Phase 2 Cafeteria / Cardiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00481	Phase 2 ER / Radiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00482	Phase 3 West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 08/01/2025	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-00484	MRI Addition - Structurally connected to BLD-00478	OSHPD 1-Not an Independent Building	N/A								N/A				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-02944	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/01/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-05222	Phase 4 Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/01/2025	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-05308	Phase 3 West Wing - East Portion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 08/01/2025	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-08123	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-08124	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-08125	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-08126	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	BLD-08127	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-03744	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/08/2023	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-03745	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/08/2023	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-07386	WT-01 Water Tank	OSHPD 1-Proposed	5s								5s				
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	BLD-07387	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-02453	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 04/20/2023	Rpt: Review Completed 12/06/2023	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-02454	Central Service Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-07211	Hospital Addition - 2005	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	BLD-07212	Tech Dock	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02447	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 08/14/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02448	North Addition (Hospital Tower)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Awaiting review 08/14/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02449	Phase 1 Hospital - Utility Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/01/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02450	Phase II Hospital	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Open - Returned 12/06/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02451	Generator Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-02452	Waste, Gas Farm Enclosure	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-03504	Phase II Link Corridor	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	BLD-07034	Drop Off Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/06/2023	
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-00276	Main Hospital	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/21/2023	Rpt: In Review 12/21/2023	
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-05620	ED Expansion	OSHPD 1-In Service	5								4			Rpt: In Review 12/21/2023	
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-05621	OR Expansion	OSHPD 1-In Service	5								4			Rpt: In Review 12/21/2023	
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-07699	Pump House	OSHPD 1-Proposed	5s								5s				
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-07700	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-07701	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	16228	San Ramon Regional Medical Center	BLD-07702	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
07 - Contra Costa	16166	San Ramon Regional Medical Center South Building	BLD-03688	Rehabilitation Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02461	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02462	ER / Lab Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02466	Nursing Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-02467	Ambulatory Services	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03032	Mechanical Building - Structurally connected to BLD-02461	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03033	OR Storage Expansion	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03034	Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Not Submitted	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03484	Womens Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03667	Nursing Tower - Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03668	Nursing Tower - Dining Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03669	Nursing Tower - Admin Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-03670	Nursing Tower - Lobby Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/30/2023	
07 - Contra Costa	10052	Sutter Delta Medical Center	BLD-07948	IDF Building	OSHPD 1-Proposed	5s								4s				
08 - Del Norte	12784	Sutter Coast Hospital	BLD-01054	Hospital Building	OSHPD 1-In Service	4								4			Rpt: In Review 12/30/2023	
08 - Del Norte	12784	Sutter Coast Hospital	BLD-01055	Special Care Unit	OSHPD 1-In Service	5								4			Rpt: In Review 12/30/2023	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00485	Original and Nursing Wing Addition	OSHPD 1-In Service	2						12/31/2032 AB 869		2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00486	Two Story Addition	OSHPD 1-In Service	4						12/31/2032 AB 869		2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: In Review 12/18/2023	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00487	Mechanical Plant and Addition	OSHPD 1-In Service	4						12/31/2032 AB 869		2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/18/2023	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-00488	MRI Addition	OSHPD 1-In Service	5						12/31/2032 AB 869		4			Rpt: In Review 12/18/2023	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-05600	New Central Utility Plant	OSHPD 1-In Service	5						12/31/2032 AB 869		4			Rpt: In Review 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
09 - El Dorado	10109	Barton Memorial Hospital	BLD-06620	Utility Tunnel	OSHPD 1-Tunnels	N/A						12/31/2032 AB 869		2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/18/2023	
09 - El Dorado	10109	Barton Memorial Hospital	BLD-07883	Pump House	OSHPD 1-Proposed	5s						12/31/2032 AB 869		5s				
09 - El Dorado	10109	Barton Memorial Hospital	BLD-07884	WT-01 Water Tank	OSHPD 1-Proposed	N/A						12/31/2032 AB 869		5s				
09 - El Dorado	10109	Barton Memorial Hospital	BLD-07885	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A						12/31/2032 AB 869		5s				
09 - El Dorado	10109	Barton Memorial Hospital	BLD-07886	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A						12/31/2032 AB 869		5s				
09 - El Dorado	10109	Barton Memorial Hospital	BLD-07887	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A						12/31/2032 AB 869		5s				
09 - El Dorado	10112	Marshall Medical Center	BLD-00489	Original Building (Bldg I)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10112	Marshall Medical Center	BLD-00490	1971 Addition No. 1 (Bldg II)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10112	Marshall Medical Center	BLD-00491	1971 Addition No. 2 (Bldg III) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A								N/A				
09 - El Dorado	10112	Marshall Medical Center	BLD-00492	1974 Addition (Bldg IV)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-00493	1981 Addition No. 1 (Bldg V)	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
09 - El Dorado	10112	Marshall Medical Center	BLD-00494	1981 Addition No. 2 (Bldg VI)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-00495	1988 Addition (Bldg VII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-00496	1991 Addition (Bldg VIII) - Structurally connected to BLD-00494	OSHPD 1-Not an Independent Building	N/A								N/A				
09 - El Dorado	10112	Marshall Medical Center	BLD-00497	1964 Addition (Bldg IX) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
09 - El Dorado	10112	Marshall Medical Center	BLD-05594	2012 Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06515	2012 Addition - Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06516	2012 Addition - Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06517	2012 Addition - South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06518	2012 Addition - Center Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06519	2012 Addition - North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06617	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	
09 - El Dorado	10112	Marshall Medical Center	BLD-06982	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-00513	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-00514	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-00515	Rec. Room & Office Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-00516	Lab & Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-00517	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	10162	Adventist Health Reedley	BLD-00518	Birthing Center	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-02949	LDR Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-05522	ER / Radiology / Clinic Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-05681	Generator Shed	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	BLD-06036	Lobby Remodel & Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06037	Corridor Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06038	Mechanical & Electrical Building Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06039	Main Entrance Canopy Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-06040	ER Canopy Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/26/2023	
10 - Fresno	10162	Adventist Health Reedley	BLD-07806	New Generator Canopy	OSHPD 1-Proposed	5s								4s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07844	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07845	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07846	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07847	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07848	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07849	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10162	Adventist Health Reedley	BLD-07850	FT-03 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10160	Adventist Health Selma	BLD-00507	Medical / Surgical / Birthing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00508	Maintenance Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: In Review 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00509	Nursing Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	10160	Adventist Health Selma	BLD-00510	Emergency / Laboratory	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/26/2023	
10 - Fresno	10160	Adventist Health Selma	BLD-00511	Multi-Use Facility	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	BLD-00512	Warehouse	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	16116	Clovis Community Medical Center	BLD-00020	Nursing Unit	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00021	Diagnosis and Treatment	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00022	Administration and Support	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-00023	Central Plant	OSHPD 1-In Service	4								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05376	Central Plant Expansion	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05377	Bed Tower	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05378	Diagnostic & Treatment Expansion	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05379	Support Expansion 1	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05380	Support Expansion 2	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-05381	Canopy 1	OSHPD 1-In Service	5								5s			Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-06051	North Bed Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06052	Support Expansion 3A	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	16116	Clovis Community Medical Center	BLD-06053	Support Expansion 3B	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06054	Diagnostic & Treatment Expansion 3A	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06055	Diagnostic & Treatment Expansion 3B	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06056	Utility Racks	OSHPD 1-Not a Building Structure	N/A								5s	1/1/2030		Rpt: Review Completed 11/22/2023	
10 - Fresno	16116	Clovis Community Medical Center	BLD-06556	Bottle Storage	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06591	Front Entry	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06694	Entry Canopy-North	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-06695	Entry Canopy-South	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-07148	Emergency Entry Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	BLD-07488	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07489	WWT-02 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07490	WWT-03 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07491	WWT-04 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07492	WWT-05 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07493	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07494	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07495	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07552	Pump House	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
10 - Fresno	16116	Clovis Community Medical Center	BLD-07978	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	16116	Clovis Community Medical Center	BLD-07979	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10122	Coalinga Regional Medical Center	BLD-00498	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
10 - Fresno	10122	Coalinga Regional Medical Center	BLD-06696	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
10 - Fresno	10127	Community Regional Medical Center	BLD-00003	West Wing / East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02535	Radiology Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02536	Aa - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	10127	Community Regional Medical Center	BLD-02537	Ab - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02538	Ac - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02539	Ad - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	BLD-02540	Ae - East Wing	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02541	Angiography Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02951	Trauma & Critical Care Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02952	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-02953	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-03513	D/P Skilled Nursing Facility	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-05190	MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-05208	Data Center Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-06508	Trauma Center Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
10 - Fresno	10127	Community Regional Medical Center	BLD-06509	Trauma Center Utility Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	10127	Community Regional Medical Center	BLD-07921	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07922	WT-02 Water Tank (industrial)	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07923	Canopy #1	OSHPD 1-Proposed	5s								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07924	Canopy #2	OSHPD 1-Proposed	5s								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07925	Pump House	OSHPD 1-Proposed	5s								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07926	Wastewater Tank #1	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07927	Wastewater Tanks #2	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07928	Wastewater Tank #4	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07929	Wastewater Tanks #5	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	10127	Community Regional Medical Center	BLD-07930	Well #1	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05187	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05188	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-05278	Wing A	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-07980	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-07981	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
10 - Fresno	17938	Fresno Heart And Surgical Hospital	BLD-07982	Equipment Canopy	OSHPD 1-Proposed	5s								5s				
10 - Fresno	16878	Fresno Surgical Hospital	BLD-00294	Recovery Center	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	
10 - Fresno	16878	Fresno Surgical Hospital	BLD-03748	Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
10 - Fresno	16878	Fresno Surgical Hospital	BLD-05252	New Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
10 - Fresno	16878	Fresno Surgical Hospital	BLD-05366	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
10 - Fresno	16878	Fresno Surgical Hospital	BLD-07246	New Tower Support	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00976	Sequoia Mall	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00977	Hospital Tower North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00978	Hospital Tower South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00979	Ancillary/Yosemite Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00980	Ancillary Building Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/09/2022	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-00981	Utility/Grapevine Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06468	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/01/2023	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06499	Medical Gas Storage	OSHPD 1-In Service	4s								4s		Rpt: Not Submitted	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06502	Medical Waste Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06503	Med Gas Cylinder Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06633	Emergency Department Expansion	OSHPD 1-Under Construction	5s								5s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06922	Entrance Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06923	Utility Shaft	OSHPD 1-Not a Building Structure	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06924	Fuel Pump House	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06925	Connecting Corridor	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-06926	Utility Tunnel	OSHPD 1-Tunnels	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07049	Carpenter Shop	OSHPD 1-In Service	4								4			Rpt: Review Completed 11/21/2023	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07171	Medical Waste Enclosure	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07452	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07453	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07454	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07591	Entrance Canopy	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07592	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	BLD-07593	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00500	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/27/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00501	West Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00502	Cogeneration Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00503	Chapel	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 04/07/2026	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00504	Northwest Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00505	East Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-00506	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-03307	Cath Recovery Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-03308	North Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-05548	Canopy and Bridges	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/27/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	BLD-05877	UPS Flywheel Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
10 - Fresno	10155	Saint Agnes Medical Center	BLD-06564	21 KV Switchgear Building	OSHPD 1-Under Construction	5s								4s				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-06600	Fire Pump / Chiller Building	OSHPD 1-Under Construction	5s								5s				
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07077	North Addition Auditorium	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07078	North Addition Canopy #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07080	North Addition Canopy #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
10 - Fresno	10155	Saint Agnes Medical Center	BLD-07175	Incinerator Canopy	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/29/2023	
10 - Fresno	16404	San Joaquin Valley Rehabilitation Hospital	BLD-02531	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/27/2023	Rpt: Open - Returned 12/27/2023	
11 - Glenn	10175	Glenn Medical Center	BLD-00519	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00520	Garage Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00521	600 Wing (Accounting) Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-00522	Nurses Locker Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
11 - Glenn	10175	Glenn Medical Center	BLD-03773	Main Building - ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
11 - Glenn	10175	Glenn Medical Center	BLD-03774	Main Building - Dietary / Purchasing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
11 - Glenn	10175	Glenn Medical Center	BLD-03775	Main Building - 700 Wing South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03776	Main Building - 700 Wing North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03777	Main Building - 800 Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03778	Main Building - Medical / Surgery	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	BLD-03825	Shop & Maint. Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-00751	Main Building and Additions	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Not Submitted	Rpt: Review Completed 09/08/2016	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-03334	ER Addition	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Not Submitted	Rpt: Review Completed 09/08/2016	
12 - Humboldt	10186	Jerold Phelps Community Hospital	BLD-05453	Clinic Building and Additions	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
12 - Humboldt	13087	Mad River Community Hospital	BLD-00186	Main Hospital	OSHPD 1-In Service	2						1/1/2032 AB 869		4D-L2			Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	13087	Mad River Community Hospital	BLD-00187	Central Plant	OSHPD 1-In Service	2						1/1/2032 AB 869		4D-L2			Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
12 - Humboldt	13087	Mad River Community Hospital	BLD-00188	Administration/Urgent Care	OSHPD 1-In Service	4						1/1/2032 AB 869		4D-L1			Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-00189	Short Stay Surgery	OSHPD 1-In Service	4						1/1/2032 AB 869		4D-L2			Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-00190	Obstetrics Addition	OSHPD 1-In Service	4						1/1/2032 AB 869		4			Rpt: Review Completed 12/31/2023	
12 - Humboldt	13087	Mad River Community Hospital	BLD-05471	AHU Platform	OSHPD 1-Under Construction	5s						1/1/2032 AB 869		4s				
12 - Humboldt	13087	Mad River Community Hospital	BLD-05715	Conference Room Addition	OSHPD 1-In Service	4						1/1/2032 AB 869		4D-L1			Rpt: Review Completed 12/31/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00529	Original Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00530	O.B. Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00531	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00532	East Wing Expansion	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-00533	E. Wing Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-03890	Surgery Department - Structurally connected to BLD-00529	OSHPD 1-Not an Independent Building	N/A								N/A				
12 - Humboldt	10183	Providence Redwood Memorial Hospital	BLD-05824	Rehab. Addition	OSHPD 1-Under Construction	5s								5s				
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00535	Original Hospital and Central Plant	OSHPD 1-In Service	1			Withdrawn		12/31/2019 Com Acc Replace	11/29/2024 AB 2190 Rebuild		2	1/1/2024	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00536	Linear Accelerator (Phase II)	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00537	Phase III Addition Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00538	Emergency Entrance Vestibule	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00539	Radiation Oncology Addition	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00540	Heart Center	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00541	East Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-00542	Emergency Entrance Vestibule Addition	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-02735	Emergency Generator #1 CMU Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-02736	Emergency Generator #2 Enclosure Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03375	Northeast Building Entry Link	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03376	Fire Pump House	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-03625	Northeast Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-05767	Northeast Building Ambulance Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-05768	Northeast Building Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-07820	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-07821	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-07822	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
12 - Humboldt	10184	Providence St. Joseph Hospital	BLD-07823	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06703	Hospital	OSHPD 1-Proposed	5s								5s				
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06704	Entry Canopy	OSHPD 1-Proposed	5s								5s				
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	BLD-06705	ED Canopy	OSHPD 1-Proposed	5s								5s				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00752	South Wing	OSHPD 1-In Service	4D	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00753	L/D Bldg	OSHPD 1-In Service	4D	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00754	Central Wing	OSHPD 1-In Service	4D	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00755	West Addition - Structurally connected to BLD-00754	OSHPD 1-Not an Independent Building	N/A	01/01/2020							N/A				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00756	Central Plant	OSHPD 1-In Service	4D	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00757	North Wing	OSHPD 1-In Service	4D	01/01/2020					1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00758	ICU Addition - Structurally connected to BLD-00757	OSHPD 1-Not an Independent Building	N/A								N/A				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00759	Admin Bldg	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00760	OB Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00761	Radiology Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00762	Rad Annex	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00763	Lab Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-00764	Annex	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-02685	East Wing - South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-02686	New Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-02687	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-02887	Admin Bldg Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-02888	East Wing - North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/28/2023	Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-03219	Electrical Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-03331	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-05694	Ancillary Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-05940	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06098	Data Center Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06389	Entrance Lobby	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06390	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06391	Driveway Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06392	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06419	North ASB Utility Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06420	South ASB Utility Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06421	ASB Covered Link	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06427	Central Plant Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06428	Hazardous Waste Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-06429	Pharmacy Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07800	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07801	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07802	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07803	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07804	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10190	Imperial Valley Health - El Centro Hospital	BLD-07805	Pump House	OSHPD 1-Proposed	5s								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00765	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Open - Returned 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00766	Original Power Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Open - Returned 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00767	Administration Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2024	Rpt: Open - Returned 10/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00768	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00769	Outpatient Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00770	Women's Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00771	ER	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00772	New Power Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-00773	Dietary	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-02892	Link between 05B and 01A	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-02893	Link between 05B and 05C	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-05909	Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-06240	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 05/13/2024	Rpt: Open - Returned 10/31/2024	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07931	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Not Submitted	Rpt: Not Submitted	
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07935	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07936	WWT-01 Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07937	WT-01 Water Tanks	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07938	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07939	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07940	Pump House	OSHPD 1-Proposed	5s								5s				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07941	WT-03 Water Tank	OSHPD 1-Tanks	N/A								N/A				
13 - Imperial	10192	Pioneers Memorial Hospital	BLD-07942	FT-3 Fuel Tank	OSHPD 1-Proposed	N/A								5				
14 - Inyo	10200	Northern Inyo Hospital	BLD-00775	Main Hosp Bldg/Existing Central Plant	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
14 - Inyo	10200	Northern Inyo Hospital	BLD-00776	ICU Addition	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-00777	Central Plant Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-00778	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
14 - Inyo	10200	Northern Inyo Hospital	BLD-02922	New Hospital Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/29/2023	
14 - Inyo	10200	Northern Inyo Hospital	BLD-05321	New Central Plant Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-06524	Covered Walkway - West	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-06525	Covered Walkway - North	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10200	Northern Inyo Hospital	BLD-06526	Corridor Connection	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00779	Main Hospital Building	OSHPD 1-In Service	2					1/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Awaiting review 08/08/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00780	Maintenance Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Awaiting review 08/09/2026	Rpt: Review Completed 08/08/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00781	Entrance Addition - Structurally connected to BLD-00779	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00782	East Wing Addition	OSHPD 1-In Service	2					7/1/2019 Risk Bsd Retrofit			2	1/1/2030	Rpt: Awaiting review 08/08/2026	Rpt: Review Completed 08/08/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	BLD-00783	West Wing Addition - Structurally connected to BLD-00779	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00784	Diagnostics & Treatment Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 08/08/2026	Rpt: Review Completed 08/08/2026	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00785	Patient Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 08/08/2026	Rpt: Review Completed 08/08/2026	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00786	Storage Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 08/08/2026	Rpt: Review Completed 08/08/2026	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00787	Boiler Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 08/09/2026	Rpt: Review Completed 08/08/2026	
14 - Inyo	10202	Southern Inyo Hospital	BLD-00788	Boiler Room 2 Addition - Structurally connected to BLD-00787	OSHPD 1-Not an Independent Building	N/A								N/A				
14 - Inyo	10202	Southern Inyo Hospital	BLD-00789	Laundry Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
14 - Inyo	10202	Southern Inyo Hospital	BLD-00790	Storage Building	OSHPD 1-In Service	2					7/1/2019 Risk Bsd Retrofit			2	1/1/2030	Rpt: Awaiting review 08/09/2026	Rpt: Review Completed 08/08/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12881	Adventist Health Bakersfield	BLD-00948	Original Building (Main Hospital)	OSHPD 1-In Service	2								3		Rpt: Awaiting review 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12881	Adventist Health Bakersfield	BLD-00949	Emergency Department Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00951	Emergency Generator Enclosure	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00952	Fire Pump Enclosure	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-00953	Bulk Medical Storage Facility	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-06018	Tower Number 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-06555	New Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
15 - Kern	12881	Adventist Health Bakersfield	BLD-07024	Tank Storage	OSHPD 1-In Service	2s								2s		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/20/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01049	Main Building	OSHPD 1-In Service	2	Withdrawn							2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12765	Adventist Health Delano	BLD-01050	Radiology Addition	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01051	ICU/TCU Facility	OSHPD 1-In Service	4								2		Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-01052	Med Gases Ancillary	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	12765	Adventist Health Delano	BLD-01053	Med Gases	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-05953	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
15 - Kern	12765	Adventist Health Delano	BLD-06162	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-06618	Switchgear Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	12765	Adventist Health Delano	BLD-06622	Hospital Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	17358	Adventist Health Specialty Bakersfield	BLD-00085	Bakersfield Heart Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/06/2024	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-03237	Main Entrance Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05541	Medical / Surgical Facility Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05542	Obstetrical Facilities Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05543	D & T Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05544	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05545	ED Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05546	CT Trailer Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-05547	Water Tank (WT-01)	OSHPD 1-Tanks	N/A								N/A				
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06624	Main Entrance High Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06625	ED High Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06626	Trash Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
15 - Kern	18202	Adventist Health Tehachapi Valley	BLD-06627	Mechanical Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00791	Main Hospital / Lobby / Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00792	East Wing	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00793	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00794	Main Hospital West Wing / Business Office	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00795	Maternity Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00796	Labor & Delivery	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00797	Labor & Delivery II	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00798	Main Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00799	New Cath Lab & Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00800	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-00801	Main Hospital East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03377	Endoscopy Building	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03378	Main Tower - Connecting Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-03379	Laundry / Warehouse Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05215	Entrance Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05659	Endoscopy Corridor	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05896	Cardiac Rehab	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05897	Physical Therapy / Regional Human Resources	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-05902	Ambulance Porte Cochere	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06326	Kitchen / Shell Bldg.	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06357	Pediatric Pavilion for Emergency Care	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06373	Lobby Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-06497	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10207	Bakersfield Memorial Hospital	BLD-07934	Mechanical Building	OSHPD 1-In Service	2s								2		Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06330	Vibra Rehabilitation Hospital of Bakersfield	OSHPD 1-In Service	5								5				Earthquake Resilient
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06332	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								5				
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06333	O2 Yard	OSHPD 1-Equipment Yard	N/A								5				
15 - Kern	10820	Central California Rehabilitation Hospital	BLD-06334	Main Entry Drop Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-00281	East Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-00282	West Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05565	20 Bed Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05566	Emergency Power Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-05567	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07088	Generator Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07620	Pump House #1	OSHPD 1-Proposed	5s								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07621	Pump House #2	OSHPD 1-Proposed	5s								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07622	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07623	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07624	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-07625	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-08001	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	BLD-08002	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10219	Good Samaritan Hospital	BLD-00811	Original Hospital & Additions	OSHPD 1-In Service	2					1/1/2014 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	BLD-00812	Pediatrics Wing & Additions	OSHPD 1-In Service	2					1/1/2015 Fin Hdsp Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	BLD-00813	Patient Wing	OSHPD 1-In Service	2					1/1/2014 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	BLD-00814	Intensive Care Unit Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
15 - Kern	10208	Kern Medical Center	BLD-00803	Wing B/C - North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10208	Kern Medical Center	BLD-00804	Wing D	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-00805	Wing E	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-00806	Infill at E Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/28/2023	
15 - Kern	10208	Kern Medical Center	BLD-00807	Wing G / Laundry / Boiler Room	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2018 Com Acc Rebuild			N/A				
15 - Kern	10208	Kern Medical Center	BLD-00808	Wing G/Dietary	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10208	Kern Medical Center	BLD-00809	Central Utilities Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10208	Kern Medical Center	BLD-03806	Wing B/C - South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	BLD-00810	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	BLD-02964	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02965	Surgical Suite Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02966	Service Facility Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-02967	Skilled Nursing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
15 - Kern	10210	Kern Valley Healthcare District	BLD-07133	Connecting Corridor	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
15 - Kern	10214	Mercy Hospital	BLD-00827	Main Wing/Courtyard Infill	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	BLD-00828	Addition to the Main Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00829	Patient Tower (T & D Stair No. 3)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00830	Treatment and Diagnostic Building (Central Plant and Emergency Generator Enclosure)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00831	T & D Admitting Wing (Boiler Building and Mezzanine)	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	BLD-00832	T & D Stair No. 1 (Laundry Building)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10214	Mercy Hospital	BLD-00833	T & D Stair No. 2 (Treatment and Diagnostic Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00834	T & D Stair No. 3 (T & D Stair No. 4)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00835	T & D Stair No. 4 (Patient Tower)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00836	Boiler Building and Mezzanine (T&D Stair Number 1)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-00837	Central Plant and Emergency Generator Enclosure (T&D Admitting Wing)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-03315	Corridor - Northwest Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-05203	Boiler Building and Mezzanine (T&D Stair Number 2)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06181	Porte Cochere	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06182	Corridor - Northeast Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06196	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10214	Mercy Hospital	BLD-06207	Emergency Generator and Aboveground Fuel Tank	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	17632	Mercy Southwest Hospital	BLD-02623	Main Hospital Building 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
15 - Kern	17632	Mercy Southwest Hospital	BLD-02624	Main Hospital Building 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
15 - Kern	17632	Mercy Southwest Hospital	BLD-06359	New Four Story Patient Tower	OSHPD 1-Under Construction	5s								5s				
15 - Kern	17632	Mercy Southwest Hospital	BLD-06360	New Two Story East Addition	OSHPD 1-Under Construction	5s								5s				
15 - Kern	17632	Mercy Southwest Hospital	BLD-06361	New One Story West Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
15 - Kern	17632	Mercy Southwest Hospital	BLD-06362	New Central Utility Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
15 - Kern	17632	Mercy Southwest Hospital	BLD-06363	Main Entry Canopy	OSHPD 1-Under Construction	5s								5s				
15 - Kern	17632	Mercy Southwest Hospital	BLD-06364	Loading Dock Canopy	OSHPD 1-Under Construction	5s								5s				
15 - Kern	17632	Mercy Southwest Hospital	BLD-07755	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
15 - Kern	17632	Mercy Southwest Hospital	BLD-07756	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
15 - Kern	17632	Mercy Southwest Hospital	BLD-08061	ICU Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	17632	Mercy Southwest Hospital	BLD-08062	Lab Expansion	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	17632	Mercy Southwest Hospital	BLD-08063	Emergency Department Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00815	Main Core	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00817	B Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00818	C Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/13/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00819	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/13/2023	Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00820	D Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-00821	E Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-03483	Addition to Existing Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-03619	Cafeteria / Dining Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06578	Entrance Canopy 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06579	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06580	Electrical Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
15 - Kern	10220	Ridgecrest Regional Hospital	BLD-06582	Entrance Canopy 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
16 - Kings	18194	Adventist Health Hanford	BLD-05346	Main Hospital - West Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
16 - Kings	18194	Adventist Health Hanford	BLD-05347	Main Hospital - East Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
16 - Kings	18194	Adventist Health Hanford	BLD-05570	Womens Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
16 - Kings	18194	Adventist Health Hanford	BLD-05571	Energy Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
16 - Kings	18194	Adventist Health Hanford	BLD-06785	Trellis	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/26/2023	
16 - Kings	18194	Adventist Health Hanford	BLD-07179	Cath Lab	OSHPD 1-Proposed	5s								5s				
17 - Lake	10247	Adventist Health Clearlake	BLD-00431	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 10/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
17 - Lake	10247	Adventist Health Clearlake	BLD-00432	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-00434	Central Supply/Maintenance	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-05509	Chiller Platform	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-06023	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-07026	ED Department	OSHPD 1-In Service	5								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-07131	ED Department Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 10/27/2023	
17 - Lake	10247	Adventist Health Clearlake	BLD-07145	Med Gas Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 10/27/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00268	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00269	Hospital Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-00270	CT Scanner	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: In Review 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
17 - Lake	14345	Sutter Lakeside Hospital	BLD-02981	Conference Room - Structurally connected to BLD-00268	OSHPD 1-Not an Independent Building	N/A								N/A				
17 - Lake	14345	Sutter Lakeside Hospital	BLD-02982	LDRP Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-03052	Purchasing Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
17 - Lake	14345	Sutter Lakeside Hospital	BLD-03558	Surgery & Emergency Department	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-06296	Pharmacy Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-06486	ED Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
17 - Lake	14345	Sutter Lakeside Hospital	BLD-07254	MRI Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: In Review 12/31/2023	
18 - Lassen	17940	Banner Lassen Medical Center	BLD-05185	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/27/2026	
18 - Lassen	17940	Banner Lassen Medical Center	BLD-06331	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/27/2026	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01940	Rehabilitation Wing	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01941	Mental Health Building	OSHPD 5-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01942	Main Building - North East - Structurally connected to BLD-03263	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01943	Main Building - South	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01944	Main Building - West (SICU)	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01945	Main Building - Stair Tower #5	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01946	Wilson Parking Structure	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01949	Link Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01950	Link Building - West	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01951	Link Building - East	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01952	TCU	OSHPD 1-In Service	2					7/16/2013 Risk Bsd Retrofit			4D-L1			Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-01953	D & T / D & T Plant	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03015	Womens Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03016	Mental Health Bldg South Addition	OSHPD 5-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03263	Main Building - North East	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03439	West Tower Phase 2 / 3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03440	West Tower Phase 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03441	West Tower Link to Main Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03762	Main Building - Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-03913	Main Building - North	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-05932	Exhaust Stack - Structurally connected to BLD-03440	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11668	Adventist Health Glendale	BLD-06399	Compounding Pharmacy Building	OSHPD 1-In Service	4								2	1/1/2024	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07021	Addition #1	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07022	Addition #2	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07023	Addition #3	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11668	Adventist Health Glendale	BLD-07358	Stair Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02187	D & T Building (North Tower)	OSHPD 1R-Delicensed Clinic under OSHPD	N/A								N/A				
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02188	East Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02189	Chiller Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02191	East Building North Addition (B-1)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02192	South Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-02193	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03157	East Building South Addition (B-2)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/23/2021	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03287	Shop Building Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03288	Boiler Building Replacement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03290	Service Tunnel Replacement	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03291	Specialty Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-03859	Entry Concourse Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06511	Entry Concourse Building (South)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06512	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06513	Stair / Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06514	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-06520	Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-07770	Equipment Storage Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12198	Adventist Health White Memorial	BLD-07771	Bio-Hazard Waste Storage	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00613	Service Building & Additions (Block I)	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00614	Home Health (Block II) Nursing & Lab	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00615	Nursing Administration (Block III)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00616	Accounting & Respiratory Therapy (IV)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00617	Emerson Wing - Nursing Unit (V) - Structurally connected to BLD-00614	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00618	Main Building North (Block VI)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00619	Canopy (Block VII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00620	OB Addition (Block VIII)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-00621	MRI Facility (Block IX)	OSHPD 1-In Service	5					Denied			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-03872	Main/Utility/Tower (Block VI)	OSHPD 1-In Service	2					12/1/2016 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/23/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-05504	Central Plant and Ambulance Area	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-06415	Equipment Yard – Hot Water System	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	BLD-06729	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11386	Alhambra Hospital Medical Center	BLD-00722	Hospital	OSHPD 1-In Service	2	Denied				1/1/2015 Risk Bsd Retrofit			3		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00737	Original Hospital	OSHPD 1-In Service	2			01/01/2015		12/31/2019 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00738	Storeroom Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00739	East Wing Addition	OSHPD 1-In Service	2			01/01/2015		12/31/2019 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00740	Dining Room Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00741	Cobalt Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00742	Hospital Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00743	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00744	Emergency Room Addition - Structurally connected to BLD-00746	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00745	Storage Building	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00746	Hospital Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00747	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00748	Entrance Addition - Structurally connected to BLD-00742	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00749	Kitchen and Dining Additions (west side addition) - Structurally connected to BLD-02621	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-00750	Storeroom & Dock Addition - Structurally connected to BLD-00738	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02621	Kitchen Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02804	New Women's and Children's Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/02/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-02805	New WCH Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/02/2024	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-03486	Northeast Canopy	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05484	Kitchen and Dining Additions (east side addition) - Structurally connected to BLD-02621	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05708	New Women's and Children's Hospital Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/02/2024	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05709	New Women's and Children's Hospital Electrical Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/02/2024	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-05711	New Women's and Children's Hospital LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 01/02/2024	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06091	Central Plant Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06107	Entrance Canopy	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06108	Central Plant Addition - West	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06501	Prefabricated ED Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06646	Replacement Hospital	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06647	Main Entry Canopy	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06648	Emergency Entrance Canopy	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-06650	Central Utility Plant	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-07990	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-07991	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11399	Antelope Valley Medical Center	BLD-07992	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00730	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00731	Dining/Kitchen Building & Additions (1902)	OSHPD 1-In Service	2			01/01/2015		7/1/2019 Com Acc Rebuild			3		Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00732	1927 Addition (Original Building)	OSHPD 1-In Service	2			01/01/2015		7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Open - Returned 02/27/2026	Rpt: Review Completed 08/20/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-00733	1974 Addition "A"	OSHPD 1-In Service	2			01/01/2015		7/1/2019 Com Acc Rebuild			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-02707	1974 Addition "B"	OSHPD 1-In Service	2			01/01/2015		7/1/2019 Com Acc Rebuild			3		Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-02708	1974 Addition "C"	OSHPD 1-In Service	2			01/01/2015		7/1/2019 Com Acc Rebuild			3		Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-03010	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 08/20/2026	
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06489	Entry Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-06490	Rear Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-07916	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-07917	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-07918	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-07919	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11417	Barlow Respiratory Hospital	BLD-07920	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 08/20/2026	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00622	Tibbitts Tower A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00623	Tibbitts Tower B	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00625	D & T Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00626	1963 Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00627	1969 Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-00628	1964 Tower	OSHPD 1-In Service	1					7/1/2019 Com Acc Rebuild	1/1/2025 AB 2190 Rebuild		2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03122	Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03212	Emergency Department and Women's Services	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03213	Stair Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-03214	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	BLD-06543	Cooling Tower Platform	OSHPD 1-Not a Building Structure	N/A								2		Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-00940	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-02910	LOX Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-03876	Trigen Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-03908	Central Plant Expansion 3	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	BLD-05781	Drop Off Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-02885	New Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05310	Medical Surgical Addition and 31 Bed Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05311	Electrical Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-05473	Mechanical Yard Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-06219	Welcome Gallery	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-06220	Imaging Connector	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11496	Casa Colina Hospital	BLD-08033	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11496	Casa Colina Hospital	BLD-08034	Pump House #1	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11496	Casa Colina Hospital	BLD-08035	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11496	Casa Colina Hospital	BLD-08036	Pump House #2	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11496	Casa Colina Hospital	BLD-08037	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	10095	Catalina Island Medical Center	BLD-07226	Hospital	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	10095	Catalina Island Medical Center	BLD-07227	ER Canopy	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11410	Catalina Island Medical Center	BLD-00725	Original Building	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11410	Catalina Island Medical Center	BLD-00726	East Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01039	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01040	CCU Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-01041	Outpatient Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06232	Pharmacy Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06366	Hospital	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06367	Central Utility Plant (Energy Center)	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06368	Gas Yard	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06418	Hospital Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06572	Loading Dock	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-06730	MRI/CT Trailers Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07187	Hospital Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07579	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07580	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07581	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07582	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07583	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	BLD-07584	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00384	Main Medical Center	OSHPD 1-In Service	2								3		Rpt: Awaiting review 12/13/2023	Rpt: Review Completed 03/15/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00385	Harvey Morse Conference Center - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-00386	Becker Building - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02806	Imaging Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02807	Saperstein Critical Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-02808	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/15/2024	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-03438	Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-05265	Comprehensive Cancer Center	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-05304	Advanced Health Sciences Pavilion	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-07658	New Patient Wing Addition	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11891	Cedars-Sinai Medical Center	BLD-07783	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00633	West Wing/ER Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00634	North Wing/Day Surgery	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00635	Dietary Storage	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00636	East Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00637	West Tower	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00638	Engineering	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00639	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00640	Central Plant Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-00641	Nursery Addition	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-03466	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-05404	Electrical Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-06894	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07248	Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07359	Transformer and Medical Gas Enclosure	OSHPD 1-Equipment Yard	N/A								2s		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07374	ER Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07375	Drop-Off Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07522	East Wing - West Side	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07751	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07752	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07753	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07754	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11510	Centinela Hospital Medical Center	BLD-07956	Pump House	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00643	Duque Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00644	Page Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00645	McAllister Building	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00646	Page Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00647	Weingart Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-00648	McDonald's Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 09/14/2023	Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-02847	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/08/2023	Intent to Remove GAC	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-02848	DWP Substation	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03292	Central Plant/Anderson Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03293	Subterranean Parking Structure	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03294	Cooling Tower - Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-03531	Surgery Center/Anderson Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-05279	Anderson Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11525	Children's Hospital Los Angeles	BLD-07000	Duque Building Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Review Completed 06/30/2026	Rpt: Review Completed 08/18/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00650	Northwest	OSHPD 1-In Service	2	Denied				1/1/2015 Risk Bsd Remove GAC			3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00652	Main Medical	OSHPD 1-In Service	2	Denied				Denied			3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-00653	ICU	OSHPD 1-In Service	4								3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02575	Wing 1	OSHPD 1-In Service	2								3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02576	Wing 5	OSHPD 1-In Service	2								3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02577	Wing 6	OSHPD 1-In Service	2								3		Rpt: Review Completed 1800-01-01	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-02578	Food Service Facility	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-03091	Chiller Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-03851	Helford Clinical Research Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06155	Helford Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06683	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06779	Main Medical Stair Tower	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06953	Cogeneration Building	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	BLD-06956	TES Tank (WT-01)	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02151	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02670	Lobby & Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02671	X-ray Entry	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-02672	OR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12088	Coast Plaza Hospital	BLD-03646	Telephone Equipment Building	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00402	North and East Wings	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Documents Uploaded 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00404	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 02/26/2025	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00405	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
19 - Los Angeles	11927	College Medical Center	BLD-00406	Engineering	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2025	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-00410	Admin/West Entry Lobby - Structurally connected to BLD-00402	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11927	College Medical Center	BLD-02822	Assembly	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	BLD-06635	North Wing Addition	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11549	Community Hospital Of Huntington Park	BLD-00669	Main Hospital	OSHPD 1-In Service	2					2/1/2016 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11549	Community Hospital Of Huntington Park	BLD-03426	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12024	Docs Surgical Hospital	BLD-01224	Main Hospital - Structurally connected to BLD-05236	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
19 - Los Angeles	12024	Docs Surgical Hospital	BLD-06601	New Hospital	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00670	Original Building	OSHPD 1-In Service	2	Withdrawn				2/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00671	East Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A	Withdrawn				Denied			N/A				
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00672	North Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A	Withdrawn				Denied			N/A				
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00673	South Addition	OSHPD 1-In Service	2	Withdrawn				1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	BLD-00674	South Addition - Structurally connected to BLD-00673	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-00191	Original Building	OSHPD 1-In Service	2								3R		Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-00192	Gift Shop Addition	OSHPD 1-In Service	3								4D-L1			Rpt: Not Submitted	
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	BLD-03840	Emergency Dept.	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02019	Original Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02020	East Wing Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02021	West Wing Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02022	Psychiatric Wing Addition	OSHPD 1-In Service	2					3/31/2013 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02023	Lobby Addition	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02024	Generator Building	OSHPD 1-In Service	2					10/24/2014 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02025	Power Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02026	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02027	Conference Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-02028	Surgery Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-05422	CCU Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-05423	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-06673	ER Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	BLD-07782	Canopy	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01163	Main Building	OSHPD 1-In Service	2					1/1/2018 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01164	Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01165	South Wing Addition	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01166	1968 West Wing Addition	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01167	Outpatient Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01168	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01169	1983 Lobby Addition - Structurally connected to BLD-01163	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01171	Chiller Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01172	Cardiac Cath Lab Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-01173	Maternal & Child Health Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-03409	Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-05424	Bridge Connector	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06654	ED & ICU Addition Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06655	Connecting Corridor	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06665	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 06/25/2024	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06727	Main Switchgear Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06728	MRI / CT Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06796	MRI / CT Pedestrian Walkway	OSHPD 1-In Service	5								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-06815	Pump Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-07475	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	BLD-07476	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00675	North Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00676	West Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-00677	Main Tower / Basement / Mech Bldg	OSHPD 1-In Service	2					1/1/2016 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-07165	Lab Extension	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11621	Encino Hospital Medical Center	BLD-07166	Engineering Shop	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 08/05/2024	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01934	Main Hospital	OSHPD 1-In Service	2	Denied				7/1/2019 Risk Bsd Retrofit			3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	BLD-01935	Nursery/Post Partum	OSHPD 1-In Service	2	Denied				3/31/2013 Risk Bsd Retrofit			3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11658	Garfield Medical Center	BLD-01936	Emergency Wing	OSHPD 1-In Service	2	Denied				3/31/2013 Risk Bsd Retrofit			3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	BLD-01937	O.B. Pavilion	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01938	O.B. Addition	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-01939	Cath Lab	OSHPD 1-In Service	3								4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03427	ER Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03428	Extended Service Canopy	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-03429	Service Canopy	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11658	Garfield Medical Center	BLD-06302	Medical Gas Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01779	Original Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2016 Fin Hdsp Remove GAC			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01780	1942 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2016 Fin Hdsp Replace			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01781	Radiology Addition A - Structurally connected to BLD-01780	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01782	Radiology Addition B	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2016 Fin Hdsp Remove GAC			N/A				
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01783	South Tower	OSHPD 1-In Service	2					7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01784	Juncture Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A					7/1/2019 Fin Hdsp Retrofit			N/A	1/1/2030			

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01785	Patient Tower	OSHPD 1-In Service	2					7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01786	Heart and Emergency Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01787	Central Plant	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-01788	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	BLD-03382	Administration Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	13224	Greater El Monte Community Hospital	BLD-00214	Main Hospital/Radiology Addition	OSHPD 1-In Service	2	Withdrawn							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13224	Greater El Monte Community Hospital	BLD-00215	Nursery & LDR Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00216	Main Hospital - Original Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00217	Main Hospital - Administration Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00218	Main Hospital - Emergency Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00219	Main Hospital - Main Lobby Building	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00222	Central Plant Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00223	Pavilion - Main Building	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00224	Pavilion - Adult Day Health Care	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-00225	Pavilion - Pavilion Plant Building	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-02862	Main Hospital - Emergency Entrance Canopy	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-02863	Main Hospital- Main Entrance Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03259	Patient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03309	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03338	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03413	Loading Dock	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-03414	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-05854	Basement Lab Expansion	OSHPD 1-In Service	5								2		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-05855	Connecting Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07255	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07321	Radiology Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/14/2023	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07605	Oxygen Tank Yard	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07610	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07611	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions						CO/CF **	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status						
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07612	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	BLD-07757	Pump House	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01977	North Wing	OSHPD 1-In Service	1	Withdrawn				12/31/2019 Com Acc Rebuild	5/22/2024 AB 2190 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01978	South Wing	OSHPD 1-In Service	2	Withdrawn				12/21/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01979	D & T Tower	OSHPD 1-In Service	2	Withdrawn				12/21/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01980	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 07/09/2025	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01981	Kitchen Addition	OSHPD 1-In Service	1	Withdrawn				12/31/2019 Com Acc Rebuild	5/22/2024 AB 2190 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01982	Emergency Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-01983	Linear Accelerator Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03505	Chalet Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03506	New Service Yard (Medical Gas Storage)	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-03507	Acute Care Services Replacement Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-06293	2nd Floor Pedestrian Walkway	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	BLD-06723	Switchgear Building	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11733	Huntington Hospital	BLD-02000	East Tower (3 story)	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-02001	West Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11733	Huntington Hospital	BLD-02002	La Vina Building	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-02003	Della Martin Center - Psychiatric B	OSHPD 5-Acute Psych Only	N/A								N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02004	Energy Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-02005	Chiller Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-02008	Cooling Towers	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-02010	Valentine Building - Structurally connected to BLD-02014	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02011	Wingate / Hahn Building	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit			3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11733	Huntington Hospital	BLD-02012	Hahn Building - Structurally connected to BLD-02011	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02013	Service Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02014	1938 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Replace			N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02015	1921 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02017	North Parking Structure - Structurally connected to BLD-02000	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11733	Huntington Hospital	BLD-02018	Electrical Switchgear Vault	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-03301	East Tower (7 story)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11733	Huntington Hospital	BLD-03302	East Tower Main Lobby	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-03303	New Boiler Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05497	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05498	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05796	West Tower Tunnel	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05955	South Campus Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05956	East Tower Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05957	ED Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05970	East Tower Pedestrian Tunnel	OSHPD 1-Tunnels	4								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-05990	Bulk Oxygen Storage	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-06058	Bulk Oxygen	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/31/2023	
19 - Los Angeles	11733	Huntington Hospital	BLD-07962	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11733	Huntington Hospital	BLD-07963	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11733	Huntington Hospital	BLD-07964	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11733	Huntington Hospital	BLD-07965	Pump House #1	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11733	Huntington Hospital	BLD-07966	Pump House #2	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02519	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02520	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/05/2022	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02521	Clinic Wing	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/05/2022	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-02522	MRI Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/05/2022	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-03509	Clinic - MRI Connector	OSHPD 1-In Service	3								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-06883	ED Expansion	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-06905	Canopy #1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-07295	MRI Addition	OSHPD 1-In Service	5s								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-07465	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-07466	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	BLD-07467	WT-02 Water Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05180	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05181	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05914	Canopy 01	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05915	Canopy 02	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-05916	Main Building - Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06157	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06158	Main Building - Tower Addition	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06159	ED Drop-Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06323	ED Walk-in Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-06324	ED Entry Vestibule	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-07442	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-07443	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-07594	Booster Pump Building	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	BLD-07595	WT-02 Water Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-01707	Centrex Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Open - Returned 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-02792	LAMC Hospital - Phase I	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-02793	Central Utility Plant - 1550 Edgemont	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/15/2023	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	BLD-07038	Pedestrian and Utility Passageway	OSHPD 1-Tunnels	N/A								4			Rpt: Open - Returned 12/15/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-01698	East MOB	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-02794	New Hospital Replacement Project	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-02795	New Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-05676	South Specialty Medical Office Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-06967	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/14/2023	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	BLD-06968	ER Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/14/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02037	South Hospital - Ancillary Wing	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 07/20/2023	Rpt: Open - Returned 12/13/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02038	South Hospital - Patient Tower	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 07/20/2023	Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02039	South Hospital - Elevator Tower	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 07/20/2023	Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-02040	South Hospital - Central Plant	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 07/20/2023	Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03086	Boiler House - Structurally connected to BLD-02040	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03276	Vermont Pavilion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-03277	Annex Connecting Corridor (North)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-05247	Annex Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-05248	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06482	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06483	Emergency Department Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06687	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06688	Electrical Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06689	Emergency Generator Enclosure #1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06690	Emergency Generator Enclosure #2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-06971	South Hospital - Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07036	Replacement Hospital Corridor #1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07037	Replacement Hospital Corridor #2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07051	Annex Connecting Corridor (Center)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07052	Annex Connecting Corridor (South)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07053	Vermont Pavilion Corridor #1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07054	Vermont Pavilion Corridor #2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07055	Vermont Pavilion Corridor #3	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07056	Stair #3	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07059	Water Tank Service Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07060	South Hospital - Generator Cage	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 07/27/2023	Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07062	South Hospital - Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Proposed Retrofit Acceptable 07/27/2023	Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07063	South Hospital - Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07159	Canopy #1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07160	Canopy #2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07161	Pet Scan Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/13/2023	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07446	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07447	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07448	WWT-02 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07449	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	BLD-07450	WT-02 Water Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00327	Medical Center Tower	OSHPD 1-In Service	3								3		Rpt: Review Completed 06/13/2023	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00328	Plant Services Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 06/13/2023	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00329	Nursing Tower II	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-00330	MRI Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 08/16/2022	Rpt: Open - Returned 11/17/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05847	Chiller / Generator Support Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05879	Service MSB Yard - Normal Power	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05984	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-05985	ED Patient Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06129	Ambulance/Tech Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06221	Canopy No. 2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06222	Canopy No. 1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-06452	Tank Farm	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07005	Decontamination Showers	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/17/2023	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07430	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07431	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07432	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	BLD-07433	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00941	Center Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 03/28/2023	Rpt: Open - Returned 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00942	North Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/28/2023	Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00943	South Tower	OSHPD 1-In Service	3								3		Rpt: Review Completed 08/16/2022	Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-00944	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-03275	West Wing Tower	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-03539	Generator Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06843	24 Hour Outpatient Pharmacy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06844	Covered Walkway #1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06845	West Wing Tower Bridge	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06946	Covered Walkway #2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06947	Covered Walkway #3	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06948	Covered Walkway #4	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-06949	Covered Walkway #5	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07001	Canopy	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07267	MRI 2	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07646	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07647	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07648	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07649	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	BLD-07650	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-03163	Main Hospital	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/28/2023	Rpt: In Review 12/20/2023	
19 - Los Angeles	16483	Keck Hospital of USC	BLD-06993	Acute Care Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/20/2023	
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07176	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07177	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07231	Infill Building	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07364	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07396	Wastewater Tank WWT-01	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07397	Wastewater Tank WWT-02	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-07398	Water Tank WT-01	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	16483	Keck Hospital of USC	BLD-08003	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	16483	Keck Hospital of USC	BLD-08004	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00727	Original Building - Building I	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00728	Southeast Addition - Building III	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-00729	Power Service Station - Building IV	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-03027	Addition - Building II	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-03066	Storage / Maintenance - Building V	OSHPD 1-In Service	2					7/1/2017 Com Acc Retrofit			3		Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	BLD-05829	Entrance Canopy	OSHPD 1-In Service	2					7/1/2017 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-01722	Building I (Acute Care Facility)	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-05840	Building II (Acute Care Support Services)	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	BLD-05841	Building III (Acute Care Facility)	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03708	Main Hospital	OSHPD 1-In Service	2					3/31/2013 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03709	Main Hospital Addition	OSHPD 1-In Service	2					3/31/2013 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-03710	ICU Addition	OSHPD 1-In Service	2					3/31/2013 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	BLD-06115	Emergency Generator #2 Yard	OSHPD 1-Under Construction	N/A								4s				
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-00909	Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/08/2024	Rpt: Review Completed 03/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-00910	Emergency Room	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 03/08/2024	
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-06652	Liquid Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12787	Kindred Hospital Paramount	BLD-06653	Emergency Generator	OSHPD 1-Under Construction	N/A								4s				
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00658	Original Building	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00659	South Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00660	North Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-00661	Laboratory Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-06614	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	11547	Kindred Hospital South Bay	BLD-06615	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/18/2024	Rpt: Review Completed 03/18/2024	
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-00055	Hospital and Medical Office	OSHPD 1-In Service	2					11/1/2016 Risk Bsd Retrofit			3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-00056	Boiler & Emergency Generator	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-03826	Main Hospital - West	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-06178	Oxygen Storage Yard	OSHPD 1-Equipment Yard	N/A								3		Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	13225	L.A. Downtown Medical Center	BLD-07618	Pumps & Main Electrical Service	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01759	Main Hospital Building - Patient Tower	OSHPD 1-In Service	2								2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01760	Main Hospital Building - North Wing	OSHPD 1-In Service	2								2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01761	Main Hospital Building - South Wing	OSHPD 1-In Service	2					1/1/2017 Com Acc Retrofit			2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01762	Main Hospital Building - Cafeteria	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01763	Main Hospital Building - FCLC	OSHPD 1-In Service	2								2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01764	PCDC Building	OSHPD 1-In Service	3								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01765	Central Plant Building	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01766	Central Plant West Expansion	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-01767	Communications Building 2 East	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05316	Surgery / Emergency	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05317	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05318	Tunnel	OSHPD 1-Tunnels	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05884	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-05885	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06025	Surgery / Emergency Lower Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06026	Surgery / Emergency Upper Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06029	Surgery / Emergency Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06498	12KV Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/26/2024	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06876	Interim Helipad	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06950	Inpatient Tower	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-06954	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07072	Temporary Loading Dock Canopy	OSHPD 1-In Service	5								4			Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07164	Chiller Building	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07217	12kV General Access Power (GAP) Switchgear Building	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07519	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07520	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07521	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	BLD-07785	Utility Bridge	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00337	Main Hospital Building	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00338	Central Plant	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-00339	Cooling Tower	OSHPD 1-In Service	4s								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-03620	Emergency Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-03621	Tuberculosis Isolation Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-05912	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06033	Canopy 05B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06034	Canopy 04B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06035	Canopy 04C	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06168	Emergency Generator	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06684	Emergency Generator Enclosure #1	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06685	Emergency Generator Enclosure #2	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-06686	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/21/2023	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	BLD-07892	Cooling Tower and Equipment Yard	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02502	Bldg 100 Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02503	Bldg 101/102 Main Hosp Expansion	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02504	Outpatient Entrance Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02506	JPI Bldg South Wing	OSHPD 1-In Service	3								5				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02507	JPI Bldg North Wing	OSHPD 1-In Service	3								5				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02508	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02509	Fire Pump Building	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02511	Safety Police Building	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02516	JPI Bldg West Wing	OSHPD 1-In Service	3								5				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02924	JPI Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-02925	JPI Drop-off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-05943	JPI Tunnel	OSHPD 1-Tunnels	N/A								5				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06145	NPC-5 Domestic Water Storage Tank (WT-01)	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06146	NPC-5 Sewer Storage Tank (WWT-01)	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06147	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	BLD-06643	JPI Bldg Loading Dock	OSHPD 1-In Service	5								5				Earthquake Resilient

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-00654	Original Building & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-00655	Dietary Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-03779	1st and 2nd Story Addition	OSHPD 1-In Service	2					1/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	BLD-06645	Oxygen Farm	OSHPD 1-Proposed	N/A								4s				
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02749	New Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02750	New Diagnostic and Treatment	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	11810	Los Angeles General Medical Center	BLD-02751	Inpatient Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02047	Medical Records & Laundry (Hospital Service Building (HSB))	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02048	Central Plant Phase I	OSHPD 1-In Service	5	Withdrawn							4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02049	Central Plant Phase II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/23/2015	Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02052	Pediatric Acute Care (Main Lobby and Admitting (MLA))	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02053	Trauma Center (Hospital (IPT))	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-02054	Hawkins Building (Augustus F Hawkins Building)	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05261	Central Plant 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05262	Central Plant 4	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05263	Pedestrian Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05264	Ancillary Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05412	Central Plant Phase 1 Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05413	Hawkins Building Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05416	Trauma Center Connecting Tunnel	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05821	Bulk Medical Gas Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-05859	Main Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-07993	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-07994	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	BLD-07995	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11843	Memorial Hospital of Gardena	BLD-01778	Hospital	OSHPD 1-In Service	2	Withdrawn				9/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01789	2A-2C- Central Plant & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01791	1E - Center for Health Education - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01792	03 - Memorial West - Nursing Unit	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01793	4A 4B- Memorial West - Rehab Unit	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01794	1B - Old Pathology - Structurally connected to BLD-03123	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01795	5 - X-Ray Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01796	6A-6C - Surgery & Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01797	1G -Doctor's Dining & Administration - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01798	1C - Original Coffee Shop - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01799	7A-7B - Outpatient Surgery	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/20/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-01800	8 - Cancer Prevention Center	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-02637	10 - Emergency Power Area	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-03123	1A -1K Main Tower & Additions	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-03524	9 - ER Addition & Remodel	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-07096	ER Addition Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08020	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08021	Pump House	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08022	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08023	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08024	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	BLD-08038	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03899	101- Miller's Children's Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03900	102- Miller's Children's Hospital Entry	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Awaiting review 10/11/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03901	103- Miller Children's Clerical Addition	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03905	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-03906	4 Story Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-05883	Oxygen Farm	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-07082	Central Plant Pump Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-07768	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Proposed Retrofit Acceptable 03/19/2026	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08025	WT-01 Water Tanks	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08026	Pump House #1	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08027	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08028	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08029	Pump House #2	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	BLD-08030	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11847	Mission Community Hospital	BLD-00352	Building A - Tower	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11847	Mission Community Hospital	BLD-00353	Building B - Ancillary Building	OSHPD 1-In Service	2					Denied			2		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11847	Mission Community Hospital	BLD-00354	Building C - Emergency Department B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 05/06/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11847	Mission Community Hospital	BLD-03891	Building D - South Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 05/06/2024	
19 - Los Angeles	11847	Mission Community Hospital	BLD-05536	Building E - Psychiatric Unit	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11847	Mission Community Hospital	BLD-05537	Building F - Psychiatric Administration	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11847	Mission Community Hospital	BLD-05538	Building G - Lobby Clinical Lab	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11847	Mission Community Hospital	BLD-05539	Building H - Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11874	Monrovia Memorial Hospital	BLD-00377	Main Building	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit	6/1/2032 AB 869		3		Rpt: Review Completed 12/14/2022	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12878	Monterey Park Hospital	BLD-00946	Original Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12878	Monterey Park Hospital	BLD-00947	Radiology Basement Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00388	Farr Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00389	D&T Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00390	Support Services Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00391	IFL Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00392	Therapy Pool Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00393	Clinical Laboratory Bldg Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00394	F Tower - Main Tower	OSHPD 1-In Service	2			01/01/2015					2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00395	G Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-00396	Cancer Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03092	F Tower - Elevator Tower - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A				01/01/2015				N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03094	Linear Accelerator	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03095	Emergency Room Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03096	MRI Addition - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03097	Outpatient Registration Building - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03135	Clinical Laboratory Building (Original) - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A				Withdrawn				N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03136	Quiet/Dining	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03487	Service Elevator Tower	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-03645	Electrical Equipment Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-05464	Clinical Laboratory Building (D&T Addition)	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-06078	Gift Shop	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-06079	Admitting	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-07027	IFL Bridge	OSHPD 1-In Service	3s								2		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11906	Northridge Hospital Medical Center	BLD-07028	Addition #1	OSHPD 1-In Service	2s								2s		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00397	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Open - Returned 12/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00398	Service Enclosure - East Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00399	Administration Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Open - Returned 12/19/2025	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-00400	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02690	Service Enclosure - West Side	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Open - Returned 12/19/2025	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02691	Walk In Freezer	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02692	Boiler Room	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-02693	Engineering Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03759	1956 Storage Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Open - Returned 12/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03760	1983 Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/08/2025	
19 - Los Angeles	11910	Norwalk Community Hospital	BLD-03800	Original Building - South Wing - Structurally connected to BLD-00397	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-00368	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11863	Olympia Medical Center	BLD-00369	East Wing & Additions	OSHPD 1-In Service	2					1/1/2020 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	BLD-00371	Pavilion / Addition	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	BLD-06983	West Wing	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06984	Bridge	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06985	Porte Cochere	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-06986	Generator Enclosure	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	11863	Olympia Medical Center	BLD-07048	Utility Enclosure	OSHPD 5-Under Construction	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00017	Building 1	OSHPD 1-In Service	1	Withdrawn				7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit		2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00018	Building 2	OSHPD 1-In Service	1	Withdrawn				7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit		2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-00019	Building 3	OSHPD 1-In Service	1	Withdrawn				7/1/2019 Com Acc Retrofit	1/1/2025 AB 2404 Retrofit		2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-06541	Cafeteria	OSHPD 1-In Service	4D								2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	BLD-06542	Central Plant	OSHPD 1-In Service	4D								2	1/1/2024	Rpt: Review Completed 12/28/2023	Rpt: Not Submitted	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-05182	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-06852	Employee Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07329	West Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07330	East Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07331	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	18141	Palmdale Regional Medical Center	BLD-07336	Outpatient Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02203	Original Nursing Tower	OSHPD 1-In Service	2	Denied				6/30/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02204	Original Surgery and Lab Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02206	Pathology Addition - Structurally connected to BLD-02203	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02207	Scanner Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02208	ER/Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02209	ICU/CCU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02210	Respiration Therapy Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02211	Cath Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02212	36 Bed Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02213	Building A, Mech. Equipment Bldg.	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02214	Building B	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02215	Building C	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02216	Radiology Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-02217	ER Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-03221	Generator #2 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-06135	Original Mechanical Area	OSHPD 1-In Service	4D					7/1/2019 Com Acc Replace			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-06325	ICU / ER Connection Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 07/08/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-06735	New Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 07/08/2024	
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07968	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07969	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07970	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07971	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07972	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12235	PIH Health Downey Hospital	BLD-07973	Pump House	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01993	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01994	ICU / CCU Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01995	Mechanical Plant	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01996	MRI Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01997	1927 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01998	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-01999	Linear Accelerator Addition - Structurally connected to BLD-01998	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-03322	Radiation Oncology Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06917	Tunnel Connecting BLD-01993 to BLD-06918	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-06918	1953 Bldg. (Low-Height Portion)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-07809	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-07810	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-07811	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	BLD-07967	Pump House	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01156	Original Building Patient Tower	OSHPD 1-In Service	2					1/1/2016 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01158	Long Term Care	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01160	Power Plant	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-01162	1992 Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03151	Health Center (North Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03152	Health Center (East Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03272	ED Shannon Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03273	Plaza Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03666	1968 Generator Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 06/04/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-03715	1992 Pavilion Bridge	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 06/04/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-05468	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06460	Link Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06465	Electrical/Mechanical/Compactor Segment	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06466	Communication Room & Utility Tunnel Segment	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06467	Cooling Tower Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-06473	Pump Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/04/2024	
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-07996	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-07997	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-07998	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-07999	Pump House #1	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11968	PIH Health Whittier Hospital	BLD-08000	Pump House #2	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00411	1972 Building - ICU/Emergency	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00412	D&T Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00413	Women's Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00414	1913 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00415	1928 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00416	1953 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00417	1961 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00418	1963 Building - Cafeteria	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-00419	1963 Building - Lab/Peds - Structurally connected to BLD-00411	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-02838	Building 01A	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-02839	Building 01B Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03468	Pitzer Bldg Admin/Marketing/Acct	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03850	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-03877	1961 Dining Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05176	1958 Lobby Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05202	1958 Building (Emergency Wing)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/31/2019 Com Acc Replace			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05669	2013 Vestibule	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05670	2013 Low Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	BLD-05671	2013 High Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00170	Patient Tower	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					12/27/2019 Com Acc Retrofit	12/31/2023 AB 2190 Rebuild		N/A				
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00171	Ancillary Wing	OSHPD 1-In Service	4D					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 01/21/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00172	Service Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00173	Cardiology Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 01/21/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00174	Admitting/Emergency	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 01/21/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00175	Women's Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 01/21/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-00176	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/21/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-03423	Patient Wing	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-03424	Interim Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06372	Hospital Main Lobby Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06398	Emergency Cat Lab	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 01/15/2026	Rpt: In Review 12/28/2023	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06691	D&T Expansion	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	BLD-06692	D&T Canopy	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01984	Main Building	OSHPD 1-In Service	3s								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01985	ICU/CCU Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01986	Cardiac Heart Center	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01987	Central Plant Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01988	Utility Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01989	Chapel Building	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-01991	New Equipment Shelter	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-02714	Old Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-02715	New Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03628	South Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03636	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03637	Sub-Acute Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-03638	Control Room	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05337	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05338	Transformer Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/28/2023	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	BLD-05339	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01215	Central Wing North	OSHPD 1-In Service	2								3R		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01216	West Wing & Entrance Canopy	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			3R		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01217	East Wing	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01218	Laboratory Addition	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01219	Conference Center	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-01220	ED Entry Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03147	Central Wing Tower	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			3R		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03148	Central Wing South	OSHPD 1-In Service	2								3R		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03149	Central Wing Stair Tower	OSHPD 1-In Service	2								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-03150	West Wing Elevator Tower	OSHPD 1-In Service	2								3R		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-05177	Drop-Off Canopy	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-06496	Emergency Generator Enclosure	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	BLD-06841	West Wing Stair Tower	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01727	Original Hospital	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01731	11 Technology Center & Lab	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01733	Emergency Generator	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01734	Liquid Oxygen Storage Tanks and Manifolds	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01735	West Tower Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01737	Radiation Therapy Building Walkway	OSHPD 1-In Service	5s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01738	Dining Room Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01739	Generator Building	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-01741	ER/Cardiac Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-02625	Administrative Wing	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03159	South Tower Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03160	Earl Street Loading Dock Improvement	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03162	South Tower Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03340	Hazardous Material Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03537	11 Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03716	Dietary Loading Dock and Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03717	Entrance Canopy	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-03718	Radiation Therapy Building	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06195	Med Gas Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06929	North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06930	East Canopy - Low	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06931	East Canopy - High	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-06932	South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-07932	Pedestrian Canopy	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	BLD-07933	Patient Drop-Off Canopy	OSHPD 1-Proposed	5s								4s				
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01185	Robertson Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01186	Robertson Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01187	Robertson Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01188	East Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01190	South Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01191	ER/CCU Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01192	Laundry/Central Plant Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01193	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01194	P & E Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01195	MRI Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-01197	Parking Structure 1A	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-03515	Northeast Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05355	Connector Corridor - 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05356	Connector Corridor - 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05357	Connector Corridor - 3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05358	Connector Corridor - 4	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05359	Connector Corridor - 5	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05360	Northeast Building Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05361	Central Plant Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05362	East Building Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05363	Cooling Towers	OSHPD 1-Not a Building Structure	N/A								2		Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-05549	South Building Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-06412	Emergency Department	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-06575	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-07094	Urgent Care	OSHPD 3 - Local-Proposed	N/A								N/A				
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-07296	Water Tank Pump House	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	BLD-07657	Patricia and Roy Disney Family Cancer Center	OSHPD 3 - Local-Proposed	N/A								N/A				
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	BLD-02895	Ronald Reagan UCLA Medical Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	BLD-02926	Emergency Services Building	OSHPD 1-In Service	5s								1		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12006	Saint John's Health Center	BLD-03700	North Pavilion Inpatient Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-03703	New Central Plant	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-03704	Keck Center Diagnostic & Treatment	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-05271	Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-05987	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-05988	Flue Building	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12006	Saint John's Health Center	BLD-07816	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12006	Saint John's Health Center	BLD-07817	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12006	Saint John's Health Center	BLD-07818	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12006	Saint John's Health Center	BLD-07819	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12006	Saint John's Health Center	BLD-08086	Technology Dock and Connector	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12006	Saint John's Health Center	BLD-08087	ER Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00166	Main Hospital	OSHPD 1-In Service	2								3R		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00167	CT Scan Addition	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023	
19 - Los Angeles	13084	San Dimas Community Hospital	BLD-00168	Boiler Room Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/11/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00662	Pavilion Building	OSHPD 1-In Service	2	Withdrawn			Withdrawn	1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00663	Cooling Tower (Chiller Room)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00664	Radiology and Surgery Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00665	Surgery Addition - Structurally connected to BLD-00664	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00666	Emergency Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00667	CCU Building	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	BLD-00668	Patient Tower	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01225	Merle Norman Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 03/15/2022	Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01230	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-01231	New Southwest Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02774	New Central Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02775	New North Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-02776	New Orthopedic Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	BLD-06557	Loading Dock Annex Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01232	01 Orig Bldg Complex & 02 Addition	OSHPD 1-In Service	2					1/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01233	Addition Building Complex - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01234	Burn Center Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01235	1961 Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01236	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01237	Laboratory Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01238	ER Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01239	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	12047	Sherman Oaks Hospital	BLD-01240	Chiller Room - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00355	Tower	OSHPD 1-In Service	1	Withdrawn				1/1/2019 Fin Hdsp Retrofit	1/1/2025 AB 2190 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 07/27/2026	
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00356	Pavilion	OSHPD 1-In Service	2	Withdrawn				7/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 07/27/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-00357	Outpatient Building & Additions	OSHPD 1-In Service	2	Withdrawn				1/1/2019 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 07/27/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-06640	Ambulance Canopy	OSHPD 1-Under Construction	5s								4s				
19 - Los Angeles	11848	Southern California Hospital At Culver City	BLD-06641	ED Drop-off Canopy	OSHPD 1-Under Construction	5s								4s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11718	Southern California Hospital at Hollywood	BLD-01976	Original Building	OSHPD 1-In Service	2					3/31/2013 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/23/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01177	Family Life Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01178	Health Services Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01179	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-01180	New Hospital Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/18/2023	
19 - Los Angeles	12004	St. Francis Medical Center	BLD-05791	Psychiatric Care Unit	OSHPD 5-Acute Psych / SNF only	N/A								N/A				
19 - Los Angeles	12004	St. Francis Medical Center	BLD-06904	Generator Yard	OSHPD 5-Under Construction	N/A								N/A				
19 - Los Angeles	12004	St. Francis Medical Center	BLD-08120	Thermal Storage Vault	OSHPD 1-Tanks	N/A								N/A				
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01205	Bauer Wing	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01206	MRI Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01207	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Remove GAC			N/A				
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01208	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01209	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Remove GAC			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12012	St. Mary Medical Center	BLD-01210	Emergency / Generator Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/25/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02218	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02219	Original Central Plant	OSHPD 1-In Service	2								3R		Rpt: Proposed Retrofit Acceptable 09/21/2022	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02220	East Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02221	Lobby/Cath Lab Addition	OSHPD 1-In Service	3								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02222	Surgery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02223	Doctors' Dining/Medical Records	OSHPD 1-In Service	3								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02224	Admitting/Business	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02225	Linear Accelerator	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02226	Central Plant Addition	OSHPD 1-In Service	4								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02227	North Wing	OSHPD 1-In Service	3								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02228	Elevator Core (North Wing)	OSHPD 1-In Service	4								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02229	MRI Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02230	Ambulatory Care	OSHPD 1-In Service	3								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02231	Gallery	OSHPD 1-In Service	3								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02232	Central Plant Expansion - A	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02233	Central Plant Expansion - B	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02234	Central Plant-South Wing Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-02235	East Wing Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-03478	New Hospital Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-03848	MRI Addition Corridor	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05421	Bulk Medical Gas System	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05668	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05705	Surgery Addition West	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-05733	Emergency Generators and Switchgear	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06132	Central Plant Elevator and Stair	OSHPD 1-In Service	5								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06133	Utility Tunnel	OSHPD 1-Tunnels	N/A								3		Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06148	Central Plant Walkway Canopy	OSHPD 1-In Service	3								4			Rpt: In Review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06149	Lundquist North Wing Connector	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06150	Lundquist Tower Connector to Center Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06211	Lundquist Connector Exit Corridor	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-06295	Original Service Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 01/08/2024	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07663	Pump House	OSHPD 1-Proposed	5s								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07664	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07665	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07666	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07667	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07668	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12249	Torrance Memorial Medical Center	BLD-07795	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12831	UCI Health-Lakewood	BLD-00924	Main Hospital	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 02/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12831	UCI Health-Lakewood	BLD-00925	Hospital Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 02/28/2024	
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-02181	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-02182	Purchasing / Central Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-03178	ED / ICU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	12182	UCLA West Valley Medical Center	BLD-03179	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00358	Main Hospital	OSHPD 1-In Service	2					1/1/2018 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00359	East Wing	OSHPD 1-In Service	4D					1/1/2019 Com Acc Rebuild			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00360	Utility Building / Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00362	West Wing	OSHPD 1-In Service	2					1/1/2019 Com Acc Rebuild			2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00363	Main-North End - Structurally connected to BLD-00358	OSHPD 1-Not an Independent Building	N/A								N/A				
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00364	Pavilion East & West	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Com Acc Replace			N/A				
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00365	Hoefflin Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00366	Surgical Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-00367	Patient Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-03711	Electrical Equipment Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05461	North Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05514	Tower Lobby	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05634	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05635	Switchgear Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05636	Switchgear Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-05848	Berger Tower Patient Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/31/2023	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-07349	Electrical Room	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Review Completed 04/26/2024	
19 - Los Angeles	11858	USC Arcadia Hospital	BLD-08074	North Tower Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-00317	Cancer Research Institute (Ezralow Tower)	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-03689	Topping Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/07/2023	
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07983	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07984	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07985	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07986	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07987	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07988	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	BLD-07989	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01025	Main Building - North Tower	OSHPD 1-In Service	2					4/1/2016 Risk Bsd Retrofit			3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01026	Main Building - South Tower	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			3R		Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/07/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01027	West Addition	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-01028	East Addition	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/07/2023	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	BLD-07073	Medical Office Building	OSHPD 3 - Local-Proposed	N/A								N/A				
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02169	Base Building (Main Hospital)	OSHPD 1-In Service	2	Denied				1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02170	Service Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02171	Administrative Expansion	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02172	Ancillary Inpatient East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02174	Elevator Lobby East	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02175	Elevator Lobby West	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02638	Ancillary Inpatient West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-02789	Inpatient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-03124	Administrative Expansion (North)	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-05197	South Tower	OSHPD 1-In Service	2	Denied				5/1/2014 Com Acc Retrofit			4D-L1			Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07205	Stair Tower #1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07206	Stair Tower #2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07209	Low Roof Area	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07210	Mechanical Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12140	Valley Presbyterian Hospital	BLD-07356	Central Plant	OSHPD 1-Under Construction	5s								5s				
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	BLD-01710	Building I	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	BLD-03469	Building II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	BLD-03470	Building III	OSHPD 1-In Service	2					1/1/2016 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	BLD-06112	Soiled Linen Storage	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	BLD-06113	Bio-Hazard Storage	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
19 - Los Angeles	12180	West Covina Medical Center	BLD-02176	Hospital Building / Additions	OSHPD 1-In Service	2					12/31/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12180	West Covina Medical Center	BLD-03430	Medical Office Building	OSHPD 1-In Service	1								1		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12180	West Covina Medical Center	BLD-06612	Skilled Nursing	OSHPD 1R-Skilled Nursing Only	N/A								N/A				
19 - Los Angeles	12180	West Covina Medical Center	BLD-06943	HVAC Tower and Enclosure	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12180	West Covina Medical Center	BLD-07083	Psych Addition	OSHPD 5-Proposed	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions						CO/CF **	HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status						
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02196	Original Building	OSHPD 1-In Service	2	Withdrawn				1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02197	Addition 1	OSHPD 1-In Service	2	Withdrawn				1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02198	Addition 2	OSHPD 1-In Service	2	Withdrawn				Denied			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02199	Addition 3	OSHPD 1-In Service	2	Withdrawn				1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02200	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02201	OB Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-02202	Pediatrics Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
19 - Los Angeles	12201	Whittier Hospital Medical Center	BLD-03422	ER Addition - West Portion	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10075	HealthBridge Central Valley Children's Center	BLD-06945	Children's Hospital	OSHPD 1-Proposed	5s								5s				
20 - Madera	10257	Madera Community Hospital	BLD-00436	Main & Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
20 - Madera	10257	Madera Community Hospital	BLD-00437	OB Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-00438	Outpatient Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-00439	ICU/ER Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-06092	Utility Canopy 1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-06093	Utility Canopy 2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-06094	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
20 - Madera	10257	Madera Community Hospital	BLD-06322	CT Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
20 - Madera	17124	Valley Children's Hospital	BLD-02518	Hospital (G Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-02650	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05429	Hospital (A Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
20 - Madera	17124	Valley Children's Hospital	BLD-05430	Hospital (B Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05431	Hospital (C Porte-Cochere)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05432	Hospital (D Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05433	Hospital (E Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05434	Hospital (F Canopy)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05435	Hospital (H Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05436	Hospital (I Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05437	Hospital (J Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05438	Hospital (K Wing)	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05439	West Expansion - Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05440	West Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-05441	Medical Waste Building	OSHPD 1-In Service	5								5				Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	BLD-06697	On-Site Well	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-06698	Sewer Lift Station	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-06699	Waste Water Plant	OSHPD 1-Equipment Yard	N/A								5				
20 - Madera	17124	Valley Children's Hospital	BLD-07119	Giraffe Photovoltaic Array	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07120	Switchgear Yard	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07121	Microgrid	OSHPD 1-Under Construction	N/A								4s				
20 - Madera	17124	Valley Children's Hospital	BLD-07122	Fuel Cell Yard	OSHPD 1-Under Construction	N/A								4s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00441	General Services Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00442	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/14/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00443	Medical Office Building 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/22/2023	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00444	Mechanical Equipment Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 04/15/2025	Rpt: Review Completed 12/05/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00445	Support Services Building	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-00446	Generator Switchgear Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-03283	Doctor's Sleep Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/14/2023	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-03598	Medical Records Building Addition - Structurally connected to BLD-00443	OSHPD 1-Not an Independent Building	N/A								N/A				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05615	Emergency Department	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05616	Oxygen Storage	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-05617	Mechanical Building - CUP	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-06848	Electrical Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 12/05/2023	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07898	Hospital East Tower	OSHPD 1-Proposed	5s								5s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07899	Bulk Oxygen Yard	OSHPD 1-Proposed	N/A								5s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07901	Entry Pavilion	OSHPD 1-Proposed	5s								5s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07902	Generator Yard – North	OSHPD 1-Proposed	N/A								5s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07903	MOB Connector	OSHPD 1-Proposed	5s								5s				
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-07944	Entry Canopy	OSHPD 1-In Service	2								2		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	BLD-08018	Lobby	OSHPD 1-In Service	5								2		Rpt: Not Submitted	Rpt: Not Submitted	
21 - Marin	10261	Kentfield Hospital	BLD-00440	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	BLD-00447	01 - Original Building & Additions (Redwood Pavilion)	OSHPD 1-In Service	2	Denied	Denied			Denied			2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	BLD-00448	02 - Additions & Alterations	OSHPD 1-In Service	2		Denied						2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	BLD-00449	03 - Cobalt Bomb Wing	OSHPD 1-In Service	2	Denied	Denied			1/1/2015 Fin Hdsp Rebuild			2		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	BLD-00450	Laboratory Addition & Remodel - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-00451	04 - Medical Health Center (Mental Health Center) (Cypress Pavilion)	OSHPD 1R-Acute Psych Only	N/A	Denied	Denied			7/1/2019 Com Acc Rebuild			N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-00452	05 - Elevated Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied	Denied			7/1/2019 Com Acc Rebuild			N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-00453	06 - West Wing (Cedar Pavilion)	OSHPD 1-In Service	3		Denied						2		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Open - Returned 09/17/2025	
21 - Marin	10273	Marinhealth Medical Center	BLD-00455	1A - Additions & Alterations - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-00456	04A - Medical Records - Structurally connected to BLD-00451	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-03054	1C - East Canopy - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A		Withdrawn						N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-03056	Ambulance Entry Canopy	OSHPD 1-In Service	3		Denied						2		Rpt: Already Approved 12/24/2025	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
21 - Marin	10273	Marinhealth Medical Center	BLD-03526	05A - Elevator	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied	Denied			7/1/2019 Com Acc Replace			N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-06250	Hospital Replacement Building (Oak Pavilion)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 09/17/2025	
21 - Marin	10273	Marinhealth Medical Center	BLD-06251	Hospital Replacement Building - Loading Dock	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
21 - Marin	10273	Marinhealth Medical Center	BLD-06252	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
21 - Marin	10273	Marinhealth Medical Center	BLD-07233	Behavioral Health Emergency Generator	OSHPD 5-Under Construction	N/A								N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-07619	Med Gas Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
21 - Marin	10273	Marinhealth Medical Center	BLD-07630	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-07631	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-07632	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
21 - Marin	10273	Marinhealth Medical Center	BLD-07640	MV Disc-MD2	OSHPD 1-Under Construction	N/A								5s				
21 - Marin	10273	Marinhealth Medical Center	BLD-07670	Dining Addition	OSHPD 1-Proposed	5s								5s				
21 - Marin	10273	Marinhealth Medical Center	BLD-07671	Connecting Canopy	OSHPD 1-Proposed	5s								4s				
21 - Marin	10273	Marinhealth Medical Center	BLD-07672	Lobby / Main Entrance	OSHPD 1-Proposed	5s								4s				
21 - Marin	10273	Marinhealth Medical Center	BLD-07673	Drop Off Canopy	OSHPD 1-Proposed	5s								4s				
21 - Marin	10273	Marinhealth Medical Center	BLD-07674	Gift Shop	OSHPD 1-Proposed	5s								4s				
21 - Marin	17672	Novato Community Hospital	BLD-00457	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
21 - Marin	17672	Novato Community Hospital	BLD-07325	New Generator Yard	OSHPD 1-Under Construction	N/A								4s				
21 - Marin	17672	Novato Community Hospital	BLD-07326	Mechanical Yard	OSHPD 1-Under Construction	N/A								4s				
21 - Marin	17672	Novato Community Hospital	BLD-08031	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
21 - Marin	17672	Novato Community Hospital	BLD-08032	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-00458	Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-03808	Skilled Nursing Wing	OSHPD 2-Skilled Nursing Only	N/A								N/A				
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-07703	John C. Fremont Replacement Hospital	OSHPD 1-Proposed	5s								5s				
22 - Mariposa	10287	John C. Fremont Healthcare District	BLD-07704	Drop-Off Canopy	OSHPD 1-Proposed	5s								5s				
23 - Mendocino	18198	Adventist Health Howard Memorial	BLD-05319	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/05/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
23 - Mendocino	18198	Adventist Health Howard Memorial	BLD-05320	Mechanical Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/05/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00469	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/20/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00470	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/20/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00471	Emergency Addition - West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-00472	X-Ray File Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-02787	Respiratory Neurophysiology Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 12/20/2023	Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-02788	Emergency Generator Shelter	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-03473	Emergency Addition - East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-06731	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/18/2023	
23 - Mendocino	10301	Adventist Health Mendocino Coast	BLD-06732	Medical Air System Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00305	Main Building, North Wing	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00306	OB Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-00307	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-02959	Main Building, Central Wing	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-02960	Main Building, Ancillary	OSHPD 1-In Service	4								3		Rpt: Awaiting review 12/19/2019	Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-05704	Emergency Department Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06369	Support Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06370	Electrical Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06877	OB Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06878	Main Entry Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06879	Entry Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/04/2023	
23 - Mendocino	14560	Adventist Health Ukiah Valley	BLD-06955	East Patient Wing Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/04/2023	
24 - Merced	10309	Memorial Hospital Los Banos	BLD-00029	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	BLD-00030	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	BLD-07016	Mechanical Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
24 - Merced	10315	Mercy Medical Center	BLD-03870	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-03871	Power Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
24 - Merced	10315	Mercy Medical Center	BLD-05610	Radioactive Waste and Pathology Holding	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-05611	Equipment Charging	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-05612	ER Entrance Bridge	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
24 - Merced	10315	Mercy Medical Center	BLD-07020	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 08/20/2024	
25 - Modoc	18231	Modoc Medical Center	BLD-06279	Hospital - Building 100	OSHPD 1-In Service	5								5				Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	BLD-06288	Entrance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	BLD-06784	Warnerview Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-06895	Patient Room Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	BLD-06896	Skilled Nursing Pedestrian Walkway	OSHPD 2-Skilled Nursing Only	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-06897	Skilled Nursing Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-06898	Skilled Nursing Entrance Canopy	OSHPD 2-Skilled Nursing Only	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-07585	WWT-01 Waster Water Tank	OSHPD 1-Tanks	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-07586	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-07587	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
25 - Modoc	18231	Modoc Medical Center	BLD-07588	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01621	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01622	Pump House Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01623	Heating and Storage Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01624	Generator Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01625	South Wing Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
25 - Modoc	10321	Surprise Valley Community Hospital	BLD-01626	Walk-in Box	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/21/2023	
26 - Mono	14304	Mammoth Hospital	BLD-00267	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
26 - Mono	14304	Mammoth Hospital	BLD-03697	New Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
26 - Mono	14304	Mammoth Hospital	BLD-03698	New Wing Connecting Corridor - North	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
26 - Mono	14304	Mammoth Hospital	BLD-05561	New Wing Connecting Corridor - South	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
26 - Mono	14304	Mammoth Hospital	BLD-06859	North Wing	OSHPD 1-Under Construction	5s								5s				
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01629	A Phase I - 1960 Wing	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Awaiting review 12/31/2023	Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01630	B Phase II - 1968 Wing - Structurally connected to BLD-01629	OSHPD 1-Not an Independent Building	N/A								N/A				
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01631	C 1978 Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-01633	E 1998 Cancer Center Addition	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-03714	Parking Structure	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05554	G Utility Service Building	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05555	H Cardiac EP Lab	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05556	J South Pavilion	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-05557	K Forest Pavilion	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-07228	Electrical Bunker	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	BLD-07300	Switchgear Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Proposed Retrofit Acceptable 12/11/2025	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-01634	Main Hospital	OSHPD 1-In Service	4D	Withdrawn					7/1/2030 AB 869		2	1/1/2030	Rpt: Review Completed 11/16/2023	Rpt: Review Completed 12/28/2023	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03265	New Porte Cochere	OSHPD 1-In Service	5						7/1/2030 AB 869		4			Rpt: Review Completed 12/28/2023	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03266	New Hospital	OSHPD 1-In Service	5						7/1/2030 AB 869		4			Rpt: Review Completed 12/28/2023	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-03328	Bottle Building	OSHPD 1-In Service	5						7/1/2030 AB 869		4			Rpt: Review Completed 12/28/2023	
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08039	Electrical Yard Canopy	OSHPD 1-Proposed	5s								4s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08040	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08103	Pump House	OSHPD 1-Proposed	5s								5s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08104	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08105	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10338	George L. Mee Memorial Hospital	BLD-08106	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	17353	Natividad Medical Center	BLD-02542	Extended Care Services (Bldg 100)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-02544	Food Service / Central Plant (Bldg 580) 580A	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-02545	Acute Care (Building 500)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
27 - Monterey	17353	Natividad Medical Center	BLD-03827	Material Management (Bldg 600)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-03828	Inpatient Mental Health (Bldg 940)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 02/27/2026	Rpt: Not Submitted	
27 - Monterey	17353	Natividad Medical Center	BLD-03829	Generator Building (Bldg 980)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-03862	Kitchen & Associated Fac (Bldg 600)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	17353	Natividad Medical Center	BLD-03864	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-03865	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-03867	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-03868	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-05986	Pediatric / Surgery (BLD 580) 580B	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
27 - Monterey	17353	Natividad Medical Center	BLD-07738	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	17353	Natividad Medical Center	BLD-07739	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	17353	Natividad Medical Center	BLD-07915	Storage Yard (Bldg 600)	OSHPD 1-Proposed	5s								4s				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01635	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01636	36 Bed Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01638	Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01639	Electrical and Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01640	Central Sterile Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01641	Cardiac Center North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01642	Cardiac Center South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01643	CCU Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/09/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01644	Outpatient Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/05/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01645	Cath Lab Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 05/22/2023	Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01646	Cath Lab Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01647	Cath Lab Stair Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01648	Link	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-01649	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03076	Administration Building	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/18/2023	
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03455	Utility Tunnel	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-03456	Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-05201	Rotary UPS	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-08115	Pump House	OSHPD 1-Proposed	5s								5s				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-08116	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-08117	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-08118	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
27 - Monterey	10348	Salinas Valley Health Medical Center	BLD-08119	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
28 - Napa	10366	Adventist Health St. Helena	BLD-01665	Smoking Porch Addition to Main Wing - Structurally connected to BLD-01666	OSHPD 1-Not an Independent Building	N/A								N/A				
28 - Napa	10366	Adventist Health St. Helena	BLD-01666	Main Wing & Smoking Porch Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-01667	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-01668	Ancillary Wing & (ICCU Add 5th Flr)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
28 - Napa	10366	Adventist Health St. Helena	BLD-03031	Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
28 - Napa	10366	Adventist Health St. Helena	BLD-03554	Health Center	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	BLD-05327	Chiller Plant	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/29/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01650	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			Withdrawn		1/1/2015 Risk Bsd Rebuild			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01651	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			Withdrawn		7/1/2019 Risk Bsd Rebuild			N/A				
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01652	West Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01653	Conference Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01654	Link Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01655	South Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01656	South Nursing Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01657	North Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01658	North Nursing Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01659	Maternity / Pediatrics	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01660	Admitting / Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01661	Radiology / Oncology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01663	Emergency Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-01664	Emergency Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-02881	Canopy Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05309	North Acute Care Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05323	North Acute Care Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	BLD-05463	Women's Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01669	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01670	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01671	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01673	West Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01674	Outpatient Center	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/08/2023	Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-01675	West Wing Addition #2 - Structurally connected to BLD-01670	OSHPD 1-Not an Independent Building	N/A								N/A				
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-03399	Entry Canopy West	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-03686	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-06080	Entry Canopy Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-06081	Entry Canopy East	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	BLD-07344	Pharmacy Addition	OSHPD 1-In Service	4s								2s		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01676	1950 Building and 1966 Additions	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01677	1966 North Addition Building - Structurally connected to BLD-01676	OSHPD 1-Not an Independent Building	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01678	1978 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 05/26/2022	Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01679	1990 Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-01680	1993 Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-02569	Med Gas Storage Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 05/26/2022	Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-03236	1986 Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-03897	Western Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05249	2011 ED/SPD Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05272	South Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05273	South Wing Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05474	2002 Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05475	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05476	2008 Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05477	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05478	Modular Chiller Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05479	Chiller Building Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/19/2023	
29 - Nevada	10377	Tahoe Forest Hospital	BLD-05480	Skilled Nursing Facility Addition	OSHPD 2-Skilled Nursing Only	N/A								N/A				
29 - Nevada	10377	Tahoe Forest Hospital	BLD-06666	Western Addition - Porte-Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01684	Central Plant	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01685	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01692	Phase IV/North Wing - South	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01693	Phase IV East Entrance	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-01695	Main Entrance Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03658	Corridor No. 1	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03659	Porte Cochere	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03660	Corridor No. 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03661	Corridor No. 3	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03662	Corridor No. 4	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03663	Corridor No. 5	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03664	Arcade	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03665	Phase IV/North Wing - North	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03671	Phase IV East Entrance Addition - North	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	BLD-03672	Phase IV East Entrance Addition - South	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01681	Original Building / Additions	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/30/2025	Rpt: Review Completed 06/09/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01682	ICU Addition	OSHPD 1-In Service	4								4			Rpt: Review Completed 06/09/2025	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-01683	OB/Gyn	OSHPD 1-In Service	4								4			Rpt: Review Completed 06/09/2025	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-06268	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Intent to Remove GAC	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-06269	Trash Enclosure	OSHPD 1-Equipment Yard	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-07788	Pump House	OSHPD 1-Proposed	5s								5s				
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-07789	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10381	Anaheim Community Hospital, LLC	BLD-07790	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	13061	Anaheim Global Medical Center	BLD-00996	Psychiatric Treatment	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	BLD-00997	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	BLD-00998	ICU / CCU Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	13061	Anaheim Global Medical Center	BLD-00999	ER Addition / Birthing Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	13061	Anaheim Global Medical Center	BLD-01000	Canopy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10400	Chapman Global Medical Center	BLD-02346	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10400	Chapman Global Medical Center	BLD-02347	Entry Pavilion	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02348	Mechanical Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02349	ICU/Admin Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10400	Chapman Global Medical Center	BLD-02350	Surgery Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-06670	Main Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-06671	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-06672	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07512	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07513	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07514	WT-03 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07515	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07516	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07517	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	BLD-07518	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10405	College Hospital Costa Mesa	BLD-02351	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Review Completed 11/08/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-02352	Psychiatric Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Review Completed 11/08/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10405	College Hospital Costa Mesa	BLD-03102	Radiographic and Fluoroscopy Addn	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Review Completed 11/08/2024	
30 - Orange	10405	College Hospital Costa Mesa	BLD-03417	Canopy 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Not Submitted	
30 - Orange	10405	College Hospital Costa Mesa	BLD-03419	Canopy 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/17/2024	Rpt: Not Submitted	
30 - Orange	10405	College Hospital Costa Mesa	BLD-07142	Storage Building	OSHPD 1-Under Construction	2								2				This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-07143	Utility Building	OSHPD 1-Under Construction	2								2				This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	BLD-07144	Utility Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Review Completed 09/17/2024	Rpt: Review Completed 11/08/2024	
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06151	West Building	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06152	East Building	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-06448	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A								5				
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	BLD-07400	East Expansion	OSHPD 1-Proposed	5s								5s				
30 - Orange	12573	Foothill Regional Medical Center	BLD-01029	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/24/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12573	Foothill Regional Medical Center	BLD-01030	Classroom Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/24/2025	
30 - Orange	12573	Foothill Regional Medical Center	BLD-02631	Mechanical Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/30/2023	Rpt: Review Completed 01/24/2025	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02406	Patient Tower	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: In Review 12/14/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02407	Ancillary Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: In Review 12/14/2023	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-02408	Mechanical Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/27/2023	Rpt: In Review 12/14/2023	
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-07590	Liquid Oxygen Tank Yard	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-07796	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-07797	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-07798	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	10450	Garden Grove Hospital and Medical Center	BLD-07799	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	17438	Healthbridge Children's Hospital-Orange	BLD-05189	Main Building	OSHPD 1-In Service	5								4			Rpt: In Review 09/09/2026	
30 - Orange	16319	Hoag Hospital Irvine	BLD-00283	D & T	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-00284	Nursing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-05852	ER Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-05853	Emergency Department	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	16319	Hoag Hospital Irvine	BLD-06285	Ambulance Bay Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06297	Trellis Wheel Chair Storage	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06480	Vending Kiosk	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06481	Wheelchair Storage	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06656	East Wing Addition	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06658	E-Generator Yard (E Generator Enclosure)	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06660	Dock Receiving Enclosure (Basement Connecting Corridor)	OSHPD 1-Tunnels	5								4			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-06661	Front Entrance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	16319	Hoag Hospital Irvine	BLD-06662	Front Entrance Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	16319	Hoag Hospital Irvine	BLD-06663	East Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06677	North-West Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06678	North Hospital - West Wing	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06680	North Hospital - East Wing	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06681	North-East Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06682	East Tunnel Connector	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-06938	South-East Pedestrian Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
30 - Orange	16319	Hoag Hospital Irvine	BLD-06939	South-West Pedestrian Canopy	OSHPD 1-In Service	5s								5s			Rpt: Proposed Retrofit Acceptable 09/22/2022	
30 - Orange	16319	Hoag Hospital Irvine	BLD-07116	Emergency Generator Enclosure #1	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07117	Emergency Generator Enclosure #2	OSHPD 1-Under Construction	5s								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07484	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07485	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07486	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	16319	Hoag Hospital Irvine	BLD-07487	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02360	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/16/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02361	Four-Story Building - 1957	OSHPD 1-In Service	2					7/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Awaiting review 11/27/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02363	Old ICU - 1963	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/08/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02364	Old Radiation Therapy - 1975	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02366	Power Plant - Boilers and Chillers - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02368	Inpatient Tower - 1974	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/13/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02369	Ancillary / Helistop / Power Plant	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02370	Helistop - 1974 - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02371	Chemical Dependency - 1965	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/13/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02373	Cancer Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02374	MRI / MRI Addition	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02375	South Entrance	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02376	ER East Waiting Room Addition - Structurally connected to BLD-02369	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02377	MRI Addition - Structurally connected to BLD-02374	OSHPD 1-Not an Independent Building	N/A								N/A				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02378	Link Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/10/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-02379	Emergency Department Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/10/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03098	Cancer Center - Link Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03332	Power Plant - MUSS & ATS	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03333	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03415	Energy Treatment Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-03699	East Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05442	Cogeneration Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05517	Cafe Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05518	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05519	ECU Waiting Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05520	Original Building - North Portion	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/01/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05568	East Wing Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05900	ECU Waiting Walk-In Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-05901	ECU Waiting Drop-Off Area Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-06281	Elevator Tower (for Inpatient Tower)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07102	Utility Tunnel	OSHPD 1-Tunnels	N/A								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07791	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07792	Pump Vault	OSHPD 1-Proposed	5s								5s				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07793	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	BLD-07794	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10431	Huntington Beach Hospital	BLD-02387	Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	BLD-02388	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	BLD-02389	ICU/CCU Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02390	Emergency Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02916	CT Scan Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10431	Huntington Beach Hospital	BLD-02917	X-Ray Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	BLD-07746	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10431	Huntington Beach Hospital	BLD-07747	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10431	Huntington Beach Hospital	BLD-07748	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10431	Huntington Beach Hospital	BLD-07749	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	10431	Huntington Beach Hospital	BLD-07750	FT-02 Fuel Tank	OSHPD 1-Proposed	5s								5s				
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-05274	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/07/2023	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-05275	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/07/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-06224	Walk-in Refrigerator	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/07/2023	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-06944	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/07/2023	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-07417	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-07418	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-07419	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-07598	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	BLD-07599	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-03831	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-03902	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-07408	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-07409	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-07410	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-07411	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	BLD-07412	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02353	Building I: Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02354	Building II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02355	Building III	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02356	Building IV	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02357	Building V	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02358	Building VI	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	10407	Kindred Hospital - Santa Ana	BLD-02359	Building VII	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/28/2024	Rpt: Review Completed 03/28/2024	
30 - Orange	13068	Kindred Hospital Brea	BLD-02559	Main Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
30 - Orange	10476	Kindred Hospital Westminster	BLD-01343	Patient Tower (Building I)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03059	Entry/Lobby (Building II)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03060	Critical Care (Building III)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-03061	Body Scanner Addition (Building IV)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/29/2023	
30 - Orange	10476	Kindred Hospital Westminster	BLD-03479	Entry Canopy	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	BLD-07468	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10476	Kindred Hospital Westminster	BLD-07469	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10476	Kindred Hospital Westminster	BLD-07470	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10476	Kindred Hospital Westminster	BLD-07471	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10476	Kindred Hospital Westminster	BLD-07472	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10476	Kindred Hospital Westminster	BLD-07473	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00982	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00983	Perinatal Building Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00984	Pool Building	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-00985	Service Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02758	Service Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02759	Rehabilitation Department Expansion	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-02760	Patient Room Expansion	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-05516	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-05782	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-07864	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-07865	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	13019	La Palma Intercommunity Hospital	BLD-07866	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00323	Original Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00324	South Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-00325	Emergency Room Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 05/22/2023	Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05472	Pedestrian Bridge	OSHPD 1-In Service	5								4			Rpt: Open - Documents Uploaded 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05730	Patient Care Pavilion	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05731	Covered Walkway	OSHPD 1-In Service	4								4			Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-05873	Emergency Room Addition #2	OSHPD 1-Under Construction	5s								5s				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-06027	LDR	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-06231	LDR Canopy	OSHPD 1-In Service	3								4			Rpt: Open - Documents Uploaded 12/19/2023	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-07945	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-07946	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	15630	Memorialcare Orange Coast Medical Center	BLD-07947	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01042	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01043	Women's Health Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/31/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01044	Central Plant - Steel Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/27/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-01045	Central Plant - Concrete Portion	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-02738	Critical Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-03707	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-05981	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-05989	Main Hospital Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-06020	CCP Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-06024	WHC Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07141	Central Plant	OSHPD 1-Under Construction	5s								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07477	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07478	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07479	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07480	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12755	Memorialcare Saddleback Medical Center	BLD-07481	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	18007	Orange County Global Medical Center	BLD-00295	Ancillary Building/ER Expansion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00296	Elevator Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00297	Nursing Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00298	Administration	OSHPD 1-In Service	2					7/1/2018 Fin Hdsp Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	18007	Orange County Global Medical Center	BLD-00299	Shipping & Receiving	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00300	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00301	Radiation Therapy	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-00302	Support Services	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 11/27/2024	Rpt: Not Submitted	
30 - Orange	18007	Orange County Global Medical Center	BLD-05722	Entrance Canopy	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	BLD-06693	New Cooling Tower Yard	OSHPD 1-Under Construction	N/A								4s				
30 - Orange	12804	Providence Mission Hospital	BLD-00913	Pavilion - Building 1	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12804	Providence Mission Hospital	BLD-00914	Pavilion - Building 2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/06/2023	Intent to Remove GAC	
30 - Orange	12804	Providence Mission Hospital	BLD-00915	Pavilion - Building 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Intent to Remove GAC	
30 - Orange	12804	Providence Mission Hospital	BLD-00916	Pavilion - Building 4	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Intent to Remove GAC	
30 - Orange	12804	Providence Mission Hospital	BLD-00917	Pavilion - Building 5	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Intent to Remove GAC	
30 - Orange	12804	Providence Mission Hospital	BLD-00918	Hospital Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	12804	Providence Mission Hospital	BLD-03184	Tower 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-03185	Linear Accelerator	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-03186	Perioperative Pediatric Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-06715	Tower 2 Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	12804	Providence Mission Hospital	BLD-07234	Hospital Tower 3	OSHPD 1-Proposed	5s								5s				
30 - Orange	12804	Providence Mission Hospital	BLD-07235	Canopy	OSHPD 1-Proposed	5s								5s				
30 - Orange	12804	Providence Mission Hospital	BLD-07236	Lobby Infill	OSHPD 1-Proposed	5s								5s				
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02433	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02434	Nursing Tower	OSHPD 1-In Service	2			Withdrawn		7/1/2019 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02435	Elevator Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02436	Radiographic	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02437	Radiographic - South Addition	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02438	Administration Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02439	Mechanical / Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	BLD-02440	Linear Accelerator Suite (Treatment)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Not Submitted	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02414	Main Building (A)	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02415	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02416	East/West Wing	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02417	South Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02418	North Wing / Lobby	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02419	Main Hospital Building (B)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02420	Main Hospital Building (C)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02421	Regional Cancer Center	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02422	Emergency Department Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10457	Providence St. Joseph Hospital	BLD-02784	Generator Enclosure	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03013	ICU/CCU Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03352	Patient Care Center/Plaza Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03353	Facilities Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03354	PCC Lobby / Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03355	Underground Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-03357	South Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-06061	PCC West Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
30 - Orange	10457	Providence St. Joseph Hospital	BLD-06435	Emergency Entrance Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02424	Main Building / Canopies / Boiler Room	OSHPD 1-In Service	1			Withdrawn		7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02425	West Building	OSHPD 1-In Service	1			Withdrawn		7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02426	North Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02427	CT Scan Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02428	Outpatient/Admitting Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02429	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02431	Emergency Generator Enclosure	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02432	MRI and Surgery Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02832	E.R. Waiting/Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02833	Basement Expansion	OSHPD 1-In Service	1			Withdrawn		7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-02834	Boiler Room Expansion / Chiller Rm	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03190	Southwest Acute Care Bed Tower	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03191	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03192	East Link	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03193	West Link North	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-03194	Northwest Acute Care Bed Tower	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05775	West Link South	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05776	Trash Enclosure	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05777	Medical Gas Enclosure	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-05778	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-06581	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
30 - Orange	10458	Providence St. Jude Medical Center	BLD-07401	Trash Enclosure	OSHPD 1-In Service	1s								2		Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-00271	CHOC North	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-00272	Research Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-00273	CHOC West	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2015 Com Acc Replace			N/A				
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-05243	Tower II	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-05335	CHOC Lobby	OSHPD 1-In Service	3s								2s		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-05672	Providence Tunnel	OSHPD 1R-Tunnels	N/A								N/A		Rpt: Review Completed 12/19/2023	Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-05720	La Veta Stairs	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-05721	Garage Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-07297	La Veta Stair Transition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-07298	La Veta Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-07313	Garage Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-08052	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
30 - Orange	14370	Rady Children's Hospital Orange County	BLD-08053	Pump Room	OSHPD 1-Proposed	5s								5s				
30 - Orange	13059	South Coast Global Medical Center	BLD-00994	Main Hospital and Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13059	South Coast Global Medical Center	BLD-00995	Nursing Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
30 - Orange	10039	UCI Health - Irvine	BLD-06720	Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	UCI Health - Irvine	BLD-06721	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	UCI Health - Irvine	BLD-06884	ED Canopy No 1	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	UCI Health - Irvine	BLD-06885	ED Canopy No 2	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10039	UCI Health - Irvine	BLD-06889	Utility Tunnel	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10039	UCI Health - Irvine	BLD-06911	Electrical Yard	OSHPD 1-Equipment Yard	N/A								5				
30 - Orange	10039	UCI Health - Irvine	BLD-06912	Main Switchgear	OSHPD 1-Not a Building Structure	N/A								5				
30 - Orange	10062	UCI Health Rehabilitation Hospital	BLD-06919	Rehab Hospital	OSHPD 1-Under Construction	5s								5s				
30 - Orange	10062	UCI Health Rehabilitation Hospital	BLD-06920	Generator Enclosure / Exit Stair Room / Trash Enclosure	OSHPD 1-Under Construction	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00926	Main Hospital/Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Open - Returned 12/20/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00927	Women & Children's Hosp.	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00928	Dining Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00929	Conference Room Addition	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-00931	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03497	Emergency Power Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03498	Surgery Addition	OSHPD 1-Under Construction	5s								4s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03770	ER Addition - Phase 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-03771	ER Addition - Phase 3	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-06644	Switchgear Building	OSHPD 1-In Service	4D								2s		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07547	AHU Platform	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/20/2023	
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07548	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07714	Pump House #1	OSHPD 1-Proposed	5s								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07715	Pump House #2	OSHPD 1-Proposed	5s								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07716	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07717	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07718	WT-02 Water Tank (Non-potable)	OSHPD 1-Proposed	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07719	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07720	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	12834	UCI Health-Fountain Valley	BLD-07721	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	16234	UCI Health-Fountain Valley	BLD-05195	Living Care Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
30 - Orange	16234	UCI Health-Fountain Valley	BLD-07723	Pump House	OSHPD 1-Proposed	5s								5s				
30 - Orange	16234	UCI Health-Fountain Valley	BLD-07724	WT-01 Water Tank	OSHPD 1-Proposed	5s								5s				
30 - Orange	16234	UCI Health-Fountain Valley	BLD-07725	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02395	Main Hospital/ICU - CCU/Nuclear Med	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02396	OB South/ER/Lab	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Awaiting review 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02397	Women's Center	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-02398	Linear Accelerator	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-07557	Chiller Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/20/2023	
30 - Orange	10440	UCI Health-Los Alamitos	BLD-07710	Pump House	OSHPD 1-Proposed	5s								5s				
30 - Orange	10440	UCI Health-Los Alamitos	BLD-07711	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10440	UCI Health-Los Alamitos	BLD-07712	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10440	UCI Health-Los Alamitos	BLD-07713	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10446	UCI Health-Orange	BLD-02400	Medical Center Tower Building 1A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-02401	Neuropsychiatric Center - West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-02402	Steam Plant Building 31	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 07/03/2009	Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10446	UCI Health-Orange	BLD-02403	Primary Electrical Facility Building 32	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 02/24/2026	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-02404	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 02/24/2026	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-03017	Neuropsychiatric Center - East Wing (Acute Center East)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-03412	Douglas Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-03416	Link Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05584	Medical Gas / Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 02/24/2026	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05587	Generator Switchgear	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05588	Emergency Generator Housing	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05683	Neuropsychiatric Center - East Wing (Acute Center South)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05769	Neuropsychiatric Center - East Wing (Acute Center North)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05770	Neuropsychiatric Center - East Wing (Acute Center Walkway North)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-05771	Neuropsychiatric Center - East Wing (Acute Center Walkway South)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-06008	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
30 - Orange	10446	UCI Health-Orange	BLD-06239	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00156	Main Hospital & Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00157	Patient Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00158	OB Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-00159	Classrooms & Additions	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-03742	GI Building Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-03743	GI Building Expansion Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-05701	Main Entry and Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-05718	Free-Standing Mechanical Platform	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07549	ED Expansion	OSHPD 1-In Service	5								2		Rpt: Review Completed 05/26/2026	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07550	ED Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07551	Mechanical Building	OSHPD 1-In Service	4								2		Rpt: Review Completed 05/26/2026	Rpt: Review Completed 12/18/2023	
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07706	Pump House	OSHPD 1-Proposed	5s								5s				
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07707	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07708	WT-02 Water Tank (Non-potable)	OSHPD 1-Proposed	N/A								5s				
30 - Orange	13077	UCI Health-Placentia Linda	BLD-07709	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10475	West Anaheim Medical Center	BLD-02441	Main Hospital	OSHPD 1-In Service	2					8/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
30 - Orange	10475	West Anaheim Medical Center	BLD-02675	Phase I - Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-02886	Phase I - 1 Story Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-03118	Entry Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-03559	Oxygen Tank Yard (Service Yard)	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
30 - Orange	10475	West Anaheim Medical Center	BLD-07861	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10475	West Anaheim Medical Center	BLD-07862	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
30 - Orange	10475	West Anaheim Medical Center	BLD-07863	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00260	Hospital, Building 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00261	Hospital, Building 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00262	Hospital, Building 3	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00263	Hospital Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00264	Hospital Tower North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00265	Hospital Tower South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-00266	Central Plant Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05230	Emergency Department/Radiology	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05723	Central Plant Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05724	EVS Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05725	Women & Children's Link	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05726	Women & Children's Center	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-05727	Fire Pump Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06067	Entry Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Open - Returned 02/27/2023	Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06388	MRI Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06786	Cart Wash and Compactor Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06832	Equipment Holding	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06856	Hospital Entry Canopy	OSHPD 1-Proposed	5s								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06857	Hospital Tower West	OSHPD 1-Under Construction	5s								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06858	ED Entry Canopy	OSHPD 1-Under Construction	5s								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06940	Switchgear and IT Building	OSHPD 1-Under Construction	5s								4s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06941	Generator Yard	OSHPD 1-Under Construction	N/A								4s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-06987	PRV Building	OSHPD 1-Under Construction	5s								4s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07124	Sanipak Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 11/13/2023	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07434	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07435	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07436	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07437	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07533	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07534	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	BLD-07535	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01344	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01345	Storage / Pharmacy Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01346	Dietary Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01347	Emergency Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01348	Medical Records Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01349	Electrical Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-01350	Boiler Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-02979	West Electrical Room	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05552	Cath Lab Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05553	MRI Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05779	Patient Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-05882	Emergency Generators Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07011	Addition #1	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07012	Addition #2	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07013	Addition #3	OSHPD 1-In Service	4								2		Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	10494	Sutter Auburn Faith Hospital	BLD-07014	Covered Walkway	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/27/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-00303	Main Hospital (General Hospital)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-00304	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03248	Acute Rehabilitation - East - Structurally connected to BLD-03612	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03249	Acute Rehabilitation - Pedestrian Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03580	General Hospital Pedestrian Walkway	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03581	Bed Tower South	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03582	Bed Tower North	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03583	Administration	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03584	MOB Pedestrian Walkway	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03585	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03586	Bed Tower Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03587	Bed Tower Expansion Pedestrian Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03611	NICU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03612	Acute Rehabilitation	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03613	Well Baby Nursery - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-03614	ICU Expansion - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A								N/A				
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06161	E.D. & Critical Care Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06753	Bed Tower Expansion - Walkway 2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06754	Bed Tower Expansion - Walkway 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06758	Porte-Cochere	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-06759	Gas Cylinder Enclosure	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
31 - Placer	17700	Sutter Roseville Medical Center	BLD-07608	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-01362	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: In Review 12/29/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-01364	Boiler Plant Building	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-03655	SNF Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	BLD-03656	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
32 - Plumas	10512	Plumas District Hospital	BLD-01351	Original Building	OSHPD 1-In Service	2						4/1/2030 AB 869		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10512	Plumas District Hospital	BLD-01353	1976 Addition	OSHPD 1-In Service	4						4/1/2030 AB 869		2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/18/2023	
32 - Plumas	10512	Plumas District Hospital	BLD-01354	South Addition	OSHPD 1-In Service	4						4/1/2030 AB 869		2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/18/2023	
32 - Plumas	10512	Plumas District Hospital	BLD-06957	Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A								N/A				
32 - Plumas	10512	Plumas District Hospital	BLD-07659	Lobby	OSHPD 2-Skilled Nursing Only	N/A								N/A				
32 - Plumas	10512	Plumas District Hospital	BLD-07660	Trash Enclosure	OSHPD 2-Skilled Nursing Only	N/A								N/A				
32 - Plumas	10512	Plumas District Hospital	BLD-07661	Trash Enclosure	OSHPD 2-Skilled Nursing Only	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
32 - Plumas	10513	Seneca District Hospital	BLD-01355	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-01356	Pump Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-01358	Entrance Addition - Structurally connected to BLD-01355	OSHPD 1-Not an Independent Building	N/A								N/A				
32 - Plumas	10513	Seneca District Hospital	BLD-01359	Extended Care Addn.	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-01360	Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-01361	Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
32 - Plumas	10513	Seneca District Hospital	BLD-03843	Boiler Room	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	BLD-06811	New Hospital	OSHPD 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06812	New ED Canopy	OSHPD 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06813	New Entrance Canopy	OSHPD 1-Under Construction	5s								5s				
32 - Plumas	10513	Seneca District Hospital	BLD-06814	New SNF	OSHPD 2-Under Construction	N/A								N/A				
32 - Plumas	10513	Seneca District Hospital	BLD-07110	New Ambulance Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	10529	Corona Regional Medical Center	BLD-01367	Original Hospital - Main	OSHPD 1-In Service	2	Denied				1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Review Completed 02/26/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10529	Corona Regional Medical Center	BLD-01368	Ancillary - Main	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-01369	Surgery & Delivery - Main	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Open - Returned 02/21/2025	Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-02997	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/26/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10529	Corona Regional Medical Center	BLD-03594	Generator Building (Electrical Panel Room)	OSHPD 1-In Service	4	Denied							4			Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-05887	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-05888	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-05889	Switchgear Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 02/26/2025	
33 - Riverside	10529	Corona Regional Medical Center	BLD-05890	Modular MRI Building	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
33 - Riverside	10529	Corona Regional Medical Center	BLD-06298	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/26/2025	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01393	Main Hospital & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	BLD-01395	Woman & Infants Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01396	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	BLD-01397	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01398	Shipping/Receiving	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01399	Surgery Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01400	West Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01401	Lobby	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10537	Desert Regional Medical Center	BLD-01402	Admitting	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01403	Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
33 - Riverside	10537	Desert Regional Medical Center	BLD-01404	Dinah Shore Waiting Area	OSHPD 1-In Service	3					Denied			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-02932	East Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	BLD-03720	West Tower - Corridor 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03721	West Tower - Corridor 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03722	West Tower - Corridor 3	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03723	West Tower - Corridor 4	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03725	West Tower - Corridor 5	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03741	Medical Records Building	OSHPD 1-In Service	3					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03764	Elevator Tower - Corridor 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-03765	Elevator Tower - Corridor 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-06628	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10537	Desert Regional Medical Center	BLD-07726	Pump House #1	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07727	Pump House #2	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07728	Pump House #3	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07729	WT-01 Water Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07730	WT-02 Water Tanks	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10537	Desert Regional Medical Center	BLD-07731	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07732	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10537	Desert Regional Medical Center	BLD-07733	FT Fuel Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01381	Original Hospital Building and 1961 Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01382	1971 Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-01383	Diagnostic & Treatment Wing & Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-03344	Utility Plant Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
33 - Riverside	10554	Doctors Hospital Of Riverside	BLD-05783	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
33 - Riverside	12662	Eisenhower Medical Center	BLD-01056	North Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-01057	Eisenhower Wing (North) - Structurally connected to BLD-03004	OSHPD 1-Not an Independent Building	N/A			Withdrawn		7/1/2019 Com Acc Retrofit			N/A				
33 - Riverside	12662	Eisenhower Medical Center	BLD-01058	Gene Autry Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-01059	Surgery Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-01060	Sinn Wing - Part A	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-01061	Birthing Center Bridge	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-02824	Engineering Department	OSHPD 1-In Service	2			Withdrawn		1/1/2015 Com Acc Replace			4D-L1			Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	BLD-03003	Eisenhower Wing (South) - Structurally connected to BLD-03004	OSHPD 1-Not an Independent Building	N/A			Withdrawn		7/1/2019 Com Acc Retrofit			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	12662	Eisenhower Medical Center	BLD-03004	Eisenhower Wing (Center)	OSHPD 1-In Service	2			Withdrawn		7/1/2019 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	BLD-03005	Sinn Wing - Part B (Amb. Canopy)	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03006	Sinn Wing - Part C	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03007	Sinn Wing - Part D	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03008	Sinn Wing - Part E	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03009	Sinn Wing - Part F	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03540	(CP) Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03541	Annenberg Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-03830	12 KV Switch Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-05500	Delivery Dock	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			4D-L1			Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	BLD-05647	ED / Renker Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-06760	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								2		Rpt: Not Submitted	Rpt: Review Completed 12/22/2025	
33 - Riverside	12662	Eisenhower Medical Center	BLD-07376	Telecom Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2025	
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	BLD-05790	Rehabilitation Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	BLD-06553	Admin	OSHPD 1-In Service	5								5				Earthquake Resilient
33 - Riverside	10541	Hemet Global Medical Center	BLD-01405	Pre 1980 Emergency - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A					Denied			N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01406	Tower I	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01407	1965 Mechanical Room - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A					Denied			N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01408	1948 Addition	OSHPD 1-In Service	2					8/31/2017 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01409	North Wing and Annex	OSHPD 1-In Service	2					3/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01410	Obstetrics I - Structurally connected to BLD-01409	OSHPD 1-Not an Independent Building	N/A					Denied			N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01411	1965 NW Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01412	Behavioral Health	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	BLD-01413	Obstetrics II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-01414	Tower II Lower Levels - Structurally connected to BLD-01415	OSHPD 1-Not an Independent Building	N/A								N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01415	Tower II Upper Levels	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-01416	1980 Entrance - Structurally connected to BLD-01417	OSHPD 1-Not an Independent Building	N/A								N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-01417	Main Lobby and Entrance	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10541	Hemet Global Medical Center	BLD-01418	Area A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-02857	Area B	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-02858	Area C - Structurally connected to BLD-02857	OSHPD 1-Not an Independent Building	N/A								N/A				
33 - Riverside	10541	Hemet Global Medical Center	BLD-05649	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
33 - Riverside	10541	Hemet Global Medical Center	BLD-06156	Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01370	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01371	Central Plant	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01372	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01373	North Wing/E.R. Expansion	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01374	West/South Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-01375	ICU - MED / Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-03525	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06500	MRI	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-06587	CT#2 Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-07734	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-07735	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-07736	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	10545	John F. Kennedy Memorial Hospital	BLD-07737	Pump House	OSHPD 1-Proposed	5s								5s				
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-00285	Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02918	Stair and Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02919	Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02920	Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-02921	Waiting Room Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-05418	Bulk Oxygen Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-05732	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06545	Diagnostic and Treatment Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06546	Energy Center (CUP)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06547	Booster Pump House	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06548	Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06873	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-06874	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/19/2023	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-07461	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-07462	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-07463	WT-02 Water Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	BLD-07464	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-00274	Hospital Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-00275	Plant Service Building	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05460	MRI Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05651	Switchgear Enclosure	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/12/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05652	Generator Enclosure - Number 1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05653	Generator Enclosure - Number 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-05654	Generator Enclosure - Number 3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06761	Bed Tower	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06762	Rotunda	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06763	North Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06764	South Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06868	Fire Pump Room	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06869	Tech Dock Building	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06890	Generator Enclosure - Number 4	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06891	Propane Tank and Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-06973	Hospital Tower Basement	OSHPD 1-In Service	4								2		Rpt: Proposed Retrofit Acceptable 12/14/2022	Rpt: Open - Returned 12/12/2023	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07455	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07456	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07457	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07458	WT-03 Water Tank	OSHPD 1-Tanks	N/A								N/A				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07596	WT-04 Water Tank	OSHPD 1-Under Construction	N/A								5s				
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	BLD-07597	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
33 - Riverside	13030	Kindred Hospital Riverside	BLD-00986	Main Hospital	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 03/07/2024	Rpt: Review Completed 03/07/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	13030	Kindred Hospital Riverside	BLD-03519	Storage	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 03/07/2024	Rpt: Review Completed 03/07/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05595	Main Hospital Facility	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05596	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05800	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05801	North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05802	East Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05803	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-05804	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-07867	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-07868	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-07869	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	BLD-07870	Pump House	OSHPD 1-Proposed	5s								5s				
33 - Riverside	16148	Menifee Global Medical Center	BLD-00351	Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02897	Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02898	Stair and Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	
33 - Riverside	16148	Menifee Global Medical Center	BLD-02899	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/26/2024	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10553	Palo Verde Hospital	BLD-01376	Building A	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01377	Building B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01378	Building C	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 02/21/2025	Rpt: Not Submitted	
33 - Riverside	10553	Palo Verde Hospital	BLD-01379	Building D	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	BLD-01380	Building E	OSHPD 1-In Service	2					1/1/2015 Com Acc Replace			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-05443	Main Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-06095	Dining Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	BLD-06096	Rehab Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10556	Riverside Community Hospital	BLD-01384	Building A (Main)	OSHPD 1-In Service	1					9/1/2017 Com Acc Rebuild		Yes	2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	10556	Riverside Community Hospital	BLD-01385	Building B	OSHPD 1-In Service	2					2/1/2018 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10556	Riverside Community Hospital	BLD-01386	Building C (Inpatient Building)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/15/2023	
33 - Riverside	10556	Riverside Community Hospital	BLD-01387	Building D	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	10556	Riverside Community Hospital	BLD-01388	Old Radiology Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10556	Riverside Community Hospital	BLD-03107	Emergency Generator Enclosure	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/15/2023	
33 - Riverside	10556	Riverside Community Hospital	BLD-03421	Building G	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
33 - Riverside	10556	Riverside Community Hospital	BLD-07245	Building H	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10556	Riverside Community Hospital	BLD-07888	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10556	Riverside Community Hospital	BLD-07889	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10556	Riverside Community Hospital	BLD-07890	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
33 - Riverside	10556	Riverside Community Hospital	BLD-07893	Building C Access Pavilion	OSHPD 1-Proposed	5s								5s				
33 - Riverside	10556	Riverside Community Hospital	BLD-08129	Building C Vehicle Canopy	OSHPD 1-Proposed	5s								5s				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-02517	Main Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03488	Ancillary Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03489	Central Plant / Dining Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 06/01/2023	Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-03490	Generator Building	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-05814	Co-Gen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-05906	MRI Trailer	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06352	Central Plant Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/08/2023	
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06830	Exterior Canopy 1	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-06831	Exterior Canopy 2	OSHPD 1-Under Construction	5s								4s				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-07403	Emergency Department Addition	OSHPD 1-Proposed	5s								5s				
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-07404	Wellness Center	OSHPD 5-Proposed	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	15007	Riverside University Health System - Medical Center	BLD-07405	Ancillary Building Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/08/2023	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01389	Original Building-OB Addition-'64 Addition	OSHPD 1-In Service	2	Denied				Denied			2	1/1/2030	Rpt: Review Completed 02/13/2025	Rpt: Review Completed 02/06/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01390	O.R. Addition	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 02/13/2025	Rpt: Review Completed 02/06/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01391	Addition (1980)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-01392	O.B. Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-02947	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-02948	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05235	ED / ICU	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05303	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-05425	Oxygen Tank and Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	10559	San Gorgonio Memorial Hospital	BLD-06816	Pedestrian Walkway Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 02/06/2025	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00331	Building A	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00332	Building B & ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00334	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-00335	OR/Amb. Care Addn - Bldg D, North	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-02980	OR/Amb. Care Addn - Bldg D, South	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05228	ER, ICU & Radiology Expansion - Building G	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05281	Bed Addition, Building "i"	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05282	ER, ICU & Radiology Expansion - Building F	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05284	ER, ICU & Radiology Expansion - Building H	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-05521	ER, ICU & Radiology Expansion - Building B1D	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06605	Replacement Hospital	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06606	Central Plant	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06776	Main Entry Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06777	Loading Dock Canopy	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	BLD-06807	Service Building	OSHPD 1-Under Construction	5s								5s				
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-00290	Original Hospital Building & Conversions	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-00291	Acute Care Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-05229	Women's Center and Emergency Room	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-06770	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	BLD-06828	Hospital and Women's Center Generator	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Not Submitted	
33 - Riverside	18167	Temecula Valley Hospital	BLD-05259	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
33 - Riverside	18167	Temecula Valley Hospital	BLD-06130	D&T Expansion 2018	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
33 - Riverside	18167	Temecula Valley Hospital	BLD-07279	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/13/2024	
34 - Sacramento	10027	California Northstate University Medical Center	BLD-06522	CNU Medical Center	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-06523	Central Plant	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07308	Open Parking Garage (North)	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07309	Open Parking Garage (South)	OSHPD 1-Proposed	5s								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07523	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07524	WT-04 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07525	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07526	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07527	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07528	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07529	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10027	California Northstate University Medical Center	BLD-07530	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01419	Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01420	Hospital Addition Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01421	3 - Hospital Addition Clinic	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-01422	Camellia Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-03284	ATS Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-03557	Telephone Equipment Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-05469	Central Utility Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-05905	Camellia Utility Bridge	OSHPD 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	BLD-06474	ED Expansion	OSHPD 1-In Service	5								4			Intent to Remove GAC	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00319	Hospital, Building 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00320	Hospital, Building 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/09/2022	Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00321	Hospital Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/18/2022	Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-00322	Central Plant	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03502	Communications Building	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03503	ER / Radiology Expansion	OSHPD 1-In Service	5s								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03608	Central Utility Plant (Chiller Plant)	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-03609	Hospital Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06109	ED Trauma Addition	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06128	Corridors	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06249	CUP Water Tank No. 2 (WT-01)	OSHPD 1-Tanks	N/A								N/A				
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-06602	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/11/2023	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	BLD-07600	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06442	Hospital	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06443	Energy Center	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06444	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-06446	Ambulance Canopy	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07266	Fire Pump House	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07269	Oxygen Yard	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07501	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07502	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07503	WT-03 Water Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07504	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07505	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07506	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07507	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	BLD-07508	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
34 - Sacramento	10606	Mercy General Hospital	BLD-01423	South Wing / East Wing (South Wing)	OSHPD 1-In Service	2					7/1/2017 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	BLD-01424	East Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
34 - Sacramento	10606	Mercy General Hospital	BLD-01425	Northeast Wing, Part A	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	BLD-01426	Northeast Wing, Part B	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	BLD-01427	North Wing	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10606	Mercy General Hospital	BLD-03110	Northeast Wing, Part D	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/08/2023	Rpt: Review Completed 12/22/2023	
34 - Sacramento	10606	Mercy General Hospital	BLD-03380	Heart Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
34 - Sacramento	10606	Mercy General Hospital	BLD-03381	Equipment Yard	OSHPD 1-Equipment Yard	N/A								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
34 - Sacramento	10606	Mercy General Hospital	BLD-05211	2 Story Corridor Structure	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/22/2023	
34 - Sacramento	10606	Mercy General Hospital	BLD-05212	4 Story Corridor Structure - Structurally connected to BLD-01427	OSHPD 1-Not an Independent Building	N/A								N/A				
34 - Sacramento	10606	Mercy General Hospital	BLD-06125	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00078	South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/07/2024	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00079	West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/07/2024	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00080	East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/07/2024	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-00081	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/07/2024	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06990	Central Plant Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06991	Ambulance Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-06992	Emergency Department	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 08/05/2024	
34 - Sacramento	16150	Mercy Hospital Of Folsom	BLD-08121	Entry Canopy	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01428	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01429	Central Plant	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01430	CCU/Telemetry	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01431	New Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01432	New Hospital Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-01433	Cath Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-03404	McAuley Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-05784	McAuley Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06461	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06988	McAuley Canopy - Low	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-06989	Lobby and Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07284	Emergency Shower	OSHPD 1-In Service	5								2		Rpt: Review Completed 09/05/2024	Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07285	Vehicular Emergency Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07286	Emergency Entry	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07835	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07836	WT-02 Water Tanks	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07837	WT-04 Water Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07838	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07839	WWT-02 Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07840	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07841	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07842	FT-03 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	10607	Mercy San Juan Medical Center	BLD-07843	FT-04 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00971	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00972	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00973	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/23/2007	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00974	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-00975	North Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03216	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03696	Medical Gas Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03705	East Wing Addition	OSHPD 1-In Service	5								3		Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-03706	East Wing Canopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06308	ED Upper South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06309	ED Lower South Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	13012	Methodist Hospital of Sacramento	BLD-06310	ED North Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	BLD-06365	Vibra Rehabilitation Hospital of Natomas	OSHPD 1-In Service	5								5				Earthquake Resilient
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	BLD-06397	Main Entry Drop Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
34 - Sacramento	14506	Shriners Hospitals For Children Northern California	BLD-02530	Main Hospital	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 01/11/2024	Rpt: Review Completed 12/22/2025	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-01446	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: In Review 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03264	Radiation Oncology Center - Structurally connected to BLD-05216	OSHPD 1-Not an Independent Building	N/A								N/A				
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03622	Sutter Capital Pavilion	OSHPD 1-In Service	5								4			Rpt: In Review 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-03629	Foot Bridge	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05216	Women's & Children's Center	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: In Review 12/30/2023	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05907	Sutter Capital Pavilion Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Not Submitted	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	BLD-05908	Main Hospital Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Not Submitted	
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06469	UC Davis Rehabilitation Institute	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06470	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								5				
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-06664	Porte-Cochere	OSHPD 1-In Service	5								5				Earthquake Resilient
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	BLD-07357	Trash Enclosure	OSHPD 1-In Service	5								5				Earthquake Resilient
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01434	North/South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				12/31/2019 Com Acc Replace	1/1/2025 AB 2190 Rebuild		N/A				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01435	University Surgery Center - Structurally connected to BLD-01434	OSHPD 1-Not an Independent Building	N/A	Denied							N/A				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01436	East Wing (Tower)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 06/26/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01437	East Wing (Radiology)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 06/26/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01438	East Wing (Laundry)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01439	University Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01440	MRI	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01443	Emergency Room Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01444	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-01445	Davis Tower	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-02840	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-02841	Surgery and Emergency Services Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
34 - Sacramento	10619	University of California Davis Medical Center	BLD-05815	CT Scan Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06783	California Tower	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06825	Interim Ambulance Canopy	OSHPD 1-Proposed	5s								4s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-06826	Interim Drop-off Canopy	OSHPD 1-Proposed	5s								4s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07203	CUP Annex	OSHPD 1-Under Construction	5s								5s				
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07261	Surgery and Emergency Services Pavilion - West	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07262	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07263	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07264	Vestibule Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07265	Mechanical Room	OSHPD 1-In Service	5								2		Intent to Remove GAC	Intent to Remove GAC	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07281	Gas Bottle Storage	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07324	University Tower Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
34 - Sacramento	10619	University of California Davis Medical Center	BLD-07904	Well #1 Enclosure	OSHPD 1-In Service	5s								5s			Rpt: Not Submitted	
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-03267	Main Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/27/2023	
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05493	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05494	Biowaste / Storage Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
34 - Sacramento	10631	Vibra Hospital of Sacramento	BLD-05495	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01458	Original Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01459	ICU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-01460	Conference	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03063	Emergency Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03064	Reception	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03065	Radiology	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03472	Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03761	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-03820	Radiology Wing	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-05467	Women's Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-05874	William and Inez Mabie SNF	OSHPD 2-Skilled Nursing Only	N/A								N/A				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-07362	Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-07363	Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-07763	Electrical Utility Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08093	Pump House #2	OSHPD 1-Proposed	5s								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08094	Pump House #3	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08095	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08096	Pump House #1	OSHPD 1-Proposed	5s								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08097	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08098	WT-03 Water Tank	OSHPD 1-Proposed	5s								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08099	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	BLD-08100	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00071	Diagnostic & Treatment Bldg.	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00072	Nursing Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00073	Clinics Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00074	Mental Health Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00075	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00076	MRI Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	BLD-00077	Loading Dock	OSHPD 1-In Service	3								5				
36 - San Bernardino	16877	Ballard Rehabilitation Hospital	BLD-00293	Hospital	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Open - Returned 12/27/2023	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05294	Main Hospital Tower - North	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05295	Main Hospital - South	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05296	Porte-Cochere	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05297	Entrance Canopy - East	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	18197	Barstow Community Hospital	BLD-05298	Entrance Canopy - West	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	13035	Bear Valley Community Hospital	BLD-00987	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	13035	Bear Valley Community Hospital	BLD-00988	Mechanical Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01003	Building 1 (Main Core)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01004	Building Two	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01005	Building Three	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01006	Building Four	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-01007	Building Five	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07250	Main Entrance Canopy	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07251	Ambulance Canopy	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07252	Nuclear Medicine	OSHPD 1-In Service	3s								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07253	Storage	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07851	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07852	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07853	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07854	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07855	FT-03 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	13072	Chino Valley Medical Center	BLD-07856	FT-04 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01471	Main Hospital, Wing A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01472	Main Hospital, Wing B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	BLD-01473	Main Hospital, Wing C	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/26/2026	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	BLD-07827	Pump House	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10684	Colorado River Medical Center	BLD-07828	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10684	Colorado River Medical Center	BLD-07829	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10684	Colorado River Medical Center	BLD-07830	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01846	Original Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				01/01/2015				N/A				
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01847	Storage Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				01/01/2015				N/A				
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01848	Physical Therapy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/17/2023	Rpt: Not Submitted	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01849	South Hospital	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01850	North Hospital	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01851	Wings 700/800/900	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01852	Utility/Central Plant 1/Service Buildings	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01853	Central Plant #2	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Not Submitted	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-01854	Central Plant #3	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10697	Community Hospital of San Bernardino	BLD-03223	Telecom Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01046	Main Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01047	Birthing Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-01048	Emergency Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-02612	Main Hospital Entrance Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-02613	Emergency Room Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05640	Outpatient Surgery Waiting & Connecting Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05641	Cath Lab and Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-05642	65 Bed Acute Care Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
36 - San Bernardino	12763	Desert Valley Hospital	BLD-07204	ED Addition	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	12763	Desert Valley Hospital	BLD-07602	CUP	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	12763	Desert Valley Hospital	BLD-07606	Oxygen Yard	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	12763	Desert Valley Hospital	BLD-08131	WT Tanks	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-00245	Acute Care Hospital Building	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-00246	Emergency Department Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05124	Continuing Care Center	OSHPD 2-Skilled Nursing Only	N/A								N/A				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05702	Perinatal Addition	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-05703	Pedestrian Walkway	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06062	Emergency Water Supply Pump Enclosure	OSHPD 1-Not a Building Structure	N/A								5				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06105	Cooling Tower and Emergency Generator	OSHPD 1-Equipment Yard	N/A								5				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06106	Emergency Ambulance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06576	Electrical Building	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-06577	Generator Enclosure	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-07882	CCC Electrical Building	OSHPD 2-Proposed	N/A								N/A				
36 - San Bernardino	14100	Hi-Desert Medical Center	BLD-07891	CCC Emergency Generator Enclosure	OSHPD 2-Proposed	N/A								N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01494	Phase 2	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01495	Phase 1A3 - Structurally connected to BLD-01489	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01496	Central Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01498	Phase 4 Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01499	Phase 5 Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 02/27/2023	Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01500	MRI Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 02/27/2023	Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-01501	Telecom Addition	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-03053	Parking Structure	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05250	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05251	Hospital Tower	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05512	Phase 3	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Rebuild			2	1/1/2030	Rpt: Review Completed 04/11/2023	Rpt: Open - Returned 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05564	Hospital Support Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05602	Hospital Drop-off Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05603	ED Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05604	Loading Dock Storage	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05605	Central Plant Storage	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-05606	Pedestrian Tunnel	OSHPD 1-Tunnels	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-06933	MRI Addition #2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-06981	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07182	Phase 2 Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07183	Phase 5 Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Proposed Retrofit Acceptable 09/25/2024	Rpt: Open - Returned 12/06/2023	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07413	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07414	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07415	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07416	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07444	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07445	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	BLD-07601	WT-03 Water Tank	OSHPD 1-Tanks	N/A								N/A				
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-05244	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-05258	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06958	Tech Dock Canopy 1	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06959	Tech Dock Canopy 2	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06960	Tech Dock Canopy 3	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06961	Tech Dock Canopy 4	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06962	E.D. Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06963	Medical Storage Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06964	CUP Expansion	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06965	IT Admin	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-06966	IT Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-07420	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	BLD-07421	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-01466	Building I	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-01467	Ambulance Canopy	OSHPD 1-In Service	4s								4D-L1			Rpt: Review Completed 12/29/2023	
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05842	Building III (Patient Wing 5)	OSHPD 1-In Service	2								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05843	Building IV (Support Services)	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05844	Building V (Patient Wing 6)	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	BLD-05845	Building VI (Patient Wing 7)	OSHPD 1-In Service	2								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-03042	Original Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/20/2024	Rpt: Review Completed 03/20/2024	
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-03043	Generator Enclosure	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 03/20/2024	Rpt: Review Completed 03/20/2024	
36 - San Bernardino	14102	Kindred Hospital Rancho	BLD-07010	Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/20/2024	
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07345	Loma Linda Rehabilitation Hospital	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07346	Porte-Cochere	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07347	Trash Enclosure	OSHPD 1-Under Construction	5s								5s				
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	BLD-07348	Generator Yard	OSHPD 1-Under Construction	N/A								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01479	Main Hospital Tower - Area C	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				7/1/2019 Com Acc Rebuild	4/1/2024 AB 2190 Rebuild		N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01480	Main Hospital Tower - Area B	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					Denied			N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01481	Emergency Room Expansion - 1976	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01482	Northeast Wing - Schuman Pavilion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01483	South Wing Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01484	Emergency Room Expansion - 1987 - Structurally connected to BLD-01481	OSHPD 1-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01485	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-01486	Co-Generation Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-02961	Chiller Facility	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03021	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03022	South Wing Phase I	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03023	Main Hospital Tower - Area A	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				7/1/2019 Com Acc Rebuild	4/1/2024 AB 2190 Rebuild		N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03024	South Wing Phase 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-03025	Original Plant	OSHPD 1-In Service	4D	Denied				12/31/2019 Com Acc Retrofit			4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05372	Utility Tunnel Expansion	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05373	Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05375	Edison Yard (Underground Vault)	OSHPD 1-In Service	N/A								2	1/1/2030	Rpt: Review Completed 12/28/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05482	Emergency Generator Fuel Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05488	South Tower Fuel Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05489	South Tower Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05490	Emergency Generator	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05592	South Wing Tunnel Phase 1	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-05878	New Replacement Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06022	Utility Tunnel – BLD 12B	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06028	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06032	CTP Generator Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06068	Unimed Switchgear	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06070	CTP Decontam Shower	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06071	CTP Loading Dock Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06072	CTP Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06073	CTP Galleria	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06074	CTP 7 & 8 Connector	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06075	CTP Grand Hallway Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06076	Schuman Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06077	Schuman Bridge	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06395	Shop Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06406	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06740	TES Generator	OSHPD 1-Under Construction	5s								4s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06791	CTP Emergency Generator No. 1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06792	CTP Emergency Generator No. 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06793	CTP Emergency Generator No. 3	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06794	CTP Emergency Generator No. 4	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-06839	P3 Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-07786	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-07875	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-07876	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-07877	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10677	Loma Linda University Medical Center	BLD-08108	Linear Accelerator New Vault	OSHPD 1-Proposed	5s								4s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01008	Hospital Ancillary	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: In Review 12/28/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01009	Nursing Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: In Review 12/28/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01010	X-Ray Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: In Review 12/28/2023	Rpt: Review Completed 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-01011	Storage Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: In Review 12/28/2023	Rpt: Review Completed 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-02882	24 Bed Rehabilitation Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-03814	Telephone Building	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: In Review 12/28/2023	Rpt: Review Completed 12/27/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-05593	Mechanical Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-05793	24 Bed Rehabilitation Hospital - Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-07871	Pump House	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-07872	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-07873	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-07874	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	BLD-07949	Entrance Canopy	OSHPD 1-Proposed	5s								4s				
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-05322	Heart and Surgical Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07186	Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07878	Pump House	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07879	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07880	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	BLD-07881	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00963	Service Wing - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00965	Service Wing - Dining Room Addition	OSHPD 1-In Service	5s								4D-L1			Rpt: Review Completed 12/14/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00966	Service Wing - Medical Records Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00967	North Wing - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00968	North Wing - Labor & Delivery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00969	East Wing - Original Hospital	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-00970	Plant Services - Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-02737	Plant Services - Engineering Addition	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/14/2023	
36 - San Bernardino	12992	Montclair Hospital Medical Center	BLD-06936	Monochloramine Generating Station	OSHPD 1-Proposed	5s								4s				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01474	Main Building	OSHPD 1-In Service	2	Denied				7/1/2017 Risk Bsd Retrofit			2		Rpt: Awaiting review 09/08/2026	Rpt: Review Completed 12/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01475	Radiology/Lab and ER Addition	OSHPD 1-In Service	5								2		Rpt: Not Submitted	Rpt: Review Completed 12/19/2025	
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01476	ER Addition - Structurally connected to BLD-01475	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01477	Emergency Generator Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-01478	Oxygen Storage Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10681	Mountains Community Hospital	BLD-03687	Emergency Generator Bldg II	OSHPD 1-In Service	5								2		Rpt: Not Submitted	Rpt: Review Completed 12/19/2025	
36 - San Bernardino	10681	Mountains Community Hospital	BLD-05687	LOX Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/19/2025	
36 - San Bernardino	10681	Mountains Community Hospital	BLD-06479	Skilled Nursing Building	OSHPD 1R-Skilled Nursing Only	N/A								N/A				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-07304	Med/Surg and ED Addition	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10681	Mountains Community Hospital	BLD-07305	Porte-Cochere	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01821	Original Hospital & ER	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01822	Transitional Care-CCU/ICU	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01823	Emergency Addition - Structurally connected to BLD-01821	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01824	CCU/ICU Addition - Structurally connected to BLD-01822	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01825	Boiler Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01826	Chiller Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01827	Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01828	West Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01829	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01830	Obstetrics/Prenatal/LDR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01831	Medical/Surgical	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-01832	New Hospital Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-02928	MRI Building	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06087	Filter Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06088	South Building Connector	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06089	South Building West Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06090	South Building South Canopy	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06230	Inpatient MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06404	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10695	Providence St. Mary Medical Center	BLD-06405	Generator Distribution / Transfer Switch Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01801	Original Main Hospital	OSHPD 1-In Service	2					1/1/2015 Com Acc Remove GAC			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01802	Part 1 Addition - Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01803	Part 2 Addition - Surgery	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01804	Part 3 Addition - Admitting	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01806	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01807	Radiology Addition	OSHPD 1-In Service	2					1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01808	Patient Tower	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/12/2023	Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01809	Central Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01810	North Hallway	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01811	Radiotherapy Addition	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-01813	Emergency Building 2	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02812	Phase 2 Building Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02813	1958 Radiology Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	BLD-02814	Electrical Utility Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10691	Redlands Community Hospital	BLD-05892	Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-05904	Oxygen Farm	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06299	Gift Shop Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06327	North / South Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-06328	East / West Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/26/2023	
36 - San Bernardino	10691	Redlands Community Hospital	BLD-07474	Phase 3 Replacement Building	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10691	Redlands Community Hospital	BLD-07633	Pump House	OSHPD 1-Proposed	5s								5s				
36 - San Bernardino	10691	Redlands Community Hospital	BLD-07634	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01833	Auditorium & Administration	OSHPD 1-In Service	2			01/01/2015					2	1/1/2030	Rpt: In Review 12/14/2023	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01834	Latimer Wing	OSHPD 1-In Service	2			01/01/2015		1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Awaiting review 12/14/2023	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01835	Maternity - Structurally connected to BLD-01834	OSHPD 1-Not an Independent Building	N/A			01/01/2015		Withdrawn			N/A				
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01836	Power Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01837	Laundry Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01838	Main Building	OSHPD 1-In Service	2			Denied					2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01839	Increment II, Phase 1 - East	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01840	Increment II	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01841	Maternity Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01842	Mental Health - South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01843	Increment II - Phase 2 East & Middle	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Awaiting review 12/14/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-01845	NICU Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03020	Increment II - Phase 2 West Section	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03542	Mental Health - North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/14/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-03548	Increment II, Phase 1 - North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-05253	Main Hospital Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06154	New Oxygen Service Area	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06377	East Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06378	West Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06385	Central Plant	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06386	Emergency Drive Canopy	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06387	Emergency Walkway Canopy	OSHPD 1-In Service	3								3		Rpt: Awaiting review 08/19/2026	Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06604	Main Electrical Switchgear Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-06619	New Tower - Pedestrian Corridor	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
36 - San Bernardino	10696	San Antonio Regional Hospital	BLD-07626	West Wing Corridor (formerly Latimer / Maternity)	OSHPD 1-Proposed	2s								2s				
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01814	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					4/1/2019 Com Acc Replace			N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01815	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2016 Risk Bsd Remove GAC			N/A				
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01816	Emergency Building	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01817	Central Tower	OSHPD 1-In Service	4D					12/31/2019 Com Acc Retrofit			2	1/1/2024	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01818	North Tower	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01819	Service Building	OSHPD 1-In Service	4								3		Rpt: In Review 10/25/2016	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-01820	Ancillary Building	OSHPD 1-In Service	2								3		Rpt: Awaiting review 12/18/2023	Rpt: Review Completed 12/25/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-03363	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-05639	IT Services Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06229	CoGen Plant	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06255	Loading Dock Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06259	CCU Med Air and Vacuum Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06260	Medical Gas Canopy	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/25/2023	
36 - San Bernardino	10694	St. Bernardine Medical Center	BLD-06287	Conference Center	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/25/2023	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-04912	Subacute	OSHPD 2-Skilled Nursing Only	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-05483	Acute Care Building No. 1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-05959	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/15/2023	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-06126	Medical Gas Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	BLD-06127	Lighthouse Bulk Medical Gas Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01855	Medical / Surgical / Surgery Add	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01856	Radiology/Surgery/L&D/Emergency	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01857	Equipment Shelter Pump House	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01858	Emergency Building - Structurally connected to BLD-01856	OSHPD 1-Not an Independent Building	N/A								N/A				
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01859	Nursing Wing (BHU/PCU)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01860	Cath Lab/ICU/Outpatient Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01861	Emergency Generator Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-01862	Urgent Care E.R. Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03131	O.B. Addition	OSHPD 1-Under Construction	N/A	Denied							N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03132	Canopy Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/10/2024	Rpt: Not Submitted	
36 - San Bernardino	10707	Victor Valley Global Medical Center	BLD-03134	Helistop	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/10/2024	Rpt: Not Submitted	
37 - San Diego	12322	Grossmont Hospital	BLD-02098	Emergency Generator Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02099	West Wing - West	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02100	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02101	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-02102	Central Plant & Cooling Plant Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/03/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02103	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02104	Physical Rehabilitation Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12322	Grossmont Hospital	BLD-02105	Meeting Room Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02622	Main Entry	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-02829	Heart and Vascular Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-02830	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12322	Grossmont Hospital	BLD-03678	Old Administration Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-03683	Womens Health Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-03685	East Wing Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-03767	West Wing - East	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-03768	West Wing - North	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/06/2023	Rpt: Review Completed 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	BLD-05312	Mental Health Building	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12322	Grossmont Hospital	BLD-05336	ED/CCU and ACNU Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05368	Physical Rehabilitation Utility Vault	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-05510	MRI / Angio Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-05678	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05764	Emergency Generator 1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-05765	Emergency Generator 2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-06787	Neuro ICU Addition	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12322	Grossmont Hospital	BLD-06788	PCU Addition	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12322	Grossmont Hospital	BLD-06867	Main Entry Canopy	OSHPD 1-In Service	4								2		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12322	Grossmont Hospital	BLD-07007	South Loading Dock	OSHPD 1-In Service	4D								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07008	Utility Trellis	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07070	Tunnel / Storage Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07071	ER Substation	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07153	Oxygen Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/15/2023	
37 - San Diego	12322	Grossmont Hospital	BLD-07685	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
37 - San Diego	12322	Grossmont Hospital	BLD-07686	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-02943	Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-03552	Central Utility Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-05690	Hospital Support Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06311	Main Entrance Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06312	Emergency Entry Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06313	Fire Pump Room	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06314	Tech Dock Canopy - Lower	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	BLD-06315	Tech Dock Canopy - Upper	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06531	Hospital Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06532	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06533	Entry Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06534	ED Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-06536	Garden Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07097	Tech Dock Canopy West	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07098	Tech Dock Canopy East	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07100	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								5				
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	BLD-07101	Bunker Fire Pump Rooms	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00198	Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 06/05/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00199	Hospital Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00200	Clinic Tower Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00201	Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 06/05/2023	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00202	Emergency Generator Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/16/2022	Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-00203	Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-03295	Med Gas Chain Link Fence Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-07426	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-07427	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-07428	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	BLD-07429	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02106	Building I (Building A)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02107	Building II (Building B)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02108	Building III (Building C)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Awaiting review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02109	Building IV (Building D)	OSHPD 1-In Service	4								4D-L1			Rpt: Awaiting review 12/22/2023	
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-02110	Building V (Building E)	OSHPD 1-In Service	4								4D-L1			Rpt: Awaiting review 12/22/2023	
37 - San Diego	12328	Kindred Hospital - San Diego	BLD-07607	Exterior Blue Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Awaiting review 12/22/2023	
37 - San Diego	18230	Palomar Rehabilitation Institute	BLD-06258	Palomar Rehabilitation Institute	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	18173	Palomar UCSD Medical Center Escondido	BLD-05231	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
37 - San Diego	18173	Palomar UCSD Medical Center Escondido	BLD-05232	Central Plant	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/29/2023	
37 - San Diego	18173	Palomar UCSD Medical Center Escondido	BLD-07814	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	18173	Palomar UCSD Medical Center Escondido	BLD-07815	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-00255	Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-00256	Ancillary Building (East)	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-00257	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-00258	Angio / Cath Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-00259	Emergency Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-02896	Co-Generation Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03240	Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03241	Pedestrian Link	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03588	Villa Pomerado	OSHPD 2-Skilled Nursing Only	N/A								N/A				
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03589	Steam Plant	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03592	Patient Elevator Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-03593	Lobby	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-06245	Ancillary Building (West)	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-06246	Loading Dock/Electrical Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/29/2023	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-06451	Power Conditioning UPS/ATS Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-06808	Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-07812	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	14190	Palomar UCSD Medical Center Poway	BLD-07813	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12348	Paradise Valley Hospital	BLD-02132	Main Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12348	Paradise Valley Hospital	BLD-02133	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12348	Paradise Valley Hospital	BLD-02134	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02135	ER Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02136	Boiler Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02137	Pediatrics Wing	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02138	Chiller Building	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02139	Generator Building	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02140	Medical Office Building	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/04/2023	Rpt: Review Completed 12/18/2023	
37 - San Diego	12348	Paradise Valley Hospital	BLD-02141	Storage Building - BLD-06432 at 24384	OSHPD 1-Not an Independent Building	N/A					12/1/2015 Risk Bsd Replace			N/A				
37 - San Diego	12348	Paradise Valley Hospital	BLD-07857	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12348	Paradise Valley Hospital	BLD-07858	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12348	Paradise Valley Hospital	BLD-07859	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02066	Dining Room - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02070	2nd Dining Room - Original Hospital	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02071	Intensive Care Unit	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 03/23/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02072	Co-Generation Plant	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02073	Clinical Lab	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02076	Radiology Addition	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02079	Children's Way Pavilion (15A & 15B)	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02080	Childrens Way Pavilion - Clock Tower	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02669	Surgical Unit	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02770	Gas Storage Building	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02772	Bridge to Acute Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-02773	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03127	C Wing - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03128	D Wing - Original Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03129	Bridge to Sharp Hospital - Structurally connected to BLD-03128	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03130	Trauma Room Addition	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03195	Intensive Care Unit	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03197	Passageway to NICU	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03198	Children's Way Pavilion - Bridge	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03647	Acute Care Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-03896	Hahn Pavilion Loading Dock Canopy	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 03/23/2023	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06800	ICU/ES Pavilion	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06801	Campus Connector	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06802	Central Utility Plant	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06803	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06804	Ambulance Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-06805	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-07360	MBH Bridge	OSHPD 5-Proposed	N/A								N/A				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-07361	Mental and Behavioral Health Building (MBH)	OSHPD 5-Proposed	N/A								N/A				
37 - San Diego	12285	Rady Children's Hospital San Diego	BLD-07705	Electrical Doghouse	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	14181	Scripps Green Hospital	BLD-00250	Original Building - Phase I North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00251	Original Building - Phase I South Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00253	Dining and Kitchen Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	14181	Scripps Green Hospital	BLD-00254	Storage & Maintenance Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	14181	Scripps Green Hospital	BLD-02662	Heart, Lung, Vascular Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/15/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02085	Wood Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02086	Masonry Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02088	OSA Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 03/21/2025	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02089	East Wing Addition - North	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02090	Emergency Room Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02091	ICU Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-02586	Loading Dock	OSHPD 1-In Service	3								4D-L1			Rpt: Not Submitted	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03553	Central Energy Plant Service Yard	OSHPD 1-Equipment Yard	N/A								5				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03673	East Wing Addition - South	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-03674	East Wing Addition - Center	OSHPD 1-In Service	3								4D-L1			Rpt: Review Completed 12/04/2023	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-05299	Critical Care Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-05301	Central Energy Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06537	Acute Care Building	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06538	Entry Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	BLD-06539	Loading Dock	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01118	Building 1-3-4	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01119	Building 1-A	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01120	West Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01121	Transition Tower (& 5A)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01122	Addition to Women's Center - Structurally connected to BLD-01121	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01123	East Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01124	Building 7	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01125	Service Building (8, 8A, 8B)	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01126	Co-Generation Plant	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01127	Building 10	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01128	Emergency Expansion	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-01129	Building 6A	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02583	Dining Area Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02584	Mericos Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-02585	Outpatient Waiting Room	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03051	Building 10A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03549	Scripps Clinic La Jolla Medical Office Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03550	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-03551	Prebys Cardiovascular Institute Pedestrian Walkway	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-05266	Prebys Cardiovascular Institute	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-05267	Central Energy Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06436	New Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06747	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-06927	Pedestrian Tunnel	OSHPD 1-Proposed	5s								4s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07213	RA/Chem Storage	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07214	Bio Hazard Storage	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07905	Tower III	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07906	Staff Connector	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	BLD-07908	Transitional Loading Dock	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02114	Main Hospital Tower	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02115	Main Hospital Wing	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02116	ICU Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02119	ICU Addition	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02120	Elevator Tower	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02121	Ambulatory Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02122	Ambulatory Add - Elevator Tower	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02123	Ambulatory Addition	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02124	Ambulatory Addition - Structurally connected to BLD-02121	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02589	Mechanical Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-02590	Clinic Building	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03543	Central Energy Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03545	Canopy 1	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03546	Canopy 2	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03547	Canopy 3	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03712	Ambulatory Add - Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-03713	Ambulatory Add - East Stair Add	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12339	Scripps Mercy Hospital	BLD-05637	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12339	Scripps Mercy Hospital	BLD-05638	Replacement Stair - Structurally connected to BLD-02119	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06492	Replacement Hospital	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06493	New Canopy 1	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06806	Pedestrian Access Bridge	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06853	Canopy 2	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06854	Pedestrian Access Canopy	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12339	Scripps Mercy Hospital	BLD-06855	Canopy 3	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02055	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02056	Tower Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02057	Emergency Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02058	Hospital Expansion	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02060	Hospital Expansion - Emergency Dept	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-02061	Mechanical Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03044	Hospital Expansion - Lobby	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03045	Hospital Expansion - ICU	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/21/2023	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03842	Connector Building - Structurally connected to BLD-02056	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03874	Modular Cath Lab	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-03875	Cath Lab Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	BLD-07740	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								2s		Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08041	Central Energy Plant	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08042	Utility Tunnel 1	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08043	Hospital Tower 1 Canopy	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08044	Hospital Tower 2 Canopy	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08045	Hospital Tower 2	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08046	Hospital Connector	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08047	Hospital Loading Dock	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10105	Scripps San Marcos Hospital	BLD-08048	Hospital Tower 1	OSHPD 1-Proposed	5s								5s				
37 - San Diego	16703	Select Specialty Hospital - San Diego	BLD-00292	Hospital and M.O.B.	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/21/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00227	East Tower - North Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00228	East Tower - South Portion	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00229	West Tower - Lobby	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Review Completed 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-00230	Cardiac Operating Room Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Review Completed 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02717	West Tower - Administrative Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Review Completed 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02718	Emergency Generator Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02719	West Tower - Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 09/07/2023	Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-02828	Ocean View Tower	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05673	Entry Building	OSHPD 1-In Service	5								5				Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05674	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-05969	Birch Patrick Convalescent Center	OSHPD 2-Skilled Nursing Only	N/A								N/A				
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06011	Loading Dock Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06238	Bulk O2 Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Not Submitted	
37 - San Diego	13336	Sharp Chula Vista Medical Center	BLD-06394	Gas Bottle Storage	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02081	Main Tower	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02082	ICU Building (Emergency Department Building)	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02083	Ancillary Building	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-02827	Prospect Place Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03680	Morgue Building	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03681	Long Term Care Building (Outpatient Pavilion Building)	OSHPD 1-In Service	4D								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-03682	Sub Acute Care II Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	BLD-07669	Emergency Department Plaza Canopy	OSHPD 1-Proposed	5s								4s				
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-03892	Mary Birch Womens Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/12/2022	Rpt: Not Submitted	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06769	Mary Birch Expansion	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06900	Loading Dock Canopy	OSHPD 1-Proposed	5s								4s				
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-06903	Temporary Dietary Exit Canopy	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	BLD-07578	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01130	North Tower - East Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01131	North Tower - Central Building	OSHPD 1-In Service	2			01/01/2014					2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01132	North Tower - West Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 02/27/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01133	Inter-Hospital Passageway	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01134	South Tower	OSHPD 1-In Service	2				01/01/2014				2	1/1/2030	Rpt: Review Completed 01/09/2023	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01135	Rehabilitation Center	OSHPD 1-In Service	3								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01136	Emergency / Radiology	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01137	Dietary Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01138	Service Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01139	Long Term Care Building	OSHPD 1-In Service	2								4D-L1			Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01140	MRI Building	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-01142	New Central Plant	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-02835	New Acute Care Tower (Stephen Birch West Tower)	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-02836	Stephen Birch East Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03753	Corridor 1 - North	OSHPD 1-In Service	2					1/1/2018 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03754	Corridor 1 - South	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03755	Corridor 2 - North	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03756	Corridor 2 - Middle	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03757	Corridor 2 - South	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-03758	Corridor 2 - Long Term Care	OSHPD 1-In Service	4								4D-L1			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05526	Passageway Link	OSHPD 1-In Service	2					1/1/2018 Risk Bsd Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05527	Telephone Switch Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05534	Corridor 1 - North Segment B	OSHPD 1-In Service	4					Denied			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05535	Corridor 1 - North Segment C	OSHPD 1-In Service	4					Denied			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05540	Kitchen / Pharmacy Storage Building - Structurally connected to BLD-01136	OSHPD 1-Not an Independent Building	N/A					1/1/2018 Risk Bsd Retrofit			N/A				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05550	Outpatient Pavilion	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05551	Shop Building	OSHPD 1-In Service	2s								2s		Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05975	Emergency Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05976	Parking Structure Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05977	East Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05978	Main Front Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-05979	Lower Level SB Connector	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06596	Campus Connector (Center)	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06755	New Central Energy Plant	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06756	ED Expansion	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06757	New Oxygen Yard	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06768	New Tower	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06810	Electrical Yard	OSHPD 1-Proposed	N/A								4s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06851	ED Canopy	OSHPD 1-Under Construction	5s								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06901	Campus Connector - North	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-06902	Campus Connector - South	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07571	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07573	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07574	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07575	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07576	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12364	Sharp Memorial Hospital	BLD-07577	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
37 - San Diego	12372	Tri-City Medical Center	BLD-01143	Center Tower	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01144	North Wing	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01145	Center Complex - North	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01146	South Tower	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/14/2024	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01147	Electrical Building	OSHPD 1-In Service	2	Denied							4D-L1			Rpt: In Review 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	BLD-01148	1976 Center Complex Addition	OSHPD 1-In Service	4	Denied							4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01149	Materials/Laboratory Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01150	1976 Radiology Addition	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01151	Emergency Room Addition	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01152	Administration Building	OSHPD 1-In Service	4	Denied							4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01153	Pavilion Building Canopy	OSHPD 1-In Service	4	Denied							4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01154	Pavilion Building	OSHPD 1-In Service	4	Denied							4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-01155	Ancillary Building	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12372	Tri-City Medical Center	BLD-02868	South Tower Stair Shaft - Structurally connected to BLD-01146	OSHPD 1-Not an Independent Building	N/A	Denied				6/28/2013 Risk Bsd Retrofit			N/A	1/1/2030			
37 - San Diego	12372	Tri-City Medical Center	BLD-02869	Electrical Building Addition	OSHPD 1-In Service	4	Denied							4			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02870	Emergency Room Addition Canopy	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02871	Perinatal Unit/Women's Center	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02872	Perinatal Unit/Women's Center Canopy 1	OSHPD 1-In Service	4	Denied							4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02873	Perinatal Unit/Women's Center Canopy 2 - Structurally connected to BLD-02872	OSHPD 1-Not an Independent Building	N/A	Denied							N/A				
37 - San Diego	12372	Tri-City Medical Center	BLD-02874	Perinatal Unit/Women's Center Canopy 3	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02875	Surgery Addition 1	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02876	Surgery Addition 2	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02877	Surgery Addition Canopy	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-02878	Central Plant	OSHPD 1-In Service	4	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-03766	Center Complex - South	OSHPD 1-In Service	3	Denied							2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/30/2023	Rpt: In Review 12/30/2023	
37 - San Diego	12372	Tri-City Medical Center	BLD-05487	Behavioral Health Unit	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12372	Tri-City Medical Center	BLD-06565	Utility Tunnel	OSHPD 1-Tunnels	N/A								4D-L1			Rpt: In Review 12/30/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00935	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/21/2023	Rpt: Review Completed 11/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00938	Service Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/21/2023	Rpt: Review Completed 11/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-00939	Fire Pump Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/21/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-03050	East Equipment Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/21/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-03453	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-06631	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-07193	Rehabilitation Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/20/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-07194	Connecting Bridge	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 11/20/2023	Rpt: Review Completed 11/22/2023	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08076	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08077	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08078	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08079	Pump House #1	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08080	Pump House #2	OSHPD 1-Proposed	5s								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08081	Fuel Tank #1	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08082	Fuel Tank #2	OSHPD 1-Proposed	N/A								5s				
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	BLD-08083	Fuel Tank #3	OSHPD 1-Tanks	N/A								N/A				
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02142	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02143	Ancillary & Support Services Facility	OSHPD 1-In Service	3								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02144	West Wing & Psychiatric Inpatient	OSHPD 5-Acute Psych Only	N/A								N/A				
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02145	Central Plant - Structurally connected to BLD-03304	OSHPD 1-Not an Independent Building	N/A								N/A				
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02146	Utility Line Bridge	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02147	Telecommunications	OSHPD 1-In Service	5								4			Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-02148	Outpatient Clinic	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03304	Boiler House and Shops	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03853	OR Suite Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-03854	Delivery / Surgery Expansion	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05175	Utility Line Bridge - South	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05560	Chiller Building	OSHPD 1-In Service	5								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	BLD-05846	Emergency Generator Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-02561	Main Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-02846	Main Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05315	UCSD Sulpizio Family Cardiovascular Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05419	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05420	Bed Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-05974	Emergency Preparedness Supplies Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	BLD-07320	MRI Suite Expansion	OSHPD 1-Under Construction	5s								4s				
37 - San Diego	10086	UCSD Health Hillcrest Medical Center	BLD-08101	Hospital Building	OSHPD 1-Proposed	5s								5s				
37 - San Diego	10086	UCSD Health Hillcrest Medical Center	BLD-08102	Central Utility Plant	OSHPD 1-Proposed	5s								5s				
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01100	North Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01101	Link Building	OSHPD 1R-Acute Psych / SNF only	N/A					7/1/2019 Com Acc Rebuild			N/A				
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01102	South Tower	OSHPD 1R-Acute Psych / SNF only	N/A					7/1/2019 Com Acc Rebuild			N/A				
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01103	Rehabilitation Building	OSHPD 1R-Acute Psych / SNF only	N/A					1/1/2015 Com Acc Rebuild			N/A				
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01104	Emergency Systems Additions	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	BLD-01105	MER Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2023	
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	BLD-03810	New Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	BLD-07628	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A								N/A				
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	BLD-07629	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
38 - San Francisco	18165	California Pacific Medical Center - Van Ness Campus	BLD-03801	New Acute Care Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
38 - San Francisco	14621	Chinese Hospital	BLD-00316	Comprehensive Health Care Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	
38 - San Francisco	14621	Chinese Hospital	BLD-05688	Patient Tower	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/21/2023	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01093	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 10/31/2022	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01094	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2022	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01095	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/19/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01096	MEE Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/19/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-01097	Doctor's Sleep Annex	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 01/17/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	BLD-06935	Loading Dock Extension	OSHPD 1-In Service	4								3		Rpt: Review Completed 09/07/2022	Rpt: Review Completed 12/06/2023	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-03809	South Residence	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05918	North Residence	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05919	Pavilion Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-05920	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06623	Connecting Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06772	Knuckle Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06773	North Knuckle - SRB Connecting Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06774	South Knuckle - SRB Connecting Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06775	Loading Dock	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06781	Water Tank #1	OSHPD 1-Tanks	N/A								N/A				
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	BLD-06782	Water Tank #2 (WT-02)	OSHPD 1-Tanks	N/A								N/A				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01069	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01070	M Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-01071	Service Building	OSHPD 1-In Service	5			Withdrawn					2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/29/2025	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	BLD-03339	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2025	
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	BLD-01072	Main Tower	OSHPD 1-In Service	2								3R		Rpt: Review Completed 12/18/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	BLD-01073	McAuley Wing	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
38 - San Francisco	12457	UCSF Health Hyde Hospital	BLD-01079	Main Tower	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health Hyde Hospital	BLD-01080	1958 Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: In Review 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health Hyde Hospital	BLD-01081	Pierotti Pavilion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: In Review 12/26/2023	
38 - San Francisco	12476	UCSF Medical Center	BLD-01012	Moffitt Hospital	OSHPD 1-In Service	2								3		Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12476	UCSF Medical Center	BLD-01013	Long Hospital	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/21/2023	
38 - San Francisco	12476	UCSF Medical Center	BLD-01014	Emergency Entrance Structure	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/21/2023	
38 - San Francisco	12476	UCSF Medical Center	BLD-01016	Central Utilities Plant	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	
38 - San Francisco	12476	UCSF Medical Center	BLD-06771	Helen Diller Hospital	OSHPD 1-Under Construction	5s								5s				
38 - San Francisco	12476	UCSF Medical Center	BLD-06928	Oxygen Yard	OSHPD 1-Under Construction	N/A								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-06994	Pump House	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-07135	Electrical Building	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-07377	Fire Suppression House	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	12476	UCSF Medical Center	BLD-07378	FT Fuel Tanks	OSHPD 1-Under Construction	5s								4s				
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	BLD-05445	UCSF Benioff Children's Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	BLD-05523	Energy Center	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01082	Building A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: In Review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01083	Building B	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01084	Building D - Structurally connected to BLD-01083	OSHPD 1-Not an Independent Building	N/A				01/01/2015				N/A				
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	BLD-01085	Building R	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01876	Central (Main)/East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01877	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01878	Central Plant	OSHPD 1-In Service	4s								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01879	North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Awaiting review 12/22/2023	Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-01880	Emergency Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-02864	New Patient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-03624	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	BLD-07232	New Elevator Tower	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10729	Dameron Hospital	BLD-01863	1987 Building - 87-A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01864	1987 Building - 87-B	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01865	1975 Building - 75-A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01866	1967 Building - 67-A	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	BLD-01867	1964 Building - 64-A	OSHPD 1-In Service	2	Denied				Withdrawn			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	BLD-01868	1957 Building - 57-A - Structurally connected to BLD-01871	OSHPD 1-Not an Independent Building	N/A					Denied			N/A				
39 - San Joaquin	10729	Dameron Hospital	BLD-01869	Generator Building - Fuel Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01870	Generator Building - Cooling Tower	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-01871	1932 Building - 32-A	OSHPD 1-In Service	2	Denied				1/1/2015 Com Acc Rebuild			2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	BLD-03615	Generator Building	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10729	Dameron Hospital	BLD-05397	Generator Building - Bulk Oxygen	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01881	Main Hospital & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01882	Outpatient/Administration	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01883	OR Addition/Meeting Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01884	East Patient Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01885	Purchasing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01886	Telephone Equipment Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01887	ER Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01888	X-Ray Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01889	Ultrasound/Storage	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01890	CT Scan	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01891	OB Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01892	Mechanical Equip. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01893	Entrance Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01894	OR Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01895	LDR Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/19/2023	
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01896	Mechanical Equip. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/19/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-01897	Freezer - Structurally connected to BLD-01881	OSHPD 1-Not an Independent Building	N/A								N/A				
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-07687	Pump House	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-07688	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-07689	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-07690	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10745	Doctors Hospital of Manteca	BLD-07692	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00065	East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Open - Returned 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00066	West Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Open - Returned 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-00067	Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 01/19/2023	Rpt: Open - Returned 11/17/2023	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07075	Emergency Department Expansion	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07273	Emergency Department Canopy A	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07274	Emergency Department Canopy B	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07275	Emergency Department Canopy C	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07276	Emergency Department Canopy D	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07277	MRI Canopy A	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07278	MRI Canopy B	OSHPD 1-Under Construction	5s								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07459	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	BLD-07460	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01911	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2024	Rpt: Review Completed 12/31/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01912	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01913	OPD Building / Conference Center / Admin Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2015 Com Acc Replace			N/A				
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01914	OPD Emergency Generator Shed	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn				7/1/2019 Com Acc Remove GAC			N/A				
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01915	Dietary Building	OSHPD 1-In Service	2	Withdrawn				1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/31/2024	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-01917	A & B Wings	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn				12/31/2019 Com Acc Rebuild			N/A				
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03035	Loading Dock	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03171	Clinical Laboratory	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03172	Area F	OSHPD 1-In Service	5s								5s			Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03726	Compacter / Sterilizer / Baler	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03727	Connecting Link - Part 1 - North	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03728	Connecting Link - Part 2 - North	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03729	Area D	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03730	Area E	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03731	Main Hospital Canopy	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03732	Connecting Link - Part 1 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03733	Connecting Bridge - Part 1 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03734	Connecting Bridge - Pylon	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03735	Connecting Link - Part 2 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03736	Connecting Bridge - Part 2 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03737	Connecting Bridge - Pylon 2	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10753	San Joaquin General Hospital	BLD-03738	Connecting Link - Part 3 - West	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/23/2024	Rpt: Review Completed 12/31/2024	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01898	Main Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				01/01/2015				N/A				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01899	North Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01900	South Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01901	West Wing	OSHPD 1-In Service	2				01/01/2015				2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01902	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01903	Administrative Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01904	Southeast Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01905	Cafeteria	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01906	Heart Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01907	Outpatient Surgery Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01908	Cancer Center (Main Entrance)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-01909	Hospital Main Entrance (Admitting)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03367	Women & Children's Pavilion Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03369	LOX Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03370	New Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03371	Pedestrian Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03492	Elevator Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03493	Kitchen Remodel 1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03494	Kitchen Remodel 2	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03495	Material Management Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03496	Utility Plant	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-03575	Generator Enclosure for Women and Children's Pavilion Building	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07237	Ambulance Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07238	Stair Tower	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07239	ED Lobby Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07240	Linear Accelerator Building	OSHPD 1-In Service	4								2		Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07241	Arcade	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07242	OSB Canopy	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07243	Main Entrance Canopy	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07244	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07343	North Tower	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-07653	Dietary Dock	OSHPD 1-Under Construction	5s								4s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08065	Pump House	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08066	WT-01 Water Tanks	OSHPD 1-Proposed	N/A								5s				

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08067	WT-02 Water Tanks	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08068	WWT-01 Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08069	WWT-02 Wastewater Tanks	OSHPD 1-Proposed	5s								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08070	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08071	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08072	FT-03 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08073	FT-04 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08109	Utility Electrical Service Room	OSHPD 1-Proposed	5s								4s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08110	Electrical Outbuilding	OSHPD 1-Proposed	5s								4s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08111	Bulk Oxygen Storage Enclosure	OSHPD 1-Proposed	N/A								4s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08112	Medical Gas Cylinder Enclosure	OSHPD 1-Proposed	5s								4s				
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	BLD-08113	Generator Yard	OSHPD 1-Proposed	N/A								4s				
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06280	Stockton Rehabilitation Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06282	LOX Tank	OSHPD 1-Equipment Yard	N/A								5				
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	BLD-06319	Porte Cochere	OSHPD 1-In Service	5								5				Earthquake Resilient
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01918	Original Hospital Building / Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01919	Building Block No. 2	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01920	1976 Alterations & Additions	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-01921	Two Story Addition West	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03046	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03075	Central Plant	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03200	North Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03345	Northwest Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03346	One Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03347	Northeast Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03348	West Canopy	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/26/2023	Rpt: Not Submitted	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03903	Ambulatory Care Entrance Corridor	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-03904	Ambulatory Care Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-07761	Bulk Medical Gas Yard	OSHPD 1-Proposed	N/A								5s				
39 - San Joaquin	10757	Sutter Tracy Community Hospital	BLD-07762	Storage Building	OSHPD 1-Proposed	5s								4s				
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00839	Main Hospital and Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00840	Patient Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00841	West Wing	OSHPD 1-In Service	3					Withdrawn			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	BLD-00842	E. R. Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/22/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00241	Main Hospital	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00242	Radiology Addition/Cath Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00243	E.R. Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-00244	Administrative Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 11/27/2023	Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03458	Diagnostic & Treatment Expansion	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03459	West Nurse Addition	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03460	Support Service Building	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-03461	Patient Tower Addition	OSHPD 1-In Service	5					Denied			4			Rpt: Review Completed 12/06/2023	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-05966	Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	BLD-05967	Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	BLD-07154	Dignity Health Central Coast Rehabilitation Hospital	OSHPD 1-Proposed	5s								5s				
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	BLD-07155	Porte-Cochere	OSHPD 1-Proposed	5s								5s				
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00955	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00956	Cath Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-00957	Surgery Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-03600	Mechanical Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-05622	Electrical Room	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06242	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06458	Patient Tower Addition	OSHPD 1-Proposed	5s								5s				
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06630	Chapel	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06642	Generator Yard	OSHPD 1-Proposed	N/A								4s				
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06675	Bell Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06745	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	12964	French Hospital Medical Center	BLD-06746	Patient Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01922	Canopy	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01923	Kitchen Addition	OSHPD 1-In Service	5								4D-L1			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01924	Central Supply	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01925	Skilled Nursing	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01926	Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01927	Critical Care Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01928	Corridor	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01929	Surgery, Emergency, Food Service	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01930	Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01931	Main Entrance	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01932	Storage and Service	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-01933	Nursing Unit, Admin, Laboratory	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-03310	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	BLD-03312	Acute Rehab	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00846	1963 Tower	OSHPD 1-In Service	2	Withdrawn				12/31/2019 Fin Hdsp Retrofit			3R		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00847	Front Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Withdrawn				12/31/2019 Fin Hdsp Replace			N/A				
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00848	Area A & B	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00849	Area C	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00850	Area D	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00851	Center Pod	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00852	South Pod	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10801	AHMC Seton Medical Center	BLD-00853	Utilities Service Building	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-03280	Central Plant	OSHPD 1-In Service	5								5				Earthquake Resilient
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-05277	Replacement Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	BLD-06356	Medical Office Building 2	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00177	Hospital - Building 1	OSHPD 1-In Service	2								3		Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00178	Hospital - Building 2	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00179	Hospital Tower - Building 3	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00180	Hospital - Building 4	OSHPD 1-In Service	2								3		Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00181	Hospital - Building 5	OSHPD 1-In Service	4D								3		Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00182	Hospital - Building 6	OSHPD 1-In Service	2								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00183	Hospital - Building 7.1	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00184	Hospital - Building 8	OSHPD 1-In Service	3								2	1/1/2024	Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-00185	Hospital - Building 9	OSHPD 1-In Service	3								3		Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-03475	Hospital - Building 6 Canopy	OSHPD 1-In Service	2								4			Rpt: Open - Returned 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-03477	Hospital - Building 7.2 Exhaust Hood	OSHPD 1-In Service	4								3		Rpt: Review Completed 09/02/2021	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-06030	Chiller Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/15/2023	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-07536	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-07537	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	BLD-07538	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
41 - San Mateo	10804	Mills-Peninsula Medical Center	BLD-03217	New Hospital	OSHPD 1-In Service	5s								5s			Rpt: In Review 12/28/2023	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00856	Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00857	Nursing Wing	OSHPD 1-In Service	5								2	1/1/2024	Rpt: Not Submitted	Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00858	Nursing Wing Link	OSHPD 1-In Service	5								2	1/1/2024	Rpt: Review Completed 08/31/2007	Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-00859	North Addition	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-02636	Diagnostic and Treatment Center	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
41 - San Mateo	10810	San Mateo Medical Center	BLD-03317	1958 Building - Structurally connected to BLD-00854	OSHPD 1-Not an Independent Building	N/A								N/A				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07103	Soiled Storage Canopy	OSHPD 1-Under Construction	5s								4s				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07104	Med Gas Storage Shed	OSHPD 1-Under Construction	5s								4s				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07195	Central Plant Loading Dock Canopy	OSHPD 1-Under Construction	5s								4s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
41 - San Mateo	10810	San Mateo Medical Center	BLD-07451	WT-01 Water Tank	OSHPD 1-Tanks	N/A								N/A				
41 - San Mateo	10810	San Mateo Medical Center	BLD-07691	North Addition - South Side	OSHPD 1-In Service	5s								4			Rpt: Not Submitted	
41 - San Mateo	10811	Sequoia Hospital	BLD-00860	Building 1	OSHPD 1-In Service	4D			07/01/2015 per AB 2557					3		Rpt: In Review 12/19/2023	Rpt: Review Completed 12/26/2023	
41 - San Mateo	10811	Sequoia Hospital	BLD-00861	Building 2	OSHPD 1-In Service	2			07/01/2015 per AB 2557					3		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-00862	Building 3	OSHPD 1-In Service	2								3		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-00863	Building 4	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-00864	Building 5	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-00865	Building 6, 8, 9 and 10	OSHPD 1-In Service	2			09/01/2015 per AB 2557					3		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-00866	Building 7	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-05198	Building 1A	OSHPD 1-In Service	2			01/01/2015					3		Rpt: Awaiting review 12/19/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	BLD-05233	Pavilion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
41 - San Mateo	10811	Sequoia Hospital	BLD-05234	Dining Room	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
41 - San Mateo	10811	Sequoia Hospital	BLD-08130	Med Waste Storage	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01022	Hospital Building	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01023	Locker Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-01024	Administration Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-02677	Breezeway Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	BLD-02678	Office Infill Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-03218	East Building	OSHPD 1-In Service	5			Denied					4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05365	Bulk Oxygen Storage	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05935	Lobby	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05936	West Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	BLD-05937	Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10836	Lompoc Valley Medical Center	BLD-03028	Replacement Facility	OSHPD 1-In Service	5								4			Rpt: Proposed Retrofit Acceptable 03/06/2025	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00878	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00879	Surgery Addition	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00881	Central Plant II - 1993	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00882	ER/CCU/Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-00883	Laboratory Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-03385	Mechanical / Electrical Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-03386	New Hospital Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05455	New Hospital Expansion - Section J	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05456	New Hospital Expansion - Section K	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05457	New Hospital Expansion - Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05458	New Hospital Expansion - Emergency Department Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05459	New Hospital Expansion - Ambulance Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05623	Breezeway	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/19/2023	
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05994	Extended Care Center - Main Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05996	Extended Care Center - Colonnade	OSHPD 2-Skilled Nursing Only	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05997	Extended Care Center - Adult Day Care	OSHPD 2-Skilled Nursing Only	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-05998	Extended Care Center - Child Day Care	OSHPD 2-Skilled Nursing Only	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-06180	Extended Care Center - Day Care Connector	OSHPD 2-Skilled Nursing Only	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07909	Pump House	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07910	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07911	WWT-01 Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07912	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07913	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
42 - Santa Barbara	10838	Marian Regional Medical Center	BLD-07914	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00901	South Wing (Building D) (Pueblo Pavilion)	OSHPD 1-In Service	4D			01/01/2015		3/31/2013 Risk Bsd Retrofit			3R		Rpt: Review Completed 01/07/2026	Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00902	East Wing (Building E) (Bath Pavilion)	OSHPD 1-In Service	2			Denied					3R		Rpt: Not Submitted	Rpt: Review Completed 01/26/2026	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00904	Surgery Wing (Building G)	OSHPD 1-In Service	4			Denied					3		Rpt: Not Submitted	Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00905	Building H - Structurally connected to BLD-00902	OSHPD 1-Not an Independent Building	N/A			Denied					N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00906	Centennial Wing (Building I) (Arlington Pavilion)	OSHPD 1-In Service	4			Denied					4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-00907	Cancer Center (Building K)	OSHPD 1-In Service	5s			Denied					3		Rpt: Not Submitted	Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05285	D & T Building (Junipero Pavilion)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05286	D & T "B" - Structurally connected to BLD-05285	OSHPD 1-Not an Independent Building	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05287	Pavilion E (Wood-Claeyssens Pavilion)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05288	Pavilion F (Ridley-Tree Pavilion)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05289	New Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-05292	Medical Gas Yard	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06007	Knapp Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06021	Link Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06402	Pavilion D (Compton Pavilion)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06403	Treatment Pavilion (Arlington Pavilion)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06447	Surgery Center of Santa Barbara	OSHPD 3 - Local-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06748	Cottage Center For Advanced Imaging	OSHPD 3 - Local-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06836	Cloister Garden	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06837	Main Lobby Canopy - High	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-06838	Main Lobby Canopy - Low	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-07033	Pediatric Medical Office Building	OSHPD 3 - Local-Proposed	N/A								N/A				
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	BLD-07114	Cottage Heart Center	OSHPD 3 - Local-Proposed	N/A								N/A				
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-00896	Hospital Building	OSHPD 1-In Service	4D			07/31/2015 per AB 2557		Withdrawn			4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-00897	Emergency Services Building	OSHPD 1-In Service	4			Denied					4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-03256	Patient Unit and Radiology Department	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05972	Emergency Entrance Porte Cochere (Entry Canopy)	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05973	Lobby Porte Cochere	OSHPD 1-In Service	5								4			Rpt: Review Completed 01/26/2026	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-05980	CT Scanner Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A								N/A				
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	BLD-07676	Imaging Addition	OSHPD 1-Proposed	5s								4s				
43 - Santa Clara	16713	Children's Healthcare Organization of Northern California - Pediatric Hospital	BLD-03912	Main Building	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10883	El Camino Health	BLD-02254	1 - Orchard Pavilion	OSHPD 1-In Service	3								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-02255	2 - Willow Pavilion	OSHPD 1-In Service	3								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-02262	10 - Central Plant	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-02264	13a - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-02265	14 - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-03529	12 - Psychiatric Wings - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-03535	10 - Central Plant - Switchgear	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-03536	10 - Central Plant - Substation	OSHPD 1-In Service	5								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-03577	Slot Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-03578	New Main Hospital Building (West)	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-05794	Behavioral Health Building	OSHPD 5-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10883	El Camino Health	BLD-05795	Behavioral Health Building - Entrance Canopy	OSHPD 5-Not an Independent Building	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10883	El Camino Health	BLD-05797	Utility Tunnel (East-West)	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-05962	New Main Hospital/Women's Hospital Connector	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-05963	New Main Hospital SE Vestibule	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-05964	New Main Hospital SE Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-05965	New Main Hospital SW Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-06083	New Main Hospital Building - East	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-06084	North-South Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-06085	New Main Hospital/Women's Hospital Tunnel	OSHPD 1-Tunnels	5								2		Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-06086	New Main Hospital / Willow Pavilion Tunnel	OSHPD 1-Tunnels	5								2		Rpt: Review Completed 12/29/2023	Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10883	El Camino Health	BLD-06570	New Canopy at Women's Hospital	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10883	El Camino Health	BLD-07189	Wing J	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10883	El Camino Health	BLD-07190	BHS Link	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10883	El Camino Health	BLD-07322	Bulk Gas - Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 09/30/2025	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02243	Original Building / Outpatient	OSHPD 1-In Service	2			Withdrawn	01/01/2015				3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02244	Generator Building	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02245	Unit 2 Addition / CCU Building	OSHPD 1-In Service	2			Denied					2	1/1/2024	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02246	Surgery / Medical Center	OSHPD 1-In Service	2								3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02247	Administration Building	OSHPD 1-In Service	2			Denied					3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02248	ICU Building	OSHPD 1-In Service	2								3R		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02249	Emergency	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02250	Endoscopy	OSHPD 1-In Service	5								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02251	Entrance Canopy	OSHPD 1-In Service	5								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-02252	O.B. Gyn / Cancer Center	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03692	Rehabilitation Center	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03693	Emergency Generator Building	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03694	Rehab Center Addition 1	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03695	Rehab Center Addition 2	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03821	Back-of-house addition (freezer)	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03822	Back-of-house Facility	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03823	Ambulatory Surgery Holding	OSHPD 1-In Service	4								3		Intent to Remove GAC	Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-03824	Switch Gear Building	OSHPD 1-In Service	5								4			Intent to Remove GAC	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-08084	New Hospital	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10874	El Camino Hospital Los Gatos	BLD-08085	Generator Yard	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07112	Rehabilitation Hospital	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07113	Trash Enclosure	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	BLD-07249	Emergency Generator Enclosure	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-02267	Main Building	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-02268	MRI Building	OSHPD 1-In Service	3								3		Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03445	Women's & Children's Center	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03446	Connection	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03447	Central Plant	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-03448	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/28/2023	
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07291	New Main Hospital	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07292	EMS Canopy	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07293	ED Canopy	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07294	New Central Plant	OSHPD 1-Proposed	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10890	Good Samaritan Hospital	BLD-07860	Tunnel	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07126	Replacement Hospital	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07127	Energy Center	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07128	ED Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07129	Main Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07130	West Canopy	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07509	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07510	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	BLD-07511	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	BLD-00954	Hospital	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	BLD-03599	ED Expansion	OSHPD 1-In Service	5								4			Intent to Remove GAC	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-03701	Hospital - Phase I	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-03702	Chiller Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-05951	Sanipak Cover	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07197	Hospital Phase IIA	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07198	Hospital Phase IIB	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07199	Hospital Phase IIC	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07200	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07201	Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07202	Water Treatment Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07389	Vestibule #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07390	Vestibule #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07391	Side Canopy #1	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07392	Side Canopy #2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07393	Main Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/12/2023	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07741	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07742	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	BLD-07743	WT-01 Water Tank	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-00286	L.S. Packard Children's Hospital	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/26/2023	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-02867	LPCH Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/26/2023	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05369	New LPCH Expansion Building	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05370	New LPCH Loading Dock	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-05371	LPCH Tunnel	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-07532	LPCH Bike Cage	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-07644	Emergency Generator #1	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	BLD-07645	Emergency Generator #2	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Not Submitted	
43 - Santa Clara	10878	Mission Oaks Hospital	BLD-02253	Main Building	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/28/2023	Rpt: Review Completed 12/28/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-02278	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A				
43 - Santa Clara	10919	O'Connor Hospital	BLD-02279	1953 Boiler House / Laundry	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					7/1/2019 Fin Hdsp Replace			N/A				
43 - Santa Clara	10919	O'Connor Hospital	BLD-02280	1969 Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: In Review 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10919	O'Connor Hospital	BLD-02281	Replacement Facility	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-02282	Replacement Boiler House	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03316	2005 Emergency Expansion	OSHPD 1-In Service	5								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03318	Linear Accelerator	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03319	Canopy 1	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-03320	Canopy 2	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 05/04/2026	Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-05675	2005 Emergency Expansion Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-06234	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10919	O'Connor Hospital	BLD-07318	Medical Gas Canopy	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10919	O'Connor Hospital	BLD-07764	Pump House	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10919	O'Connor Hospital	BLD-07765	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10919	O'Connor Hospital	BLD-07766	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02236	Main Tower and North Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02237	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02238	Obstetrics Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			09/01/2015 per AB 2557					N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02239	Emergency Department Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02240	Lab Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02241	Surgery Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02242	ICU/CCU Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-02958	7A Outpatient Surgery Center	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03387	East Patient Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03388	ICU Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03389	West Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03391	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-03639	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06316	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: Review Completed 12/20/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06396	West Wing Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/20/2023	
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06551	Connecting Corridor - Structurally connected to BLD-02241	OSHPD 1-Not an Independent Building	N/A								N/A				
43 - Santa Clara	10856	Regional Medical Center of San Jose	BLD-06980	ED Waiting Expansion	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02546	Ancillary B (6043)	OSHPD 1-In Service	2			01/01/2015		1/1/2015 Com Acc Retrofit			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02547	Old Main Hospital C West (6001)	OSHPD 1-In Service	1			01/01/2015		12/31/2019 Com Acc Retrofit	7/1/2026 AB 1471 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02548	Old Main Hospital C East (6001)	OSHPD 1-In Service	1			01/01/2015		12/31/2019 Com Acc Retrofit	7/1/2026 AB 1471 Rebuild		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02550	Rehabilitation Center Str B (6004)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/29/2023	Rpt: In Review 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02552	Rehabilitation Center Str C (6004)	OSHPD 1-In Service	2			01/01/2015		1/1/2015 Com Acc Retrofit			2	1/1/2030	Rpt: Awaiting review 12/29/2023	Rpt: In Review 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02553	West Wing K Nursing (6006)	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02554	Main Hospital M (6009)	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/29/2023	Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02555	Energy Plant S1 - Boiler Room (6016)	OSHPD 1-In Service	4								4			Rpt: Not Submitted	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02556	Energy Plant S2 - Addition (6016)	OSHPD 1-In Service	4								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-02557	Mech/Elec Bldg U (6017)	OSHPD 1-In Service	5								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03654	M/E Chiller Addition (6017)	OSHPD 1-In Service	5								4			Rpt: In Review 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03860	Services Bldg F (Unit 5) (6002)	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Review Completed 12/29/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03861	Services Bldg S (Unit 4) (6002) - Structurally connected to BLD-03860	OSHPD 1-Not an Independent Building	N/A					7/1/2019 Com Acc Retrofit			N/A	1/1/2030			
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03869	Connecting Corridor (6002) - Structurally connected to BLD-03860	OSHPD 1-Not an Independent Building	N/A					7/1/2019 Com Acc Retrofit			N/A	1/1/2030			
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-03907	Rehabilitation Center Str A (6004)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Awaiting review 12/29/2023	Rpt: In Review 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05256	Replacement Bed Building (Sobrato Pavilion) (6011)	OSHPD 1-In Service	5								4			Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05306	Barbara Arons Pavilion (0914)	OSHPD 5-Acute Psych Only	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-05677	West Wing K Nursing (6006) Air Intake	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: In Review 12/29/2023	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06589	Receiving and Support Center N (6008)	OSHPD 1-In Service	2						12/31/2025 AB 1471 RSC Tier 2		2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: In Review 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06590	Receiving and Support Center Tunnel (6008)	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06702	Link Building	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06733	BHSC Building	OSHPD 5-Under Construction	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06734	BHSC Tunnel	OSHPD 5-Under Construction	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06833	ED Addition (6006)	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06834	ED Addition - North Side (6006)	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06835	ED Addition - East Side (6006)	OSHPD 1-Under Construction	5s								4s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06850	Stair Tower #10	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-06899	Subgrade Water Tank/Pump Enclosure (WT-01)	OSHPD 1-Tanks	N/A								N/A				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07371	MRI Trailer Awning	OSHPD 1-Proposed	5s								4s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07558	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07559	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07560	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07561	WWT-04 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07562	WWT-05 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07563	WWT-06 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10935	Santa Clara Valley Medical Center	BLD-07564	WWT-07 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02627	Hospital Building Area A	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02628	Hospital Building Area B/C	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-02629	Central Plant	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/22/2023	
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-06892	Above Ground Fuel Tank	OSHPD 1-Under Construction	N/A								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07332	Canopy	OSHPD 1-Under Construction	5s								4s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07758	Mechanical Enclosure	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07759	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07760	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	17487	St. Louise Regional Hospital	BLD-07767	Emergency Generator	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10035	Stanford Health Care	BLD-02865	New Stanford Hospital - Generator Building	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	BLD-05260	New Stanford Hospital	OSHPD 1-In Service	5								5				Earthquake Resilient

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10035	Stanford Health Care	BLD-05880	New Stanford Hospital - Elevator / Stair Enclosure	OSHPD 1-In Service	5								5				Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	BLD-05881	New Stanford Hospital - Utility Tunnel	OSHPD 1-Tunnels	N/A								5				
43 - Santa Clara	10943	Stanford Health Care	BLD-02290	Edwards Building-Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02291	Lane Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Replace			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02292	Alway Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02293	Grant Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Remove GAC			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02294	Central Core	OSHPD 1-In Service	2								3		Rpt: Awaiting review 12/21/2023	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02295	Central Core - East and West	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Rebuild			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02296	Boswell Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A					1/1/2020 Com Acc Rebuild			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-02297	West Pavilion	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02298	East Pavilion	OSHPD 1-In Service	2								3		Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	BLD-02299	Phase 1 Central Core Expansion	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02300	Nursing Pod D	OSHPD 1-In Service	4								4			Rpt: In Review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10943	Stanford Health Care	BLD-02301	Nursing Pod E	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02302	Nursing Pod F	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02303	Diagnostic Treatment Center	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/27/2016	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02304	Atrium	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02305	F Pod Extension	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 10/27/2016	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02799	OSHPD Plant	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02800	OSHPD Electrical Equipment Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02801	OSHPD Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02802	OSHPD Cooling Towers	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02803	OSHPD Above Grade Fuel Tanks	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-02866	Modular Steam Plant	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03435	Utility Substation	OSHPD 1-Not a Building Structure	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03436	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03437	Utility Substation	OSHPD 1-Not a Building Structure	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-03805	Boiler Building - Office Portion - Structurally connected to BLD-02309	OSHPD 1-Not an Independent Building	N/A					Withdrawn			N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-05867	North Feed Steam Tunnel (OSHPD)	OSHPD 1-Tunnels	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-06567	Nursing Pod DX	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10943	Stanford Health Care	BLD-06568	Nursing Pod EX	OSHPD 1-Under Construction	5s								5s				
43 - Santa Clara	10943	Stanford Health Care	BLD-06849	Pediatric ED Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
43 - Santa Clara	10943	Stanford Health Care	BLD-06995	Breezeway Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-06996	Liquid Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-07004	Waste Management Building	OSHPD 1-In Service	4								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-07288	300P Fire Pump House	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-07289	300P Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: In Review 12/28/2023	
43 - Santa Clara	10943	Stanford Health Care	BLD-07651	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-07652	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
43 - Santa Clara	10943	Stanford Health Care	BLD-07807	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10943	Stanford Health Care	BLD-07808	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
43 - Santa Clara	10177	Sutter Medical Center, Santa Clara	BLD-07683	Hospital	OSHPD 1-Proposed	5s								5s				
43 - Santa Clara	10177	Sutter Medical Center, Santa Clara	BLD-07684	Central Plant	OSHPD 1-Proposed	5s								5s				
44 - Santa Cruz	10972	Dominican Hospital	BLD-02320	Main Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
44 - Santa Cruz	10972	Dominican Hospital	BLD-02321	Boiler House/Original Corridor	OSHPD 1-Not an Independent Building	N/A								N/A	1/1/2030			
44 - Santa Cruz	10972	Dominican Hospital	BLD-02322	North Wing	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-02323	Original East Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-02324	Emergency Wing - Structurally connected to BLD-02323	OSHPD 1-Not an Independent Building	N/A								N/A	1/1/2030			
44 - Santa Cruz	10972	Dominican Hospital	BLD-02325	Ancillary Building	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
44 - Santa Cruz	10972	Dominican Hospital	BLD-03373	Generator #3	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Not Submitted	Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-03527	Emergency Parking Deck - Structurally connected to BLD-02320	OSHPD 1-Not an Independent Building	N/A								N/A				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07299	Utility Tunnel	OSHPD 1-Tunnels	N/A								4			Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-07572	Canopy	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/26/2023	
44 - Santa Cruz	10972	Dominican Hospital	BLD-07772	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07773	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07774	WT-01 Water Tanks	OSHPD 1-Proposed	N/A								5s				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07775	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
44 - Santa Cruz	10972	Dominican Hospital	BLD-07776	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	BLD-00240	Sutter Maternity	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/30/2023	
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	BLD-05910	Connector Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/13/2023	Rpt: Review Completed 12/30/2023	
44 - Santa Cruz	15019	Watsonville Community Hospital	BLD-00057	Main Hospital	OSHPD 1-In Service	5								4			Rpt: Open - Returned 02/20/2023	
44 - Santa Cruz	15019	Watsonville Community Hospital	BLD-00058	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 02/20/2023	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02327	Original Hospital	OSHPD 1-In Service	2	Withdrawn				12/31/2019 Fin Hdsp Rebuild			2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02328	Long Term Beds Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02329	Surgery/O.B. Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/07/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-02332	Pharmacy and 12 Bed Addition	OSHPD 1-In Service	4								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
45 - Shasta	11000	Mayers Memorial Hospital	BLD-05268	Skilled Nursing Building - Burney Campus	OSHPD 2-Skilled Nursing Only	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
45 - Shasta	11000	Mayers Memorial Hospital	BLD-05334	Emergency Department Expansion	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06253	Connector	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06254	Drop-Off Canopy	OSHPD 1-In Service	5								5				Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06969	Water Tank	OSHPD 1-Tanks	N/A								N/A				
45 - Shasta	11000	Mayers Memorial Hospital	BLD-06970	Water Tank Pump Enclosure	OSHPD 1-Not a Building Structure	N/A								5				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01502	Main Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01503	Pediatrics	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01504	East Wing	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01505	Radiology Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01506	Central Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01507	Doctor's Lounge - Structurally connected to BLD-01504	OSHPD 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01508	Cafeteria Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01509	Third Floor L & D Addition - Structurally connected to BLD-01502	OSHPD 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01510	West Tower	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01511	Engineering Addition - Structurally connected to BLD-01502	OSHPD 1-Not an Independent Building	N/A								N/A				
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01512	Pediatrics Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01513	ER/ICU Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01514	Radiology & Cafeteria Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01515	Oncology Center Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-01516	Generator Bunker	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03642	Corridor	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03643	Oncology Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-03644	Emergency Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-05354	MRI Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/18/2023	
45 - Shasta	11002	Mercy Medical Center Redding	BLD-05618	Service Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/18/2023	
45 - Shasta	16679	Patients' Hospital of Redding	BLD-00289	Hospital Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/31/2023	Rpt: Open - Returned 12/31/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02340	East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02341	West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02342	Surgery/Radiology/ICU	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02343	ER Expansion	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/27/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02344	Surgery/Cardiology/LDR	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-02345	Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/14/2023	
45 - Shasta	11001	Shasta Regional Medical Center	BLD-07957	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
45 - Shasta	11001	Shasta Regional Medical Center	BLD-07958	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
45 - Shasta	11001	Shasta Regional Medical Center	BLD-07959	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
45 - Shasta	11001	Shasta Regional Medical Center	BLD-07960	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
45 - Shasta	11001	Shasta Regional Medical Center	BLD-07961	Pump House	OSHPD 1-Proposed	5s								5s				
45 - Shasta	16620	Vibra Hospital Of Northern California	BLD-00064	N. Ca. Rehabilitaion Hosp. Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/27/2023	Rpt: Open - Returned 12/27/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00082	Nursing Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00083	D & T Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-00084	Med. Gas Shed	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07087	Emergency Department Waiting Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07093	Bulk O2 and Propane Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/22/2023	
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07156	Emergency Department Expansion	OSHPD 1-Under Construction	5s								5s				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07157	Generator Yard	OSHPD 1-Under Construction	N/A								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07158	Patient Drop-Off Canopy	OSHPD 1-Under Construction	5s								4s				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-07897	FT Fuel Tanks	OSHPD 1-Tanks	N/A								N/A				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-08005	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
47 - Siskiyou	14900	Fairchild Medical Center	BLD-08006	WWT-01 Wastewater Septic Tank	OSHPD 1-Proposed	N/A								5s				
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00231	1973 Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00232	Administration Building - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A				
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00233	Laboratory Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A				
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00234	Radiology Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A								N/A				
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00235	Skilled Nursing Facility & Maintenance Shop	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-00236	Generator Enclosure	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/11/2023	Rpt: Review Completed 12/26/2023	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06101	Emergency Dept. Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06118	1973 Nursing Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	BLD-06321	OPS Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00204	Central Plant East	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00205	Hospital Addition	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-00207	Central Plant West	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-02778	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-02779	Hospital Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-03631	Central Plant East Storage / LOX	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 05/01/2023	Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07215	Central Plant North-West	OSHPD 1-In Service	2								2		Rpt: Review Completed 08/20/2024	Rpt: Review Completed 12/06/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07216	Central Plant East Pathway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07423	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07424	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	BLD-07425	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-03834	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-03835	Central Utility Plant Phase 2	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-06842	Emergency Department Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/06/2023	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07381	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07382	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07383	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	5s								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07384	WT-03 Water Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07385	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	BLD-07545	WT-01 Water Tank	Local-Tanks	N/A								N/A				
48 - Solano	11019	Northbay Medical Center	BLD-01519	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01520	Phase 1 Replacement Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-01521	Original Hospital Building A	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
48 - Solano	11019	Northbay Medical Center	BLD-01522	Emergency Room Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02681	Med/Surg Addition	OSHPD 1-In Service	4s								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02682	Original Hospital Building B	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 08/28/2013	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-02683	Original Hospital Building C	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-03029	Emergency Room Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-03030	Phase 1 Replacement Building Canopy	OSHPD 1-In Service	5s								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-05345	Electrical Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-05875	New North Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-05876	Overhead Utility Support Structure	OSHPD 1-Not a Building Structure	N/A								4			Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-06335	Laboratory Building	OSHPD 1-In Service	5								4s		Rpt: Not Submitted	Rpt: Review Completed 12/29/2023	
48 - Solano	11019	Northbay Medical Center	BLD-07340	Med Gas Storage Canopy	OSHPD 1-Proposed	5s								4s				
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00340	Nursing Wing	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00341	Main Entrance	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00342	Ancillary Wing	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00343	Administration Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00344	Central Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00345	Cafeteria Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-00347	Service Yard Canopy	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-05991	MRI Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-05993	Bulk Oxygen Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
48 - Solano	15807	NorthBay VacaValley Hospital	BLD-07675	ED / Lobby Addition	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Not Submitted	
48 - Solano	12525	Sutter Solano Medical Center	BLD-01019	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	12525	Sutter Solano Medical Center	BLD-01020	One Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-01021	Tower Addition	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-02969	Two Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-07017	Addition #1 (Chiller Building)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
48 - Solano	12525	Sutter Solano Medical Center	BLD-07018	Medical Gas Yard	OSHPD 1-Equipment Yard	N/A								5				
49 - Sonoma	12823	Healdsburg Hospital	BLD-00919	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/18/2023	Rpt: Open - Returned 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	12823	Healdsburg Hospital	BLD-00920	Entrance Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-00921	CT Scanner Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
49 - Sonoma	12823	Healdsburg Hospital	BLD-00922	Mechanical/Electrical Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-00923	Materials Management Addition	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Open - Returned 12/28/2023	
49 - Sonoma	12823	Healdsburg Hospital	BLD-05449	ED Addition	OSHPD 1-In Service	5s								4			Rpt: Open - Returned 12/28/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00277	Hospital	OSHPD 1-In Service	3								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00278	Central Plant	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00279	Central Plant Addition	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-00280	Electrical Building	OSHPD 1-In Service	4								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02780	Hospital, South - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A								N/A				
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02781	Hospital, North - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A								N/A				
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02782	Canopy, South	OSHPD 1-In Service	3								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-02783	Canopy, North	OSHPD 1-In Service	3								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-03610	North Wing Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-03849	Generator Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-05699	Connecting Tunnel	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-05700	CUP / Boiler Room Expansion	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-06104	North Wing Expansion Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/18/2023	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-07438	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A								5s				
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-07439	WT-01 Water Tank	OSHPD 1-Under Construction	N/A								5s				
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	BLD-07440	WT-02 Water Tank	OSHPD 1-Under Construction	N/A								5s				
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00311	Original Hospital - Southwest	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00312	Emergency Room Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00313	Power Plant Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00314	Switchgear Building	OSHPD 1-In Service	5								3		Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-00315	Power Plant Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02579	Original Hospital - Northeast	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02580	Original Hospital - Northwest	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02581	Original Hospital - Southeast	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-02757	Power Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/28/2023	
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-07824	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-07825	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
49 - Sonoma	14568	Petaluma Valley Hospital	BLD-07826	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01529	Original Hospital	OSHPD 1-In Service	2								3		Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01530	Physical Therapy Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-01531	Psychiatric Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-02755	Dietary Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	BLD-02756	Social Services Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01533	West Pavilion - North Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01534	West Pavilion - West Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01535	Service Building	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01536	West Pavilion - Entry Lobby and Canopy (Entry Lobby)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01537	Emergency Wing	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01538	Center East - West Link	OSHPD 1-In Service	3								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01539	Center East Wing	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01540	East Wing and East Wing Link	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-01543	Emergency Wing-Entrance Canopy	OSHPD 1-In Service	4								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03203	ED Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03205	Ambulance Drop Off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03206	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03207	Surgery Building and Cath Lab Infill	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-03208	Observation #3	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06270	Oxygen Tank - Generator - Underground Fuel Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06275	West Pavilion - Entry Lobby and Canopy (West Canopy)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06276	West Pavilion - Entry Lobby and Canopy (East Canopy)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06277	Main Entrance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/29/2023	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06340	Water Treatment Structure	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	BLD-06351	Bio-Hazard Holding	OSHPD 1-In Service	2								3		Rpt: Review Completed 12/15/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01523	Hospital Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01524	Entrance Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01525	Emergency Canopy	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01526	Mechanical Room	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11052	Sonoma Specialty Hospital	BLD-01527	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01544	West Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01545	Central Wing	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-01546	East Wing North	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-02990	Central Wing Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-02991	West Wing Canopy	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03079	East Wing Center	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03080	East Wing South	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-03873	Chiller Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05409	East Wing Loading Dock Canopy	OSHPD 1-In Service	5s								2	1/1/2030	Rpt: Review Completed 12/29/2023	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05410	ED / OR	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/29/2023	
49 - Sonoma	11064	Sonoma Valley Hospital	BLD-05411	ED / OR Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/29/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05237	Hospital Building - West Wing	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05238	Hospital Building - Center Wing	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05239	Hospital Building - East Wing	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05240	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05241	Water Treatment Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05242	Medical Gas Storage Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-05364	Utility Building	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-06549	Expansion Wing	OSHPD 1-In Service	5								5				Earthquake Resilient
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	BLD-07019	Medical Waste	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-01551	Orig Hospital Bldg & Add - Bldg III	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit	7/1/2022 AB 2190 Retrofit		2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-01552	1978 Hospital Building - Bldg I	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11098	Central Valley Specialty Hospital	BLD-03534	Building II	OSHPD 1-In Service	2					1/1/2015 Risk Bsd Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	BLD-01579	Main Hospital & Additions	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	BLD-01580	South Tower	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	BLD-01581	North Tower	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01582	Cath Lab	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01583	Lobby Addition	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01584	Women & Children's Center	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01585	Central Mechanical Plant	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01586	West Tower	OSHPD 1-In Service	5					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01587	ER/Lab	OSHPD 1-In Service	5					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11085	Doctors Medical Center	BLD-01588	Cardiology	OSHPD 1-In Service	4					Denied			2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01589	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01590	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01591	Endoscopy	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01592	Pharmacy Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-01593	Dining Room Addition - Structurally connected to BLD-01579	OSHPD 1-Not an Independent Building	N/A					Denied			N/A	1/1/2030			
50 - Stanislaus	11085	Doctors Medical Center	BLD-03405	ER/LAB Connecting Corridor	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-06179	Women & Children's Center - Steam Generator Room	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-06200	Entry Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-07074	Utility Tunnel	OSHPD 1-Tunnels	N/A								2		Rpt: Review Completed 12/22/2023	Rpt: In Review 12/22/2023	
50 - Stanislaus	11085	Doctors Medical Center	BLD-07695	Pump House	OSHPD 1-Proposed	5s								5s				
50 - Stanislaus	11085	Doctors Medical Center	BLD-07696	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11085	Doctors Medical Center	BLD-07697	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11085	Doctors Medical Center	BLD-07698	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01604	Main Building - East Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01605	Main Building - West Wing	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01606	Mental Health Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01607	Critical Care Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01608	Diagnostic Imaging/ER Emergency	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01609	Nursing Unit Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01610	Engineering Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01611	Central Supply Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01612	Central Plant Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01613	O.R. / G.I. Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01614	Walk-In Freezer	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01615	Dietary Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01616	Surgery Addition	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01617	Utility Tunnel	OSHPD 1-Tunnels	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11090	Emanuel Medical Center	BLD-01618	Exit Passage Way	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03229	Cardio Vascular Surgery Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03230	ED Addition - North West Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03231	Obstetrics Expansion	OSHPD 1-In Service	5								4			Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03232	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								2	1/1/2030	Rpt: Review Completed 12/20/2023	Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03690	Exit Passage Way - Part II	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03691	Exit Passage Way - Part III	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-03813	Exit Passage Way - Part IV	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/15/2023	Rpt: In Review 12/15/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07191	North West Tower Canopy	OSHPD 1-In Service	5								4			Rpt: In Review 12/15/2023	
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07677	Pump House	OSHPD 1-Proposed	5s								5s				
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07678	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07679	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07682	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
50 - Stanislaus	11090	Emanuel Medical Center	BLD-07787	Entry Canopy	OSHPD 1-In Service	2s								2s		Rpt: Not Submitted	Rpt: In Review 12/15/2023	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05648	South Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05655	North Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05656	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	BLD-05657	Bulk Oxygen Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05183	Main Building	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05184	Central Plant	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-05531	Central Utility Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Open - Returned 12/12/2023	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-07406	ED Canopy	OSHPD 1-In Service	5								4			Rpt: Open - Returned 12/12/2023	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	BLD-07638	Pump House	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Open - Returned 12/12/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01567	Connecting Corridor Infill	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01568	Physical Plant & Additions	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01569	G. I. Lab Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01570	Emergency/Ancillary Services	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01571	West Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01572	Same Day Surgery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01573	Advanced Medical Diagnostic	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01574	Radiation Oncology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11111	Memorial Medical Center	BLD-01575	Original Hospital	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11111	Memorial Medical Center	BLD-01576	Obstetrics Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01577	Surgery/Emergency Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-01578	Dietary/Dining	OSHPD 1-In Service	4								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03140	ER Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03225	North Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03226	Central Plant Expansion	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03837	North Tower	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03838	Family Birthing Center Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03839	Surgery/Emergency Expansion - East	OSHPD 1-In Service	4								4			Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-03847	Original Hospital - South	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11111	Memorial Medical Center	BLD-05405	Corridor and Elevator Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-05406	Emergency/Ancillary Services Canopy	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Not Submitted	
50 - Stanislaus	11111	Memorial Medical Center	BLD-05407	West Expansion - Labor and Delivery	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-05408	West Expansion - Chapel	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
50 - Stanislaus	11111	Memorial Medical Center	BLD-05417	GI Lab	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: In Review 12/31/2023	
50 - Stanislaus	11111	Memorial Medical Center	BLD-07627	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A								4s		Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	11111	Memorial Medical Center	BLD-08049	Trash Enclosure	OSHPD 1-In Service	4s								2s		Rpt: Not Submitted	Rpt: Not Submitted	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00193	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/14/2023	Rpt: Review Completed 12/19/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00194	ICU Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00195	Emergency Dept. Addition	OSHPD 1-In Service	5								4D-L1			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-00196	300 Wing Addition	OSHPD 1-In Service	5								4D-L1			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03243	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03244	Replacement Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03245	Canopy #6	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	13110	Oak Valley Hospital District	BLD-03246	Canopy #7	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/19/2023	
50 - Stanislaus	17461	Stanislaus Surgical Hospital	BLD-03242	Hospital Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	BLD-05179	Emergency Generator	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/27/2023	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	BLD-05344	Hospital	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/27/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01560	Main Hospital - North Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01561	Six Bed Addition - Structurally connected to BLD-02977	OSHPD 1-Not an Independent Building	N/A								N/A				
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01562	Surgery Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01563	Patient Rooms Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01564	Medical Records Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01565	Surgery Expansion - Structurally connected to BLD-01562	OSHPD 1-Not an Independent Building	N/A								N/A				
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-01566	Administration Addition - Structurally connected to BLD-01560	OSHPD 1-Not an Independent Building	N/A								N/A				
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-02977	Main Hospital - Southwest Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-02978	Main Hospital - Southeast Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/06/2023	Rpt: Review Completed 12/26/2023	
52 - Tehama	11121	St. Elizabeth Community Hospital	BLD-06031	Drop-off Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
53 - Trinity	11125	Trinity Hospital	BLD-02523	Main Hospital Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02524	SNF Building	OSHPD 2-Skilled Nursing Only	N/A								N/A				
53 - Trinity	11125	Trinity Hospital	BLD-02525	Security Addition	OSHPD 1-In Service	2					7/1/2019 Com Acc Retrofit			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02526	16-Bed Addition	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
53 - Trinity	11125	Trinity Hospital	BLD-02527	Lab and Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 09/01/2026	Rpt: Not Submitted	
53 - Trinity	11125	Trinity Hospital	BLD-02528	Emergency Generator Building	OSHPD 1-In Service	2					Denied			2	1/1/2030	Rpt: Not Submitted	Rpt: Not Submitted	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	BLD-02529	Connecting Corridor Addition	OSHPD 1R-Skilled Nursing Only	N/A					7/1/2019 Com Acc Remove GAC			N/A	1/1/2030			
54 - Tulare	11145	Adventist Health Tulare	BLD-00564	Original Structure & Additions	OSHPD 1-In Service	2								2		Rpt: Review Completed 08/29/2025	Rpt: Review Completed 06/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-00569	Fifth Addition: Radiology Addition	OSHPD 1-In Service	4								2		Rpt: Review Completed 08/29/2025	Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-00570	Sixth Addition - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-00571	Sixth Add - 1.8	OSHPD 1-In Service	4								2		Rpt: Review Completed 08/29/2025	Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-00572	Sixth Add - 1.9 - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-02963	MRI Modular Building	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-03517	First Addition	OSHPD 1-In Service	2								2		Rpt: Review Completed 05/23/2025	Rpt: Review Completed 06/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-03518	Second Addition	OSHPD 1-In Service	2								2		Rpt: Review Completed 08/29/2025	Rpt: Review Completed 06/19/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	BLD-05607	Tower 1	OSHPD 1-Under Construction	5s								5s				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
54 - Tulare	11145	Adventist Health Tulare	BLD-05868	Generator Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-05869	Tower 1 Generator Yard	OSHPD 1-Under Construction	N/A								5s				
54 - Tulare	11145	Adventist Health Tulare	BLD-05870	Bulk Medical Gas and Water Tank Yard	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-05871	CT Scan Building	OSHPD 3 - Local-Outpatient Only	N/A								N/A				
54 - Tulare	11145	Adventist Health Tulare	BLD-06041	Sixth Add - 1.8 - Lobby	OSHPD 1-In Service	4								2		Rpt: Review Completed 05/23/2025	Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-06042	Sixth Add - 1.7 - North Restroom Addition	OSHPD 1-In Service	4								2		Rpt: Review Completed 05/23/2025	Rpt: Review Completed 06/19/2025	
54 - Tulare	11145	Adventist Health Tulare	BLD-06043	Sixth Add - 1.7 - South Restroom Addition	OSHPD 1-In Service	4								2		Rpt: Review Completed 05/23/2025	Rpt: Review Completed 06/19/2025	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01031	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/13/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01032	1st. East Expansion	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01033	Cafeteria - Dining Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01034	Special Services	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01035	Co-Gen. Building	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01036	Special Procedures	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01037	West Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-01038	East Expansion	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Review Completed 10/03/2023	Rpt: Review Completed 12/13/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
54 - Tulare	12601	Kaweah Health Medical Center	BLD-02716	Cafeteria - Office Unit	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/11/2023	Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-03616	North Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-05583	Dietary Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-06048	Emergency Department Addition	OSHPD 1-In Service	5								5s			Rpt: Review Completed 12/13/2023	
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08007	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08008	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08009	WWT-03A Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08010	WWT-03B Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08011	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08012	WT-02 Water Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08013	WT-03 Water Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08014	FT Tanks	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08015	Pump House #1	OSHPD 1-Proposed	5s								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08016	Pump House #2	OSHPD 1-Proposed	5s								5s				
54 - Tulare	12601	Kaweah Health Medical Center	BLD-08017	Pump House #3	OSHPD 1-Proposed	5s								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03749	Original Building - Part 1	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03750	Original Building - Part 3	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-03751	Original Building - Part 2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/12/2023	Rpt: Review Completed 12/12/2023	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08054	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08055	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08056	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08057	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08058	Pump House	OSHPD 1-Proposed	5s								5s				
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	BLD-08059	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A								N/A				

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
54 - Tulare	11140	Sierra View Medical Center	BLD-00556	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11140	Sierra View Medical Center	BLD-00557	Radiology Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00558	Emergency Addition #1	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00560	3 Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00561	4 Story Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00562	Emergency Addition #2	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 03/13/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-00563	Administration Addition #2	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-02696	Laboratory Addition	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-02697	Service Building	OSHPD 1-In Service	5								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-03239	Central Utility Plant	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-05569	Emergency Department Electrical Room Addition	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-06706	CT Building	OSHPD 1-In Service	3								3		Rpt: Review Completed 03/13/2023	Rpt: In Review 12/28/2023	
54 - Tulare	11140	Sierra View Medical Center	BLD-06707	Cath Lab	OSHPD 1-In Service	5								4			Rpt: In Review 12/28/2023	
55 - Tuolumne	11151	Adventist Health Sonora	BLD-03833	OB Unit 9	OSHPD 1-In Service	2								2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
55 - Tuolumne	18163	Adventist Health Sonora	BLD-05178	Main Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
55 - Tuolumne	18163	Adventist Health Sonora	BLD-06910	O.R. – Admin. Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/26/2023	
55 - Tuolumne	18163	Adventist Health Sonora	BLD-07654	Canopy	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01246	Original Building	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01249	Main Hospital Building	OSHPD 1-In Service	3								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-01253	New Bridge/Elevator & Med. Gas Enclosure	OSHPD 1-In Service	4s								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-03335	North and South Patient Care Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05217	Patient Care Tower Entrance	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05679	ED / Surgery Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-05680	ED / Surgery Addition Entrance	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11177	Adventist Health Simi Valley	BLD-07115	Central Utility Plant	OSHPD 1-Proposed	5s								5s				
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-00606	Hospital Building	OSHPD 1-In Service	2								3R		Rpt: Review Completed 03/20/2025	Rpt: Review Completed 03/27/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-02994	Nursing Wing	OSHPD 1-In Service	4								4D-L1			Rpt: Review Completed 03/27/2025	
56 - Ventura	11169	Community Memorial Hospital - Ojai	BLD-02995	Laboratory Addition	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 03/20/2025	Rpt: Review Completed 03/27/2025	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03167	New Ambulance Entry	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03168	New 6 Story Hospital Tower - West	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03169	New 6 Story Hospital Tower - East	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-03170	New 2 Story Hospital Tower (3 Story Wing)	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05528	New ER Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05529	New Main Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	BLD-05530	New 1 Story Pedestrian Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/30/2023	
56 - Ventura	10040	Harvest Medical Complex	BLD-06934	Hospital	OSHPD 1-Proposed	5s								5s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00601	North Wing / Central Core	OSHPD 1-In Service	2					1/1/2018 Risk Bsd Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00602	South Wing	OSHPD 1-In Service	2					1/1/2018 Risk Bsd Retrofit			2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00603	West Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00604	New South Wing	OSHPD 1-In Service	3								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-00605	Emergency Generator Shed	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-02950	Emergency Department Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-03108	ICU/CCU	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-03464	New Expansion	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-06341	Exit Discharge Area Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-06413	OR Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07111	ED Waiting Room Expansion	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07172	ED Entry Canopy	OSHPD 1-Under Construction	5s								4s				
56 - Ventura	11164	Los Robles Hospital & Medical Center	BLD-07319	Dietary Expansion	OSHPD 1-Under Construction	5s								5s				
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02641	Building One	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02642	Building Two - Dining/Kitchen	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02643	Building Three	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02644	Building Four - Gymnasium	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-02645	Building Five	OSHPD 1-In Service	3s								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/18/2023	Rpt: Review Completed 12/22/2023	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	BLD-06012	Outpatient Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/22/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00607	Link Building 1	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00608	Hospital Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-00612	Canopy and Entrance Bridge	OSHPD 1-In Service	4s								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02614	Patient Tower	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02615	Link Building 2	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-02616	Central Plant	OSHPD 1-In Service	4								3		Rpt: Proposed Retrofit Acceptable 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-05872	MRI Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06160	Angiography Operating Suite Exterior Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06174	New ED Expansion & Covered Entry	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06175	New Free-Standing Covered Walkway	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-06176	New Free-Standing Covered Entry	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07032	Canopy #1	OSHPD 1-In Service	4s								2s		Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/18/2023	
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07950	WWT-01 Wastewater Tanks	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07951	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07952	Pump House	OSHPD 1-Proposed	5s								5s				
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07953	WT Water Tanks	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07954	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	11172	St Johns Regional Medical Center	BLD-07955	WWT-04 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00209	Main Hospital	OSHPD 1-In Service	1					7/1/2019 Com Acc Rebuild		Yes	2	1/1/2030	Intent to Remove GAC	Intent to Remove GAC	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00210	Central Plant/ Utilities Building	OSHPD 1-In Service	3								3		Rpt: Awaiting review 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00211	Ancillary Building	OSHPD 1-In Service	3								3		Rpt: Awaiting review 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-00212	Ambulatory Surgery Center	OSHPD 1-In Service	3s								3		Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-03257	Hospital Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAi
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-03845	Skilled Nursing Building	OSHPD 1-In Service	3								3		Rpt: Proposed Retrofit Acceptable 12/17/2023	Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-05209	ED Addition	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06318	SNF Connection	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06870	Recycle Enclosure	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06871	Water Pump Yard	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	13181	St. John's Hospital Camarillo	BLD-06872	Dietary Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/25/2023	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-05186	Main Building	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07180	Entry Canopy	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07181	Porte-Cochere	OSHPD 1-In Service	5s								4s		Rpt: Not Submitted	Rpt: Review Completed 12/22/2023	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07974	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07975	WT-01 Water Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07976	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A								5s				
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	BLD-07977	Pump Vault	OSHPD 1-Proposed	5s								5s				
56 - Ventura	11162	Ventura County Medical Center	BLD-00594	Main Hospital Building - Bldg 305	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-00595	Fainer Wing - Building 304	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	11162	Ventura County Medical Center	BLD-00596	Administration Building - Bldg 306	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-00597	Mental Health Center - Building 399	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-03341	Electrical Services Building 400	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-03640	Administration Bldg Addition - #306	OSHPD 1-No Gen Acute Care - OSHPD Bldg	N/A	01/01/2020							N/A				
56 - Ventura	11162	Ventura County Medical Center	BLD-03641	Medical Lab / Kitchen - Bldg 401	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-05572	Cafeteria Building - Building 403	OSHPD 1-In Service	2								4D-L1			Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11162	Ventura County Medical Center	BLD-05660	Med Gas Enclosure - Building 307	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-05661	Fainer Wing Cooling Tower Enclosure - Building 308	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-05707	Hospital Replacement Wing	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-05729	Interim LOX Tank	OSHPD 1-Equipment Yard	N/A								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-06225	Hospital Porte Cochere	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11162	Ventura County Medical Center	BLD-06227	Ambulance and ED Porte Cochere	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01241	Main Building / East & North Addition	OSHPD 1-In Service	2	Withdrawn				1/1/2017 Com Acc Retrofit			3R		Rpt: Not Submitted	Rpt: Review Completed 06/24/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01242	East Addition - Structurally connected to BLD-01241	OSHPD 1-Not an Independent Building	N/A								N/A				
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01243	North Addition - Structurally connected to BLD-01241	OSHPD 1-Not an Independent Building	N/A								N/A				
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01244	E.R. Addition	OSHPD 1-In Service	5								3R		Rpt: Not Submitted	Rpt: Review Completed 06/24/2025	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-01245	Storage Building & Storage Addition	OSHPD 1-In Service	4								3		Rpt: Not Submitted	Rpt: Review Completed 06/24/2025	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02647	Generator Building	OSHPD 1-In Service	5								4			Rpt: Review Completed 06/24/2025	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02648	I.C.U. Addition	OSHPD 1-In Service	2	Withdrawn				1/1/2017 Com Acc Retrofit			3R		Rpt: Not Submitted	Rpt: Review Completed 06/24/2025	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02724	Storage Addition - Structurally connected to BLD-01245	OSHPD 1-Not an Independent Building	N/A								N/A				
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	BLD-02929	Infectious Waste Sterilizer Bldg	OSHPD 1-In Service	5								3		Rpt: Not Submitted	Rpt: Review Completed 06/24/2025	
57 - Yolo	17725	Sutter Davis Hospital	BLD-01256	Main Hospital Building	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/15/2023	Rpt: Review Completed 12/31/2023	
57 - Yolo	17725	Sutter Davis Hospital	BLD-01257	Central Plant	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/31/2023	
57 - Yolo	17725	Sutter Davis Hospital	BLD-06114	Post Anesthesia Recovery Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
57 - Yolo	17725	Sutter Davis Hospital	BLD-06528	Birthing Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
57 - Yolo	17725	Sutter Davis Hospital	BLD-06529	Emergency Department Expansion	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
57 - Yolo	17725	Sutter Davis Hospital	BLD-06530	Ambulance Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
57 - Yolo	17725	Sutter Davis Hospital	BLD-07307	MRI Canopy	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/31/2023	
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01258	Building A	OSHPD 1-In Service	2								4D-L1			Rpt: Open - Returned 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01259	Building B	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Open - Returned 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01260	Building C	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Open - Returned 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01261	Building D	OSHPD 1-In Service	2								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Open - Returned 12/26/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01262	Building E, Ancillary Wing	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/19/2023	Rpt: Open - Returned 12/26/2023	
57 - Yolo	11198	Woodland Memorial Hospital	BLD-01263	Lobby	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/08/2023	Rpt: Open - Returned 12/26/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01264	Patient Tower/Cath Lab/4th Floor	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01265	Patient Tower Cath Lab - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01266	Patient Tower 4th Floor Buildout - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01267	Central Plant (1960 & 1988)	OSHPD 1-In Service	2	Denied							2	1/1/2030	Rpt: Review Completed 12/21/2023	Rpt: Review Completed 12/21/2023	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating

HCAI
Department of Health Care Access and Information

Extensions for Hospital Buildings as of 9/17/2026

County Code	Facility Nbr	Facility Name	Building Nbr	Building Name	Building Status	SPC Rating*	SPC Extensions							HCAI NPC rating*	NPC Extensions	NPC 4/4D Status, Submittal Date	NPC 5 Status, Submittal Date	AB 1882 Notice
							SB 306 Extension Status	AB 523 Extension Status	SB 1661/AB 2557/AB 81 Extension Status	SB 499 Extension Status	SB 90 Extension Status	Other Extension Status	CO/CF **					
58 - Yuba	11205	Adventist Health And Rideout	BLD-01268	Central Plant CP-1 ('92 '98 & 2000)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Proposed Retrofit Acceptable 12/21/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01269	Central Plant CP-1 1998 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01270	Central Plant (1988) - Structurally connected to BLD-01267	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01271	Central Plant CP-1 2000 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01272	East Wing (1978)	OSHPD 1-In Service	4								2	1/1/2030	Rpt: Review Completed 12/22/2023	Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-01273	West Wing (1960)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	Denied				1/1/2018 Com Acc Rebuild			N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01276	North Wing N-1 1980 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-01277	North Wing N-1 1986 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A								N/A				
58 - Yuba	11205	Adventist Health And Rideout	BLD-02785	New Patient Tower	OSHPD 1-In Service	5								4			Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-03769	Registration Building	OSHPD 1-In Service	4								4			Rpt: Review Completed 12/21/2023	
58 - Yuba	11205	Adventist Health And Rideout	BLD-07207	North Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	
58 - Yuba	11205	Adventist Health And Rideout	BLD-07208	South Entry Canopy	OSHPD 1-In Service	5								4			Rpt: Not Submitted	

Risk Bsd = Risk Based SB 90 extension
Fin Hdsp = Financial Hardship based SB 90 extension
Com Acc = Community Access based SB 90 extension
GAC = General Acute Care

Retrofit = Building will be retrofitted
Rebuild = GAC services will be moved to new building/s
Replace = GAC services will be moved to existing SPC 2 or higher building/s
Remove = GAC services will be removed from building

NPC 4/4D Status: This column shows NPC 4 or NPC 4D evaluation report submittal status.
NPC 5 Status: This column shows NPC 5 evaluation report submittal status.
Rpt: Submitted – means HCAI has received an NPC evaluation report. Submittal date is noted.
Rpt: Not Submitted – means HCAI has not received an NPC evaluation report.
Rpt: Unacceptable Submittal – means HCAI has received a document but was missing major required NPC evaluation report content. Submittal date is noted. These submittals did not comply with the NPC evaluation 1/1/2024 submittal deadline.
Intent to Remove GAC – means HCAI received a signed letter that the facility intends to remove this building's GAC services by 2030 and therefore NPC evaluation report is not required.

* 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD
* 1s is a temporary rating assigned to seismically separate buildings created by retrofits
** Statutory SPC 1 requirements satisfied, but building is required to be removed from GAC service or reclassified to a higher SPC rating