2019 Plan Review Reminder List - Fire Sprinkler

Applicable Codes and Standards

CAC 2019, CBC 2019, CFC 2019 NFPA 13 - 2016

Instructions: The following items are to be verified for completeness prior to submitting to OSHPD for plan review.

CHK. N/A Submittal Requirements

 \Box

- Image: Image:
 - 2. Two (2) sets of equipment submittals or in an acceptable electronic format (cut CAC, Sec. 7-113 (a) 2. C sheets and product information)
 - 3. Water supply and pressure data from city, district or water purveyor. (test data NFPA 13, Sec. 23.2.1.1, CFC must be no more than six months old)
 507.4
 - **4.** Transmittal letter with name, address, phone, fax, email and license number of CAC, Sec. 7-115 (c) 5. sprinkler contractor
 - 5. Construction documents shall be of sufficient clarity to indicate the location, nature CFC, Sec. 105.4.2 and extent of the work proposed and show in detail that it will conform to the provisions of the California Fire Code and relevant laws, ordinances, rules and regulations as determined by the fire code official.
 - **6.** Shop drawings shall contain all information as required by the referenced **CFC**, **Sec. 105.4.2.1** installation standards in the California Fire Code, Chapter 9.

<u>CHK.</u>	<u>N/A</u>	I. General Information - Working Plans	
		1. Name of owner and occupant	NFPA 13, Sec. 23.1.3 (1)
		2. Location, including street address	NFPA 13, Sec. 23.1.3 (2)
		3. Symbol legend, sheet numbers	CFC, Sec. 105.4.2
		4. Point of compass, graphic scale	NFPA 13, Sec. 23.1.3 (3) (32)
		5. Scope of work. Indicate if part of a remodel or new building project or a separate fire sprinkler project.	CFC, Sec. 105.4.2
		6. Stamp and signature of the designer in responsible charge, if applicable	CAC, Sec. 7-115 (a) & (b)
		Location of partitions and fire-resistance rated walls and partitions	NFPA 13, Sec. 23.1.3 (5) (6)
		Design numbers and details of through penetration fire stop systems	CFC, Sec. 105.4.2
		 Full height cross section of building showing location of fire sprinklers, piping, structural members and ceiling construction 	NFPA 13, Sec. 23.1.3 (4)
		10. Reflected ceiling plans indicating fire sprinkler locations and structural members	CFC, Sec. 105.4.2
		11. Use and function of each area or room	NFPA 13, Sec. 23.1.3 (7)
		12. Location and size of concealed spaces, closets, attics, and bathrooms	NFPA 13, Sec. 23.1.3 (8)
		13. Any small enclosures in which no sprinklers are to be installed	NFPA 13, Sec. 23.1.3 (9)
		 Make, type, model, sprinkler identification number and nominal K-factor of sprinklers. Indicate existing sprinkler type where applicable 	NFPA 13, Sec. 23.1.3 (12)
		15. Temperature rating and location of high temperature sprinklers	NFPA 13, Sec. 23.1.3 (13)
		16. Number of sprinklers on each riser per floor and total area of protected space	NFPA 13, Sec. 23.1.3 (15)
		17. Total number of sprinklers on each dry pipe, preaction, or deluge system	NFPA 13, Sec. 23.1.3 (16)
		18. Approximate capacity in gallons of each dry pipe system	NFPA 13, Sec. 23.1.3 (17)
		19. Pipe type and schedule of wall thickness	NFPA 13, Sec. 23.1.3 (18)
		20. Nominal pipe size and cutting lengths of pipe	NFPA 13, Sec. 23.1.3 (19)
		21. Location and size of riser nipples	NFPA 13, Sec. 23.1.3 (20)
		22. Location and complete detail of sprinkler and standpipe risers	CFC, Sec. 105.4.2
		23. Types of fittings and joints and location of all welds (Welding inspection to be included on TIO)	NFPA 13, Sec. 23.1.3 (21)

<u>CHK.</u>	<u>N/A</u>	I. G	eneral Information - Working Plans (Continued)	
		24.	Type and location of hangers, trapezes, methods of restraint, sleeves and braces (Provide calculations for sway bracing)	NFPA 13, Sec. 23.1.3 (22) (39)
		25.	All control valves, check valves, drain pipes, and test connections	NFPA 13, Sec. 23.1.3 (23)
		26.	Make, type, model and size of alarm, dry pipe, preaction or deluge valve	NFPA 13, Sec. 23.1.3 (24) (25)
		27.	Size and location of standpipe risers, hose connections, small hand hose and related equipment	NFPA 13, Sec. 23.1.3 (27)
		28	Type and location of outside alarm	CFC, Sec. 903.4.2
			Reference plans of the private fire service main to the city connection including	NFPA 13, Sec. 23.1.3 (10) (23)
			size, type and location of pipe control valves and check valves	
		30	Type and location of backflow prevention devices	NFPA 13, Sec. 23.1.3 (41)
			Size, location, and piping arrangements for fire department connections	NFPA 13, Sec. 23.1.3 (44)
			Complete installation details for fire pumps where provided	CFC, Sec. 105.4.2
			Where the installation is an addition to an existing system, enough of the existing system indicated on the plans to make all conditions clear	NFPA 13, Sec. 23.1.3 (30)
		34.	The information on the hydraulic data nameplate	NFPA 13, Sec. 23.1.3 (31)
			Hydraulic reference points shown on the plan that correspond to the hydraulic	NFPA 13, Sec. 23.1.3 (34)
_	_	•••	calculations	
		36.	The minimum rate of water application (density or flow or discharge pressure), the design area of water application and the water required for hose streams both inside and outside	NFPA 13, Sec. 23.1.3 (35)
		37.	When room design method is used, show unprotected wall openings on floor	NFPA 13, Sec. 23.1.3 (38)
			The pressure setting for pressure reducing/regulating valves	NFPA 13, Sec. 23.1.3 (40)
		39.	Relative elevations of sprinklers and hydraulic reference points	NFPA 13, Sec. 23.1.3 (37)
		40.	Location of fire hydrants	NFPA 13, Sec. 23.1.3 (43)
		41.	Ceiling heights and slopes not included in full height cross section	NFPA 13, Sec. 23.1.3 (45)
		42.	When scope includes installation of private fire mains, provide main sizes, lengths, locations, weights, materials, point of connection to city main; the sizes, types and locations of valves, valve indicators, regulators, meters, and valve pits; and the depth that the top of the pipe is laid below grade (See NFPA 24)	NFPA 13, Sec. 23.1.3 (28)
<u>CHK.</u>	N/A	Ш.	Hydraulic Calculation Worksheets	
			Hydraulic calculations on sheets that include a summary sheet, graph sheet, water	NFPA 13, Sec. 23.3.5.1.1
			supply analysis, node analysis and detailed worksheets	·
		2.	Sheet number	NFPA 13, Sec. 23.3.5.6 (1)
			Sprinkler discharge, discharge constant (K), and flow in GPM	NFPA 13, Sec. 23.3.5.6 (4) (5)
			Hydraulic reference points	NFPA 13, Sec. 23.3.5.6 (2)
			Provide hazard classification for all areas to be sprinklered	NFPA 13, Sec. 23.3.5.2 (10)
			Indicate if system is hydraulic, pipe schedule or a combination	NFPA 13, Sec. 23.3.5.2 (15)
			System design requirements including design area, minimum rate of application area per sprinkler and number of sprinklers calculated.	NFPA 13, Sec. 23.3.5.2 (15)
		8.	Pipe Size, internal diameter, pipe lengths center to center of fittings	NFPA 13, Sec. 23.3.5.6 (7) (8) (10)
		9.	Equivalent pipe lengths for fittings and devices	NFPA 13, Sec. 23.3.5.6 (11)
		10.	Friction loss in psi/ft of pipe and appropriate "C" factor of pipe	NFPA 13, Sec. 23.3.5.6 (13) (14)
		11.	Total friction loss between reference points	NFPA 13, Sec. 23.3.5.6 (17)
		12.	Elevation head in psi between each reference point	NFPA 13, Sec. 23.3.5.6 (16)
		13.	Required pressure in psi at each reference point	NFPA 13, Sec. 23.3.5.6 (18)
		14.	Velocity pressure and normal pressure if included in calculations	NFPA 13, Sec. 23.3.5.6 (19) (a)
		15.	Diagram of gridded system indicating flows and directions for remote area	NFPA 13, Sec. 23.3.5.6 (19) (d)
		16.	Pressure loss assigned the backflow device	NFPA 13, Sec. 23.3.5.6 (19) (f)
		17.	Graph sheet showing supply curve, demand and hose allowance	NFPA 13. Sec. 23.3.5.3

CUK	NI/A	III Additional Information	
<u>CHK.</u> □	<u>N/A</u>	 III. Additional Information General notes Basic building information including occupancy group, type of construction, number of stories, floor area and presence of sprinkler protection in adjacent 	CFC, Sec. 105.4.2 CFC, Sec. 105.4.2
		 Indication of applicable editions of NFPA 13, CBC & CFC Reference CBC amendments to NFPA 13 in CBC Chapter 35 Reference OSHPD Policy Intent and Code Application Notices Record of local authority approval for appliance locations, water supply requirements and cross-connection protection - OSHPD form available 	CFC, Sec. 105.4.2 CFC, Sec. 105.4.2 CFC, Sec. 105.4.2 CFC, Sec. 507, Sec. 912 & Title 17, CCR, Div. 1, Ch. 5, Grp. 4, Subchp. 1, Art. 1 & 2, Secs. 7583 - 7605
<u>СНК.</u>	<u>N/A</u>	 IV. Equipment Submittals 1. Manufacturer's installation instructions for any specially listed equipment, includi 	ng NFPA 13, Sec. 23.1.4

- descriptions, applications, and limitations for any sprinklers, devices, piping, or fittings
 2. California State Fire Marshal listing sheets indicating expiration date for all listed CFC, Sec. 907.1.3
- California State Fire Marshal listing sheets indicating expiration date for all listed CFC, Sec. 907.1.3 components

NOTE

 \Box

Compliance with all items on this list does not necessarily assure compliance with all provisions of the applicable codes and standards. This reminder list should be used only by persons with a comprehensive knowledge of the applicable codes and

OSHPD Policy Intent Notices and Code Application Notices. <u>https://oshpd.ca.gov/construction-finance/codes-and-regulations/#cans-pins-faqs</u> OSHPD Project Review Status <u>https://esp.oshpd.ca.gov/CitizenAccess/</u> OSHPD Public Use Forms <u>https://oshpd.ca.gov/construction-finance/resources/forms-applications-reminder-lists/#ProjectForms</u>