

EXPEDITED BUILDING
PERMIT FOR
ROOF-MOUNTED
HVAC UNIT
REPLACEMENT



FOR SINGLE STORY
WOOD OR LIGHT
STEEL FRAME
CONSTRUCTION
SKILLED NURSING
FACILITIES &
INTERMEDIATE
CARE FACILITIES
(OSHPD 2 Buildings)

A Companion
Document to the
OSHPD FREER
Manual

October <u>2025</u>

EXPEDITED BUILDING PERMIT GUIDE FOR ROOF-MOUNTED HVAC UNIT REPLACEMENT

The Expedited Building Permit Guides are companion documents to the Office of Statewide Health Planning and Development (OSHPD) Field Review, Exempt, and Expedited Review (FREER) Manual and are intended as general reference guides and/or checklists to facilitate <u>repair, maintenance, minor renovation/remodeling, or installation of certain equipment</u> projects.

The Expedited Building Permit Guides are intended only for single-story OSHPD 2 Skilled Nursing Facilities (SNFs) and Intermediate Care Facilities (ICFs) that are of wood-frame or light steel construction and excluded from the definition of "Hospital Building" in the California Administrative Code (CAC), ARTICLE 2, Section 7-111.

The use of this Expedited Building Permit Guide is made available for use at the discretion of the facility owner. OSHPD (Office) does not mandate the use of the Expedited Building Permit Guide for any condition. Use of project-specific design and construction documents prepared by a California licensed design professional in lieu of using the Expedited Building Permit Guide is always acceptable, and in some cases, may be required.

This Expedited Building Permit Guide gives no consideration to suitability for use in a specific application, compatibility with other building systems, appropriate use of materials or design, appearances, etc. The facility owner and/or his/her authorized agent shall review all such qualities, features, and/or properties to ensure compliance with the California Building Standards Code and all applicable local codes and ordinances, appropriate integration with other building systems, and proper design for the project-specific conditions and installation, etc. This shall include a pre-assessment for existing damage or conditions that may need to be repaired and/or corrected.

While not mandatory, OSHPD recommends the facility have a California licensed architect or engineer, or a California licensed contractor assist in the review of the code compliance checklist provided in the Guide. In this manner, the facility will have a better understanding of the scope of work that may be required for a code compliant project prior to beginning the work.

The following regulations of the California Building Standards Code apply:

Before commencing construction or alteration of any health facility, the governing board or authority thereof shall submit an application for plan review to the Office, and shall obtain the written approval thereof by the Office describing the scope of work included and any special conditions under which approval is given (CAC, Section 7-113 (a)).

Construction or alteration of any health facility, governed under these regulations, performed without the benefit of review, permitting, and/or observation by the Office when review, permitting and/or observation is required, and without the exemption by the Office provided for in Section 7-127, shall be subject to examination by the Office to assess relevant code compliance. Failure to obtain the necessary reviews and approvals prior to commencing construction will result in examination fees, in addition to application fees (CAC, Section 7-128).

HVAC Unit Replacement

A roof-mounted HVAC unit replacement requires a Building Permit but may be exempt from the plan review process in accordance with Health & Safety Code (H&SC) Section 129875. Simple replacement of roof-mounted HVAC in qualifying OSHPD 2 SNFs and ICFs may be considered a maintenance project and exempt from plan review, if the following criteria are met.

- The weight of the replacement HVAC unit shall be less than 10% greater than the existing unit and less than 550 lbs.
- The CFM is equal to or greater than the existing unit and less than 2000 CFM.
- The connected fuel gas load, if applicable, is equal to or less than the existing unit.
- The connected electrical load is equal to or less than the existing unit.
- The replacement unit will fit in the space occupied by the existing unit and all required clearances and accesses will be provided and/or maintained.
- Work does not include adding, rerouting, or otherwise modifying ductwork other than addition of any required filters/filter bank at the plenum or minimal modifications to fit up existing ductwork to the new HVAC unit.
- The replacement is for maintenance work only, such as when an existing HVAC has failed, and is not for an additional HVAC unit.

This Expedited Building Permit Guide presents those criteria in a checklist format for general assessment of the specific project conditions. Installation of a HVAC unit without a permit is subject to an investigation fee, submittal of a project to the Office for plan review, demolition and/or rework of defective non-code complying work, etc. in accordance with the California Administrative Code, Title 24, Part 1, Section 7-128 "Work Performed without a Permit".

The facility owner or his/her authorized agent should review this checklist with the **OSHPD Compliance Officer** to determine program eligibility, to assess the specific project conditions and determination of possible approaches to the application, review, permitting, and construction process prior to proceeding with work. Possible approaches include, but are not limited to:

<u>Straight Replacement</u> (with minor repair work) – For removal and replacement of an existing HVAC unit, where all existing conditions are fully compliant with the code at the time of installation, this Expedited Building Permit Guide shall apply. The facility may have the work performed by its maintenance staff or by a California licensed contractor. Minor Repair Work (modifications, repair, or remedial work) shall be limited to repairing damage to original condition, adding filtration, adding or replacing filter gauge, adding up to five feet of new duct, air balancing to provide the general air balance relationships to adjacent areas, electrical disconnect, adding GFI receptacle, or adding grounding conductor. Expedite permit acceptable.

More than Minor Work – Not covered under this Expedited Building Permit Guide is the replacement of an existing HVAC unit where modification, repair, or remedial work is necessary to bring a system that did not comply with the code at the time it was installed into compliance with current code and/or to ensure a safe condition such as providing adequate structural support where the existing support is deficient. adding more than five feet of ductwork, rerouting, or otherwise modifying existing ductwork except where needed to accommodate tie-in location of the replacement HVAC unit. HVAC systems containing flammable refrigerants that do not comply with the refrigerant charge requirements of the California Mechanical Code and require additional mitigation measures will require submittal as a standard project. The facility must involve a licensed design professional (architect and/or mechanical engineer dependent upon the scope and nature of the remedial work). If this work is of sufficient limited scope, field review by the Compliance Officer can be used under this Expedited Building Permit Guide, however more involved work will require submittal as a standard project and reviewed by the Office by the Regional Architectural & Engineering Unit.

Existing HVAC Unit – Unless otherwise noted, the code excerpts on the following pages apply to **replacement** of HVAC units. If a unit serves a sub-acute area the project must be submitted to the Office as a standard project.

Determination of Eligibility – Determination of eligibility and appropriate permitting process is the responsibility of the OSHPD Regional Compliance Officer. Facilities are encouraged to work with their Compliance Officer prior to assuming eligibility or an approach to permitting.

Inspections – The approved Inspector of Record (IOR) must inspect the work prior to use. Interim inspection will be required when walls, ceilings or other construction materials will cover the finished work. Any deficiencies, identified through inspection, shall be corrected before use of the system is permitted. A "Certificate of Compliance" issued by the OSHPD Compliance Officer is required prior to use of the HVAC unit. Responsible parties shall file Verified Compliance Reports (CAC, Section 7-151) in accordance with the requirements of the Testing, Inspection and Observation (TIO) Program (CAC, Section 7-149). (See Appendix A)

Manufacturer's Written Installation, Operating, and Maintenance Instructions – The installation shall comply with the manufacturer's written installation instructions. The installer (facility's maintenance staff/contractor) shall leave or submit to the Compliance Officer the manufacturer's installation, operating, and maintenance instructions in a location on the premises where they will be readily available for reference and guidance for the Inspector of Record (IOR), OSHPD staff, service personnel, and the owner or operator. (CMC, Chapter 303.1, 2022)

Mechanical systems shall be installed in a manner that is in accordance with the California Mechanical Code (CMC), applicable standards, and the manufacturer's installation instructions. (CMC, Chapter 303, 2022)

New Project/Building Permit Application Requirements

- **Step 1.** Verify that the project is eligible for this program. Consultation with the OSHPD Compliance Officer is recommended.
- Step 2. Use the eServices Portal online application process or download and print the Expedited Building Permit Guide and complete the Roof-Mounted HVAC Unit Replacement Code Compliance Checklist beginning on Page 5 of this Guide and complete the Application for New Project/Building Permit beginning on Page 11 (Appendix B) of this Guide. These documents may be filled-in manually or electronically.
- **Step 3.** Prepare a plan/sketch showing the location(s) of where the HVAC unit(s) will be installed (a reduced copy of the building floor plan may be used for this purpose).
- **Step 4.** If not using the online application, print one (1) complete set of the entire package (the Expedited Building Permit Guide with completed Checklist and Applications), sign and date (where required), and mail or deliver to:

For construction in **Northern California**, submit to:

Office of Statewide Health Planning and Development Facilities Development Division 2020 West El Camino Avenue, Suite 800 Sacramento, CA 95833 (916) 440-8300 phone (916) 324-9188 fax

For construction in **Southern California**, submit to:

Office of Statewide Health Planning and Development Facilities Development Division 355 South Grand Avenue, Suite 1900 Los Angeles, CA 90071 (213) 897-0166 phone (213) 897-0168 fax

Upon issuance of the building permit for the project by OSHPD, you may submit a construction start letter and begin replacement of HVAC unit.

The following questions based on your answer may have requirements. These requirements will be communicated to you by the OSHPD Regional Compliance Officer.


ROOF-MOUNTED HVAC UNIT REPLACEMENT CODE COMPLIANCE CHECKLIST

NOTE: The OSHPD Compliance Officer will field verify compliance with the following checklist and additional work may be required to bring the installation into code compliance if found to be deficient.

			nplia	псе
		Yes	No	N/A
	DJECT DESCRIPTION			
1.	Is the HVAC unit replacement project located in a single-story Skilled Nursing or Intermediate Care Facility building of wood-frame or light steel frame construction?			
2.	Is this project for straight replacement of existing HVAC unit of similar size and capacity?			
	Commentary: Straight Replacement - For removal and replacement of an existing HVAC unit, where all existing conditions are fully compliant with the code at the time of installation.			
3.	Does the Estimated Construction Cost or Contract Amount exceed \$50,000?			
GEI	NERAL REQUIREMENTS			
4.	Contractor. Will work be performed by a contractor licensed by the California Contractors State License Board?			
	Note: Workers' Compensation Insurance is required for all work.			
PRO	OHIBITED LOCATIONS			
5.	Is this project for an HVAC system located in an attic or other concealed space?			
Flai	mmable Refrigerants – A2L			
6.	Does the HVAC unit utilize a flammable A2L refrigerant (R32, R454b?)			
6.a	Refrigeration concentration limits will need to comply with CMC 1104.6.1 and ASHRAE 15, 7.6.1. The maximum charge permitted is the EDVC value calculated based on the volume of the spaces served by the air handler system, the lower flammability limit (LFL) listed in CMC Table 1102.3/ASHRAE 34, a concentration factor of 0.5 and an occupancy adjustment factor of 0.5 for institutional occupancies.			
ED	OVC = Veff × LFL × CF × Focc			
ED	OVC = effective dispersal volume charge, lb (kg)			
Veff = effective dispersal volume, ft³ (m3)				
LFL = lower flammability limit, lb/ft³ (kg/m3)				
CF = concentration factor, value of 0.5				
Focc = occupancy adjustment factor; (0.5 for institutional)				
LF	L_{R32} =0.019lb/ft ³			
LF	$L_{R454b} = 0.022lb/ft^3$			

		Yes	No	N/A
6.b HVAC system must be listed per UL60335-2-40 ar requirements. (CMC 1104.6.1, ASHRAE 15, 7.6.2)	. ,			
6.c HVAC system must have a manufacturer installed for institutional. (CMC 1104.6.2.3, ASHRAE 15, 7.				
Commentary: A manufacturer installed refrigerant for all institutional occupancies. Other occupancies systems when the refrigerant charge exceeds 4.0l	require refrigerant detection			
6.d HVAC systems require nameplate and labeling in a 1104.6.2.1, 1104.6.2.2	accordance with CMC			
6.e HVAC systems must not contain ignition sources le 1104.6.3)	ocated in the ductwork. (CMC			
6.f HVAC system must perform safety actions in accor when refrigerant is sensed exceeding its setpoint. increased refrigerant quantities such as controlling separate mechanical ventilation during a refrigerar submittal.	Mitigation actions to allow dampers or activating			
HVAC INSTALLATION REQUIREMENTS				
7. Filter. Does the HVAC unit serve inpatient, treatm services, or cleaning supplies areas?	ent and/or diagnostic, direct			
Commentary: At least one 80% high-efficienc required downstream of the supply fan. The filte supported (non-collapsing type) and must open impingement, straining, and diffusion. (CMC 40)	er media must be rigid or attemption attemption attemption attemption at the principles of			
8. Filter Gauge. Is a filter gauge installed across each	h filter bank?			
Commentary: A filter gauge is required. The garded or a filter alarm light type that will provide recommended pressure drop has been reached	de signal when the			
Pressure Relationship/Ventilation Requirement change to the system design airflow or the air distribution.				
Commentary: Pressurized spaces should be c correct directional control by flutterstrip or smok pressurized spaces.	•			
10. Controls. Is the HVAC system thermostatically co zones? (CMC 320.2.2)	ntrolled in one or more			
11. Condensate Disposal. Does the condensate was less than 1/8 inch per foot to an approved receptor	• •			
Commentary: Condensate from air-cooling co appliances or similar air-conditioning equipmen discharged to an approved plumbing fixture or discharged into the drainage system, equipmer indirect waste pipe. (CMC 310.1)	t shall be collected and disposal area. Where			

		Cor	mplia	nce
		Yes	No	N/A
12.	Point of Discharge. Do the HVAC condensate waste pipes connect indirectly to a drainage system, through an airgap or airbreak, to properly trapped and vented receptors, dry wells, leach pits, or the tailpiece of plumbing fixtures? (CMC 310.5)			
13.	Outdoor Air Intake. Does the HVAC unit have outdoor air intakes?			
12.a	Is the outdoor air intake located at least 25 feet (or 10 feet if previously installed in compliance under a previous code) from exhaust outlets of ventilating systems, combustion equipment stacks, medical-surgical vacuum systems, cooling towers, plumbing vents, and areas that collect vehicular exhaust or other noxious fumes? (CMC 407.2.1)			
12.b	Where heavy snowfall is anticipated, is the outdoor air intake located at least 18 inches above roof level or 3 feet above a flat roof? (CMC 407.2.1)			
12.c	Is the outdoor air intake covered with a screen having not less than ¼ inch openings and not more than ½ inch openings, designed to manage rain entrainment, to prevent rain intrusion, and manage water from snow (where applicable)? (CMC 402.4)			
14.	Roof Slope. Is the HVAC system installed on a sloped roof?			
13.a	Does the roof have a slope of greater than 4 units vertical to 12 units horizontal (33 percent slope)?			
13.b	If the roof slope is greater than 4:12, is there a level platform of not less than 30 inches by 30 inches at the service side of the equipment for servicing? (CMC 304.2)			
15.	Gas Piping Connection. Does the HVAC unit connect to a fuel gas piping system?			
	Commentary: Each appliance connected to a piping system shall have an accessible, approved manual shutoff valve with a non-displaceable valve member or a listed gas convenience outlet. The shutoff valve shall be located within 6 feet (829 mm) of the appliance it serves (CPC 1212.6). A sediment trap shall be installed downstream of the appliance shutoff valve as close to the inlet of the appliance as practical, before the flex connector, where used at the time of appliance installation. (CPC 1212.9)			
HVA	C ANCHORAGE REQUIREMENTS			
16.	Will the replacement HVAC unit be anchored at a minimum of four (4) locations near each of the four corners of the unit?			
17.	Will the anchor spacing in each direction for the replacement HVAC unit be greater than or equal to 30 inches or the HVAC unit weight is less than 400 lbs?			
	Exception: 30" min. not required if unit weight is less the 400 pounds.			
18.	Is the replacement HVAC unit mounted on spring isolators?			
19.	Is the weight of the replacement HVAC unit less than 10% greater than the existing unit and less than 550 lbs.?			
20.	Is the height of the replacement HVAC unit above the platform 4 feet 6 inches or less?			



	Compliance		nce
	Yes	No	N/A
HVAC ELECTRICAL REQUIREMENTS			
23. Essential Power. Is essential electrical power provided for the heating equipment to maintain a minimum temperature of 60°F if serving a patient care area and plans submitted to OSHPD after January 1, 1989, or serving subacute patients?			
Commentary: Per the 1988 California Mechanical Code, HVAC units serving patient areas are required to be on Essential electrical power to maintain a minimum temperature of 60°F (CMC 321). Sub-acute patient care areas are also required to be on Essential electrical power.			
24. Disconnect. Does the HVAC unit have an electrical disconnect within sight of the unit? (CEC 440.14)			
Note: Circuit is required to be identified on cover of disconnect panel.			
25. Current. Does the replacement HVAC draw more current than the existing HVAC being replaced, and the same circuit is utilized?			
26. Overcurrent. Are overcurrent devices rated not more than the Maximum Over-Current Protection (MOCP) size shown on the nameplate of the replacement unit? (CEC 440.21)			
27. Conductors. Are conductors rated not less than Minimum Circuit Amps (MCA) shown on the nameplate of the replacement unit? (CEC 440.31)			
28. Grounding and Bonding. Is correctly sized equipment grounding conductor installed?			
Commentary: For the outdoor portion of a metallic raceway system that uses compression-type fittings, the equipment grounding conductor shall be a wire type. (CEC 250.122, CEC 440.9)			
29. Receptacle. Is 120-volt GFCI receptacle located within 25 feet of the equipment and on the same level and in an accessible location? (CEC 210.63)			

The above questions based on your answer may have requirements. These requirements will be communicated to you by the OSHPD Regional Compliance Officer.

APPENDIX A



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Phone (916) 440-8300 Phone (213) 897-0166

www.hcai.ca.gov FAX (916) 324-9188 FAX (213) 897-0168

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Testing, Inspection and Observation Program

2022 California Building Standards Code - OSHPD 2

Α	Facility #:	Facility Name:		F	Project #:	
Stre	et Address:					
City						
Rec	ord Name (Scor	pe of Project):				
В		TESTS - DOCUMENTATION / CE	ERTIFICATION REQUIRED		CONSTRUCTION VERIFICATION	OFFICE USE ONLY
		TESTS	RESPONSIBLE FIRM OR INDIVIDUAL	*TBD	IOR	OSHPD CONSTRUCTION ACCEPTANCE
ELE	ECTRICAL TE	STS				
	que Electrical (0110.3(B) & 110					CO:
ME	CHANICAL TI	ESTS				
CM	ronics C 1205.2, 1220.4 ssure test of stea	4.6 & 1221.3 am and water piping				CO:
Exis	sting System A C 407.3.1					CO:
Ven	tilation system C 407.3.1 & Tab as test and balar	le 4-A				CO:
PLU	JMBING TEST	rs				
CPO Air,	ering or conceal	r inert gas tested prior to use, ment				CO:
app CPC Whe pres Mine pres cond dete	licable and when C 1213.1.2 are repairs or ad assure test, the after repairs and acceptance and acceptance tested provinections are test	and additions, where en permitted by the CO ditions are made following the fected piping shall be tested. ditions are not required to be vided that work is inspected, and led with a non-corrosive leak-proved by the Authority Having				CO:

NOTE: To Be Determined (TBD) – The name of the firm or individual to perform this test or special inspection shall be submitted to and approved by the Office prior to proceeding with the work that requires this test or special inspection.

APPENDIX A



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT 2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 Phone (916) 440 Phone (213) 897 Phone (213) Phone (213) Phone (213) Phone (213) Phone (213) Phone (213) Phone (213)

www.hcai.ca.gov

Phone (916) 440-8300 FAX (916) 324-9188 Phone (213) 897-0166 FAX (213) 897-0168

Testing, Inspection and Observation Program

2022 California Building Standards Code - OSHPD 2

D	CONSTRUCTION OBSERVATION AND REPORTING									
	REQUIRED CONSTRUCTION OBSERVATION (See "PERSONAL KNOWLEDGE" as defined in California Administrative Code, Section 7-151)	OBSERVATION Per "PERSONAL KNOWLEDGE" defined in California Administrative Code, VERIFIED COMPLIANCE REPORT REQUIRED AS INDICATED (Form OSH-FD-123)					FOR OFFICE USE ONLY			
Ref. No.	*MILESTONES	GEOR	AOR	SEOR	MEOR	EEOR	CONT	SP INSP	IOR	OSHPD
	FINAL VERIFIED COMPLIANCE REPORT AT COMPLETION						X		X	

Е	FOR OFFICE USE ONLY	
	OSHPD Field Acceptance:	
	Name:	Date:

NOTE: To Be Determined (TBD) – The name of the firm or individual to perform this test or special inspection shall be submitted to and approved by the Office prior to proceeding with the work that requires this test or special inspection.

APPENDIX B

www.hcai.ca.gov



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Phone (916) 440-8300 FAX (916) 324-9188 Phone (213) 897-0166 FAX (213) 897-0168

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Application for New Project/Building Permit					RECEIVED	
	OFFICE USE ONLY					
Project #						
Facility						
Facility #		Facility Name				
)					
Type of Facility ☐ Skil	led Nursing or Intermedia					
December Detail						
Record Detail						
Record/Project Name	ROOF-MOUNTED HVAC	UNIT REPLACE	<u>MENT</u>			
Detailed Description						
Application Spec	ific Information					
Submittal Type ⊠ Fin	al					
Kind of Project ⊠ Re						
Annual Building Permit						
Contact Informat	ion					
O Primary	Type Legal Owner /	Administrator (F	Required for All Applicat	ions)		
First Name		M.I	Last Name			
Organization Name						
Street Address						
				Zip Co	ode	
Primary	Type Authorized Ag	gent (Authorization	he Attached)			
·		•	•			
				Zip Co	ode	



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

 LOPMENT
 www.hcai.ca.gov

 Phone (916) 440-8300
 FAX (916) 324-9188

 Phone (213) 897-0166
 FAX (213) 897-0168

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Application for New Project/Building Permit

	struction Performed By (check one	7)								
	ensed Contractor		01	- · · · - · ·						
				Expiration Date						
ddres	s Line 2									
				Zip Code						
hone		Phone 2		Fax						
	Division 3 of the Business and Professions	I am licensed Code, and my	under provisions of 0 Icense is in full for							
		Contractor or Authorized Agent's Name								
	Date	Email								
	provisions of the Contractors State License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business an Professions Code) or that he/she is exempt from licensure and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars [\$500].).									
	Please check all that apply for the following:									
	not intended or offered for sale (Section 70	44, Business employees' of or sale. If, hov	and Professions Coo r personal effort, bui vever, the building o							
	☐ I am exempt under Section: ,Building and Professions Code for this reason:									
	☐ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractor's State License Law does not apply to an owner of property who builds or improves thereon, and who contracts for the projects with a contractor(s) licensed pursuant to the Contractor's State License Law.).									
		contractors. I	understand that a co	at I have built as an owner-builder if it has not opy of the applicable law, Section 7044 of the on is submitted or at the following website:						
	Signature of Legal Owner or Authorized Ag	gent								
		,								



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Phone (916) 440-8300 FAX (916) 324-9188
Phone (213) 897-0166 FAX (213) 897-0168

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Application for New Project/Building Permit

Workers' Compensation Insurance Coverage

WORKERS' COMPENSATION DECLARATION (Section 3800, Labor Code):

WARNING: FAILURE TO SECURE WORKERS' COMPENSATION INSURANCE COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE INTEREST, AND ATTORNEY'S FEES

CODE, INTEREST, AND ATTORN	IEY'S FEES.	on order of the endore
I hereby affirm under penalty of pe	rjury <u>one</u> of the following declarations:	
as to become subject to the Worke	rformance of the work for which this permit is issued, I shall not employ any rs' Compensation Laws of California, and agree that, if I should become subj n 3700 of the Labor Code, I shall forthwith comply with those provisions.	
	eve and will maintain workers' compensation insurance, as required by Sectivork for which this permit is issued. My workers' compensation insurance ca	
Policy #	Insurance Carrier	
Expiration Date		
□ CopyAttached	Insurance Agent Phone	
Industrial Relations as required by	naintain a certificate of consent to self-insure for workers' compensation, iss Section 3700 of the Labor Code, for the performance of the work for which	this permit is issued.
Applicant's Signature	Date	
Costs		
CostType	ct Construction Costs (excluding fixed equipment, imaging equipment, design fees, inspection fees, and off-site improvements) Note: For SB 1838 projects, this amount must not exceed \$50,000 Fixed Equipment Costs	\$
	(sterilizers, chillers, boilers, etc., excluding installation)	\$
_	Note: See Instructions for Fee Information	
Reason		

APPENDIX B



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Phone (916) 440-8300 FAX (916) 324-9188 Phone (213) 897-0166 FAX (213) 897-0168

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Inspector of Record Applicant First Name ______ M.I. ___ Last Name _____ Organization Name Street Address Address Line 2 _____ State_____ Zip Code Phone Phone 2 _____ Date _____ Email _____ Signature **Application Specific Information – Inspector of Record** OSHPD Certification Number Class □ A \sqcap R \Box C Are you engaged in a business or other employment that requires a portion of your time? ☐ Yes ☐ No If yes, describe below: CERTIFICATION OF APPLICANT for INSPECTOR OF RECORD I hereby certify that all answers to the questions on this form are true, and I agree and understand that any misstatement of material fact contained in this application will be sufficient cause for my dismissal on this project, and possible suspension or revocation of my Hospital Inspector Certification. If I undertake additional work other than stated herein. I will notify the owner. the Architect, and/or Engineer, and the Office of Statewide Health Planning and Development, without delay. If appointed, I will accept the responsibilities of Inspector of Record on the above-mentioned project and will discharge the duties imposed upon me by all applicable sections of the Health and Safety Code. _____ Date ____ Signature **LEGAL OWNER** This person is being employed by the facility subject to the approval of the architect, structural engineer, or other applicable professional engineer, and OSHPD, and is gualified and able to provide competent, adequate and continuous inspection during construction of this project. Printed Name _____ Title _____ Signature _____ Date ____ **OFFICE USE ONLY OSHPD APPROVAL** Printed Name ____ **Enclosures for Project** Number Number **Enclosure Type Enclosure Type** of Copies of Copies How - To Guide 4 with Compliance Checklist Plans or sketch showing the location(s) of completed. HVAC units being replaced. Certificate of Insurance from a California

Other

licensed or Certificate of Consent to Self-Insure.

APPENDIX B



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

2020 West El Camino Avenue, Suite 800, Sacramento, California 95833 355 South Grand Avenue, Suite 1900 Floor, Los Angeles, California 90071

Phone (916) 440-8300 F Phone (213) 897-0166 F

www.hcai.ca.gov FAX (916) 324-9188 FAX (213) 897-0168

Letter of Authorization

(If application is made by an Agent on behalf of the Legal Owner/Administrator)

Project #		

To: Office of Statewide Health Planning and Development							
I hereby authorize:							
Name	Title						
"Legal Owner" or "Authorized Agent" on E	licant" in accordance with the application for New Project and Building Permit, Post Approval Document, Notice of Start of ms and required documents, for the facility known as:	as the					
Facility Name	Facility #						
Signature: Name: Title:		-					
Phone:		_					
E-mail:							

REVISION HISTORY

Version 2.0 October 2025 Added requirements related to A2L flammable

refrigerants found in the 2022 California Mechanical

Code July 1st, 2024 supplement.

Version 1.0 August 2020 First Issued