

Title: Senior Associate

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR HCAI SPECIAL SEISMIC	OFFICE OSE ONET			
CERTIFICATION PREAPPROVAL (OSP)	APPLICATION #: OSP-0760			
HCAI Special Seismic Certification Preapproval (OSP)				
Type: X New Renewal				
Manufacturer Information				
Manufacturer: Generac Power Systems				
Manufacturer's Technical Representative: Richard Ansley				
Mailing Address: S45W29290 HIGHWAY 59, Waukesha, WI 53189				
Telephone: (262) 544-2335 Email: Richard.Ansley@ge	nerac.com			
Product Information				
Product Name: Emergency and Standby Power Systems	4			
Product Type: Generators	3			
Product Model Number: ERG450	in the second se			
General Description: Natural Gas Generator Y: Mohammad Karim	0			
Mounting Description: Rigid, Floor Mounted				
Tested Seismic Enhancements: None DATE: 03/22/2023	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\			
Applicant Information	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\			
Applicant Information	4,			
Applicant Company Name: Buehler				
Contact Person: Gillian Montgomery				
Mailing Address: 600 Q Street, Suite 200, Sacramento, CA 95811				
Telephone: (916) 443-0303 Email: gmontgomery@buel	hlerengineering.com			





STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Respon	sible for the Engineering and Test Report(s)				
Company Name: BUEHLER ENGINEERING, INC.					
Name: Gillian Montgomery California License Number: S6852					
Mailing Address: 600 Q Street, Sacramento, CA 95811					
Telephone: (916) 443-0303 Email	l: gmontgomery@buehlerengineering.com				
Certification Method					
GR-63-Core X ICC-ES AC156	☐ IEEE 344 ☐ IEEE 693 ☐ NEBS 3				
Other (Please Specify):					
E.O.F.	CODECO				
Testing Laboratory	Mp.				
Company Name: UNIVERSITY OF BUFFALO (SEESL)					
Contact Person: Mark Pitman	2				
Mailing Address: 212 Ketter Hall, Buffalo NY 14260	JSP-0760				
Telephone: (716) 645-4377	il:_mpitman@buffalo.edu				
DATE:	03/22/2023				





03/22/2023 OSP-0760 Page 2 of 6



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters					
Design Basis of Equipment or Components	s(Fp/Wp) = 0.9				
SDS (Design spectral response accele	eration at short period, g) = 2.0				
ap (Amplification factor) =	1				
R _P (Response modification factor) =	2.5				
Ω o (System overstrength factor) =	2.0				
Ip (Importance factor) =	1.5				
z/h (Height ratio factor) =	0				
Natural frequencies (Hz) =	See Attachment				
Overall dimensions and weight =	See Attachment				

HCAI Approval (For Office Use Only) - Approval Expires on 03/21/2029						
Date:	3/22/2023 OSP-0760	12				
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities			
Special	Seismic Certification Valid Up to: Sps (g) = 2.0	z/h =	0			
Conditio	n of Approval (if applicable): DATE 03/22/2023					





03/22/2023 OSP-0760 Page 3 of 6



Special Seismic Certification OSHPD Preapproval Generac Natural Gas Unit



Table 1. Certified Product List

Model Number	Tested/	Length	Width	Height	Max Operating
	Interpolated	(in)	(in)	(in)	Weight (lbs)
ERG450*	UUT-1	120	96	144	18,790

^{*}as configured on UUT sheet. Generac is ISO 9001 certified.



03/22/2023 OSP-0760 Page 4 of 6



Special Seismic Certification OSHPD Preapproval Generac Natural Gas Unit



UUT-1 Test Summary

Testing Lab: University of Buffalo (SEESL)

Testing Report: 2023.01

Testing Unit Num: 1

Model Number	Measured Operating Weight (lbs)	Mounting	Excitation Direction		Frequency (Hz)	Length (in)	Width (in)	Height (in)	
		Digid	Х	Front-Back	4.25				
ERG450	18,790	Rigid Floor	-	Υ	Side-Side	6.88	120	96	144
		1 1001	Z	Vertical	12.75				

Notes: Frequencies are for units prior to ICC ES AC-156 testing.

Attachment Method
Twelve (12) - 3/4"Ø Grade 8 bolts with nuts and washers.

Seismic Parameters							
Building	Test Criteria	S _{DS}	z/h	Horiz	ontal	Vertical	
Code	Test Criteria	S _{DS} (g)	2/11	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2022	AC 156	2.00	0.0	2.00	0.80	1.34	0.54






Figure 1.2: Mounting Detail

Notes: The UUT was full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test



Special Seismic Certification OSHPD Preapproval Generac Natural Gas Unit



UUT-1 Summary Tested Sub-Component						
Sub-Component	Weight (lb)	Part Number/ Description	Manufacturer	Material		
Base	2000	CONDUIT TRAY	GENERAC	Steel		
Enclosure	6300	SEISM	GENERAC	Steel		
Engine	3317	G21.9L	GENERAC	Cast iron and carbon steel		
Alternator	2724	LSA 47	LEROY SOMER	Steel laminations, copper windings		
Exhaust System	600	24R G21.9L	GENERAC	Stainless steel		
Air Injection System	100	SAI G21.9L	GENERAC	Steel laminations, copper windings, rubber and plastic		
Cooling System	2175	10R G21.9L	GENERAC	Aluminum fins, tanks, support plate and tubes and steel mounting		
Control Panel Assembly	380	3R G21.9L	GENERAC	Carbon steel enclosure and electrical components		
Fuel Train	190	20R G21.9L R	GENERAC	Carbon steel, aluminum, rubber and plastic		
Oil Make Up	485	OIL MAKEUP G21.9L	GENERAC	Carbon steel, aluminum, rubber and plastic		
Battery	130	8D	Remy	Carbon steel, aluminum, copper and plastic		

BY: Mohammad Karim

OSP-0760

DATE: 03/22/2023

03/22/2023 OSP-0760 Page 6 of 6