



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

**APPLICATION FOR HCAI SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP-0840

**HCAI Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: Siemens Industry, Inc.

Manufacturer's Technical Representative: Scott McClelland

Mailing Address: 3617 Parkway Lane, Peachtree Corners, GA 30092

Telephone: (678) 982-2353 Email: mcclelland.scott@siemens.com

**Product Information**

Product Name: Enclosed Fusible Switches

Product Model Number(s): See attachment

Product Category: Power Isolation and Correction Systems

Product Sub-Category: Power Isolation and Correction Systems

General Description: Metal enclosed fusible switches with integrated surge protection / relays with remote operation capabilities.

Mounting Description: Wall Mounted Rigid -

Tested Seismic Enhancements: Seismic enhancements made to the test units and/or modifications required to address anomalies during the tests shall be incorporated into the production units.

**Applicant Information**

Applicant Company Name: WE Gundy & Associates, Inc

Contact Person: Travis Soppe

Mailing Address: PO Box 9121, Boise, ID 83707

Telephone: (208) 342-5989 Email: tsoppe@wegai.com

Title: President





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: W.E. GUNDY & ASSOCIATES INC.  
Name: Travis Soppe California License Number: S6115  
Mailing Address: P.O. Box 9121, Boise, ID 83707  
Telephone: (208) 342-5989 Email: tsoppe@wegai.com

**Certification Method**

GR-63-Core       ICC-ES AC156       IEEE 344       IEEE 693       NEBS 3  
 Other (Please Specify): \_\_\_\_\_

**Testing Laboratory**

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)  
Contact Person: Jeremy Lange  
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513  
Telephone: (972) 247-9657 Email: jeremy@etldallas.com





**DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION  
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT**

**Seismic Parameters**

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.50 for SDS = 2.0 at z/h = 1 and 1.13 for SDS = 2.5 at z/h = 0

SDS (Design spectral response acceleration at short period, g) = 2.00 (z/h = 1.0) and 2.50 (z/h = 0.0)

$a_p$  (Amplification factor) = 2.5

$R_p$  (Response modification factor) = 6.0

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

**HCAI Approval (For Office Use Only) - Approval Expires on 04/11/2031**

Date: 4/11/2025


Name: Mohammad Karim

Title: Supervisor, Health Facilities

Special Seismic Certification Valid Up to: SDS (g) = 2.0

z/h = 1

Condition of Approval (if applicable): \_\_\_\_\_



**TABLE 1**

**SIEMENS ENCLOSED FUSIBLE SWITCH  
CERTIFIED PRODUCT LINE MATRICES**



**Elevator Control Switches - ECS  
Fusible Shunt Trip Switches - STF  
Fusible Safety Switches w/ Integrated SPD - HF**

Identification Number <sup>1,2</sup>	Ampreage	NEMA Rating	<sup>3</sup> Dimensions (in)			Weight (lb)	Representative UUT
			Width	Depth	Height		
HF16xCxJ	30A	1/3R/12	16.8	6.6	33	64	extrapolated
HF26xCxJ	60A	1/3R/12	16.8	6.6	33	64	extrapolated
HF36xCxJ	100A	1/3R/12	16.8	6.6	33	66	extrapolated
STF1xxxxxJ	30A	1/3R/12	16.8	6.6	33	70	extrapolated
STF2xxxxxJ	60A	1/3R/12	16.8	6.6	33	70	extrapolated
STF3xxxxxJ	100A	1/3R/12	16.8	6.6	33	72	extrapolated
ECS1TxRxxxxA	30A	1	16.8	6.4	31.1	71	extrapolated
ECS2TxRxxxxA	60A	1	16.8	6.4	31.1	71	extrapolated
ECS3TxRxxxxA	100A	1	16.8	6.4	31.1	73	extrapolated
<b>ECS3T1R1RNA</b>	<b>100A</b>	<b>1</b>	<b>16.7</b>	<b>6.4</b>	<b>31.1</b>	<b>76</b>	<b>UUT-1</b>
ECS1TxRxxJxxA	30A	3R/12	16.8	6.6	33	72	interpolated
ECS2TxRxxJxxA	60A	3R/12	16.8	6.6	33	72	interpolated
ECS3TxRxxJxxA	100A	3R/12	16.8	6.6	33	74	interpolated
HF46xCxJ	200A	1/3R/12	23.3	7.4	37.4	86	interpolated
STF4xxxxxJ	200A	1/3R/12	23.3	7.4	37.4	92	interpolated
ECS4TxRxxJxxA	200A	1/3R/12	23.3	7.4	37.4	94	interpolated
HF56xCxJ	400A	1/3R/12	23.3	7.4	48	130	interpolated
STF5xxxxxJ	400A	1/3R/12	23.3	7.4	48	136	interpolated
ECS5TxRxxJxxA	400A	1/3R/12	23.3	7.4	48	138	interpolated
<b>ECS5T1R1RJNCA</b>	<b>400A</b>	<b>1/3R/12</b>	<b>23.4</b>	<b>7.4</b>	<b>48</b>	<b>138</b>	<b>UUT-2</b>

Notes:

- <sup>1</sup> All components are manufactured by Siemens and the part numbers listed uniquely identify type of component, manufacturer, and material of construction for each sub-component within the tested unit.
- <sup>2</sup> The enclosed fusible switch configurations utilize the same carbon steel enclosures and internal subcomponents and . The Elevator Control Switch (ECS) configurations contain the most subcomponents in the listing and the Fusible Shunt Trip Switch (STF) / Fusible Safety Switch w/ Integrated SPD (HF) configurations are identical with fewer internal subcomponents.  
 ECS\*: Fusible power switch with remote operation (OFF only) and internal relays for integration with building fire alarm system  
 HF\*: Fusible power switch with integrated surge protection  
 STF\*: Fusible power switch with remote operation (OFF only)
- <sup>3</sup> Dimensions listed are main enclosure box dimensions and do not include handles or anchor tabs that extend beyond the box.

**SEISMIC CERTIFICATION LIMITS**

System Component	Code	S <sub>DS</sub> (g)	z / h	I <sub>P</sub>	a <sub>P</sub>	R <sub>P</sub>	Ω <sub>0</sub>	F <sub>P</sub> / W <sub>P</sub>
Enclosed Switches	CBC 2022	2.0	1	1.50	2.5	6.0	2.0	1.50
		2.5	0					1.13

**TABLE 2**

**SIEMENS ENCLOSED FUSIBLE SWITCH  
CERTIFIED SUBCOMPONENT MATRIX**



**Elevator Control Switches - ECS  
Fusible Shunt Trip Switches - STF  
Fusible Safety Switches w/ Integrated SPD - HF**


ID/Catalog Number	Manufacturer	Description	Weight (lbs)	Representative UUT
<b>Relays</b>				
3TX71175HF13C	SIEMENS	120 VAC 4P Ice Cube Relay	< 1	UUT-1 / UUT-2
<b>Molded Case Switch</b>				
3VA51101BB310AA0	SIEMENS	100A	3	UUT-1
3VA5	SIEMENS	30A-400A	3 - 12	interpolated
3VA53401BB310AA0	SIEMENS	400A	12	UUT-2
<b>Control Power Transformers</b>				
KT8100	SIEMENS	100VA	6	UUT-1
<b>Selector Switch / Pilot Light</b>				
3SU1	SIEMENS	Selector Switch / Pilot Light	< 1	UUT-1 / 2
<b>Fuse Block</b>				
HBB22	SIEMENS	30A Load Base QTY 2	1.8	extrapolated
HBB62	SIEMENS	60A Load Base QTY 2	2.0	interpolated
HBB63	SIEMENS	100A Load Base QTY 2	2.0	UUT-1
US2:R507013	SIEMENS	200A Fuse Block Assy	2.2	interpolated
US2:R507012	SIEMENS	400A Fuse Block Assy	7.0	UUT-2
<b>Surge Protective Device</b>				
TPS403	SIEMENS	TPS4 Surge Protective Device	< 1	UUT-2
<b>Neutral Kit</b>				
N125X	SIEMENS	30-100A	0.8	UUT-1
HN64	SIEMENS	200A	0.6	interpolated
HN656A	SIEMENS	400A	1.6	UUT-2
<b>Ground Lug</b>				
HG61234	SIEMENS	30-200A	< 1	UUT-1
HG656A	SIEMENS	400A	< 1	UUT-2
<b>Fuses</b>				
A4J100	Mersen	100A	< 1	UUT-1
A4J	Mersen	30-400A	< 1	interpolated
A4J400	Mersen	400A	< 1	UUT-2

**UUT-1**

**UNIT UNDER TEST (UUT)  
SUMMARY SHEET**



**Mounting Details:** Rigid wall mounted with (3) 1/4" grade 5 bolts



DATE: 04/11/2025

<b>Manufacturer:</b> Siemens	<b>Test Location:</b> ETL, Dallas TX
<b>Product Line:</b> Enclosed Fusible Switch - ECS	<b>Test Date:</b> October 2024
<b>Component:</b> ECS3T1R1RNA	<b>Report Number:</b> 17491-Rev.1

**UUT Function:** Power interruption for equipment and circuit protection

**UUT Description:** 100A elevator control switch configuration in wall mounted NEMA 1 enclosure containing 3TX71175HF13C Relay, 3VA51101BB310AA0 Switch, KT8100 CPT, 3SU1 Switch, HBB63 Fuse Block, N125X Neutral Kit, HG61234 Ground Lug, and A4J100 Fuse

**UUT PROPERTIES**

Weight (lb)	Enclosure Box Dimensions (inches)			Natural Frequency (Hz)		
	Width	Depth	Height	FB	SS	V
76	16.7	6.4	31.1	NA	NA	NA

**SEISMIC TEST PARAMETERS**

Building Code / Test Criteria	S <sub>DS</sub> (g)	z / h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022 / ICC-ES AC156	2.00	1	1.5	3.20	2.40	-	-
	2.50	0	1.5	-	-	1.67	0.67

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 test.

**UUT-2**

**UNIT UNDER TEST (UUT)  
SUMMARY SHEET**



**Mounting Details:** Rigid wall mounted with (4) 1/4" grade 5 bolts



<b>Manufacturer:</b> Siemens	<b>Test Location:</b> ETL, Dallas TX
<b>Product Line:</b> Enclosed Fusible Switch - ECS	<b>Test Date:</b> October 2024
<b>Component:</b> ECS5T1R1RJNCA	<b>Report Number:</b> 17491-Rev.1

**UUT Function:** Power interruption for equipment and circuit protection

**UUT Description:** 400A elevator control switch configuration in wall mounted NEMA 12 / 3R enclosure containing 3TX71175HF13C Relay, 3VA53401BB310AA0 Switch, 3SU1 Switch, US2:R507012 Fuse Block, TPS403 Surge Protective Device, HN6565A Neutral Kit, HG656A Ground Lug, and A4J400 Fuse

**UUT PROPERTIES**

Weight (lb)	Enclosure Box Dimensions (inches)			Natural Frequency (Hz)		
	Width	Depth	Height	FB	SS	V
138	23.4	7.4	48.0	NA	NA	NA

**SEISMIC TEST PARAMETERS**

Building Code / Test Criteria	S <sub>DS</sub> (g)	z / h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
CBC 2022 / ICC-ES AC156	2.00	1	1.5	3.20	2.40	-	-
	2.50	0	1.5	-	-	1.67	0.67

Note: The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. The unit maintained structural integrity during and after the ICC-ES AC156 test.