

2025 CBC Changes to HCAI Preapprovals

Timothy Piland, Senior Structural Engineer

April 9th, 2025

Proudly Partnered with AIA California

Attendees will earn 1.5 AIA LU/HSW for attending this presentation live.

AIA CA will submit you for AIA credit within 10 days of the presentation.

2025 CBC Changes to HCAI Preapprovals (ASCE 7-22 Chapter 13 Nonstructural Components)

ASCE 7-22 will be incorporated into the 2025 CBC, with significant changes to the seismic horizontal nonstructural component lateral forces within Chapter 13.

Specifically, Eqn 13.3-1 (F_p), Table 13.5-1 Architectural Components and Table 13.6-1 Mechanical and Electrical Components.

The changes reflect a more refined approach to the behavioral response of nonstructural components during major seismic events, via testing and the collaborative efforts of ASCE 7-22 Seismic Committee.



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR HCAI PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM)	OFFICE USE ONLY APPLICATION #: OPM-0669
---	--

HCAI Preapproval of Manufacturer's Certification (OPM)

Type: New Renewal/Update



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC CERTIFICATION PREAPPROVAL (OSP)	OFFICE USE ONLY APPLICATION #: OSP-0699
--	--

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

2025 CBC Changes to HCAI Preapprovals (ASCE 7-22 Chapter 13 Nonstructural Components)

Webinar will review the **new horizontal seismic design force, F_p** (eqn. 13.3-1), within ASCE 7-22 Chapter 13, used in existing, renewal, and new HCAI preapprovals, focusing on the ***DPOR responsibilities*** by the:

- 1) DPOR for preapproval submittals (***Preapproval DPOR***) with added focus on preapproval-project efficiency
 - 2) DPOR for preapproval project use (***Project DPOR***)
- Changes to the seismic design force, F_p used in eqn. 13.3-1 from ASCE 7-16 => 7-22
 - Review of new variables introduced within eqn. 13.3-1
 - ASCE 7-16 => 7-22 F_p comparison plots for components in Tables 13.5-1 & 13.6-1
 - Application of horizontal seismic design force F_p for both preapproval submittals and projects use
 - OPM and OSP preapproval examples and DPOR responsibilities

The OSHPD preapproval programs are defined on the HCAI website within PIN 62 and PIN 55 for the OPM and OSP programs, respectively.

Adaptation of the ASCE 7-22 Nonstructural Component to the Preapproval Programs; OPM/OSP



ASCE 7-22 Seismic Design Force, F_p :

$$F_p = 0.4S_{DS}I_pW_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right] \quad (13.3-1)$$

~~Preapproval capacities for F_p , can no longer be determined by simply specifying S_{DS} and z/h !~~

Per ASCE 7-22, S_{DS} and H_f/R_μ are now required. OSHPD, however, decided to extend the requirements to the mass coefficient (accelerations).

Citing Sir Issac Newton's **2nd Law of Motion**:

Force = Mass times Acceleration

$F = m * a$ where:

$m = \text{Weight/gravity}$

$a = \text{acceleration}$

$F_p = C_p W_p \Rightarrow F_p / W_p = C_p$

where:

$C_p = \text{mass coefficient (accelerations)}$, referenced as the component design force coefficient

For OPMs... the component design force coefficient, $C_{Pm} = 0.4S_{DS}I_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right]$; Analytical ✓ (supports and attachments)

For OSPs... the tested component design force coefficient, $C_{Ps} = \text{RRS accelerations (A}_{FLX-H}, \text{A}_{RIG-H}, \text{A}_{FLX-V}, \text{A}_{RIG-V})$; Tested Spectral Accelerations ✓ (SSC tested components)

Note:
 C_p for the OPMs \neq OSPs $\Rightarrow C_{Pm} \neq C_{Ps}$
 OPM $C_{Pm} \sim$ analytical value (eqn 13.3-1)
 OSP $C_{Ps} \sim$ tested spectral acceleration value (C_{AR} , R_{po} , and $I_p = 1$)

ASCE 7-16 vs 7-22 Nonstructural Horizontal Seismic Component Equation Comparison

F_p = Horizontal seismic component design force equation comparison
(similarities)

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p} \right)} \left(1 + 2 \frac{z}{h} \right) \quad (13.3-1) \quad \text{ASCE 7-16}$$

ASCE 7-16

VS

$$F_p = 0.4 S_{DS} I_p W_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right] \quad (13.3-1) \quad \text{ASCE 7-22}$$

ASCE 7-22

Portions remain unchanged


Upper and lower bounds remain unchanged

F_p is not required to be taken as greater than

$$F_p = 1.6 S_{DS} I_p W_p \quad (13.3-2)$$

and shall not be taken as less than

$$F_p = 0.3 S_{DS} I_p W_p \quad (13.3-3)$$



ASCE 7-16 vs 7-22 Nonstructural Component Equation Comparison

F_p = Horizontal seismic component design force equation comparison
(changes)

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{z}{h}\right) \quad \text{ASCE 7-16}$$


$$F_p = 0.4 S_{DS} I_p W_p \left[\frac{H_f}{R_\mu}\right] \left[\frac{C_{AR}}{R_{po}}\right] \quad \text{ASCE 7-22}$$

a_p = Component amplification factor
 R_p = Component response modification factor

$\left(1 + 2 \frac{z}{h}\right)$ z = height in structure of point of attachment
 h = average roof height of structure

C_{AR} = Component resonance ductility factor
 R_{po} = Component strength factor

$\left[\frac{H_f}{R_\mu}\right]$ H_f = Force amplification as a function of height
 R_μ = Structure ductility reduction factor



For all practical purposes:

$a_p \approx C_{AR}$ as both variables possibly amplify the component response (ability to achieve resonance)

Where: C_{AR} = Peak Component Acceleration/Peak Floor Acceleration (PCA/PFA)
(component flexibility, ratio of component to building period, and ductility)

$R_p \approx R_{po}$ as both variables possibly reduce the component response

Where: R_{po} = Component inherent overstrength

ASCE 7-16 vs 7-22 Nonstructural Component Equation Variables

H_f = Force amplification as a function of height (*New*)

Where: H_f is based upon the Ratio of *Peak Floor Acceleration / Peak Ground Acceleration (PFA)/(PGA)*.

$$H_f = 1 + a_1 \left(\frac{z}{h}\right) + a_2 \left(\frac{z}{h}\right)^{10} \quad (13.3-4) \quad H_f \approx 2.46 \quad (T_a = 2; a_1 = 0.5; a_2 = 0.96) \quad (\text{based upon building period} = 2s.)$$

$$H_f = 1 + 2.5 \left(\frac{z}{h}\right) \quad \text{Default} \quad (13.3-5) \quad \text{Above Grade:} \quad H_{fMAX} = 3.5$$

Where:

$$a_1 = 1/T_a \leq 2.5$$

$$a_2 = 1 - 0.4T_a^2 \geq 0$$

z = Height above the base of structure to component attachment


h = Average roof height of structure with respect to the base

T_a = *Lowest approximate fundamental period of the supporting building or nonbuilding structure* in either orthogonal direction. For structures with combinations of seismic force-resisting systems (SFRSs), the SFRS that produces the lowest value of T_a shall be used.

At or below grade:

$$H_{fMIN} = 1$$

$$\frac{F_p}{W_p} = (0.4S_{DS}) \times \left[\frac{H_f}{R_\mu}\right] \times \left[\frac{C_{AR}}{R_{po}}\right] \times I_p$$



F_p is *now* a function of the **Building Seismic Force Resisting Systems (SFRS)**

$$F_p = 0.4S_{DS}I_pW_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right]$$

$$R_\mu = [1.1R(I_e\Omega_0)]^{1/2} \geq 1.3 \quad (13.3-6)$$

R_μ = Structure **ductility** reduction factor, based upon the SFRS

R = Response modification coefficient, **SFRS in Table 12.2-1, 15.4-1, or 15.4-2**

I_e = Importance Factor

Ω_0 = Overstrength factor as defined in **Table 12.2-1, 15.4-1, or 15.4-2**



Concrete Shear wall




Moment Frame



Steel Braced Frame

Seismic Force-Resisting System

$T_{comp} = 0.5 \text{ sec}$



Effect of building stiffness on PCA/PGA for instrumental recordings

ASCE 7-16 vs 7-22 Nonstructural Component Equation Variables

R_μ = Structure Ductility Reduction Factor (*New*)

Where: R_μ is *based upon the building's ductility* within the Seismic Lateral Force System (*SFRS*)

$$\left[\frac{H_f}{R_\mu} \right] R_\mu = [1.1R(I_e\Omega_0)]^{1/2} \geq 1.3 \quad (13.3-6)$$

Where:

R = Response modification factor

Ω_0 = Overstrength factor

(both from Tables 12.2-1, 15.4-1, or 15.4-2)

Above grade:

$R_{\mu MAX} = 1.71$ (only for a single SFRS within Table 12.2-1)

$R_{\mu MIN} = 1.30$ (min within Table 12.2-1 or when SFRS is not listed or specified)

At or below grade:

$R_{\mu MIN} = 1.0$

Resulting in:

$$\left[\frac{H_f}{R_\mu} \right]_{MAX} = 2.69 \text{ (with } H_{f MAX} / R_{\mu MIN} \text{) (Above grade)}$$

$$\left[\frac{H_f}{R_\mu} \right]_{MIN} = 1.0 \text{ (At or below grade)}$$

As a minimum, all preapprovals must be certified for either one or both conditions, dependent upon the nonstructural component.

R_μ as a function of SFRS within Table 12.2-1

R_μ for different SFRS
1.30 ≤ R_μ < 1.40

$$F_p = 0.4S_{DS}I_pW_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{p0}} \right]; R_\mu = [1.1R/(I_e\Omega_0)]^{1/2} \geq 1.3 \quad (13.3-6)$$

Seismic Force-Resisting System	ASCE 7 Section Where Detailing Requirements Are Specified	Response Modification Coefficient, R ^a	Overstrength Factor, Ω _e ^b	Deflection Amplification Factor, C _d ^c	R _μ
A. BEARING WALL SYSTEMS					
A.1 <i>Special reinforced concrete shear walls^{a,b}</i>	14.2	5	2.5	5	1.30
A.3 Ordinary reinforced concrete shear walls ^d	14.2	4	2.5	4	1.30
A.4 Detailed plain concrete shear walls ^e	14.2	2	2.5	2	1.30
A.5 Ordinary plain concrete shear walls ^f	14.2	1.5	2.5	1.5	1.30
A.6 Intermediate precast shear walls ^g	14.2	4	2.5	4	1.30
A.7 Ordinary precast shear walls ^h	14.2	3	2.5	3	1.30
A.8 <i>Special reinforced masonry shear walls</i>	14.4	5	2.5	3.5	1.30
A.9 Intermediate reinforced masonry shear walls	14.4	3.5	2.5	2.25	1.30
A.10 Ordinary reinforced masonry shear walls	14.4	2	2.5	1.75	1.30
A.11 Detailed plain masonry shear walls	14.4	2	2.5	1.75	1.30
A.12 Ordinary plain masonry shear walls	14.4	1.5	2.5	1.25	1.30
A.13 Prestressed masonry shear walls	14.4	1.5	2.5	1.75	1.30
A.14 Ordinary reinforced AAC masonry shear walls	14.4	2	2.5	2	1.30
A.15 Ordinary plain AAC masonry shear walls	14.4	1.5	2.5	1.5	1.30
A.16 Light-frame (wood) walls sheathed with wood structural panels rated for shear resistance	14.5	6.5	3	4	1.30
A.17 Light-frame (cold-formed steel) walls sheathed with wood structural panels rated for shear resistance or steel sheets	14.1	6.5	3	4	1.30
A.18 Light-frame walls with shear panels of all other materials	14.1 and 14.5	2	2.5	2	1.30
A.19 Light-frame (cold-formed steel) wall systems using flat strap bracing	14.1	4	2	3.5	1.30
A.20 Cross-laminated timber shear walls	14.5	3	3	3	1.30
A.21 Cross-laminated timber shear walls with shear resistance	14.5	4	3	4	1.30

B. BUILDING FRAME SYSTEMS					
B.3 Steel ordinary concentrically braced frames	14.1	3.25	2	3.25	1.30
B.4 <i>Special reinforced concrete shear walls^{a,b}</i>	14.2	6	2.5	5	1.33
B.6 Ordinary reinforced concrete shear walls ^f	14.2	5	2.5	4.5	1.30
B.7 Detailed plain concrete shear walls ^g	14.2 and 14.2.2.7	2	2.5	2	1.30
B.8 Ordinary plain concrete shear walls ^h	14.2	1.5	2.5	1.5	1.30
B.9 Intermediate precast shear walls ⁱ	14.2	5	2.5	4.5	1.30
B.10 Ordinary precast shear walls ^j	14.2	4	2.5	4	1.30
B.12 <i>Steel and concrete composite special concentrically braced frames</i>	14.3	5	2	4.5	1.35
B.13 Steel and concrete composite ordinary braced frames	14.3	3	2	3	1.30
B.14 Steel and concrete composite plate shear walls	14.3	6.5	2.5	5.5	1.38
B.15 <i>Steel and concrete composite special shear walls</i>	14.3	6	2.5	5	1.33
B.16 Steel and concrete composite ordinary shear walls	14.3	5	2.5	4.5	1.30
B.17 <i>Special reinforced masonry shear walls</i>	14.4	5.5	2.5	4	1.30
B.18 Intermediate reinforced masonry shear walls	14.4	4	2.5	4	1.30
B.19 Ordinary reinforced masonry shear walls	14.4	2	2.5	2	1.30
B.20 Detailed plain masonry shear walls	14.4	2	2.5	2	1.30
B.21 Ordinary plain masonry shear walls	14.4	1.5	2.5	1.25	1.30
B.22 Prestressed masonry shear walls	14.4	1.5	2.5	1.75	1.30
B.25 Light-frame walls with shear panels of all other materials	14.1 and 14.5	2.5	2.5	2.5	1.30
C. MOMENT-RESISTING FRAME SYSTEMS					
C.2 Steel special truss moment frames	14.1	7	3	5.5	1.31
C.3 Steel intermediate moment frames	12.2.5.7 and 14.1	4.5	3	4	1.30
C.4 Steel ordinary moment frames	12.2.5.6 and 14.1	3.5	3	3	1.30
C.6 Intermediate reinforced concrete moment frames	14.2	5	3	4.5	1.30
C.7 Ordinary reinforced concrete moment frames	14.2	3	3	2.5	1.30
C.9 Steel and concrete composite intermediate moment frames	14.3	5	3	4.5	1.30
C.10 Steel and concrete composite partially restrained moment frames	14.3	6	3	5.5	1.30
C.11 Steel and concrete composite ordinary moment frames	14.3	3	3	2.5	1.30
C.12 <i>Cold-formed steel—special bolted moment frame^a</i>	14.1	3.5	3	3.5	1.30

D. DUAL SYSTEMS WITH SPECIAL MOMENT FRAMES CAPABLE OF RESISTING AT LEAST 25% OF PRESCRIBED SEISMIC FORCES						
D.5 Ordinary reinforced concrete shear walls ^f	12.2.5.1	14.2	6	2.5	5	1.33
D.7 <i>Steel and concrete composite special concentrically braced frames</i>	14.3	6	2.5	5	1.33	
D.10 Steel and concrete composite ordinary shear walls	14.3	6	2.5	5	1.33	
D.11 <i>Special reinforced masonry shear walls</i>	14.4	5.5	3	5	1.30	
D.12 Intermediate reinforced masonry shear walls	14.4	4	3	3.5	1.30	
E. DUAL SYSTEMS WITH INTERMEDIATE MOMENT FRAMES CAPABLE OF RESISTING AT LEAST 25% OF PRESCRIBED SEISMIC FORCES						
E.1 <i>Steel special concentrically braced frames^a</i>	12.2.5.1	14.1	6	2.5	5	1.33
E.2 <i>Special reinforced concrete shear walls^{a,b}</i>	14.2	6.5	2.5	5	1.38	
E.3 Ordinary reinforced masonry shear walls	14.4	3	3	2.5	1.30	
E.4 Intermediate reinforced masonry shear walls	14.4	3.5	3	3	1.30	
E.5 <i>Steel and concrete composite special concentrically braced frames</i>	14.3	5.5	2.5	4.5	1.30	
E.6 Steel and concrete composite ordinary braced frames	14.3	3.5	2.5	3	1.30	
E.7 Steel and concrete composite ordinary shear walls	14.3	5	3	4.5	1.30	
E.8 Ordinary reinforced concrete shear walls ^f	14.2	5.5	2.5	4.5	1.30	
F. SHEAR WALL-FRAME INTERACTIVE SYSTEM WITH ORDINARY REINFORCED CONCRETE MOMENT FRAMES AND ORDINARY REINFORCED CONCRETE SHEAR WALLS						
	12.2.5.8 and 14.2	4.5	2.5	4	1.30	
G. CANTILEVERED COLUMN SYSTEMS DETAILED TO CONFORM TO THE REQUIREMENTS FOR:						
G.1 <i>Steel special cantilever column systems</i>	12.2.5.2	14.1	2.5	2.5	2.5	1.30
G.2 Steel ordinary cantilever column systems	14.1	1.25	1.25	1.25	1.30	
G.3 <i>Special reinforced concrete moment frames^m</i>	12.2.5.5 and 14.2	2.5	2.5	2.5	1.30	
G.4 Intermediate reinforced concrete moment frames	14.2	1.5	1.5	1.5	1.30	
G.5 Ordinary reinforced concrete moment frames	14.2	1	1.25	1	1.30	
G.6 Timber frames	14.5	1.5	1.5	1.5	1.30	
H. STEEL SYSTEMS NOT SPECIFICALLY DETAILED FOR SEISMIC RESISTANCE, EXCLUDING CANTILEVER COLUMN SYSTEMS						
	14.1	3	3	3	1.30	

R_μ as a function of SFRS within **Table 12.2-1**

R_μ for different SFRS
 $1.40 \leq R_\mu < 1.50$

$$F_p = 0.4S_{DS}I_pW_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right]; R_\mu = [1.1R/(I_e\Omega_0)]^{1/2} \geq 1.3 \quad (13.3-6)$$

Seismic Force-Resisting System	ASCE 7 Section Where Detailing Requirements Are Specified	Response Modification Coefficient, R^a	Overstrength Factor, Ω_0^b	Deflection Amplification Factor, C_d^c	R_μ
B. BUILDING FRAME SYSTEMS					
B.2 <i>Steel special concentrically braced frames</i>	14.1	6	2	5	<i>1.48</i>
B.23 Light-frame (wood) walls sheathed with wood structural panels rated for shear resistance	14.5	7	2.5	4.5	<i>1.43</i>
B.24 Light-frame (cold-formed steel) walls sheathed with wood structural panels rated for shear resistance or steel sheets	14.1	7	2.5	4.5	<i>1.43</i>
C. MOMENT-RESISTING FRAME SYSTEMS					
C.1 <i>Steel special moment frames</i>	14.1 and 12.2.5.5	8	3	5.5	<i>1.40</i>
C.5 <i>Special reinforced concrete moment frames^m</i>	12.2.5.5 and 14.2	8	3	5.5	<i>1.40</i>
C.8 <i>Steel and concrete composite special moment frames</i>	12.2.5.5 and 14.3	8	3	5.5	<i>1.40</i>
D. DUAL SYSTEMS WITH SPECIAL MOMENT FRAMES CAPABLE OF RESISTING AT LEAST 25% OF PRESCRIBED SEISMIC FORCES					
	12.2.5.1				
D.2 <i>Steel special concentrically braced frames</i>	14.1	7	2.5	5.5	<i>1.43</i>
D.3 <i>Special reinforced concrete shear walls^{g,h}</i>	14.2	7	2.5	5.5	<i>1.43</i>
D.8 Steel and concrete composite plate shear walls	14.3	7.5	2.5	6	<i>1.48</i>
D.9 <i>Steel and concrete composite special shear walls</i>	14.3	7	2.5	6	<i>1.43</i>

R_μ as a function of SFRS within **Table 12.2-1**

R_μ for different SFRS
 $1.50 \leq R_\mu$

$$F_p = 0.4S_{DS}I_pW_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right]; R_\mu = [1.1R/(I_e\Omega_0)]^{1/2} \geq 1.3 \quad (13.3-6)$$

Seismic Force-Resisting System		ASCE 7 Section Where Detailing Requirements Are Specified	Response Modification Coefficient, R^a	Overstrength Factor, Ω_0^b	Deflection Amplification Factor, C_d^c	R_μ
A. BEARING WALL SYSTEMS						
A.2	Reinforced concrete ductile coupled walls ^g	14.2	8	2.5	8	1.53
B. BUILDING FRAME SYSTEMS						
B.1	Steel eccentrically braced frames	14.1	8	2	4	1.71
B.5	Reinforced concrete ductile coupled walls ^g	14.2	8	2.5	8	1.53
B.11	Steel and concrete composite eccentrically braced frames	14.3	8	2.5	4	1.53
B.26	Steel buckling-restrained braced frames	14.1	8	2.5	5	1.53
B.27	Steel special plate shear walls	14.1	7	2	6	1.60
B.28	Steel and concrete coupled composite plate shear walls	14.3	8	2.5	5.5	1.53
D. DUAL SYSTEMS WITH SPECIAL MOMENT FRAMES CAPABLE OF RESISTING AT LEAST 25% OF PRESCRIBED SEISMIC FORCES		12.2.5.1				
D.1	Steel eccentrically braced frames	14.1	8	2.5	4	1.53
D.4	Reinforced concrete ductile coupled walls ^g	14.2	8	2.5	8	1.53
D.6	Steel and concrete composite eccentrically braced frames	14.3	8	2.5	4	1.53
D.13	Steel buckling-restrained braced frames	14.1	8	2.5	5	1.53
D.14	Steel special plate shear walls	14.1	8	2.5	6.5	1.53
D.15	Steel and concrete coupled composite plate shear walls	14.3	8	2.5	5.5	1.53

ASCE 7-16 vs 7-22 Nonstructural Component Table Comparisons

Partial Table 13.6-1 Mechanical and Electrical Components comparison 7-16 => 7-22 (changes are also within Architectural Components Table 13.5-1)

Table 13.6-1 Seismic Coefficients for Mechanical and Electrical Components

Mechanical and Electrical Components	a_p^a	R_p^b
Air-side HVAC, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical components constructed of sheet metal framing	2.5	6.0
Wet-side HVAC, boilers, furnaces, atmospheric tanks and bins, chillers, water heaters, heat exchangers, evaporators, air separators, manufacturing or process equipment, and other mechanical components constructed of high-deformability materials	1.0	2.5

ASCE 7-16

$$a_p / R_p \approx 0.41$$

Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

MECHANICAL AND ELECTRICAL COMPONENTS	C_{AR}		R_{PO}
	Supported at or below grade plane	Supported above grade plane by a structure	
Air-side HVACR, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical components constructed of sheet metal framing	1.4	1.4	2
Wet-side HVACR, boilers, furnaces, atmospheric tanks and bins, chillers, water heaters, heat exchangers, evaporators, air separators, manufacturing or process equipment, and other mechanical components constructed of high-deformability materials	1	1	1.5
Air coolers (fin fans), air-cooled heat exchangers, condensing units, dry coolers, remote radiators, and other mechanical components elevated on integral structural steel or sheet metal supports	1.8	2.2	1.5

ASCE 7-22

$$C_{AR} / R_{PO} \approx 0.67 \text{ to } 1.46$$

Where: The *addition of $C_{AR} \leq \text{grade} \ \& \ > \text{grade}$* is based on the component amplification at grade being typically < component amplification within a building

ASCE 7-22 Nonstructural Component Table 13.6-1 Additions

New additions to ASCE 7-22 Table 13.6-1 Mechanical and Electrical Components

A new separate section for *component supports (>24")* and *distributions supports* have been added to Table 13.6-1.



Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

MECHANICAL AND ELECTRICAL COMPONENTS	C_{AR}		R_{nw}
	Supported at or below grade plane	Supported above grade plane by a structure	
EQUIPMENT SUPPORT STRUCTURES AND PLATFORMS			
Support structures and platforms where $T_p/T_a < 0.2$, or $T_p \leq 0.06$ s, per Section 13.6.4.6	NA	1	1.5
Seismic force-resisting systems with $R > 3$	1.4	1.4	1.5
Seismic force-resisting systems with $R \leq 3$	1.8	2.2	1.5
Other systems	2.2	2.8	1.5
DISTRIBUTION SYSTEM SUPPORTS			
Tension-only and cable bracing	1	1	1.5
Cold-formed steel rigid bracing	1	1	1.5
Hot-rolled steel bracing	1	1	1.5
Other rigid bracing	1	1	1.5
Lateral resistance provided by rods in flexure	1.8	2.2	1.5
Vertical cantilever supports such as pipe tees and moment frames above and supported by a floor or roof	1.8	2.2	1.5



ASCE 7-22 Nonstructural Component Table 13.6-1 Support Structure / Platform Definitions

New additions to ASCE 7-22 Table 13.6-1 Mechanical and Electrical Components ~ cont'd

What constitutes Equipment Support Structures and Platforms?

Per the ASCE 7-22 *Commentary* §C13.6.4

Equipment supports are classified into *three (3)* groups (*distribution supports are not equipment supports*)

- ***Integral(1) Supports ≤ 24 " (NOT an Equipment Support)***

Supports which are **directly connected to both the component** and the attachment to the structure or foundation **up to 24 inches** in length (height); i.e., lugs, skirts, saddles, and short legs.

- ***Equipment Support Structures(2) and Platforms(3) > 24 "***

Assemblies of structural members that provide support for a piece of equipment or system, including moment frames, braced frames, skids, or legs **greater than 24 inches**.

The commentary also delineates equipment Supports from equipment Platforms, with Platforms supporting multiple components or systems. The differences are inconsequential as both equipment Supports and Platforms have the same C_{AR} lateral coefficients.

ASCE 7-22 Nonstructural Component Support Structures / Platforms

New additions to ASCE 7-22 Table 13.6-1 Mechanical and Electrical Components ~ cont'd

§C13.6.4: "...The 24 in. length limit *for legs...*"

≤ 24" NOT EQUIPMENT SUPPORT OR PLATFORM




Figure C13.6.4.1. Example of a nonstructural component with integral equipment supports.
Source: FEMA E-74 (2015).

~~Integral equipment supports (≤ 24" in length)~~




Figure C13.6.4.2. Example of an equipment support structure for a heavy light fixture.
Source: FEMA E-74 (2015).
Note: 1 in. = 25 mm.

Equipment *Support* (> 24" in length)




Figure C13.6.4.3. Example of an equipment support platform supporting two mechanical components.
Source: FEMA E-74 (2015).

Equipment *Platform* (> 24" in length)

ASCE 7-22 Nonstructural Component Table 13.6-1 Support/Platform Design Requirements

New additions to ASCE 7-22 Table 13.6-1 Mechanical and Electrical Components ~ cont'd

	C_{AR}		R_{PO}
	$\leq grd$	$> grd$	
*EQUIPMENT SUPPORT STRUCTURES AND PLATFORMS			
Support structures and platforms where $T_p/T_a < 0.2$, or $T_p \leq 0.06$ s, per Section 13.6.4.6	NA	1	1.5
Seismic force-resisting systems with $R > 3$ (from Table 12.2-1, 15.4-1)	1.4	1.4	1.5
Seismic force-resisting systems with $R \leq 3$ (from Table 12.2-1, 15.4-1)	1.8	2.2	1.5
Other systems	2.2	2.8	1.5

where:

→ T_p = Fundamental period of the component, **including the support/platform and attachments (per Section 13.3.3) (i.e., the component assembly).**

T_a = Approximate fundamental period of the building as determined in Section 12.8.2

13.3.1.3 Component Resonance Ductility Factor, C_{AR}

The *component resonance ductility factor* (C_{AR}) for mechanical and electrical equipment mounted on the equipment support structures or platforms **shall not be less than** the component resonance ductility factor **used** for ***the equipment support structure or platform itself***.

Translation:

If a component is attached to a support $> 24"$, the *component* C_{AR} , \geq *support* C_{AR} .

ASCE 7-22 Nonstructural Component Table 13.6-1 Support/Platform Design Requirements

Period Determination of Component and Component Assemblies

T_p = Fundamental period of the component, *including the support/platform and its attachment per Section 13.3.3* (i.e., *the component assembly*).

Component period, T_p is **not** a function, nor is related to C_{AR} (component resonance ductility factor - ability to achieve resonance).

§13.3.3 **Component Period** states in part... The fundamental period, T_p ... shall be determined by... $T_p = 2\pi\sqrt{\frac{W_p}{K_p g}}$
Further stating: ...**provided** the component, supports, and attachment can be reasonably represented analytically by a simple single-degree-of-freedom spring-and-mass system (active and energized systems typically cannot be modeled)

The §C13.3.3 (commentary) states ...*Determination of the fundamental period of an architectural, mechanical, or electrical component using analytical, or test methods is often difficult and, if not properly performed, may yield incorrect results.*

Further stating: ...A resonant frequency search procedure, **such as that given in the ICC-ES AC156**..., may be used to identify the dominant modes of vibration of a component.

Note: *Supports* used during Special Seismic Certification (SSC) of active or energized components are deemed to meet the lateral force requirements for equipment Supports/Platforms. The *attachments*, however, must still be designed according to Table 13.6-1.

ASCE 7-22 Nonstructural Component Support/Platform

EQUIPMENT SUPPORT STRUCTURES AND PLATFORMS ~ cont'd.

- ¹Support structures and platforms where ^{1a} $T_p/T_a < 0.2$, or ^{1b} $T_p \leq 0.06$ s, per Section 13.6.4.6
- ²Seismic force-resisting systems with $R > 3$ (must conform to Table 12.2-1, 15.4-1)
- ²Seismic force-resisting systems with $R \leq 3$ (must conform to Table 12.2-1, 15.4-1)
- ³Other systems (none of the above)

	C_{AR}		R_{PO}
	$\leq grd$	$> grd$	
¹	NA*	1	1.5
²	1.4	1.4	1.5
²	1.8	2.2	1.5
³	2.2	2.8	1.5

*must use one of the other 3 remaining supports conditions.

Clarification:

For Components on Equipment Supports or Platforms

¹

- ^{1a}Component is *within a building/nonbuilding structure*, and $T_p/T_a < 0.2$ (i.e., component assembly period < 20% building period) the component assembly $C_{AR}=1$, $R_p=1.5$, using a support/platform designed using a Chp 14 material standard.
- ^{1b}Component is *within a building/nonbuilding structure*, the component assembly is rigid ($T_p \leq 0.06$ s), $C_{AR}=1$, $R_p=1.5$, using a support/platform designed using a Chp 14 material standard.

²To date, equipment supports/platforms designed using an SFRS from Tables 12.2-1, and 15.4-1 are rarely used (typically project specific).

³Component is *flexible* ($T_p > 0.06$ s), regardless of the Equipment Support or Platform stiffness, *the entire component assembly is flexible and must use Other Systems* with $C_{AR}=2.2$ or 2.8, $R_p=1.5$, using a support/platform designed using a Chp 14 material standard.

ASCE 7-22 Nonstructural Component Support Structures / Platforms

Example of a *Flexible* Component on a *Rigid* Support

Support > 24"

Support is rigid, Mechanical component is flexible

Resulting *component assembly* $T_p > 0.06$ s.

Component assembly (component, support, and attachments), must be designed to *Other Systems* within Table 13.6-1 *Equipment Supports and Platforms*

May apply to *computer racks, suspended supported components*
i.e., mobile lighting fixtures, X-ray booms.



EQUIPMENT SUPPORT STRUCTURES AND PLATFORMS

Support structures and platforms where $T_p/T_a < 0.2$, or $T_p \leq 0.06$ s, per Section 13.6.4.6

Seismic force-resisting systems with $R > 3$

Seismic force-resisting systems with $R \leq 3$

Other systems

	C_{AR}	R_{PO}	Ω_0
NA	1	1.5	2
1.4	1.4	1.5	2
1.8	2.2	1.5	1.75
<i>2.2</i>	<i>2.8</i>	<i>1.5</i>	<i>1.5</i>

ASCE 7-22 Nonstructural Component Distribution System Support Design Requirements

New additions to ASCE 7-22 Table 13.6-1 Mechanical and Electrical Components


DISTRIBUTION SYSTEM SUPPORTS*	C_{AR}		R_{PO}
Tension-only and cable bracing	1	1	1.5
Cold-formed steel rigid bracing	1	1	1.5
Hot-rolled steel bracing	1	1	1.5
Other rigid bracing	1	1	1.5
¹ Lateral resistance provided by rods in flexure	1.8	2.2	1.5
¹ Vertical cantilever supports such as pipe tees and moment frames above and supported by a floor or roof	1.8	2.2	1.5
<i>¹Other than bracing supports</i>			

13.6.4.7 Distribution System Supports

Seismic loads for distribution system supports and trapeze assemblies shall be based on the *weight of the distribution system tributary to the supports*, including fittings and in-line components. See Sections 13.6.5, 13.6.6, and 13.6.7 for specific system requirements.

***Note:** The design of distribution system supports is now a separate design from distribution systems.

ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level



Facility S_{DS} percent change enforced within ASCE 7-22.

ASCE 7-22 §11.2 Definitions: USGS SEISMIC DESIGN GEODATABASE: The USGS Seismic Design Geodatabase is available at the ASCE 7 Hazard Tool

<https://asce7hazardtool.online/>

ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Mechanical and Electrical Components

Air-side HVACR, fans, air handlers, air conditioning units...

Motor control centers, panel boards, switch gear...



On Projects:

Do not simply compare the preapproval S_{DS} to the project S_{DS} !

Other variables, i.e., H_f and R_μ may reduce project demands and use of Hybrid RRS spectrums for OSPs may allow for project use of preapprovals with higher S_{DS} levels.

ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Mechanical and Electrical Components

Other mechanical or electrical components, i.e., **Medical Imaging Equipment**



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Vibration-Isolated Components and Systems

Spring-isolated components and systems and vibration-isolated floors closely restrained using built-in or separate elastomeric snubbing devices or resilient perimeter stops

Internally isolated components and systems



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Vibration-Isolated Components and Systems

Components and systems isolated using **neoprene** elements and neoprene isolated floors with built-in or separate **elastomeric snubbing devices** or resilient perimeter stops

Suspended vibration-isolated equipment, including in-line duct devices and **suspended internally** isolated components



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Distribution Systems (copper pipe)

Piping **in accordance** with ASME B31 (2001, 2002, 2008, 2010), including in-line components with joints made **by welding or brazing**



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Distribution Systems (scheduled pipe)

Piping **in accordance** with ASME B31, including in-line components, constructed of high-limited-deformability materials, with joints made by **threading, bonding, compression couplings, or grooved couplings**

Piping and tubing **not in accordance** with ASME B31, including in-line components, constructed of high-deformability materials, with joints made by **welding or brazing**

Duct systems, including in-line components, constructed of high-deformability materials, with joints made **by welding or brazing**



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*




Table 13.6-1. Seismic Coefficients for Mechanical and Electrical Components.

Distribution System Supports (New)

- Tension-only and cable **bracing**
- Cold-formed steel rigid **bracing**
- Hot-rolled steel **bracing**
- Other rigid **bracing**



Distribution Systems

- Electrical conduit, cable trays, and raceways



ASCE 7-16 vs ASCE 7-22 Nonstructural Component Design Force Level *Comparisons*





Table 13.5-1. Coefficients for Architectural Components

Interior nonstructural walls and **partitions**

Light frame ≤ 9 ft (2.74 m) in height

Light frame > 9 ft (2.74 m) in height



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OPM/OSP/OPD

Affected OSHPD Preapproval Programs:

OPD-0001 Standard Partition Wall Details*

OPD-0002 Standard Suspended Ceiling Details*

OPD-0003 Standard Gypsum Board Ceiling Details*

OPM – OSHPD Preapproval of Manufacturer's Certification

OSP – OSHPD Special Seismic Certification Preapproval

*Efforts to update the inhouse OPD to the current Code are currently underway.

Continued use of the all existing preapprovals, if not expired, are valid, if project demands \leq preapproval capacities.

Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OPM/OSP/OPD

Existing OPM Preapprovals valid for use on any project, regardless of CBC version (including 2025 CBC).

Renewal and New OPM Preapprovals to the 2025 CBC (ASCE 7-22) requires updated calculations and drawing revisions reflecting the current Code. OPM will have a new updated Application for the 2025 CBC via eSP.

Existing OSP Preapprovals which have not expired, are valid for use on any project, regardless of CBC version (including 2025 CBC). Existing shake table tests are valid on any project (including 2025 CBC).

Renewal and New OSP Preapprovals to the 2025 CBC (ASCE 7-22) requires a new updated Application for the 2025 CBC via eSP.

Existing OPD Preapprovals valid for use on any project, regardless of CBC version (including 2025 CBC).

Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OPM/OSP ~ cont'd

Preapproval Design Professionals of Record


Although readily apparent, **two Design Professionals of Record (DPOR)** are involved in preapprovals:

1. *Preapproval DPOR* who submits a new or renewal preapproval to OSHPD
2. *Project DPOR* who submits the preapproval for project use



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Existing Preapproval Programs; OPM

OPM



Use of **Existing** OPM for 2025 CBC

Project DPOR Submittal Responsibilities:

Calculate the *OPM design force capacities* for both horizontal and vertical, using **ASCE 7-16** lateral coefficients

$$F_p = \frac{0.4a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2\frac{z}{h}\right) \quad (13.3-1)$$

13.3.1.2 Vertical Force: $F_v = 0.2S_{DS} W_p$

Calculate the *2025 CBC project demands*, using the **ASCE 7-22** lateral force eqn.

$F_{p (Project) demands} \leq F_{p (Preapproval) capacities}$

OPM design force coefficients for both the Preapproval and the Project must be listed on:

1. Project calculations.
2. May be included on the construction drawings (CD), to possibly reduce an Amended Construction Document (ACD) to a Non-Material Alteration (NMA) – saving time and costs.



Use of Existing ASCE 7-16 OPM for 2025 CBC

Use of Existing OPM: Example

PREAPPROVAL OF MANUFACTURER'S CERTIFICATION

THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE

MANUFACTURER: _____ Sheet: 1 of 6

EQUIPMENT NAME: _____ Date: _____

GENERAL NOTES


- THIS HCAI PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2022 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2022 CBC.
- THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
- THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE WHERE S_{ds} IS NOT GREATER THAN 2.30. SEE DETAIL FOR APPLICABILITY.
- FORCES PER ASCE 7-16 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3, WHERE: $S_{ds} = 2.30$, $a_p = 1.0$, $I_p = 1.5$, $R_p = 1.5$, $z/h = 0$. AT CONCRETE SLAB & $z/h < 1$ AT CONCRETE SLAB ON METAL DECK. SEE FOLLOWING SHEETS FOR Ω .
- THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
- ALL DESIGN FORCES SHOWN ON THE DRAWINGS ARE FACTORED LOADS THAT SHALL BE USED FOR STRENGTH DESIGN.
- CONCRETE SLAB ON METAL DECK DETAIL VALID FOR DEMANDS SHOWN AT ANY ELEVATION IN THE BUILDING. (i.e. $z/h < 1$)
- CONCRETE SLAB DETAIL

9. RESPONSIBILITIES

- PROVIDE SUPPORT
- VERIFY THAT THE MATERIAL AND GALLERIES ARE AS SHOWN IN THE PREAPPROVAL DOCUMENTS.

Using the listed coefficients, calculate OPM component design force, using ASCE 7-16 F_p equations.

Compare to 2025 project demands



Renewal Update or New OPM to 2025 CBC

The OPM component design force coefficient, C_p must be determined.

$$F_p/W_p = C_{Pm}$$

where:

C_{Pm} = Component design force coefficient

W_p = Component operating weight

$$F_p/W_p = C_{Pm} = 0.4S_{DS}I_p W_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right]$$

$$C_{Pm} = 0.4S_{DS}I_p \left[\frac{H_f}{R_\mu} \right] \left[\frac{C_{AR}}{R_{po}} \right] \quad \checkmark$$



Renewal Update or New OPM to 2025 CBC

Preapproval DPOR Submittal Responsibilities:

Updated ASCE 7-22 drawings, depicting:

- a. C_{Pm} for both F_p/W_p and F_v/W_p , S_{DS} , I_p , C_{AR} , R_{PO} , Ω_0 , H_f , R_μ , updated or added anchorage forces (T_U & V_U) specifying Ω_0 , for each different component configuration, for ease of use by the *Project DPOR*.
- b. As a minimum, H_f/R_μ must be listed for above grade (2.69) and/or at or below grade (1).
 - Specific intermediate building elevations and SFRS only, *are not allowed*, as specific conditions may be overlooked during design / installation or future equipment relocation.
- c. Revise KB-TZ anchors to KB-TZ2 (if applicable)
- d. Update anchorage capacities to latest ICC-ESR version
- e. Update all listed reference Standards
- f. Manufacturer's cut sheets depicting model numbers, configurations, dimensions, wts, etc. used within the OPM.
 - Catalogs may be provided, but only for units included within the preapproval, depicting the above cut sheet requirements. Do not submit entire manufacturer's catalogs for review.
- g. **Additional top-sided only post-installed anchor configuration & drawings** – see next slide

Renewal Update or New OPM to 2025 CBC

Preapproval DPOR Submittal Responsibilities: ~ cont'd


Additional requirements to the OPM Preapprovals:

If applicable and within reason, add conc/mtl deck component anchorage, using top-sided only post-installed anchor connections, as opposed to through-bolts, which may be achieved by:


1. Reducing the OPM design force (F_p), albeit within reason, i.e.; an $S_{DS} = 0.25$ serves no purpose.
2. Providing additional supports and attachments, may redistribute the component attachment forces.
3. Using larger post installed anchors.
4. Changing the mounting configuration, if possible.
5. If omitted, a written valid basis must be provided.

Intended to:

1. **Reduce project change orders** observed with through-bolts.
2. **Reduce labor costs** associated with through-bolts.



Top Sided
Post-Installed Anchor




Through-bolt
Post-Installed Anchor

Renewal Update or New OPM to 2025 CBC

Preapproval DPOR Submittal Responsibilities: ~ cont'd

Although not required, may be beneficial **listing both the ASCE 7-16 AND the 7-22 versions** within the same preapproval, for use with past and current codes. Within the preapproval drawings, **one version would be attached as an *Appendix***, referenced within the Table of Contents.



Project DPOR Submittal Responsibilities

Calculate the **2025 CBC project demands**, using the **ASCE 7-22** lateral force eqn.

$$F_{p (Project)} \text{ demands} \leq F_{p (Preapproval)} \text{ capacities}$$

OPM design force coefficients for both the Preapproval and the Project must be listed on:

1. Project calculations.
2. May be included on the construction drawings (CD), to possibly reduce an Amended Construction Document (ACD) to a Non-Material Alteration (NMA) – saving time and costs.

Renewal Update or New OPM to 2025 CBC: Example

Renewal Update or New OPM: Example

PREAPPROVAL OF MANUFACTURER'S CERTIFICATION

THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE

MANUFACTURER:	Sheet: <u>1 of 6</u>
EQUIPMENT NAME:	Date:


GENERAL NOTES

- THIS HCAI PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2022 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2022 CBC.
- THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
- THIS PREAPPROVAL CONFORMS TO THE 2022 CALIFORNIA BUILDING CODE WHERE S_{DS} IS NOT GREATER THAN 2.30. SEE DETAIL FOR APPLICABILITY.
- FORCES PER ASCE 7-16 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3, WHERE $S_{DS} = 2.30$, $a_p = 1.0$, $I_p = 1.5$, $R_p = 1.5$, $z/h = 0$ AT CONCRETE SLAB & $z/h < 1$ AT CONCRETE SLAB ON METAL DECK. SEE FOLLOWING SHEETS FOR Ω .

THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.


Update OPM, with the required coefficients, i.e., C_{pm} for both F_p/W_p and F_v/W_p , S_{DS} , I_p , C_{AR} , R_{PO} , Ω_0 , H_f , R_μ and ASCE 7-22, 2025 CBC code references.

- PROVIDE SUPPORTING STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN ADDITION TO ALL OTHER LOADS.
- VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2022 CBC AND WITH THE DETAILS, MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OSP

OSP



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OSP ~ cont'd

OSP Preapproval

The OSP *tested component design force coefficient*, C_{Ps} , is defined using a simple method.

$$F_p = \text{RRS accelerations } (A_{FLX-H}, A_{RIG-H}, A_{FLX-V}, A_{RIG-V}) * W_p$$

Where: *RRS accelerations* = C_{Ps} (*tested component design force coefficient*)

The certified RRS values are listed on the UUT sheets.



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OSP ~ cont'd

ASCE 7-22 Proposed Changes to ICC-ES AC156 Required Response Spectra (RRS)

The equation parameters $[C_{AR}/R_{po}]$ represent the dynamic characteristics and capacity of the component and *do not affect the dynamic test demand motion*. Thus, $[C_{AR}/R_{po}] = 1.0$ for all spectra. I_p is a measure of the component's functionality after the test $\therefore I_p = 1$.

For the *normalized response spectra accelerations* within **ICC-ES AC156**:

$0.4S_{DS}$ (40% of peak spectral design response acceleration) is an accepted approximation of the peak ground acceleration at zero period, $T = 0$ (rigid region)

where: S_{DS} = the peak spectral design response acceleration at 0.2s period ($T = 0.2s$) (5Hz flexible region)

Resulting in:

$$2.5(0.4 S_{DS}) = S_{DS} \Rightarrow 2.5(\text{Peak Ground}) \text{ equates to Peak Response}$$




Figure 11.4-1. Two-period design response spectrum.

ICC-ES AC156 RRS Eqns for ASCE 7-22

Horizontal Response:

$$A_{FLX-H} = (2.5) 0.4 S_{DS} (H_f/R_\mu) \quad A_{RIG-H} = 0.4 S_{DS} (H_f/R_\mu) \\ = S_{DS} (H_f/R_\mu) : S_{DS} (1.6)_{cap}$$

Vertical Response: Per the 1991 UBC = $(2/3)$ horizontal with $z/h = 0$, $H_f/R_\mu = 1$



$$A_{FLX-V} = (2/3) S_{DS} (H_f/R_\mu) \quad A_{RIG-V} = (2/3) 0.4 S_{DS} (H_f/R_\mu) \\ = (2/3) S_{DS} \quad = 0.27 S_{DS}$$

Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OSP ~ cont'd

ICC-ES AC156 Required Response Spectrums (RRS)



Using the *maximum ASCE Code limits* of the RRS, only results in a slight reduction for $A_{RIG-H} = 2.15 > \text{grade}$ (2.40 for ASCE 7-16), with all other spectral accelerations remaining the same, as in ASCE 7-16.

The *RRS accelerations* are the OSP tested component design force coefficients, C_{Ps} ✓



Adaptation of the ASCE 7-22 Nonstructural Component Changes to the Preapproval Programs; OSP ~ cont'd

5% Damped Spectral Response / 2-Point Spectra relative to ICC-ES AC156 Shake Table Test (> Grade)
 Response spectrum regions, as related to shake table tested regions.



Use of Existing OSP for 2025 CBC


Use of Existing OSP: Example

Project DPOR Responsibilities:

RRS accelerations are listed, for all tested components, on the UUT Sheets. Interpolated values must use the most conservative value.

The OSP *component tested capacities*:

$$F_{ph (Tested)} = \text{RRS Accelerations } (A_{FLX-H} \ \& \ A_{RIG-H}) * W_p$$

$$F_{pv (Tested)} = \text{RRS Accelerations } (A_{FLX-V} \ \& \ A_{RIG-V}) * W_p$$


By substituting the project variables S_{DS} , H_f , and R_μ into the **ICC-ES AC156 RRS eqns.**, the *project component demands*:

$$F_{ph (Project)} = \text{Calculated accelerations } (A_{FLX-H} \ \& \ A_{RIG-H}) * W_p$$

$$F_{pv (Project)} = \text{Calculated accelerations } (A_{FLX-V} \ \& \ A_{RIG-V}) * W_p$$

$$F_p (Project) \text{ demands} \leq F_p (Tested) \text{ capacities}$$

UNIT UNDER TEST (UUT) SUMMARY SHEET								
Manufacturer: Model Line: Model Number: Serial Number:						UUT 1		
<i>RRS Accelerations</i>								
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)				
	Depth	Width	Tested Height	Front-Back	Side-Side	Vertical		
1,411	36.7	94.5	31.0	4.7	14.0	6.7		
UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	S_{DS}	z/h	I_p	A_{FLX-H}	A_{RIG-H}	A_{FLX-V}	A_{RIG-V}
	ICC-ES AC156	2.0	1.0	1.5	3.20	2.40	1.67	0.67
		2.5	0.0					

ICC-ES AC156 RRS Eqns

Horizontal Response:

$$A_{FLX-H} = (2.5) 0.4 S_{DS} (H_f/R_\mu) \quad A_{RIG-H} = 0.4 S_{DS} (H_f/R_\mu)$$

$$= S_{DS} (H_f/R_\mu)$$

Vertical Response: $(2/3)$ horizontal with $z/h = 0, H_f/R_\mu = 1$

$$A_{FLX-V} = (2/3) S_{DS} (H_f/R_\mu) \quad A_{RIG-V} = (2/3) 0.4 S_{DS} (H_f/R_\mu)$$

$$= (2/3) S_{DS} \quad = 0.27 S_{DS}$$

Use of Existing OSP for 2025 CBC

Use of Existing OSP: Example ~ cont'd

Note:

On Existing OSP (designed to ASCE 7-16), F_p/W_p on the 3rd Application page:

✗ $F_p/W_p \neq$ OSP C_{Ps} (RRS accelerations (A_{FLX-H} , A_{RIG-H} , A_{FLX-V} , A_{RIG-V}))

The $F_p/W_p = C_{Pm}$ for OPMs

The analytical C_{Pm} that may be used for support and attachments

where:

$$F_p/W_p = C_{Pm}$$

OPMs... the component design force coefficient, $C_{Pm} = \frac{0.4a_p S_{DS}}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2\frac{z}{h}\right)$; ASCE (7-16) Analytical

2025 CBC OSP Applications will be modified to remove any possible confusion.

Seismic Parameters	
Design Basis of Equipment or Components (F_p/W_p) =	(3.60 @ SDS = 2.0, z/h = 1); (1.50 @ SDS = 2.50, z/h = 0)
SDS (Design spectral response acceleration at short period, g) =	(2.00 @ z/h=1); (2.50 @ z/h=0)
a_p (Amplification factor) =	2.5
R_p (Response modification factor) =	2.5
Ω_0 (System overstrength factor) =	2.0

Use of **Renewal Update** or **New OSP** for 2025 CBC

Use of Renewal or New OSP: Example

Project DPOR Responsibilities:

RRS accelerations are listed, for all tested components, on the UUT Sheets and will be listed on the New OSP Applications and/or within the Certified Product tables. Interpolated values must use the most conservative values.

The OSP *component tested capacities*:

$$F_{ph (Tested)} = \text{RRS Accelerations } (A_{FLX-H} \ \& \ A_{RIG-H}) * W_p$$

$$F_{pv (Tested)} = \text{RRS Accelerations } (A_{FLX-V} \ \& \ A_{RIG-V}) * W_p$$



By substituting the project variables S_{DS} , H_f , and R_μ into the **ICC-ES AC156 RRS eqns.**, the **project component demands**:

$$F_{ph (Project)} = \text{Calculated accelerations } (A_{FLX-H} \ \& \ A_{RIG-H}) * W_p$$

$$F_{pv (Project)} = \text{Calculated accelerations } (A_{FLX-V} \ \& \ A_{RIG-V}) * W_p$$

$F_p (Project) \text{ demands} \leq F_p (Tested) \text{ capacities}$

UNIT UNDER TEST (UUT) SUMMARY SHEET									
Manufacturer: Model Line: Model Number: Serial Number:						UUT 1			
<i>RRS Accelerations</i>									
UUT Properties									
Weight (lbs.)	Dimension (in)			Lowest Natural Frequency (Hz)					
	Depth	Width	Tested Height	Front-Back	Side-Side	Vertical			
1,411	36.7	94.5	31.0	4.7	14.0	6.7			
UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S_{DS}	R_μ	H_f	I_p	A_{FLX-H}	A_{RIG-H}	A_{FLX-V}	A_{RIG-V}
	ICC-ES AC156	2.0			1.5	3.20		1.67	0.67
		2.5							

New variables (R_μ , H_f) and may have revised A_{RIG-H}

ICC-ES AC156 RRS Eqns

Horizontal Response:
 $A_{FLX-H} = (2.5) 0.4 S_{DS} (H_f / R_\mu) = S_{DS} (H_f / R_\mu)$ $A_{RIG-H} = 0.4 S_{DS} (H_f / R_\mu)$

Vertical Response: $(2/3)$ horizontal with $\varepsilon/h = 0$, $H_f / R_\mu = 1$
 $A_{FLX-V} = (2/3) S_{DS} (H_f / R_\mu) = (2/3) S_{DS}$ $A_{RIG-V} = (2/3) 0.4 S_{DS} (H_f / R_\mu) = 0.27 S_{DS}$

Renewal Update or New OSP to 2025 CBC

Preapproval DPOR Responsibilities:

1. Updated Application with minimum seismic parameters as listed below:
 - C_{Ps} for both horizontal and vertical forces (i.e., A_{FLX-H} , A_{RIG-H} , A_{FLX-V} , A_{RIG-V}), and corresponding S_{DS} , H_f , R_{μ} , and I_p .
2. Manufacturer's cut sheets depicting model numbers, configurations, dimensions, wts, etc. used within the OSP.
 - Catalogs may be provided, but only for units included within the preapproval, depicting only the above cut sheet requirements. Do not submit entire manufacturer's catalogs for review.
3. Other submittal requirements as listed within PIN 55.

Seismic Parameters	
Design Basis of Equipment or Components (F_p/W_p) =	1.44 for fixed, 4.5 for isolated
S_{DS} (Design spectral response acceleration) =	2.00
a_p (Amplification factor) =	
R_p (Response modification factor) =	
Ω_0 (System natural frequency ratio) =	
I_p (Importance factor) =	
z/h (Height ratio) =	
Natural frequency (f_n) =	See Attachment
Overall dimensions and weight =	See Attachment

**OSP APPLICATION
REVISED FOR
2025 CBC**

Comparing Component SSC Capacity to Project Site-Specific Demand

If not readily apparent that component capacity meets project specific demand, a more detailed approach may be used.

Method: For a specific component*, per direction (horizontal and vertical)

- 1) Using an OSP, UUT sheets, or Test Report, select:
 - a. The component's resonance natural frequencies (x,y,z: typically, front-back, side-side, vertical) and corresponding RRS accelerations (A_{FLX-H} , A_{RIG-H} , A_{FLX-V} , A_{RIG-V})
- 2) Using the site-specific 2-point design response spectral acceleration plot, select:
 - a. S_a Resonance Period (design response acceleration) corresponding to the period of the above component *lowest* NF, per direction.

Example:

For the horizontal direction, the component lowest NF between the x and y directions is either within the flexible or rigid region.

- 1) If within **flexible** region (1.30Hz - 8.33Hz), A_{FLX-H} (value is constant)
 - a. Calculate $F_{PH-TESTED}$; $F_{PH-TESTED} = A_{FLX-H} (W_p)$
 - b. Calculate $F_{PH-PROJECT} = S_a \text{ Resonance Period} (H_f/R_\mu) W_p$: $F_{PH-PROJECT} \leq F_{PH-TESTED}$
- 2) If within **rigid** region (8.34Hz - 33.33Hz), $A_{RIG-H \text{ Resonance}}$ (value varies)
 - a. Calculate $F_{PH-TESTED}$; $F_{PH-TESTED} = A_{RIG-H \text{ Resonance}}$ (corresponding to component NF) (W_p)
 - b. Calculate $F_{PH-PROJECT} = S_a \text{ Resonance Period} (H_f/R_\mu) W_p$: $F_{PH-PROJECT} \leq F_{PH-TESTED}$

Vertical direction must be checked similar to above horizontal direction, using equations for A_{FLX-V} , A_{RIG-V}

*may only be valid for the tested component, not interpolated or extrapolated components, as NF may vary.

Questions/Thoughts?



Timothy.Piland@hcai.ca.gov