

- RTU - 1
- RTU - 2
- RTU - 3
- RTU - 4
- RTU - 5
- RTU - 6
- RTU - 7
- RTU - 8
- RTU - 9
- RTU - 10
- RTU - 11
- RTU - 12
- RTU - 13
- RTU - 14



Harbor Post Acute Care Center
Facility No. 22611
 12/7/2023

Location of fire extinguisher
 EVACUATION ROUTE

BLD-04791 Main Building - Bldg 01

NUMBER OF OUTLET AND LIGHTS CONNECTED TO EMERGENCY POWER

1. EVERY 4TH LIGHT IN THE HALLWAY
2. 1 LIGHT FIXTURE INSIDE THE KITCHEN
3. 2 LIGHT FIXTURE INSIDE CENTRAL SUPPLY
4. 2 LIGHT FIXTURE IN THE LOBBY
5. 1 STATION 1
6. LIGHT INSIDE MED. ROOM STATION 1 & 2
7. 1 LIGHT INSIDE UTILITY ROOM
8. 11 OUTLETS ALONG THE HALLWAYS
9. 1 OUTLET INSIDE ROOM 122
10. 1 OUTLET INSIDE ROOM 101