

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01278	Original Hospital	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		27.63	N/A	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01279	Stephens Wing	OSHDP 1-In Service	2		0.98	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01280	West Wing	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01281	South Wing	OSHDP 1-In Service	3s			2	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01282	Radiology Addition	OSHDP 1-In Service	4			2	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-01283	Medical Gas Storage	OSHDP 1-In Service	3			2	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-02630	Compactor Shed	OSHDP 1-In Service	4			2	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-03120	Emergency Room Relocation	OSHDP 1-In Service	3s			2	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-05597	LOX Tank	OSHDP 1-Equipment Yard	N/A			4	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-07777	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-07778	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-07779	FT-01 Fuel Tank	OSHDP 1-Proposed	N/A			5s	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-07780	Booster Pump Canopy	OSHDP 1-Proposed	5s			5s	
01 - Alameda	11210	Alameda Hospital	Alameda	BLD-07781	Ionization Unit/UV Lamp Canopy	OSHDP 1-Proposed	5s			5s	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00695	Ehman Building	OSHDP 1-In Service	2		1.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00696	North Wing	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00698	East Wing	OSHDP 1-In Service	2		0.71	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00699	Original West Wing	OSHPD 1-In Service	2		1.15	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00700	West Service Wing - Building 1	OSHPD 1-In Service	2		1.03	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00701	Physio-Therapy Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00702	Original Emergency Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00703	Special Procedures Addition	OSHPD 1-In Service	3			2	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00704	Emergency Department Expansion	OSHPD 1-In Service	5s			4	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00705	Cogeneration Building	OSHPD 1-In Service	4			2	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00706	Emergency Generator Building	OSHPD 1-In Service	4			2	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-00707	Transformer Building	OSHPD 1-In Service	2		0.37	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03431	South Wing - Phase 2	OSHPD 1-In Service	3			2	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03433	West Service Wing - Building 2 - Structurally connected to BLD-00699	OSHPD 1-Not an Independent Building	N/A		21.08	N/A	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-03434	Orig Emergency Wing - East Wing - Structurally connected to BLD-00702	OSHPD 1-Not an Independent Building	N/A			N/A	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-05300	Patient Care Pavilion	OSHPD 1-In Service	5			4	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-06010	New LOX Tank	OSHPD 1-Equipment Yard	N/A			4	
01 - Alameda	11322	Alta Bates Summit Medical Center	Oakland	BLD-06060	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A			4	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-00708	Main Hospital Building	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-03443	Main Entrance Canopy	OSHPD 1-In Service	3			2	
01 - Alameda	11338	Alta Bates Summit Medical Center - Summit Campus	Oakland	BLD-03444	Bridge at Link	OSHPD 1-In Service	3			2	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01285	Admin.	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01286	Laundry/Hall of Health	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01287	Boiler	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01288	1968 Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01289	1975 Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01290	1985 Building	OSHPD 1-In Service	4			2	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01291	Electric Service Building	OSHPD 1-In Service	4			2	
01 - Alameda	11214	Alta Bates Summit Medical Center-Alta Bates Campus	Berkeley	BLD-01292	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A			4	
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05340	Replacement Hospital	OSHPD 1-In Service	5			4	
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05341	Chiller Building	OSHPD 1-In Service	5			4	
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05342	Main Entrance Canopy	OSHPD 1-In Service	5			4	
01 - Alameda	18180	Eden Medical Center	Castro Valley	BLD-05343	Emergency Entrance Canopy	OSHPD 1-In Service	5			4	
01 - Alameda	11268	Fairmont Hospital	San Leandro	BLD-01311	Building B	OSHPD 2-Skilled Nursing Only	N/A			N/A	
01 - Alameda	11268	Fairmont Hospital	San Leandro	BLD-01312	Building H	OSHPD 1R-Delicensed Clinic under OSHPD	N/A		1.22	N/A	
01 - Alameda	11288	Highland Hospital	Oakland	BLD-01315	Critical Care Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11288	Highland Hospital	Oakland	BLD-02957	New Acute Care Building	OSHDP 1-In Service	5			4	
01 - Alameda	11288	Highland Hospital	Oakland	BLD-06256	Critical Care Parking Structure	OSHDP 1-In Service	5			4	
01 - Alameda	11288	Highland Hospital	Oakland	BLD-06880	Oxygen Yard	OSHDP 1-Equipment Yard	N/A			4	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02489	Hospital Patient Wing North	OSHDP 1-In Service	3			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02490	Hospital Patient Wing South	OSHDP 1-In Service	3			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02491	Hospital North	OSHDP 1-In Service	3			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02492	Hospital South	OSHDP 1-In Service	3			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02493	Central Plant	OSHDP 1-In Service	5			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-02494	General Services Building	OSHDP 1-In Service	3			3	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-07247	Entry Canopy	OSHDP 1-In Service	4s			2s	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-07613	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-07614	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-07615	FT-02 Fuel Tank	OSHDP 1-Under Construction	N/A			5s	
01 - Alameda	14509	Kaiser Foundation Hospital - Fremont	Fremont	BLD-07616	FT-01 Fuel Tank	OSHDP 1-Tanks	N/A			5	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-02986	Hospital	OSHDP 1-In Service	5			4	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-02987	Central Plant	OSHDP 1-In Service	5			4	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-05716	Loading Dock and Plaza	OSHDP 1-In Service	5			4	
01 - Alameda	18206	Kaiser Foundation Hospital - Oakland/Richmond	Oakland	BLD-07422	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	San Leandro	BLD-03481	Templated Hospital Project	OSHDP 1-In Service	5			4	
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	San Leandro	BLD-03482	Central Utility Plant	OSHDP 1-In Service	5			4	
01 - Alameda	18186	Kaiser Foundation Hospital - San Leandro	San Leandro	BLD-07441	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00692	Original Building	OSHPD 1-In Service	2	23.62	1.04	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00693	Outpatient Diag. & Treat. Center	OSHPD 1-In Service	5			3	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-00694	Boiler Enclosure	OSHPD 1-In Service	4			3	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-03083	Surgery Addition - Structurally connected to BLD-00692	OSHPD 1-Not an Independent Building	N/A			N/A	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-05427	Emergency Generator	OSHPD 1-Equipment Yard	N/A			4	
01 - Alameda	11321	Kindred Hospital - San Francisco Bay Area	San Leandro	BLD-05428	Liquid Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A			4	
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-01300	Main/Original Building	OSHPD 1-In Service	3			2	
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-02709	Emergency Addition	OSHPD 1-In Service	5			2	
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-07123	Aboveground Fuel Storage Tank	OSHPD 1-Under Construction	N/A			4s	
01 - Alameda	11256	San Leandro Hospital	San Leandro	BLD-07270	SPD Addition	OSHPD 1-Proposed	5s			4s	
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00709	Main Hospital Building	OSHPD 1-In Service	2	0.61		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00710	Engineering/Boiler Building - Structurally connected to BLD-00709	OSHPD 1-Not an Independent Building	N/A			N/A	
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00711	Emergency and Critical Care Building	OSHPD 1-In Service	3			2	
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-00712	Chiller/Generator Building	OSHPD 1-In Service	5			2	
01 - Alameda	11344	St Rose Hospital	Hayward	BLD-03084	Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A			N/A	
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-00005	Hospital Building	OSHPD 1-In Service	2	0.63		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-00006	Boiler Building	OSHPD 1-In Service	2		0.63	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-00007	Emergency Generator Building	OSHPD 1-In Service	4			2	
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-00008	Hospital Building-1967 Addition Structurally connected to BLD-00005	OSHPD 1-Not an Independent Building	N/A			N/A	
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-00009	Hospital Building - 1977 Addition - Structurally connected to BLD-00005	OSHPD 1-Not an Independent Building	N/A			N/A	
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-02992	Lobby Addition to Hospital Building	OSHPD 1-In Service	3			2	
01 - Alameda	11363	Stanford Health Care Tri-Valley	Livermore	BLD-03085	Building D: Service Building	OSHPD 1-In Service	4			2	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02532	Hospital Ambulatory Care & Inc. II	OSHPD 1-In Service	3			2	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02533	Central Plant	OSHPD 1-In Service	5			2	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02534	Valleycare (New) Addition	OSHPD 1-In Service	5			4	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02699	Arcade - Phase I - Portion 1	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02700	Arcade - Phase II - Portion 1	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02701	Porte Cochere	OSHPD 1-In Service	5			4	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02901	Arcade - Phase I - Portion 2	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02902	Arcade - Phase I - Portion 3	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-02903	Arcade - Phase II - Portion 2	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-06430	Ambulance Drop Off Canopy	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-06566	Emergency Generator Set	OSHPD 1-Under Construction	N/A			4s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07315	East Wing Hospital Addition	OSHPD 1-Proposed	5s			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07316	Canopy	OSHPD 1-Under Construction	5s			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07317	NPC-5 Potable Water Storage Tank Enclosure (WT-01)	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07539	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07540	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07541	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07542	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	16632	Stanford Health Care Tri-Valley	Pleasanton	BLD-07543	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01293	Cardiac Cath Lab - MPOE	OSHPD 1-In Service	5			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01294	Patient Tower	OSHPD 1-In Service	3			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01295	West Site Plant	OSHPD 1-In Service	3			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01296	Cafeteria Addition	OSHPD 1-In Service	3			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01297	Diagnostic & Treatment Building	OSHPD 1-In Service	3			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01298	B/C Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		3.28	N/A	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-01299	A/B Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		15.07	N/A	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-03121	Loading Dock	OSHPD 1-In Service	3			2	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05214	Western Expansion Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05822	Outpatient Clinic	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05837	Chiller Plant	OSHPD 1-In Service	5			4	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-05856	Outpatient Center 2	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-06714	Walkway	Adjacent Building - Local Jurisdiction- Outpatient Only	N/A			N/A	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07163	Medical Gas Building	OSHPD 1-In Service	5			4	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07178	Above Grade Fuel Tank (FT-01)	OSHPD 1-Tanks	N/A			5	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07184	New Hospital Building	OSHPD 1-Proposed	5s			5s	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07188	Site Support Building	OSHPD 1-Under Construction	5s			5s	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07635	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07636	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	11242	UCSF Benioff Children's Hospital Oakland	Oakland	BLD-07637	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00713	Original Hospital	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00714	South Wing Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00715	Emergency Wing Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00716	Areas No. 1 and 2 Addition	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00717	Area No. 3 Addition	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00718	Area No. 4 Addition	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00719	Area No. 5 Addition	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
01 - Alameda	11366	Washington Hospital	Fremont	BLD-00720	Entrance Canopy	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03561	Center for Joint Replacement	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03562	Central Plant	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03563	Center for Joint Replacement - Bridge	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03564	Interim Loading Dock	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-03565	Underground Service Passage	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05627	Main Building	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05628	Canopy #1	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05629	Canopy #2	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05630	Canopy #3	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05632	Pedestrian Walkway #1	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-05633	Pedestrian Walkway #2	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-06563	Pedestrian Bridge	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-06840	Emergency Room Addition	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-07118	Center for Joint Replacement - Hallway	OSHDP 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-07139	Pedestrian Walkway #2A	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
01 - Alameda	11366	Washington Hospital	Fremont	BLD-07140	Pedestrian Walkway #2B	OSHPD 1-In Service	5			4	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-07394	Expansion Building	OSHPD 1-Proposed	5s			5s	
01 - Alameda	11366	Washington Hospital	Fremont	BLD-07395	Underground Service Passage	OSHPD 1-Proposed	5s			5s	
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-00089	Hospital Building	OSHPD 1-In Service	5			4	
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-05532	Emergency Department Entry Porte Cochere - Low	OSHPD 1-In Service	5			4	
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-05533	Emergency Department Entry Porte Cochere - High	OSHPD 1-In Service	5			4	
03 - Amador	17490	Sutter Amador Hospital	Jackson	BLD-07058	Entry Canopy	OSHPD 1-In Service	5s			4s	
04 - Butte	10013	Enloe Health	Chico	BLD-00110	Original Hospital	OSHPD 1-In Service	2		0.13	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	Chico	BLD-00111	O.B. First Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10013	Enloe Health	Chico	BLD-00112	O.B. Second Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10013	Enloe Health	Chico	BLD-00113	Administration Third Addition - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10013	Enloe Health	Chico	BLD-00114	Surgery Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	Chico	BLD-00115	Corridor No. 1	OSHPD 1-In Service	2		1.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	Chico	BLD-00116	South Wing - Structurally connected to BLD-00110	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10013	Enloe Health	Chico	BLD-00117	Trauma	OSHPD 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
04 - Butte	10013	Enloe Health	Chico	BLD-00118	Pharmacy	OSHPD 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10013	Enloe Health	Chico	BLD-00119	Tower	OSHPD 1-In Service	4			2	
04 - Butte	10013	Enloe Health	Chico	BLD-00120	Cath Lab No. 1	OSHPD 1-In Service	4			2	
04 - Butte	10013	Enloe Health	Chico	BLD-00121	Radiology - Oncology - Structurally connected to BLD-02935	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10013	Enloe Health	Chico	BLD-00122	Cath Lab No. 2	OSHPD 1-In Service	4			2	
04 - Butte	10013	Enloe Health	Chico	BLD-00123	Surgery Addition	OSHPD 1-In Service	4			2	
04 - Butte	10013	Enloe Health	Chico	BLD-00124	Waiting Area/Corridor No. 2	OSHPD 1-In Service	4			2	
04 - Butte	10013	Enloe Health	Chico	BLD-02934	Magnolia Tower	OSHPD 1-In Service	5			4	
04 - Butte	10013	Enloe Health	Chico	BLD-02935	O.R. Addition	OSHPD 1-In Service	5			4	
04 - Butte	10013	Enloe Health	Chico	BLD-02936	E.R. Addition	OSHPD 1-In Service	5			4	
04 - Butte	10013	Enloe Health	Chico	BLD-07192	Angiography Room 5 Suite	OSHPD 1-Proposed	5s			4s	
04 - Butte	16464	Enloe Rehabilitation Center	Chico	BLD-00086	Rehabilitation Center	OSHPD 1-In Service	4			4	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00090	Main Hospital Building & Additions	OSHPD 1-In Service	2	0.54		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00091	East Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00092	North Wing Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00094	Boiler Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00095	Warehouse Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00096	18 Bed Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00097	Surgical Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00098	X-Ray Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00099	Entry Addition - Structurally connected to BLD-00090	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-00100	ICU Addition	OSHPD 1-In Service	4			2	
04 - Butte	10006	Orchard Hospital	Gridley	BLD-02933	Bulk Oxygen Yard	OSHPD 1-Equipment Yard	N/A			4	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00134	1960 Original Building	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00135	1963 Structural Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00136	1968 36 Bed Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00137	1971 X-Ray Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00138	1972 ICU Addition - Structurally connected to BLD-00134	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00139	1974 ER Addition	OSHPD 1-In Service	4			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00140	1978 Pathology Addition	OSHPD 1-In Service	4			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00141	1979 Business/Lobby Addition	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00142	1979 Nuclear Medicine Addition - Structurally connected to BLD-00140	OSHPD 1-Not an Independent Building	N/A			N/A	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00143	1989 South Wing Addition	OSHPD 1-In Service	4			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-00144	1997 Addition	OSHPD 1-In Service	5			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-03175	1979 Kitchen/Dining Addition	OSHPD 1-In Service	4			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-03844	1989 South Wing Addition - 1 story	OSHPD 1-In Service	4			2	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-06111	Orohealth Hospital New Patient Tower	OSHPD 1-Under Construction	5s			5s	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-06789	Orohealth Hospital Chiller Enclosure	OSHPD 1-Under Construction	5s			5s	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-06790	Orohealth Hospital Generator Enclosure	OSHPD 1-Under Construction	5s			5s	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-07641	Pump House	OSHPD 1-Under Construction	5s			5s	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-07642	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
04 - Butte	10019	Oroville Hospital	Oroville	BLD-07643	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-00131	North Wing	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-00132	South Wing	OSHPD 1-In Service	4s			2	
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-06006	South Wing - Link Corridor	OSHPD 1-In Service	4s			2	
05 - Calaveras	10029	Mark Twain Medical Center	San Andreas	BLD-07009	Steam Boilers Shed	OSHPD 1-Proposed	5s			4s	
06 - Colusa	10032	Colusa Medical Center	Colusa	BLD-00133	Main Hospital	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
06 - Colusa	10032	Colusa Medical Center	Colusa	BLD-06329	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-02468	1 - Main Hospital	OSHPD 1-In Service	5			2	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-02469	16 - Main Entrance Canopy	OSHPD 1-In Service	5			3	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-03719	2 - Clinical Lab	OSHPD 1-In Service	5			4	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-03852	Cafeteria	OSHPD 1-In Service	2		0.3	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-05505	Lower Generator Building	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-06510	Mechanical Shed	OSHPD 1-In Service	5			4	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-07280	Walkway	OSHPD 1-In Service	5			4	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-07388	Ward E	OSHPD 1-In Service	1s			1	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-07589	Cafeteria South Wing	OSHPD 1-Proposed	5s			5s	
07 - Contra Costa	10049	Contra Costa Regional Medical Center	Martinez	BLD-07784	Loading Dock A	OSHPD 1-Proposed	5s			5s	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02472	Original Hospital (Elevator Tower)	OSHPD 1-In Service	2		22.67	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02473	C Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02474	Elevator/Stair Tower - Structurally connected to BLD-02472	OSHPD 1-Not an Independent Building	N/A	9.76		N/A	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02475	C Wing-East Wing-North West Element - Structurally connected to BLD-02476	OSHPD 1-Not an Independent Building	N/A	4.48		N/A	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02476	D Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	7.03		N/A	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02477	D Wing-North Wing-Infill - Structurally connected to BLD-02473	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02478	C Wing Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02479	Linear Accelerator	OSHPD 1-In Service	4			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02480	B Wing / Surgery Equipment Room	OSHPD 1-In Service	2		1.11	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02481	Surgery Equipment Room - Structurally connected to BLD-02480	OSHPD 1-Not an Independent Building	N/A			N/A	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02482	Cancer Center	OSHPD 1-In Service	5			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02483	Emergency Room	OSHPD 1-In Service	3			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02484	Canopy - Structurally connected to BLD-02483	OSHPD 1-Not an Independent Building	N/A			N/A	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02485	A Wing	OSHPD 1-In Service	3			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02486	Linear Accelerator	OSHPD 1-In Service	5			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02487	Central Plant	OSHPD 1-In Service	4			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02488	Boiler Plant	OSHPD 1-In Service	4			2	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02939	Canopy 1	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02940	Ambulance Canopy	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02941	Canopy 2	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-02946	Canopy 3	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05223	E Tower	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05921	E-1	OSHPD 1-In Service	5			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-05971	HVAC Tunnel	OSHPD 1-Tunnels	N/A			4	
07 - Contra Costa	10048	John Muir Medical Center-Concord Campus	Concord	BLD-06886	LOX Yard	OSHPD 1-Proposed	N/A			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00478	Original Hospital (Tower & Low Rise)	OSHPD 1-In Service	2	0.49		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00479	Phase 2 Tower	OSHPD 1-In Service	2	0.47		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00480	Phase 2 Cafeteria / Cardiology	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00481	Phase 2 ER / Radiology	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00482	Phase 3 West Wing	OSHPD 1-In Service	3			2	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-00484	MRI Addition - Structurally connected to BLD-00478	OSHPD 1-Not an Independent Building	N/A			N/A	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-02944	Central Plant	OSHPD 1-In Service	5			4	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-05222	Phase 4 Tower	OSHPD 1-In Service	5			4	
07 - Contra Costa	10081	John Muir Medical Center-Walnut Creek Campus	Walnut Creek	BLD-05308	Phase 3 West Wing - East Portion	OSHPD 1-In Service	3			2	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-03744	Hospital Building	OSHPD 1-In Service	5			4	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-03745	Central Utility Plant	OSHPD 1-In Service	5			4	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-07386	WT-01 Water Tank	OSHPD 1-Proposed	5s			5s	
07 - Contra Costa	18153	Kaiser Foundation Hospital - Antioch	Antioch	BLD-07387	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-02453	Hospital Building	OSHPD 1-In Service	3			3	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-02454	Central Service Building	OSHPD 1-In Service	5			4	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-07211	Hospital Addition - 2005	OSHPD 1-In Service	5			4	
07 - Contra Costa	17749	Kaiser Foundation Hospital - Richmond Campus	Richmond	BLD-07212	Tech Dock	OSHPD 1-In Service	5s			4s	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02447	Central Plant	OSHPD 1-In Service	4			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02448	North Addition (Hospital Tower)	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02449	Phase 1 Hospital - Utility Expansion	OSHPD 1-In Service	3			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02450	Phase II Hospital	OSHPD 1-In Service	5			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02451	Generator Plant	OSHPD 1-In Service	5			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-02452	Waste, Gas Farm Enclosure	OSHPD 1-In Service	5			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-03504	Phase II Link Corridor	OSHPD 1-In Service	5			2	
07 - Contra Costa	10072	Kaiser Foundation Hospital - Walnut Creek	Walnut Creek	BLD-07034	Drop Off Canopy	OSHPD 1-In Service	5s			4s	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-00276	Main Hospital	OSHPD 1-In Service	4			3	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-05620	ED Expansion	OSHPD 1-In Service	5			4	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-05621	OR Expansion	OSHPD 1-In Service	5			4	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-07699	Pump House	OSHPD 1-Proposed	5s			5s	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-07700	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-07701	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
07 - Contra Costa	16228	San Ramon Regional Medical Center	San Ramon	BLD-07702	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
07 - Contra Costa	16166	San Ramon Regional Medical Center South Building	San Ramon	BLD-03688	Rehabilitation Hospital	OSHPD 1-In Service	3			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02461	Original Hospital	OSHPD 1-In Service	2	0.35		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02462	ER / Lab Expansion	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02466	Nursing Tower	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-02467	Ambulatory Services	OSHPD 1-In Service	5			4	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03032	Mechanical Building - Structurally connected to BLD-02461	OSHPD 1-Not an Independent Building	N/A			N/A	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03033	OR Storage Expansion	OSHPD 1-In Service	4			4	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03034	Entrance Canopy	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03484	Womens Center	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03667	Nursing Tower - Central Plant	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03668	Nursing Tower - Dining Addition	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03669	Nursing Tower - Admin Building	OSHPD 1-In Service	4			2	
07 - Contra Costa	10052	Sutter Delta Medical Center	Antioch	BLD-03670	Nursing Tower - Lobby Building	OSHPD 1-In Service	4			2	
08 - Del Norte	12784	Sutter Coast Hospital	Crescent City	BLD-01054	Hospital Building	OSHPD 1-In Service	4			4	
08 - Del Norte	12784	Sutter Coast Hospital	Crescent City	BLD-01055	Special Care Unit	OSHPD 1-In Service	5			4	
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00485	Original and Nursing Wing Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00486	Two Story Addition	OSHPD 1-In Service	4			2	
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00487	Mechanical Plant and Addition	OSHPD 1-In Service	4			2	
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-00488	MRI Addition	OSHPD 1-In Service	5			4	
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-05600	New Central Utility Plant	OSHPD 1-In Service	5			4	
09 - El Dorado	10109	Barton Memorial Hospital	South Lake Tahoe	BLD-06620	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00489	Original Building (Bldg I)	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00490	1971 Addition No. 1 (Bldg II)	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00491	1971 Addition No. 2 (Bldg III) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A			N/A	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00492	1974 Addition (Bldg IV)	OSHPD 1-In Service	4			2	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00493	1981 Addition No. 1 (Bldg V)	OSHPD 1-In Service	4			2	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00494	1981 Addition No. 2 (Bldg VI)	OSHPD 1-In Service	4			2	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00495	1988 Addition (Bldg VII)	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00496	1991 Addition (Bldg VIII) - Structurally connected to BLD-00494	OSHPD 1-Not an Independent Building	N/A				N/A	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-00497	1964 Addition (Bldg IX) - Structurally connected to BLD-00489	OSHPD 1-Not an Independent Building	N/A				N/A	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-05594	2012 Addition	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06515	2012 Addition - Connecting Corridor	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06516	2012 Addition - Bridge	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06517	2012 Addition - South Canopy	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06518	2012 Addition - Center Canopy	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06519	2012 Addition - North Canopy	OSHPD 1-In Service	5				4	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06617	Equipment Yard	OSHPD 1-Equipment Yard	N/A				2	
09 - El Dorado	10112	Marshall Medical Center	Placerville	BLD-06982	Ambulance Canopy	OSHPD 1-In Service	5				4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00513	Main Hospital Building	OSHPD 1-In Service	2	0			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00514	Mechanical Building	OSHPD 1-In Service	2	0			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00515	Rec. Room & Office Addition	OSHPD 1-In Service	2	0			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00516	Lab & Storage Addition	OSHPD 1-In Service	4				2	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00517	Canopy Addition	OSHPD 1-In Service	4				2	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-00518	Birthing Center	OSHPD 1-In Service	5				4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-02949	LDR Addition	OSHPD 1-In Service	5				4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-05522	ER / Radiology / Clinic Addition	OSHPD 1-In Service	5				4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-05681	Generator Shed	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06036	Lobby Remodel & Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06037	Corridor Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06038	Mechanical & Electrical Building Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06039	Main Entrance Canopy Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-06040	ER Canopy Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10162	Adventist Health Reedley	Reedley	BLD-07806	New Generator Canopy	OSHPD 1-Proposed	5s			4s	
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00507	Medical / Surgical / Birthing	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00508	Maintenance Building	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00509	Nursing Wing	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00510	Emergency / Laboratory	OSHPD 1-In Service	4			2	
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00511	Multi-Use Facility	OSHPD 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10160	Adventist Health Selma	Selma	BLD-00512	Warehouse	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00020	Nursing Unit	OSHPD 1-In Service	4			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00021	Diagnosis and Treatment	OSHPD 1-In Service	4			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00022	Administration and Support	OSHPD 1-In Service	4			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-00023	Central Plant	OSHPD 1-In Service	4			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05376	Central Plant Expansion	OSHPD 1-In Service	5			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05377	Bed Tower	OSHDP 1-In Service	5			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05378	Diagnostic & Treatment Expansion	OSHDP 1-In Service	5			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05379	Support Expansion 1	OSHDP 1-In Service	5			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05380	Support Expansion 2	OSHDP 1-In Service	5			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-05381	Canopy 1	OSHDP 1-In Service	5			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06051	North Bed Tower	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06052	Support Expansion 3A	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06053	Support Expansion 3B	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06054	Diagnostic & Treatment Expansion 3A	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06055	Diagnostic & Treatment Expansion 3B	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06056	Utility Racks	OSHDP 1-Not a Building Structure	N/A			5s	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06556	Bottle Storage	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06591	Front Entry	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06694	Entry Canopy-North	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-06695	Entry Canopy-South	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07148	Emergency Entry Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07488	WWT-01 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07489	WWT-02 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07490	WWT-03 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07491	WWT-04 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07492	WWT-05 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07493	WT-01 Water Tank	OSHDP 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07494	FT-02 Fuel Tank	OSHDP 1-Tanks	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07495	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
10 - Fresno	16116	Clovis Community Medical Center	Clovis	BLD-07552	Pump House	OSHPD 1-In Service	5s			4s	
10 - Fresno	10122	Coalinga Regional Medical Center	Coalinga	BLD-00498	Main Hospital Building	OSHPD 1-In Service	4			2	
10 - Fresno	10122	Coalinga Regional Medical Center	Coalinga	BLD-06696	SNF Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-00003	West Wing / East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02535	Radiology Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02536	Aa - East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02537	Ab - East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02538	Ac - East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02539	Ad - East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02540	Ae - East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02541	Angiography Addition	OSHPD 1-In Service	4			2	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02951	Trauma & Critical Care Center	OSHPD 1-In Service	5			4	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02952	New Central Plant	OSHPD 1-In Service	5			4	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-02953	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-03513	D/P Skilled Nursing Facility	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-05190	MRI Building	OSHPD 1-In Service	5			4	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-05208	Data Center Building	OSHPD 1-In Service	5			4	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-06508	Trauma Center Corridor	OSHPD 1-In Service	5			4	
10 - Fresno	10127	Community Regional Medical Center	Fresno	BLD-06509	Trauma Center Utility Tunnel	OSHPD 1-Tunnels	5			4	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05187	Main Hospital	OSHPD 1-In Service	5			4	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05188	Central Plant	OSHPD 1-In Service	5			4	
10 - Fresno	17938	Fresno Heart And Surgical Hospital	Fresno	BLD-05278	Wing A	OSHPD 1-In Service	5			4	
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-00294	Recovery Center	OSHPD 1-In Service	4			4	
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-03748	Expansion	OSHPD 1-In Service	5			4	
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-05252	New Tower	OSHPD 1-In Service	5			4	
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-05366	Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
10 - Fresno	16878	Fresno Surgical Hospital	Fresno	BLD-07246	New Tower Support	OSHPD 1-In Service	5			4	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00976	Sequoia Mall	OSHPD 1-In Service	4			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00977	Hospital Tower North	OSHPD 1-In Service	4			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00978	Hospital Tower South	OSHPD 1-In Service	4			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00979	Ancillary/Yosemite Building	OSHPD 1-In Service	4			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00980	Ancillary Building Addition	OSHPD 1-In Service	4			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-00981	Utility/Grapevine Building	OSHPD 1-In Service	5			4	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06468	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A			2	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06499	Medical Gas Storage	OSHPD 1-In Service	4s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06502	Medical Waste Enclosure	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06503	Med Gas Cylinder Canopy	OSHPD 1-In Service	5			4	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06633	Emergency Department Expansion	OSHPD 1-Under Construction	5s			5s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06922	Entrance Canopy	OSHPD 1-In Service	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06923	Utility Shaft	OSHPD 1-Not a Building Structure	N/A			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06924	Fuel Pump House	OSHPD 1-In Service	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06925	Connecting Corridor	OSHPD 1-In Service	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-06926	Utility Tunnel	OSHPD 1-Tunnels	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07049	Carpenter Shop	OSHPD 1-In Service	2s			2s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07171	Medical Waste Enclosure	OSHPD 1-Under Construction	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07452	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07453	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07454	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07591	Entrance Canopy	OSHPD 1-Under Construction	5s			4s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07592	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5s	
10 - Fresno	13018	Kaiser Foundation Hospital - Fresno	Fresno	BLD-07593	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A			5s	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00500	Main Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00501	West Addition	OSHPD 1-In Service	4			2	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00502	Cogeneration Building	OSHPD 1-In Service	4			2	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00503	Chapel	OSHPD 1-In Service	4			2	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00504	Northwest Addition	OSHPD 1-In Service	4			2	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00505	East Addition	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-00506	Central Plant	OSHPD 1-In Service	4			2	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-03307	Cath Recovery Building	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-03308	North Addition	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-05548	Canopy and Bridges	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-05877	UPS Flywheel Enclosure	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-06564	21 KV Switchgear Building	OSHPD 1-Under Construction	5s			4s	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-06600	Fire Pump / Chiller Building	OSHPD 1-Under Construction	5s			5s	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-07077	North Addition Auditorium	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-07078	North Addition Canopy #1	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-07080	North Addition Canopy #2	OSHPD 1-In Service	5			4	
10 - Fresno	10155	Saint Agnes Medical Center	Fresno	BLD-07175	Incinerator Canopy	OSHPD 1-In Service	4			2	
10 - Fresno	16404	San Joaquin Valley Rehabilitation Hospital	Fresno	BLD-02531	Hospital Building	OSHPD 1-In Service	3			3	
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00519	Main Hospital Building	OSHPD 1-In Service	2	0.49		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00520	Garage Building	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00521	600 Wing (Accounting) Addition	OSHPD 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-00522	Nurses Locker Addition	OSHPD 1-In Service	4			2	
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03773	Main Building - ICU Addition	OSHPD 1-In Service	4			2	
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03774	Main Building - Dietary / Purchasing	OSHPD 1-In Service	2	0.49		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03775	Main Building - 700 Wing South	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03776	Main Building - 700 Wing North	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03777	Main Building - 800 Wing	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03778	Main Building - Medical / Surgery	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
11 - Glenn	10175	Glenn Medical Center	Willows	BLD-03825	Shop & Maint. Building	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-00751	Main Building and Additions	OSHDP 1-In Service	2	0.73		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-03334	ER Addition	OSHDP 1-In Service	4			2	
12 - Humboldt	10186	Jerold Phelps Community Hospital	Garberville	BLD-05453	Clinic Building and Additions	OSHDP 3 - Local-Outpatient Only	N/A			N/A	
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00186	Main Hospital	OSHDP 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00187	Central Plant	OSHDP 1-In Service	2	0.13		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00188	Administration/Urgent Care	OSHDP 1-In Service	4			3	
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00189	Short Stay Surgery	OSHDP 1-In Service	4			2	
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-00190	Obstetrics Addition	OSHDP 1-In Service	4			2	
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-05471	AHU Platform	OSHDP 1- Under Construction	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
12 - Humboldt	13087	Mad River Community Hospital	Arcata	BLD-05715	Conference Room Addition	OSHDP 1-In Service	4			3	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-00529	Original Building	OSHDP 1-In Service	2	0.43		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-00530	O.B. Addition	OSHDP 1-In Service	5			3	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-00531	Generator Building	OSHDP 1-In Service	5			4	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-00532	East Wing Expansion	OSHDP 1-In Service	5			3	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-00533	E. Wing Canopy	OSHDP 1-In Service	4			3	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-03890	Surgery Department - Structurally connected to BLD-00529	OSHDP 1-Not an Independent Building	N/A			N/A	
12 - Humboldt	10183	Providence Redwood Memorial Hospital	Fortuna	BLD-05824	Rehab. Addition	OSHDP 1-Under Construction	5s			5s	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00535	Original Hospital and Central Plant	OSHDP 1-In Service	1		30.48	2	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00536	Linear Accelerator (Phase II)	OSHDP 1-In Service	5			3	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00537	Phase III Addition Building	OSHDP 1-In Service	4			3	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00538	Emergency Entrance Vestibule	OSHDP 1-In Service	5			3	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00539	Radiation Oncology Addition	OSHDP 1-In Service	5			3	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00540	Heart Center	OSHDP 1-In Service	5			3	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00541	East Wing	OSHDP 1-In Service	5			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-00542	Emergency Entrance Vestibule Addition	OSHDP 1-In Service	3			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-02735	Emergency Generator #1 CMU Building	OSHDP 1-In Service	4			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-02736	Emergency Generator #2 Enclosure Shed	OSHDP 1-In Service	5			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-03375	Northeast Building Entry Link	OSHDP 1-In Service	5			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-03376	Fire Pump House	OSHDP 1-In Service	5			4	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-03625	Northeast Building	OSHDP 1-In Service	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-05767	Northeast Building Ambulance Canopy	OSHPD 1-In Service	5s			4s	
12 - Humboldt	10184	Providence St. Joseph Hospital	Eureka	BLD-05768	Northeast Building Entry Canopy	OSHPD 1-In Service	5s			4s	
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	Garberville	BLD-06703	Hospital	OSHPD 1-Proposed	5s			5s	
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	Garberville	BLD-06704	Entry Canopy	OSHPD 1-Proposed	5s			5s	
12 - Humboldt	10037	Southern Humboldt Community Healthcare District	Garberville	BLD-06705	ED Canopy	OSHPD 1-Proposed	5s			5s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00752	South Wing	OSHPD 1-In Service	4D			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00753	L/D Bldg	OSHPD 1-In Service	4D			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00754	Central Wing	OSHPD 1-In Service	4D			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00755	West Addition - Structurally connected to BLD-00754	OSHPD 1-Not an Independent Building	N/A			N/A	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00756	Central Plant	OSHPD 1-In Service	4D			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00757	North Wing	OSHPD 1-In Service	4D			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00758	ICU Addition - Structurally connected to BLD-00757	OSHPD 1-Not an Independent Building	N/A			N/A	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00759	Admin Bldg	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00760	OB Building	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00761	Radiology Building	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00762	Rad Annex	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00763	Lab Building	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-00764	Annex	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02685	East Wing - South	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02686	New Wing	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02687	New Central Plant	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02887	Admin Bldg Addition	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-02888	East Wing - North	OSHPD 1-In Service	4			2	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-03219	Electrical Room	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-03331	Generator Yard	OSHPD 1-Equipment Yard	N/A			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05694	Ancillary Services Building	OSHPD 1-Under Construction	5s			4s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-05940	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06098	Data Center Building	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06389	Entrance Lobby	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06390	Entrance Canopy	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06391	Driveway Canopy	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06392	Ambulance Canopy	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06419	North ASB Utility Canopy	OSHPD 1-Under Construction	5s			4s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06420	South ASB Utility Canopy	OSHPD 1-Under Construction	5s			4s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06421	ASB Covered Link	OSHPD 1-Under Construction	5s			4s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06427	Central Plant Shed	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06428	Hazardous Waste Storage	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-06429	Pharmacy Expansion	OSHPD 1-In Service	5			4	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07800	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07801	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07802	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07803	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07804	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
13 - Imperial	10190	El Centro Regional Medical Center	El Centro	BLD-07805	Pump House	OSHDP 1-Proposed	5s			5s	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00765	Original Hospital	OSHDP 1-In Service	2	0.72		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00766	Original Power Plant	OSHDP 1-In Service	2	0.55		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00767	Administration Wing	OSHDP 1-In Service	2	0.29		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00768	ICU Addition	OSHDP 1-In Service	4			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00769	Outpatient Addition	OSHDP 1-In Service	4			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00770	Women's Center	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00771	ER	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00772	New Power Plant	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-00773	Dietary	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-02892	Link between 05B and 01A	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-02893	Link between 05B and 05C	OSHDP 1-In Service	5			2	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-05909	Surgery Addition	OSHDP 1-In Service	5			4	
13 - Imperial	10192	Pioneers Memorial Hospital	Brawley	BLD-06240	Emergency Generator Yard	OSHDP 1-Equipment Yard	N/A			2	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00775	Main Hosp Bldg/Existing Central Plant	OSHDP 1R-No Gen Acute Care - OSHDP Bldg	N/A			N/A	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00776	ICU Addition	OSHDP 1-In Service	4			2	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00777	Central Plant Addition	OSHDP 1-In Service	5			4	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-00778	Emergency Generator Building	OSHDP 1-In Service	5			4	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-02922	New Hospital Building	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-05321	New Central Plant Building	OSHDP 1-In Service	5			4	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-06524	Covered Walkway - West	OSHDP 1-In Service	5			4	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-06525	Covered Walkway - North	OSHDP 1-In Service	5			4	
14 - Inyo	10200	Northern Inyo Hospital	Bishop	BLD-06526	Corridor Connection	OSHDP 1-In Service	5			4	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00779	Main Hospital Building	OSHDP 1-In Service	2		1.02	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00780	Maintenance Building	OSHDP 1-In Service	2		0.77	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00781	Entrance Addition - Structurally connected to BLD-00779	OSHDP 1-Not an Independent Building	N/A			N/A	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00782	East Wing Addition	OSHDP 1-In Service	2		1.07	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00783	West Wing Addition - Structurally connected to BLD-00779	OSHDP 1-Not an Independent Building	N/A			N/A	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00784	Diagnostics & Treatment Addition	OSHDP 1-In Service	4			2	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00785	Patient Room Addition	OSHDP 1-In Service	4			2	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00786	Storage Room Addition	OSHDP 1-In Service	4			2	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00787	Boiler Room Addition	OSHDP 1-In Service	4			2	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00788	Boiler Room 2 Addition - Structurally connected to BLD-00787	OSHDP 1-Not an Independent Building	N/A			N/A	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00789	Laundry Building	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
14 - Inyo	10202	Southern Inyo Hospital	Lone Pine	BLD-00790	Storage Building	OSHDP 1-In Service	2		0.58	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00948	Original Building (Main Hospital)	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00949	Emergency Department Addition	OSHPD 1-In Service	5			3	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00951	Emergency Generator Enclosure	OSHPD 1-In Service	4			3	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00952	Fire Pump Enclosure	OSHPD 1-In Service	5			3	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-00953	Bulk Medical Storage Facility	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-06018	Tower Number 2	OSHPD 1-In Service	5			4	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-06555	New Generator Building	OSHPD 1-In Service	5			4	
15 - Kern	12881	Adventist Health Bakersfield	Bakersfield	BLD-07024	Tank Storage	OSHPD 1-In Service	2s			2s	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-01049	Main Building	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	12765	Adventist Health Delano	Delano	BLD-01050	Radiology Addition	OSHPD 1-In Service	4			2	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-01051	ICU/TCU Facility	OSHPD 1-In Service	4			2	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-01052	Med Gases Ancillary	OSHPD 1-In Service	4			4	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-01053	Med Gases	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-05953	SNF Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-06162	Generator Yard	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-06618	Switchgear Yard	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	12765	Adventist Health Delano	Delano	BLD-06622	Hospital Entry Canopy	OSHPD 1-In Service	5			4	
15 - Kern	17358	Adventist Health Specialty Bakersfield	Bakersfield	BLD-00085	Bakersfield Heart Hospital	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-03237	Main Entrance Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05541	Medical / Surgical Facility Building	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05542	Obstetrical Facilities Building	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05543	D & T Building	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05544	Main Entrance Canopy	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05545	ED Canopy	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05546	CT Trailer Canopy	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-05547	Water Tank (WT-01)	OSHPD 1-Tanks	N/A			5	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-06624	Main Entrance High Canopy	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-06625	ED High Canopy	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-06626	Trash Enclosure	OSHPD 1-In Service	5			4	
15 - Kern	18202	Adventist Health Tehachapi Valley	Tehachapi	BLD-06627	Mechanical Yard	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00791	Main Hospital / Lobby / Boiler Building	OSHPD 1-In Service	2	0.48		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00792	East Wing	OSHPD 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00793	Central Plant	OSHPD 1-In Service	4			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00794	Main Hospital West Wing / Business Office	OSHPD 1-In Service	2	0.44		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00795	Maternity Wing	OSHPD 1-In Service	2	0.21		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00796	Labor & Delivery	OSHPD 1-In Service	5			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00797	Labor & Delivery II	OSHPD 1-In Service	3			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00798	Main Tower	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00799	New Cath Lab & Surgery	OSHPD 1-In Service	4			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00800	ER Addition	OSHPD 1-In Service	4			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-00801	Main Hospital East Wing	OSHPD 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03377	Endoscopy Building	OSHPD 1-In Service	2		0.31	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03378	Main Tower - Connecting Corridor	OSHPD 1-In Service	3			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-03379	Laundry / Warehouse Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05215	Entrance Pavilion	OSHPD 1-In Service	5			4	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05659	Endoscopy Corridor	OSHPD 1-In Service	2		0.58	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05896	Cardiac Rehab	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05897	Physical Therapy / Regional Human Resources	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-05902	Ambulance Porte Cochere	OSHPD 1-In Service	5s			2	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06326	Kitchen / Shell Bldg.	OSHPD 1-In Service	5s			4	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06357	Pediatric Pavilion for Emergency Care	OSHPD 1-In Service	5			4	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06373	Lobby Expansion	OSHPD 1-In Service	5			4	
15 - Kern	10207	Bakersfield Memorial Hospital	Bakersfield	BLD-06497	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
15 - Kern	10820	Central California Rehabilitation Hospital	Bakersfield	BLD-06330	Vibra Rehabilitation Hospital of Bakersfield	OSHPD 1-In Service	5			5	Earthquake Resilient
15 - Kern	10820	Central California Rehabilitation Hospital	Bakersfield	BLD-06332	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	10820	Central California Rehabilitation Hospital	Bakersfield	BLD-06333	O2 Yard	OSHPD 1-Equipment Yard	N/A			5	
15 - Kern	10820	Central California Rehabilitation Hospital	Bakersfield	BLD-06334	Main Entry Drop Off Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-00281	East Building	OSHPD 1-In Service	4			2	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-00282	West Building	OSHPD 1-In Service	4			2	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05565	20 Bed Addition	OSHPD 1-In Service	5			4	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05566	Emergency Power Generator	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-05567	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A			4	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07088	Generator Yard	OSHPD 1-Equipment Yard	N/A			2	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07620	Pump House #1	OSHPD 1-Proposed	5s			5s	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07621	Pump House #2	OSHPD 1-Proposed	5s			5s	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07622	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07623	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07624	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
15 - Kern	16245	Encompass Health Rehabilitation Hospital of Bakersfield	Bakersfield	BLD-07625	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00811	Original Hospital & Additions	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00812	Pediatrics Wing & Additions	OSHPD 1-In Service	2		0.19	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00813	Patient Wing	OSHPD 1-In Service	2		0.14	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10219	Good Samaritan Hospital	Bakersfield	BLD-00814	Intensive Care Unit Addition	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00803	Wing B/C - North	OSHPD 1-In Service	2	0.57		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00804	Wing D	OSHPD 1-In Service	4			2	
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00805	Wing E	OSHPD 1-In Service	5			2	
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00806	Infill at E Wing	OSHPD 1-In Service	5			2	
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00807	Wing G / Laundry / Boiler Room	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		13.39	N/A	
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00808	Wing G/Dietary	OSHPD 1-In Service	2	0.61		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-00809	Central Utilities Plant	OSHPD 1-In Service	5			4	
15 - Kern	10208	Kern Medical Center	Bakersfield	BLD-03806	Wing B/C - South	OSHPD 1-In Service	2	0.31		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-00810	Main Hospital Building	OSHPD 1-In Service	2	0.35		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02964	Central Plant Addition	OSHPD 1-In Service	4			2	
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02965	Surgical Suite Addition	OSHPD 1-In Service	4			2	
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02966	Service Facility Addition	OSHPD 1-In Service	4			2	
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-02967	Skilled Nursing Addition	OSHPD 1-In Service	4			2	
15 - Kern	10210	Kern Valley Healthcare District	Lake Isabella	BLD-07133	Connecting Corridor	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00827	Main Wing/Courtyard Infill	OSHPD 1-In Service	2	2.44	0.49	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00828	Addition to the Main Wing	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00829	Patient Tower (T & D Stair No. 3)	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00830	Treatment and Diagnostic Building (Central Plant and Emergency Generator Enclosure)	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00831	T & D Admitting Wing (Boiler Building and Mezzanine)	OSHPD 1-In Service	2	5.43		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00832	T & D Stair No. 1 (Laundry Building)	OSHPD 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00833	T & D Stair No. 2 (Treatment and Diagnostic Building)	OSHPD 1-In Service	3			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00834	T & D Stair No. 3 (T & D Stair No. 4)	OSHPD 1-In Service	3			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00835	T & D Stair No. 4 (Patient Tower)	OSHPD 1-In Service	3			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00836	Boiler Building and Mezzanine (T&D Stair Number 1)	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-00837	Central Plant and Emergency Generator Enclosure (T&D Admitting Wing)	OSHPD 1-In Service	3			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-03315	Corridor - Northwest Side	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-05203	Boiler Building and Mezzanine (T&D Stair Number 2)	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06181	Porte Cochere	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06182	Corridor - Northeast Side	OSHPD 1-In Service	4			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06196	Bulk Oxygen Enclosure	OSHPD 1-Equipment Yard	N/A			2	
15 - Kern	10214	Mercy Hospital	Bakersfield	BLD-06207	Emergency Generator and Aboveground Fuel Tank	OSHPD 1-Equipment Yard	N/A			2	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-02623	Main Hospital Building 1	OSHPD 1-In Service	4			2	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-02624	Main Hospital Building 2	OSHPD 1-In Service	4			2	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06359	New Four Story Patient Tower	OSHPD 1-Under Construction	5s			5s	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06360	New Two Story East Addition	OSHPD 1-Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06361	New One Story West Addition	OSHPD 1- Under Construction	5s			5s	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06362	New Central Utility Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06363	Main Entry Canopy	OSHPD 1- Under Construction	5s			5s	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-06364	Loading Dock Canopy	OSHPD 1- Under Construction	5s			5s	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-07755	WT-01 Water Tank	OSHPD 1- Tanks	N/A			5	
15 - Kern	17632	Mercy Southwest Hospital	Bakersfield	BLD-07756	WWT-01 Wastewater Tank	OSHPD 1- Tanks	N/A			5	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00815	Main Core	OSHPD 1-In Service	2	0.18		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00817	B Wing	OSHPD 1-In Service	2	0.18		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00818	C Wing	OSHPD 1-In Service	2	0.18		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00819	ICU Addition	OSHPD 1-In Service	4			2	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00820	D Wing	OSHPD 1-In Service	4			2	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-00821	E Wing	OSHPD 1-In Service	4			2	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-03483	Addition to Existing Hospital	OSHPD 1-In Service	5			4	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-03619	Cafeteria / Dining Expansion	OSHPD 1-In Service	5			4	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-06578	Entrance Canopy 1	OSHPD 1-In Service	5			4	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-06579	New Central Plant	OSHPD 1-In Service	5			4	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-06580	Electrical Building	OSHPD 1-In Service	5			4	
15 - Kern	10220	Ridgecrest Regional Hospital	Ridgecrest	BLD-06582	Entrance Canopy 2	OSHPD 1-In Service	5			4	
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05346	Main Hospital - West Wing	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05347	Main Hospital - East Wing	OSHPD 1-In Service	5			4	
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05570	Womens Center	OSHPD 1-In Service	5			4	
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-05571	Energy Center	OSHPD 1-In Service	5			4	
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-06785	Trellis	OSHPD 1-Not a Building Structure	N/A			4	
16 - Kings	18194	Adventist Health Hanford	Hanford	BLD-07179	Cath Lab	OSHPD 1-Proposed	5s			5s	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00431	East Wing	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00432	West Wing	OSHPD 1-In Service	4			2	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-00434	Central Supply/Maintenance	OSHPD 1-In Service	4			2	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-05509	Chiller Platform	OSHPD 1-Not a Building Structure	N/A			4	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-06023	Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A			4	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-07026	ED Department	OSHPD 1-In Service	5			4	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-07131	ED Department Canopy	OSHPD 1-In Service	5			4	
17 - Lake	10247	Adventist Health Clearlake	Clearlake	BLD-07145	Med Gas Storage	OSHPD 1-In Service	5			4	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00268	Main Hospital	OSHPD 1-In Service	4			2	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00269	Hospital Addition	OSHPD 1-In Service	4			2	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-00270	CT Scanner	OSHPD 1-In Service	4			2	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-02981	Conference Room - Structurally connected to BLD-00268	OSHPD 1-Not an Independent Building	N/A			N/A	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-02982	LDRP Addition	OSHPD 1-In Service	4			2	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-03052	Purchasing Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-03558	Surgery & Emergency Department	OSHPD 1-In Service	5			4	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-06296	Pharmacy Addition	OSHPD 1-In Service	5			4	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-06486	ED Canopy	OSHPD 1-In Service	5			4	
17 - Lake	14345	Sutter Lakeside Hospital	Lakeport	BLD-07254	MRI Building	OSHPD 1-In Service	5s			4s	
18 - Lassen	17940	Banner Lassen Medical Center	Susanville	BLD-05185	Main Building	OSHPD 1-In Service	5			4	
18 - Lassen	17940	Banner Lassen Medical Center	Susanville	BLD-06331	Central Utility Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01940	Rehabilitation Wing	OSHPD 1-In Service	2	0.52		4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01941	Mental Health Building	OSHPD 5-Acute Psych Only	N/A			N/A	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01942	Main Building - North East - Structurally connected to BLD-03263	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01943	Main Building - South	OSHPD 1-In Service	3			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01944	Main Building - West (SICU)	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01945	Main Building - Stair Tower #5	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01946	Wilson Parking Structure	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01949	Link Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01950	Link Building - West	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01951	Link Building - East	OSHPD 1-In Service	4			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01952	TCU	OSHPD 1-In Service	2		1.08	4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-01953	D & T / D & T Plant	OSHPD 1-In Service	2	0.69		4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03015	Womens Pavilion	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03016	Mental Health Bldg South Addition	OSHDP 5-Acute Psych Only	N/A			N/A	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03263	Main Building - North East	OSHDP 1-In Service	3			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03439	West Tower Phase 2 / 3	OSHDP 1-In Service	5			4	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03440	West Tower Phase 1	OSHDP 1-In Service	5			4	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03441	West Tower Link to Main Building	OSHDP 1-In Service	5s			4s	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03762	Main Building - Cooling Tower	OSHDP 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-03913	Main Building - North	OSHDP 1-In Service	3			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-05932	Exhaust Stack - Structurally connected to BLD-03440	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-06399	Compounding Pharmacy Building	OSHDP 1-In Service	4			2	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-07021	Addition #1	OSHDP 1-In Service	5s			4s	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-07022	Addition #2	OSHDP 1-In Service	4s			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-07023	Addition #3	OSHDP 1-In Service	4s			3	
19 - Los Angeles	11668	Adventist Health Glendale	Glendale	BLD-07358	Stair Tower	OSHDP 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02187	D & T Building (North Tower)	OSHDP 1R-Delicensed Clinic under OSHPD	N/A			N/A	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02188	East Building	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02189	Chiller Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02191	East Building North Addition (B-1)	OSHDP 1-In Service	3			3	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02192	South Building	OSHDP 1-In Service	3			2	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-02193	Emergency Generator Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03157	East Building South Addition (B-2)	OSHDP 1-In Service	3			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03287	Shop Building Replacement	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03288	Boiler Building Replacement	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03290	Service Tunnel Replacement	OSHPD 1-Tunnels	N/A			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03291	Specialty Care Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-03859	Entry Concourse Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-06511	Entry Concourse Building (South)	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-06512	Ambulance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-06513	Stair / Elevator Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-06514	Loading Dock Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-06520	Main Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-07770	Equipment Storage Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12198	Adventist Health White Memorial	Los Angeles	BLD-07771	Bio-Hazard Waste Storage	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00613	Service Building & Additions (Block I)	OSHPD 1-In Service	2		0.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00614	Home Health (Block II) Nursing & Lab	OSHPD 1-In Service	2	1.14	0.85	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00615	Nursing Administration (Block III)	OSHPD 1-In Service	2		0.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00616	Accounting & Respiratory Therapy (IV)	OSHPD 1-In Service	2		0.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00617	Emerson Wing - Nursing Unit (V) - Structurally connected to BLD-00614	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00618	Main Building North (Block VI)	OSHPD 1-In Service	2		0.85	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00619	Canopy (Block VII)	OSHPD 1-In Service	4			2	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00620	OB Addition (Block VIII)	OSHPD 1-In Service	4			2	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-00621	MRI Facility (Block IX)	OSHPD 1-In Service	5			2	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-03872	Main/Utility/Tower (Block VI)	OSHPD 1-In Service	2	15.48	1.03	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-05504	Central Plant and Ambulance Area	OSHPD 1-In Service	5			4	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-06415	Equipment Yard – Hot Water System	OSHPD 1-Equipment Yard	N/A			2	
19 - Los Angeles	11441	Adventist Health White Memorial Montebello	Montebello	BLD-06729	Ambulance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11386	Alhambra Hospital Medical Center	Alhambra	BLD-00722	Hospital	OSHPD 1-In Service	2	0.41	1.23	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00737	Original Hospital	OSHPD 1-In Service	2		0.73	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00738	Storeroom Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00739	East Wing Addition	OSHPD 1-In Service	2		4.23	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00740	Dining Room Addition	OSHPD 1-In Service	2		1.07	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00741	Cobalt Addition	OSHPD 1-In Service	2		0.58	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00742	Hospital Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00743	Central Plant	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00744	Emergency Room Addition - Structurally connected to BLD-00746	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00745	Storage Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00746	Hospital Tower Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00747	Central Plant Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00748	Entrance Addition - Structurally connected to BLD-00742	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00749	Kitchen and Dining Additions (west side addition) - Structurally connected to BLD-02621	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-00750	Storeroom & Dock Addition - Structurally connected to BLD-00738	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-02621	Kitchen Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-02804	New Women's and Children's Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-02805	New WCH Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-03486	Northeast Canopy	OSHPD 1-In Service	4			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-05484	Kitchen and Dining Additions (east side addition) - Structurally connected to BLD-02621	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-05708	New Women's and Children's Hospital Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-05709	New Women's and Children's Hospital Electrical Room	OSHPD 1-In Service	5			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-05711	New Women's and Children's Hospital LOX Tank	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06091	Central Plant Tunnel	OSHPD 1-Tunnels	N/A			2	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06107	Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06108	Central Plant Addition - West	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06501	Prefabricated ED Addition	OSHPD 1-In Service	5			5	Earthquake Resilient	
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06646	Replacement Hospital	OSHPD 1-Proposed	5s			5s		
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06647	Main Entry Canopy	OSHPD 1-Proposed	5s			5s		
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06648	Emergency Entrance Canopy	OSHPD 1-Proposed	5s			5s		
19 - Los Angeles	11399	Antelope Valley Medical Center	Lancaster	BLD-06650	Central Utility Plant	OSHPD 1-Proposed	5s			5s		
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00730	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4				2	
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00731	Dining/Kitchen Building & Additions (1902)	OSHPD 1-In Service	2		1.03		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00732	1927 Addition (Original Building)	OSHPD 1-In Service	2		14.57		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-00733	1974 Addition "A"	OSHPD 1-In Service	2		0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-02707	1974 Addition "B"	OSHPD 1-In Service	2		0.53		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-02708	1974 Addition "C"	OSHPD 1-In Service	2		0.53		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-03010	Outpatient Clinic & Lab Addition	OSHPD 1-In Service	4				2	
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-06489	Entry Canopy	OSHPD 1-Under Construction	5s				4s	
19 - Los Angeles	11417	Barlow Respiratory Hospital	Los Angeles	BLD-06490	Rear Canopy	OSHPD 1-Under Construction	5s				4s	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00622	Tibbitts Tower A	OSHPD 1-In Service	3				2	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00623	Tibbitts Tower B	OSHPD 1-In Service	3				2	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00625	D & T Building	OSHPD 1-In Service	2				2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00626	1963 Central Plant	OSHPD 1-In Service	2	1.47	0.6	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00627	1969 Central Plant	OSHPD 1-In Service	2	0.66		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-00628	1964 Tower	OSHPD 1-In Service	1	13.2		2	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03122	Lobby	OSHPD 1-In Service	3			2	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03212	Emergency Department and Women's Services	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03213	Stair Tower	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-03214	Entry Canopy	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11480	California Hospital Medical Center - Los Angeles	Los Angeles	BLD-06543	Cooling Tower Platform	OSHPD 1-Not a Building Structure	N/A			2	
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	Los Angeles	BLD-00940	Main Hospital	OSHPD 1-In Service	2	1.22	0.78	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	Los Angeles	BLD-02910	LOX Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	Los Angeles	BLD-03876	Trigen Central Plant	OSHPD 1-In Service	2		0.72	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	Los Angeles	BLD-03908	Central Plant Expansion 3	OSHPD 1-In Service	2		0.44	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12874	California Rehabilitation Institute, LLC	Los Angeles	BLD-05781	Drop Off Canopy	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-02885	New Replacement Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05310	Medical Surgical Addition and 31 Bed Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05311	Electrical Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-05473	Mechanical Yard Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-06219	Welcome Gallery	OSHPD 1-In Service	5			4	
19 - Los Angeles	11496	Casa Colina Hospital	Pomona	BLD-06220	Imaging Connector	OSHPD 1-In Service	5			4	
19 - Los Angeles	10095	Catalina Island Medical Center	Avalon	BLD-07226	Hospital	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	10095	Catalina Island Medical Center	Avalon	BLD-07227	ER Canopy	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	11410	Catalina Island Medical Center	Avalon	BLD-00725	Original Building	OSHPD 1-In Service	2	0.19		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11410	Catalina Island Medical Center	Avalon	BLD-00726	East Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-01039	Original Building	OSHPD 1-In Service	2	0.31		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-01040	CCU Addition	OSHPD 1-In Service	4s			2	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-01041	Outpatient Addition	OSHPD 1-In Service	4s			2	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06232	Pharmacy Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06366	Hospital	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06367	Central Utility Plant (Energy Center)	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06368	Gas Yard	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06418	Hospital Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06572	Loading Dock	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-06730	MRI/CT Trailers Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07187	Hospital Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07579	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07580	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07581	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07582	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07583	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	12744	Cedars-Sinai Marina Hospital	Marina Del Rey	BLD-07584	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00384	Main Medical Center	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00385	Harvey Morse Conference Center - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-00386	Becker Building - Structurally connected to BLD-00384	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02806	Imaging Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02807	Saperstein Critical Care Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-02808	Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-03438	Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-05265	Comprehensive Cancer Center	OSHPD 3 - Local-Outpatient Only	N/A			N/A	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-05304	Advanced Health Sciences Pavilion	OSHPD 3 - Local-Outpatient Only	N/A			N/A	
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-07658	New Patient Wing Addition	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11891	Cedars-Sinai Medical Center	Los Angeles	BLD-07783	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A				5s
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00633	West Wing/ER Addition	OSHDP 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00634	North Wing/Day Surgery	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00635	Dietary Storage	OSHDP 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00636	East Tower	OSHDP 1-In Service	4			2	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00637	West Tower	OSHDP 1-In Service	2	8.47	0.8	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00638	Engineering	OSHDP 1-In Service	2	0.97	0.97	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00639	East Wing	OSHDP 1-In Service	2	0.6	0.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00640	Central Plant Addition	OSHDP 1-In Service	2	0.37		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-00641	Nursery Addition	OSHDP 1-In Service	2	4.13	0.45	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-03466	Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-05404	Electrical Services Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-06894	Emergency Generator Enclosure	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07248	Canopy	OSHDP 1-In Service	5s			4s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07359	Transformer and Medical Gas Enclosure	OSHDP 1-Equipment Yard	N/A			2s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07374	ER Addition	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07375	Drop-Off Canopy	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07522	East Wing - West Side	OSHPD 1-In Service	2		0.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07751	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07752	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07753	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11510	Centinela Hospital Medical Center	Inglewood	BLD-07754	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00643	Duque Building	OSHPD 1-In Service	2	0.27		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00644	Page Tower	OSHPD 1-In Service	3			2	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00645	McAllister Building	OSHPD 1-In Service	2	5.6	0.92	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00646	Page Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00647	Weingart Pavilion	OSHPD 1-In Service	3			2	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-00648	McDonald's Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-02847	Linear Accelerator	OSHPD 1-In Service	4			2	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-02848	DWP Substation	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03292	Central Plant/Anderson Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03293	Subterranean Parking Structure	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03294	Cooling Tower - Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-03531	Surgery Center/Anderson Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-05279	Anderson Pavilion	OSHPD 1-In Service	5			4	
19 - Los Angeles	11525	Children's Hospital Los Angeles	Los Angeles	BLD-07000	Duque Building Utility Tunnel	OSHPD 1-Tunnels	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00650	Northwest	OSHPD 1-In Service	2		0.76	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00652	Main Medical	OSHPD 1-In Service	2	1.17	0.76	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-00653	ICU	OSHPD 1-In Service	4			3	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02575	Wing 1	OSHPD 1-In Service	2	0.15		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02576	Wing 5	OSHPD 1-In Service	2	0.15		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02577	Wing 6	OSHPD 1-In Service	2	0.15		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-02578	Food Service Facility	OSHPD 1-In Service	4			3	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-03091	Chiller Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-03851	Helford Clinical Research Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06155	Helford Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06683	Central Utility Plant	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06779	Main Medical Stair Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06953	Cogeneration Building	OSHPD 1-In Service	5			2	
19 - Los Angeles	11527	City Of Hope Helford Clinical Research Hospital	Duarte	BLD-06956	TES Tank (WT-01)	OSHPD 1-Tanks	N/A			2	
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02151	Original Building	OSHPD 1-In Service	2	0.32		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02670	Lobby & Dietary Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02671	X-ray Entry	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-02672	OR Addition	OSHDP 1-In Service	4			2	
19 - Los Angeles	12088	Coast Plaza Hospital	Norwalk	BLD-03646	Telephone Equipment Building	OSHDP 1-In Service	2	1.33	0.12	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00402	North and East Wings	OSHDP 1-In Service	2	0.32		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00404	South Wing	OSHDP 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00405	West Wing	OSHDP 1-In Service	4			2	
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00406	Engineering	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-00410	Admin/West Entry Lobby - Structurally connected to BLD-00402	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-02822	Assembly	OSHDP 1-In Service	2	0.51		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11927	College Medical Center	Long Beach	BLD-06635	North Wing Addition	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11549	Community Hospital Of Huntington Park	Huntington Park	BLD-00669	Main Hospital	OSHDP 1-In Service	2		1.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11549	Community Hospital Of Huntington Park	Huntington Park	BLD-03426	Emergency Department Canopy	OSHDP 1-In Service	5			4	
19 - Los Angeles	12024	Docs Surgical Hospital	Los Angeles	BLD-01224	Main Hospital - Structurally connected to BLD-05236	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12024	Docs Surgical Hospital	Los Angeles	BLD-06601	New Hospital	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00670	Original Building	OSHDP 1-In Service	2	7.34	1.09	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00671	East Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00672	North Addition - Structurally connected to BLD-00670	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00673	South Addition	OSHPD 1-In Service	2	1.69	0.5	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11598	East Los Angeles Doctors Hospital	Los Angeles	BLD-00674	South Addition - Structurally connected to BLD-00673	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-00191	Original Building	OSHPD 1-In Service	2			3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-00192	Gift Shop Addition	OSHPD 1-In Service	3			4D-L1	
19 - Los Angeles	13093	Emanate Health Foothill Presbyterian Hospital	Glendora	BLD-03840	Emergency Dept.	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02019	Original Building	OSHPD 1-In Service	2		1.18	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02020	East Wing Addition	OSHPD 1-In Service	2		0.87	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02021	West Wing Addition	OSHPD 1-In Service	2		0.87	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02022	Psychiatric Wing Addition	OSHPD 1-In Service	2		1.18	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02023	Lobby Addition	OSHPD 1-In Service	2		1.09	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02024	Generator Building	OSHPD 1-In Service	2		2.45	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02025	Power Plant	OSHPD 1-In Service	4			2	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02026	Radiology Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02027	Conference Room Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-02028	Surgery Wing Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-05422	CCU Addition	OSHPD 1-In Service	2		1.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-05423	Canopy Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-06673	ER Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	11748	Emanate Health Inter-Community Hospital	Covina	BLD-07782	Canopy	OSHPD 1-In Service	4s			2s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01163	Main Building	OSHPD 1-In Service	2	30.36	0.96	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01164	Service Building	OSHPD 1-In Service	4	6.5		2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01165	South Wing Addition	OSHPD 1-In Service	2	9.74	0.41	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01166	1968 West Wing Addition	OSHPD 1-In Service	2		0.42	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01167	Outpatient Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01168	Mechanical Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01169	1983 Lobby Addition - Structurally connected to BLD-01163	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01171	Chiller Room Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01172	Cardiac Cath Lab Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-01173	Maternal & Child Health Center	OSHPD 1-In Service	5			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-03409	Canopy	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-05424	Bridge Connector	OSHDP 1-In Service	5			4	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06654	ED & ICU Addition Building	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06655	Connecting Corridor	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06665	Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06727	Main Switchgear Enclosure	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06728	MRI / CT Connecting Corridor	OSHDP 1-In Service	5			4	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06796	MRI / CT Pedestrian Walkway	OSHDP 1-In Service	5			4s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-06815	Pump Building	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-07475	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	11971	Emanate Health Queen Of The Valley Hospital	West Covina	BLD-07476	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00675	North Wing	OSHDP 1-In Service	2		1.02	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00676	West Wing	OSHDP 1-In Service	2		1.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-00677	Main Tower / Basement / Mech Bldg	OSHDP 1-In Service	2	0.58		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-07165	Lab Extension	OSHDP 1-In Service	4s			2s	
19 - Los Angeles	11621	Encino Hospital Medical Center	Encino	BLD-07166	Engineering Shop	OSHDP 1-In Service	4s			2s	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01934	Main Hospital	OSHDP 1-In Service	2	3.17	0.82	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01935	Nursery/Post Partum	OSHPD 1-In Service	2		1.17	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01936	Emergency Wing	OSHPD 1-In Service	2		0.91	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01937	O.B. Pavilion	OSHPD 1-In Service	4			4	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01938	O.B. Addition	OSHPD 1-In Service	4			4	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-01939	Cath Lab	OSHPD 1-In Service	3			4	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03427	ER Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03428	Extended Service Canopy	OSHPD 1-In Service	4			3	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-03429	Service Canopy	OSHPD 1-In Service	4			3	
19 - Los Angeles	11658	Garfield Medical Center	Monterey Park	BLD-06302	Medical Gas Enclosure	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01779	Original Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	7.86		N/A	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01780	1942 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	7.47		N/A	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01781	Radiology Addition A - Structurally connected to BLD-01780	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01782	Radiology Addition B	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	1.13		N/A	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01783	South Tower	OSHPD 1-In Service	2	2.24	1.02	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01784	Juncture Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A	12.62	13.74	N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01785	Patient Tower	OSHPD 1-In Service	2	1.53	1.19	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01786	Heart and Emergency Center	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01787	Central Plant	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-01788	Mechanical Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11844	Glendale Memorial Hospital and Health Center	Glendale	BLD-03382	Administration Building - Structurally connected to BLD-01783	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	13224	Greater El Monte Community Hospital	South El Monte	BLD-00214	Main Hospital/Radiology Addition	OSHPD 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13224	Greater El Monte Community Hospital	South El Monte	BLD-00215	Nursery & LDR Addition	OSHPD 1-In Service	4s			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00216	Main Hospital - Original Building	OSHPD 1-In Service	5			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00217	Main Hospital - Administration Building	OSHPD 1-In Service	5			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00218	Main Hospital - Emergency Building	OSHPD 1-In Service	5			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00219	Main Hospital - Main Lobby Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00222	Central Plant Building	OSHPD 1-In Service	4			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00223	Pavilion - Main Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00224	Pavilion - Adult Day Health Care	OSHPD 1-In Service	4			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-00225	Pavilion - Pavilion Plant Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-02862	Main Hospital - Emergency Entrance Canopy	OSHPD 1-In Service	4			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-02863	Main Hospital- Main Entrance Canopy	OSHPD 1-In Service	4			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03259	Patient Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03309	Central Utility Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03338	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03413	Loading Dock	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-03414	Emergency Department Expansion	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-05854	Basement Lab Expansion	OSHPD 1-In Service	5			2	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-05855	Connecting Covered Walkway	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07255	Ambulance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07321	Radiology Department Expansion	OSHPD 1-In Service	5			4	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07605	Oxygen Tank Yard	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07610	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07611	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07612	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	13333	Henry Mayo Newhall Hospital	Valencia	BLD-07757	Pump House	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01977	North Wing	OSHPD 1-In Service	1		17.87	2	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01978	South Wing	OSHPD 1-In Service	2	3.08	1.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01979	D & T Tower	OSHPD 1-In Service	2	3.83	0.57	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01980	Patient Tower	OSHPD 1-In Service	3			2	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01981	Kitchen Addition	OSHPD 1-In Service	1		6.09	2	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01982	Emergency Addition	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-01983	Linear Accelerator Addition	OSHPD 1-In Service	4s			2	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03505	Chalet Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03506	New Service Yard (Medical Gas Storage)	OSHPD 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-03507	Acute Care Services Replacement Building	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-06293	2nd Floor Pedestrian Walkway	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11722	Hollywood Presbyterian Medical Center	Los Angeles	BLD-06723	Switchgear Building	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02000	East Tower (3 story)	OSHPD 1-In Service	3			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02001	West Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02002	La Vina Building	OSHPD 1-In Service	3			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02003	Della Martin Center - Psychiatric B	OSHPD 5-Acute Psych Only	N/A			N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02004	Energy Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02005	Chiller Building	OSHPD 1-In Service	4			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02008	Cooling Towers	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02010	Valentine Building - Structurally connected to BLD-02014	OSHPD 1-Not an Independent Building	N/A	8.24		N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02011	Wingate / Hahn Building	OSHPD 1-In Service	2	3.94	0.42	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02012	Hahn Building - Structurally connected to BLD-02011	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02013	Service Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	7.15		N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02014	1938 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		24.4	N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02015	1921 Building	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		14.36	N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02017	North Parking Structure - Structurally connected to BLD-02000	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-02018	Electrical Switchgear Vault	OSHDP 1-In Service	4			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-03301	East Tower (7 story)	OSHDP 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-03302	East Tower Main Lobby	OSHDP 1-In Service	3			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-03303	New Boiler Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05497	ED Addition	OSHDP 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05498	Ambulance Canopy	OSHDP 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05796	West Tower Tunnel	OSHDP 1-In Service	5			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05955	South Campus Utility Tunnel	OSHDP 1-Tunnels	N/A			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05956	East Tower Utility Tunnel	OSHDP 1-Tunnels	N/A			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05957	ED Utility Tunnel	OSHDP 1-Tunnels	N/A			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05970	East Tower Pedestrian Tunnel	OSHDP 1-Tunnels	4			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-05990	Bulk Oxygen Storage	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	11733	Huntington Hospital	Pasadena	BLD-06058	Bulk Oxygen	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02519	Central Plant	OSHDP 1-In Service	5			4	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02520	Patient Tower	OSHDP 1-In Service	3			2	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02521	Clinic Wing	OSHDP 1-In Service	3			3	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-02522	MRI Building	OSHDP 1-In Service	3			3	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-03509	Clinic - MRI Connector	OSHDP 1-In Service	3			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-06883	ED Expansion	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-06905	Canopy #1	OSHDP 1-In Service	5			4	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-07295	MRI Addition	OSHDP 1-In Service	5s			4	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-07465	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-07466	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	17207	Kaiser Foundation Hospital - Baldwin Park	Baldwin Park	BLD-07467	WT-02 Water Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05180	Main Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05181	Central Plant	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05914	Canopy 01	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05915	Canopy 02	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-05916	Main Building - Tower	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06157	Central Plant Expansion	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06158	Main Building - Tower Addition	OSHDP 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06159	ED Drop-Off Canopy	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06323	ED Walk-in Canopy	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-06324	ED Entry Vestibule	OSHDP 1-In Service	5			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-07442	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-07443	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-07594	Booster Pump Building	OSHDP 1-Not a Building Structure	N/A			4	
19 - Los Angeles	17919	Kaiser Foundation Hospital - Downey	Downey	BLD-07595	WT-02 Water Tank	OSHDP 1-Tanks	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-01707	Centrex Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-02792	LAMC Hospital - Phase I	OSHPD 1-In Service	5			4	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-02793	Central Utility Plant - 1550 Edgemont	OSHPD 1-In Service	5			4	
19 - Los Angeles	11760	Kaiser Foundation Hospital - Los Angeles	Los Angeles	BLD-07038	Pedestrian and Utility Passageway	OSHPD 1-Tunnels	N/A			4	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-01698	East MOB	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-02794	New Hospital Replacement Project	OSHPD 1-In Service	5			4	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-02795	New Central Utility Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-05676	South Specialty Medical Office Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-06967	Main Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11759	Kaiser Foundation Hospital - Panorama City	Panorama City	BLD-06968	ER Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02037	South Hospital - Ancillary Wing	OSHPD 1-In Service	3			3	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02038	South Hospital - Patient Tower	OSHPD 1-In Service	3			3	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02039	South Hospital - Elevator Tower	OSHPD 1-In Service	3			3	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-02040	South Hospital - Central Plant	OSHPD 1-In Service	4			3	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03086	Boiler House - Structurally connected to BLD-02040	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03276	Vermont Pavilion	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-03277	Annex Connecting Corridor (North)	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-05247	Annex Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-05248	Replacement Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06482	Emergency Department Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06483	Emergency Department Ambulance Canopy	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06687	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06688	Electrical Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06689	Emergency Generator Enclosure #1	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06690	Emergency Generator Enclosure #2	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-06971	South Hospital - Central Plant Expansion	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07036	Replacement Hospital Corridor #1	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07037	Replacement Hospital Corridor #2	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07051	Annex Connecting Corridor (Center)	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07052	Annex Connecting Corridor (South)	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07053	Vermont Pavilion Corridor #1	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07054	Vermont Pavilion Corridor #2	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07055	Vermont Pavilion Corridor #3	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07056	Stair #3	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07059	Water Tank Service Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07060	South Hospital - Generator Cage	OSHPD 1-In Service	4			2	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07062	South Hospital - Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A			2	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07063	South Hospital - Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07159	Canopy #1	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07160	Canopy #2	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07161	Pet Scan Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07446	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07447	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07448	WWT-02 Wastewater Tank	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07449	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	11758	Kaiser Foundation Hospital - South Bay	Harbor City	BLD-07450	WT-02 Water Tank	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00327	Medical Center Tower	OSHPD 1-In Service	3			3	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00328	Plant Services Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00329	Nursing Tower II	OSHPD 1-In Service	3			2	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-00330	MRI Building	OSHPD 1-In Service	3			3	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05847	Chiller / Generator Support Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05879	Service MSB Yard - Normal Power	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05984	Emergency Department Expansion	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-05985	ED Patient Drop-off Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06129	Ambulance/Tech Dock Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06221	Canopy No. 2	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06222	Canopy No. 1	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-06452	Tank Farm	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-07005	Decontamination Showers	OSHPD 1-In Service	5			4	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-07430	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-07431	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-07432	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	15666	Kaiser Foundation Hospital - Woodland Hills	Woodland Hills	BLD-07433	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00941	Center Tower	OSHPD 1-In Service	2		0.72	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00942	North Tower	OSHPD 1-In Service	3			2	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00943	South Tower	OSHPD 1-In Service	3			3	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-00944	Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-03275	West Wing Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-03539	Generator Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06843	24 Hour Outpatient Pharmacy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06844	Covered Walkway #1	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06845	West Wing Tower Bridge	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06946	Covered Walkway #2	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06947	Covered Walkway #3	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06948	Covered Walkway #4	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-06949	Covered Walkway #5	OSHPD 1-In Service	5			4	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07001	Canopy	OSHPD 1-Proposed	5s			4s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07267	MRI 2	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07646	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07647	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07648	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07649	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	12875	Kaiser Foundation Hospital-West LA	Los Angeles	BLD-07650	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-03163	Main Hospital	OSHPD 1-In Service	4			3	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-06993	Acute Care Tower	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07176	Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07177	Entry Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07231	Infill Building	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07364	Entry Canopy	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07396	Wastewater Tank WWT-01	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07397	Wastewater Tank WWT-02	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	16483	Keck Hospital of USC	Los Angeles	BLD-07398	Water Tank WT-01	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00727	Original Building - Building I	OSHPD 1-In Service	2	12.89	0.89	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00728	Southeast Addition - Building III	OSHPD 1-In Service	3			2	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-00729	Power Service Station - Building IV	OSHPD 1-In Service	4			2	
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-03027	Addition - Building II	OSHPD 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-03066	Storage / Maintenance - Building V	OSHPD 1-In Service	2		0.57	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11414	Kindred Hospital - Los Angeles	Los Angeles	BLD-05829	Entrance Canopy	OSHPD 1-In Service	2		0.7	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-01722	Building I (Acute Care Facility)	OSHPD 1-In Service	2	3.34	6.42	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-05840	Building II (Acute Care Support Services)	OSHPD 1-In Service	2		0.89	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11776	Kindred Hospital - San Gabriel Valley	West Covina	BLD-05841	Building III (Acute Care Facility)	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03708	Main Hospital	OSHPD 1-In Service	2		0.66	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03709	Main Hospital Addition	OSHPD 1-In Service	2		0.66	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-03710	ICU Addition	OSHPD 1-In Service	2		0.66	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11704	Kindred Hospital Baldwin Park	Baldwin Park	BLD-06115	Emergency Generator #2 Yard	OSHPD 1-Under Construction	N/A			4s	
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-00909	Hospital	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-00910	Emergency Room	OSHPD 1-In Service	4			4D-L1	
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-06652	Liquid Oxygen Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12787	Kindred Hospital Paramount	Paramount	BLD-06653	Emergency Generator	OSHPD 1-Under Construction	N/A			4s	
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00658	Original Building	OSHPD 1-In Service	2		0.12	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00659	South Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00660	North Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-00661	Laboratory Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-06614	Oxygen Tank Enclosure	OSHPD 1-Equipment Yard	N/A			2	
19 - Los Angeles	11547	Kindred Hospital South Bay	Gardena	BLD-06615	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A			2	
19 - Los Angeles	13225	L.A. Downtown Medical Center	Los Angeles	BLD-00055	Hospital and Medical Office	OSHPD 1-In Service	2	0.75	0.55	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	13225	L.A. Downtown Medical Center	Los Angeles	BLD-00056	Boiler & Emergency Generator	OSHPD 1-In Service	2	0.36		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	Los Angeles	BLD-03826	Main Hospital - West	OSHPD 1-In Service	2	0.53		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13225	L.A. Downtown Medical Center	Los Angeles	BLD-06178	Oxygen Storage Yard	OSHPD 1-Equipment Yard	N/A			3	
19 - Los Angeles	13225	L.A. Downtown Medical Center	Los Angeles	BLD-07618	Pumps & Main Electrical Service	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01759	Main Hospital Building - Patient Tower	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01760	Main Hospital Building - North Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01761	Main Hospital Building - South Wing	OSHPD 1-In Service	2		18.91	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01762	Main Hospital Building - Cafeteria	OSHPD 1-In Service	4			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01763	Main Hospital Building - FCLC	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01764	PCDC Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01765	Central Plant Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01766	Central Plant West Expansion	OSHPD 1-In Service	4			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-01767	Communications Building 2 East	OSHPD 1-In Service	4			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05316	Surgery / Emergency	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05317	Emergency Generator Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05318	Tunnel	OSHPD 1-Tunnels	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05884	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-05885	Cooling Tower	OSHPD 1-Not a Building Structure	N/A			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06025	Surgery / Emergency Lower Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06026	Surgery / Emergency Upper Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06029	Surgery / Emergency Elevator Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06498	12KV Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06876	Interim Helipad	OSHPD 1-Proposed	5s			4s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06950	Inpatient Tower	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-06954	Central Utility Plant	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07072	Temporary Loading Dock Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07164	Chiller Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07217	12kv General Access Power (GAP) Switchgear Building	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07519	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07520	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07521	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
19 - Los Angeles	11809	LAC/Harbor-UCLA Medical Center	Torrance	BLD-07785	Utility Bridge	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00337	Main Hospital Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00338	Central Plant	OSHPD 1-In Service	4			3	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-00339	Cooling Tower	OSHPD 1-In Service	4s			3	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-03620	Emergency Services Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-03621	Tuberculosis Isolation Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-05912	Bulk Oxygen Tanks	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06033	Canopy 05B	OSHPD 1-In Service	5			4	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06034	Canopy 04B	OSHPD 1-In Service	5			4	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06035	Canopy 04C	OSHPD 1-In Service	5			4	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06168	Emergency Generator	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06684	Emergency Generator Enclosure #1	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06685	Emergency Generator Enclosure #2	OSHPD 1-Under Construction	5s			5s	
19 - Los Angeles	15801	LAC/Olive View-UCLA Medical Center	Sylmar	BLD-06686	Emergency Generator Enclosure #3	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02502	Bldg 100 Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02503	Bldg 101/102 Main Hosp Expansion	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02504	Outpatient Entrance Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02506	JPI Bldg South Wing	OSHPD 1-In Service	3			5	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02507	JPI Bldg North Wing	OSHPD 1-In Service	3			5	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02508	Central Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02509	Fire Pump Building	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02511	Safety Police Building	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02516	JPI Bldg West Wing	OSHPD 1-In Service	3			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02924	JPI Expansion	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-02925	JPI Drop-off Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-05943	JPI Tunnel	OSHPD 1-Tunnels	N/A			5	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06145	NPC-5 Domestic Water Storage Tank (WT-01)	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06146	NPC-5 Sewer Storage Tank (WWT-01)	OSHPD 1-Tanks	N/A			5	
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06147	Ambulance Drop Off Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11976	LAC/Rancho Los Amigos National Rehabilitation Center	Downey	BLD-06643	JPI Bldg Loading Dock	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-00654	Original Building & Additions	OSHPD 1-In Service	2	1.19	1.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-00655	Dietary Addition	OSHPD 1-In Service	2	0.42		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-03779	1st and 2nd Story Addition	OSHPD 1-In Service	2		0.78	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11545	Los Angeles Community Hospital	Los Angeles	BLD-06645	Oxygen Farm	OSHPD 1-Proposed	N/A			4s	
19 - Los Angeles	11810	Los Angeles General Medical Center	Los Angeles	BLD-02749	New Central Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
19 - Los Angeles	11810	Los Angeles General Medical Center	Los Angeles	BLD-02750	New Diagnostic and Treatment	OSHPD 1-In Service	5			4	
19 - Los Angeles	11810	Los Angeles General Medical Center	Los Angeles	BLD-02751	Inpatient Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02047	Medical Records & Laundry (Hospital Service Building (HSB))	OSHPD 1-In Service	5			2	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02048	Central Plant Phase I	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02049	Central Plant Phase II	OSHPD 1-In Service	4			2	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02052	Pediatric Acute Care (Main Lobby and Admitting (MLA))	OSHPD 1-In Service	3			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02053	Trauma Center (Hospital (IPT))	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-02054	Hawkins Building (Augustus F Hawkins Building)	OSHPD 1-In Service	4			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05261	Central Plant 3	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05262	Central Plant 4	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05263	Pedestrian Tunnel	OSHPD 1-Tunnels	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05264	Ancillary Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05412	Central Plant Phase 1 Tunnel	OSHPD 1-Tunnels	N/A			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05413	Hawkins Building Tunnel	OSHPD 1-Tunnels	N/A			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05416	Trauma Center Connecting Tunnel	OSHPD 1-In Service	5			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05821	Bulk Medical Gas Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12259	Martin Luther King, Jr. Community Hospital	Los Angeles	BLD-05859	Main Drop Off Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11843	Memorial Hospital of Gardena	Gardena	BLD-01778	Hospital	OSHPD 1-In Service	2		0.66	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01789	2A-2C- Central Plant & Additions	OSHPD 1-In Service	2	0.31		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01791	1E - Center for Health Education - Structurally connected to BLD-01789	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01792	03 - Memorial West - Nursing Unit	OSHPD 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01793	4A 4B- Memorial West - Rehab Unit	OSHPD 1-In Service	2	0.13		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01794	1B - Old Pathology - Structurally connected to BLD-03123	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01795	5 - X-Ray Addition	OSHPD 1-In Service	2	0.17		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01796	6A-6C - Surgery & Addition	OSHDP 1-In Service	3			2	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01797	1G -Doctor's Dining & Administration - Structurally connected to BLD-01789	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01798	1C - Original Coffee Shop - Structurally connected to BLD-01789	OSHDP 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01799	7A-7B - Outpatient Surgery	OSHDP 1-In Service	3			2	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-01800	8 - Cancer Prevention Center	OSHDP 1-In Service	4			2	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-02637	10 - Emergency Power Area	OSHDP 1-In Service	3			4	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03123	1A -1K Main Tower & Additions	OSHDP 1-In Service	2	9.81	1.12	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-03524	9 - ER Addition & Remodel	OSHDP 1-In Service	5			4	
19 - Los Angeles	11846	Memorialcare Long Beach Medical Center	Long Beach	BLD-07096	ER Addition Canopy	OSHDP 1-In Service	5s			4s	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03899	101- Miller's Children's Hospital	OSHDP 1-In Service	2	0.53		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03900	102- Miller's Children's Hospital Entry	OSHDP 1-In Service	5			2	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03901	103- Miller Children's Clerical Addition	OSHDP 1-In Service	3			4D-L1	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03905	Central Plant	OSHDP 1-In Service	5			4	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-03906	4 Story Addition	OSHDP 1-In Service	5			4	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-05883	Oxygen Farm	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-07082	Central Plant Pump Room	OSHDP 1-In Service	5			4	
19 - Los Angeles	17572	Memorialcare Miller Children's & Women's Hospital Long Beach	Long Beach	BLD-07768	Utility Tunnel	OSHDP 1-Tunnels	N/A			2s	
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00352	Building A - Tower	OSHDP 1-In Service	2		1.04	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHDP

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00353	Building B - Ancillary Building	OSHPD 1-In Service	2	0.87	0.73	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-00354	Building C - Emergency Department B	OSHPD 1-In Service	2	0.87	0.87	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-03891	Building D - South Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05536	Building E - Psychiatric Unit	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05537	Building F - Psychiatric Administration	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05538	Building G - Lobby Clinical Lab	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11847	Mission Community Hospital	Panorama City	BLD-05539	Building H - Canopy	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11874	Monrovia Memorial Hospital	Monrovia	BLD-00377	Main Building	OSHPD 1-In Service	2	2.24		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12878	Monterey Park Hospital	Monterey Park	BLD-00946	Original Building	OSHPD 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12878	Monterey Park Hospital	Monterey Park	BLD-00947	Radiology Basement Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00388	Farr Tower	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00389	D&T Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00390	Support Services Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00391	IFL Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00392	Therapy Pool Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00393	Clinical Laboratory Bldg Expansion	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00394	F Tower - Main Tower	OSHPD 1-In Service	2		0.98	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00395	G Tower	OSHPD 1-In Service	2	0.58		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-00396	Cancer Center	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03092	F Tower - Elevator Tower - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A	5.79		N/A	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03094	Linear Accelerator	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03095	Emergency Room Addition	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03096	MRI Addition - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03097	Outpatient Registration Building - Structurally connected to BLD-00389	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03135	Clinical Laboratory Building (Original) - Structurally connected to BLD-00394	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03136	Quiet/Dining	OSHPD 1-In Service	3			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03487	Service Elevator Tower	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-03645	Electrical Equipment Room	OSHPD 1-In Service	4			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-05464	Clinical Laboratory Building (D&T Addition)	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-06078	Gift Shop	OSHPD 1-In Service	4			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-06079	Admitting	OSHPD 1-In Service	4			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-07027	IFL Bridge	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11906	Northridge Hospital Medical Center	Northridge	BLD-07028	Addition #1	OSHPD 1-In Service	2s			2s	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00397	Original Building	OSHPD 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00398	Service Enclosure - East Side	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00399	Administration Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-00400	ICU Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02690	Service Enclosure - West Side	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02691	Walk In Freezer	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02692	Boiler Room	OSHPD 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-02693	Engineering Building	OSHPD 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03759	1956 Storage Building	OSHPD 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03760	1983 Storage Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11910	Norwalk Community Hospital	Norwalk	BLD-03800	Original Building - South Wing - Structurally connected to BLD-00397	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00368	North Wing	OSHPD 1-In Service	4			2	
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00369	East Wing & Additions	OSHPD 1-In Service	2	2.67	1.04	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-00371	Pavilion / Addition	OSHPD 1-In Service	2		0.76	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-06983	West Wing	OSHPD 5-Under Construction	N/A			N/A	
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-06984	Bridge	OSHPD 5-Under Construction	N/A			N/A	
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-06985	Porte Cochere	OSHPD 5-Under Construction	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-06986	Generator Enclosure	OSHPD 5-Under Construction	N/A			N/A	
19 - Los Angeles	11863	Olympia Medical Center	Los Angeles	BLD-07048	Utility Enclosure	OSHPD 5-Under Construction	N/A			N/A	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00017	Building 1	OSHPD 1-In Service	1		18.94	2	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00018	Building 2	OSHPD 1-In Service	1		35.28	2	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-00019	Building 3	OSHPD 1-In Service	1		18.94	2	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-06541	Cafeteria	OSHPD 1-In Service	4D		0.46	2	
19 - Los Angeles	12042	Pacifica Hospital of the Valley	Sun Valley	BLD-06542	Central Plant	OSHPD 1-In Service	4D		0.46	2	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-05182	Main Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-06852	Employee Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-07329	West Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-07330	East Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-07331	Main Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	18141	Palmdale Regional Medical Center	Palmdale	BLD-07336	Outpatient Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02203	Original Nursing Tower	OSHPD 1-In Service	2		0.32	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02204	Original Surgery and Lab Building	OSHPD 1-In Service	2	0.61		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02206	Pathology Addition - Structurally connected to BLD-02203	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02207	Scanner Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02208	ER/Surgery Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02209	ICU/CCU	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02210	Respiration Therapy Addition - Structurally connected to BLD-02204	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02211	Cath Lab	OSHPD 1-In Service	4			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02212	36 Bed Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02213	Building A, Mech. Equipment Bldg.	OSHPD 1-In Service	5			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02214	Building B	OSHPD 1-In Service	5			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02215	Building C	OSHPD 1-In Service	5			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02216	Radiology Addition	OSHPD 1-In Service	5			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-02217	ER Addition	OSHPD 1-In Service	5			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-03221	Generator #2 Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-06135	Original Mechanical Area	OSHPD 1-In Service	4D			2	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-06325	ICU / ER Connection Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12235	PIH Health Downey Hospital	Downey	BLD-06735	New Entrance Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01993	Main Hospital	OSHPD 1-In Service	4			2	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01994	ICU / CCU Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01995	Mechanical Plant	OSHPD 1-In Service	4s			2	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01996	MRI Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01997	1927 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		15.62	N/A	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01998	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		10.36	N/A	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-01999	Linear Accelerator Addition - Structurally connected to BLD-01998	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-03322	Radiation Oncology Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-06749	Witmer Street Expansion Loading Dock	OSHPD 1-Proposed	5s			4s	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-06750	Bridge Connecting BLD-01993 and BLD-01995	OSHPD 1-Proposed	5s			4s	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-06917	Tunnel Connecting BLD-01993 to BLD-06918	OSHPD 1-In Service	4			2	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-06918	1953 Bldg. (Low-Height Portion)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-07809	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-07810	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11731	PIH Health Good Samaritan Hospital	Los Angeles	BLD-07811	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-01156	Original Building Patient Tower	OSHPD 1-In Service	2	4.5	1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-01158	Long Term Care	OSHPD 1-In Service	2	0.43		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-01160	Power Plant	OSHPD 1-In Service	4s			2	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-01162	1992 Pavilion	OSHPD 1-In Service	3			2	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03151	Health Center (North Building)	OSHPD 1-In Service	3			2	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03152	Health Center (East Building)	OSHPD 1-In Service	3			2	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03272	ED Shannon Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03273	Plaza Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03666	1968 Generator Building	OSHPD 1-In Service	2	0.31		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-03715	1992 Pavilion Bridge	OSHPD 1-In Service	3			2	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-05468	Central Plant Expansion	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-06460	Link Corridor	OSHPD 1-In Service	5			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-06465	Electrical/Mechanical/Compact or Segment	OSHPD 1-In Service	5			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-06466	Communication Room & Utility Tunnel Segment	OSHPD 1-In Service	5			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-06467	Cooling Tower Enclosure	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11968	PIH Health Whittier Hospital	Whittier	BLD-06473	Pump Room	OSHPD 1-In Service	5			4	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00411	1972 Building - ICU/Emergency	OSHPD 1-In Service	2	9.79	1.05	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00412	D&T Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00413	Women's Center	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00414	1913 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		14.72	N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00415	1928 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		14.04	N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00416	1953 Building	OSHPD 1-In Service	2		1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00417	1961 Building	OSHPD 1-In Service	2	0.56		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00418	1963 Building - Cafeteria	OSHPD 1-In Service	2		0.54	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-00419	1963 Building - Lab/Peds - Structurally connected to BLD-00411	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-02838	Building 01A	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-02839	Building 01B Canopy	OSHPD 1-In Service	3s			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03468	Pitzer Bldg Admin/Marketing/Acct	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03850	Boiler Building	OSHPD 1-In Service	2		0.42	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-03877	1961 Dining Building	OSHPD 1-In Service	2		1.11	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05176	1958 Lobby Addition	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		11.33	N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05202	1958 Building (Emergency Wing)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		25.67	N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05669	2013 Vestibule	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05670	2013 Low Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	11966	Pomona Valley Hospital Medical Center	Pomona	BLD-05671	2013 High Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00170	Patient Tower	OSHPD 1-In Service	1		4.54	2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00171	Ancillary Wing	OSHPD 1-In Service	4D		2.78	2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00172	Service Building	OSHPD 1-In Service	5			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00173	Cardiology Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00174	Admitting/Emergency	OSHPD 1-In Service	3			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00175	Women's Pavilion	OSHPD 1-In Service	3			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-00176	Mechanical Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-03423	Patient Wing	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-03424	Interim Canopy	OSHDP 1-In Service	5			4	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-06372	Hospital Main Lobby Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-06398	Emergency Cat Lab	OSHDP 1-In Service	4s			2	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-06691	D&T Expansion	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	13085	Providence Cedars-Sinai Tarzana Medical Center	Tarzana	BLD-06692	D&T Canopy	OSHDP 1-Under Construction	5s			5s	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01984	Main Building	OSHDP 1-In Service	3s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01985	ICU/CCU Building	OSHDP 1-In Service	4s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01986	Cardiac Heart Center	OSHDP 1-In Service	3s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01987	Central Plant Building	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01988	Utility Building	OSHDP 1-In Service	4s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01989	Chapel Building	OSHDP 1-In Service	3s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-01991	New Equipment Shelter	OSHDP 1-In Service	3s			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-02714	Old Utility Tunnel	OSHDP 1-Tunnels	N/A			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-02715	New Utility Tunnel	OSHDP 1-Tunnels	N/A			3	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03628	South Addition	OSHDP 1-In Service	5			4	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03636	New Central Plant	OSHDP 1-In Service	5			4	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03637	Sub-Acute Building	OSHDP 2-Skilled Nursing Only	N/A			N/A	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-03638	Control Room	OSHDP 1-In Service	5			4	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05337	Generator Yard	OSHDP 1-Equipment Yard	N/A			4	
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05338	Transformer Yard	OSHDP 1-Equipment Yard	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11726	Providence Holy Cross Medical Center	Mission Hills	BLD-05339	Cooling Tower	OSHDP 1-Not a Building Structure	N/A			4s	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01215	Central Wing North	OSHDP 1-In Service	2		0.54	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01216	West Wing & Entrance Canopy	OSHDP 1-In Service	2	7.8	1.12	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01217	East Wing	OSHDP 1-In Service	3			3	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01218	Laboratory Addition	OSHDP 1-In Service	4			3	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01219	Conference Center	OSHDP 1-In Service	5			3	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-01220	ED Entry Canopy	OSHDP 1-Under Construction	5s			4s	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03147	Central Wing Tower	OSHDP 1-In Service	2	9.03	0.62	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03148	Central Wing South	OSHDP 1-In Service	2	0.47		3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03149	Central Wing Stair Tower	OSHDP 1-In Service	2	0.44		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-03150	West Wing Elevator Tower	OSHDP 1-In Service	2	0.12		3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-05177	Drop-Off Canopy	OSHDP 1-In Service	2		0.7	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-06496	Emergency Generator Enclosure	OSHDP 1-Under Construction	5s			4s	
19 - Los Angeles	12023	Providence Little Company Of Mary Medical Center San Pedro	San Pedro	BLD-06841	West Wing Stair Tower	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01727	Original Hospital	OSHPD 1-In Service	2		0.99	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01731	11 Technology Center & Lab	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01733	Emergency Generator	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01734	Liquid Oxygen Storage Tanks and Manifolds	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01735	West Tower Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01737	Radiation Therapy Building Walkway	OSHPD 1-In Service	5s			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01738	Dining Room Addition	OSHPD 1-In Service	4			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01739	Generator Building	OSHPD 1-In Service	5			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-01741	ER/Cardiac Wing	OSHPD 1-In Service	2		1.02	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-02625	Administrative Wing	OSHPD 1-In Service	2		0.54	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03159	South Tower Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03160	Earl Street Loading Dock Improvement	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03162	South Tower Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03340	Hazardous Material Storage	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03537	11 Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03716	Dietary Loading Dock and Storage	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03717	Entrance Canopy	OSHPD 1-In Service	3s			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-03718	Radiation Therapy Building	OSHPD 1-In Service	4			3	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06195	Med Gas Storage	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06574	Mobile CT Canopy	OSHPD 1-Proposed	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06929	North Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06930	East Canopy - Low	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06931	East Canopy - High	OSHPD 1-In Service	5			4	
19 - Los Angeles	11787	Providence Little Company of Mary Medical Center Torrance	Torrance	BLD-06932	South Canopy	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01185	Robertson Tower	OSHPD 1-In Service	3			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01186	Robertson Lobby	OSHPD 1-In Service	3			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01187	Robertson Canopy	OSHPD 1-In Service	3			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01188	East Building	OSHPD 1-In Service	2		1.2	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01190	South Building	OSHPD 1-In Service	2	0.7		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01191	ER/CCU Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01192	Laundry/Central Plant Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01193	Central Plant Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01194	P & E Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01195	MRI Building	OSHPD 1-In Service	4			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-01197	Parking Structure 1A	OSHPD 1-In Service	4			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-03515	Northeast Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05355	Connector Corridor - 1	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05356	Connector Corridor - 2	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05357	Connector Corridor - 3	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05358	Connector Corridor - 4	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05359	Connector Corridor - 5	OSHPD 1-In Service	5s			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05360	Northeast Building Tunnel	OSHPD 1-Tunnels	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05361	Central Plant Tunnel	OSHPD 1-Tunnels	N/A			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05362	East Building Tunnel	OSHPD 1-Tunnels	N/A			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05363	Cooling Towers	OSHPD 1-Not a Building Structure	N/A			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-05549	South Building Tunnel	OSHPD 1-Tunnels	N/A			2	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-06412	Emergency Department	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-06575	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-07094	Urgent Care	OSHPD 3 - Local-Proposed	N/A			N/A	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-07296	Water Tank Pump House	OSHPD 1-In Service	5			4	
19 - Los Angeles	12008	Providence Saint Joseph Medical Center	Burbank	BLD-07657	Patricia and Roy Disney Family Cancer Center	OSHPD 3 - Local-Proposed	N/A			N/A	
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	Los Angeles	BLD-02895	Ronald Reagan UCLA Medical Center	OSHPD 1-In Service	5			4	
19 - Los Angeles	12127	Ronald Reagan UCLA Medical Center	Los Angeles	BLD-02926	Emergency Services Building	OSHPD 1-In Service	5s			1	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-03700	North Pavilion Inpatient Tower	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-03703	New Central Plant	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-03704	Keck Center Diagnostic & Treatment	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-05271	Entry Canopy	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-05987	Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12006	Saint John's Health Center	Santa Monica	BLD-05988	Flue Building	OSHPD 1-Not a Building Structure	N/A			4	
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00166	Main Hospital	OSHPD 1-In Service	2	0.05		3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00167	CT Scan Addition	OSHPD 1-In Service	4			3	
19 - Los Angeles	13084	San Dimas Community Hospital	San Dimas	BLD-00168	Boiler Room Addition	OSHPD 1-In Service	5			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00662	Pavilion Building	OSHPD 1-In Service	2	2.89	2.29	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00663	Cooling Tower (Chiller Room)	OSHPD 1-In Service	4			2	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00664	Radiology and Surgery Addition	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00665	Surgery Addition - Structurally connected to BLD-00664	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00666	Emergency Addition	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00667	CCU Building	OSHPD 1-In Service	3s			2	
19 - Los Angeles	11548	San Gabriel Valley Medical Center	San Gabriel	BLD-00668	Patient Tower	OSHPD 1-In Service	3s			2	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01225	Merle Norman Pavilion	OSHPD 1-In Service	3			2	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01230	New Central Plant	OSHPD 1-In Service	5			4	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-01231	New Southwest Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02774	New Central Wing	OSHPD 1-In Service	5			4	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02775	New North Wing	OSHPD 1-In Service	5			4	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-02776	New Orthopedic Hospital	OSHPD 1-In Service	5			4	
19 - Los Angeles	12033	Santa Monica - UCLA Medical Center And Orthopaedic Hospital	Santa Monica	BLD-06557	Loading Dock Annex Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01232	01 Orig Bldg Complex & 02 Addition	OSHPD 1-In Service	2	2.06	0.98	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01233	Addition Building Complex - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01234	Burn Center Building	OSHPD 1-In Service	3			2	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01235	1961 Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01236	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01237	Laboratory Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01238	ER Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01239	Surgery Addition - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	12047	Sherman Oaks Hospital	Sherman Oaks	BLD-01240	Chiller Room - Structurally connected to BLD-01232	OSHPD 1-Not an Independent Building	N/A			N/A	
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00355	Tower	OSHPD 1-In Service	1		10.52	2	
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00356	Pavilion	OSHPD 1-In Service	2	10.7	1.19	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-00357	Outpatient Building & Additions	OSHPD 1-In Service	2		0.91	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-06640	Ambulance Canopy	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11848	Southern California Hospital At Culver City	Culver City	BLD-06641	ED Drop-off Canopy	OSHPD 1-Under Construction	5s			4s	
19 - Los Angeles	11718	Southern California Hospital at Hollywood	Hollywood	BLD-01976	Original Building	OSHPD 1-In Service	2	20.55	1.14	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-01177	Family Life Center	OSHPD 1-In Service	5			2	
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-01178	Health Services Pavilion	OSHPD 1-In Service	3			2	
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-01179	Central Plant	OSHPD 1-In Service	4			2	
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-01180	New Hospital Tower	OSHPD 1-In Service	5			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-05791	Psychiatric Care Unit	OSHPD 5-Acute Psych / SNF only	N/A			N/A	
19 - Los Angeles	12004	St. Francis Medical Center	Lynwood	BLD-06904	Generator Yard	OSHPD 5-Under Construction	N/A			N/A	
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01205	Bauer Wing	OSHPD 1-In Service	2	4.86	1.16	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01206	MRI Building	OSHPD 1-In Service	4s			2	
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01207	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		3.22	N/A	
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01208	East Wing	OSHPD 1-In Service	2	0.69		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01209	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	3.68	8.36	N/A	
19 - Los Angeles	12012	St. Mary Medical Center	Long Beach	BLD-01210	Emergency / Generator Building	OSHPD 1-In Service	4s			2	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02218	Original Hospital Building	OSHPD 1-In Service	2	0.75		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02219	Original Central Plant	OSHPD 1-In Service	2			3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02220	East Wing	OSHPD 1-In Service	3			2	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02221	Lobby/Cath Lab Addition	OSHPD 1-In Service	3			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02222	Surgery Addition	OSHPD 1-In Service	5			2	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02223	Doctors' Dining/Medical Records	OSHPD 1-In Service	3			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02224	Admitting/Business	OSHPD 1-In Service	3			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02225	Linear Accelerator	OSHPD 1-In Service	5			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02226	Central Plant Addition	OSHPD 1-In Service	4			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02227	North Wing	OSHPD 1-In Service	3			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02228	Elevator Core (North Wing)	OSHPD 1-In Service	4			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02229	MRI Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02230	Ambulatory Care	OSHPD 1-In Service	3			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02231	Gallery	OSHPD 1-In Service	3			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02232	Central Plant Expansion - A	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02233	Central Plant Expansion - B	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02234	Central Plant-South Wing Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-02235	East Wing Addition	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-03478	New Hospital Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-03848	MRI Addition Corridor	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05421	Bulk Medical Gas System	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05668	Emergency Generator Building	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05705	Surgery Addition West	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-05733	Emergency Generators and Switchgear	OSHPD 1-Equipment Yard	N/A			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06132	Central Plant Elevator and Stair	OSHPD 1-In Service	5			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06133	Utility Tunnel	OSHPD 1-Tunnels	N/A			3	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06148	Central Plant Walkway Canopy	OSHPD 1-In Service	3			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06149	Lundquist North Wing Connector	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06150	Lundquist Tower Connector to Center Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06211	Lundquist Connector Exit Corridor	OSHPD 1-In Service	5			4	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-06295	Original Service Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07663	Pump House	OSHDP 1-Proposed	5s			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07664	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07665	WT-02 Water Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07666	WT-03 Water Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07667	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07668	WWT-02 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12249	Torrance Memorial Medical Center	Torrance	BLD-07795	WWT-03 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
19 - Los Angeles	12831	UCI Health-Lakewood	Lakewood	BLD-00924	Main Hospital	OSHDP 1-In Service	2	1.39	1.06	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12831	UCI Health-Lakewood	Lakewood	BLD-00925	Hospital Expansion	OSHDP 1-In Service	4			2	
19 - Los Angeles	12182	UCLA West Valley Medical Center	West Hills	BLD-02181	Main Building	OSHDP 1-In Service	2	0.49		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12182	UCLA West Valley Medical Center	West Hills	BLD-02182	Purchasing / Central Supply	OSHDP 1-In Service	4			2	
19 - Los Angeles	12182	UCLA West Valley Medical Center	West Hills	BLD-03178	ED / ICU	OSHDP 1-In Service	5			4	
19 - Los Angeles	12182	UCLA West Valley Medical Center	West Hills	BLD-03179	Central Plant	OSHDP 1-In Service	5			4	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00358	Main Hospital	OSHDP 1-In Service	2		0.81	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00359	East Wing	OSHDP 1-In Service	2		1.96	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00360	Utility Building / Central Plant	OSHDP 1-In Service	5			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00362	West Wing	OSHDP 1-In Service	2		0.64	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00363	Main-North End - Structurally connected to BLD-00358	OSHDP 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00364	Pavilion East & West	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A	1.81	3.47	N/A	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00365	Hoefflin Wing	OSHDP 1-In Service	4			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00366	Surgical Wing	OSHDP 1-In Service	3			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-00367	Patient Tower	OSHDP 1-In Service	5			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-03711	Electrical Equipment Building	OSHDP 1-In Service	4			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05461	North Tower	OSHDP 1-In Service	5s			4s	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05514	Tower Lobby	OSHDP 1-In Service	5s			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05634	Generator Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05635	Switchgear Building	OSHDP 1-In Service	5			4	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05636	Switchgear Shed	OSHDP 1-In Service	5			4	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-05848	Berger Tower Patient Canopy	OSHDP 1-In Service	5			2	
19 - Los Angeles	11858	USC Arcadia Hospital	Arcadia	BLD-07349	Electrical Room	OSHDP 1-In Service	4			2	
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	Los Angeles	BLD-00317	Cancer Research Institute (Ezralow Tower)	OSHDP 1-In Service	3			3	
19 - Los Angeles	15179	USC Kenneth Norris Jr. Cancer Hospital	Los Angeles	BLD-03689	Topping Tower	OSHDP 1-In Service	5			2	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01025	Main Building - North Tower	OSHDP 1-In Service	2	3.16	0.7	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01026	Main Building - South Tower	OSHDP 1-In Service	2	4.31	0.52	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01027	West Addition	OSHDP 1-In Service	4			3	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-01028	East Addition	OSHDP 1-In Service	3s			3	
19 - Los Angeles	12551	USC Verdugo Hills Hospital	Glendale	BLD-07073	Medical Office Building	OSHDP 3 - Local-Proposed	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02169	Base Building (Main Hospital)	OSHPD 1-In Service	2		1.13	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02170	Service Building	OSHPD 1-In Service	2		1.09	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02171	Administrative Expansion	OSHPD 1-In Service	4			4D-L1	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02172	Ancillary Inpatient East	OSHPD 1-In Service	4			2	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02174	Elevator Lobby East	OSHPD 1-In Service	4			4D-L1	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02175	Elevator Lobby West	OSHPD 1-In Service	4			4D-L1	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02638	Ancillary Inpatient West	OSHPD 1-In Service	4			2	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-02789	Inpatient Tower	OSHPD 1-In Service	5			4	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-03124	Administrative Expansion (North)	OSHPD 1-In Service	4			4D-L1	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-05197	South Tower	OSHPD 1-In Service	2		0.82	4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-07205	Stair Tower #1	OSHPD 1-In Service	5			4	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-07206	Stair Tower #2	OSHPD 1-In Service	5			4	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-07209	Low Roof Area	OSHPD 1-In Service	5			4	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-07210	Mechanical Building	OSHPD 1-In Service	5s			4s	
19 - Los Angeles	12140	Valley Presbyterian Hospital	Van Nuys	BLD-07356	Central Plant	OSHPD 1-Proposed	5s			5s	
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	La Mirada	BLD-01710	Building I	OSHPD 1-In Service	2	0.75		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	La Mirada	BLD-03469	Building II	OSHPD 1-In Service	4			2	
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	La Mirada	BLD-03470	Building III	OSHPD 1-In Service	2	3.34	0.66	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	La Mirada	BLD-06112	Soiled Linen Storage	OSHPD 1-In Service	4			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
19 - Los Angeles	11768	Vista Specialty Hospital of La Mirada	La Mirada	BLD-06113	Bio-Hazard Storage	OSHPD 1-In Service	4			4	
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-02176	Hospital Building / Additions	OSHPD 1-In Service	2		0.54	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-03430	Medical Office Building	OSHPD 1-Under Construction	1			1	
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-06612	Skilled Nursing	OSHPD 1R-Skilled Nursing Only	N/A			N/A	
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-06943	HVAC Tower and Enclosure	OSHPD 1-In Service	4			2	
19 - Los Angeles	12180	West Covina Medical Center	West Covina	BLD-07083	Psych Addition	OSHPD 5-Proposed	N/A			N/A	
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02196	Original Building	OSHPD 1-In Service	2		0.97	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02197	Addition 1	OSHPD 1-In Service	2		0.39	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02198	Addition 2	OSHPD 1-In Service	2		0.39	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02199	Addition 3	OSHPD 1-In Service	2		0.51	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02200	ER Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02201	OB Addition	OSHPD 1-In Service	3			2	
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-02202	Pediatrics Addition	OSHPD 1-In Service	4			2	
19 - Los Angeles	12201	Whittier Hospital Medical Center	Whittier	BLD-03422	ER Addition - West Portion	OSHPD 1-In Service	4s			2	
20 - Madera	10075	HealthBridge Central Valley Children's Center	Madera	BLD-06945	Children's Hospital	OSHPD 1-Proposed	5s			5s	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00436	Main & Mechanical Building	OSHPD 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00437	OB Wing Addition	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00438	Outpatient Building	OSHPD 1-In Service	5			2	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-00439	ICU/ER Addition	OSHPD 1-In Service	5			2	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06092	Utility Canopy 1	OSHPD 1-In Service	5			4	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06093	Utility Canopy 2	OSHPD 1-In Service	5			4	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06094	Central Utility Plant	OSHPD 1-In Service	5			4	
20 - Madera	10257	Madera Community Hospital	Madera	BLD-06322	CT Addition	OSHPD 1-In Service	3			2	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-02518	Hospital (G Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-02650	Central Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05429	Hospital (A Canopy)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05430	Hospital (B Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05431	Hospital (C Porte-Cochere)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05432	Hospital (D Canopy)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05433	Hospital (E Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05434	Hospital (F Canopy)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05435	Hospital (H Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05436	Hospital (I Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05437	Hospital (J Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05438	Hospital (K Wing)	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05439	West Expansion - Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05440	West Expansion	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-05441	Medical Waste Building	OSHPD 1-In Service	5			5	Earthquake Resilient
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-06697	On-Site Well	OSHPD 1-Equipment Yard	N/A			5	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-06698	Sewer Lift Station	OSHPD 1-Equipment Yard	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-06699	Waste Water Plant	OSHPD 1-Equipment Yard	N/A			5	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-07119	Giraffe Photovoltaic Array	OSHPD 1-Under Construction	N/A			4s	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-07120	Switchgear Yard	OSHPD 1-Under Construction	N/A			4s	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-07121	Microgrid	OSHPD 1-Under Construction	N/A			4s	
20 - Madera	17124	Valley Children's Hospital	Madera	BLD-07122	Fuel Cell Yard	OSHPD 1-Under Construction	N/A			4s	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00441	General Services Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00442	Hospital Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00443	Medical Office Building 1	OSHPD 1-In Service	2		0.85	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00444	Mechanical Equipment Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00445	Support Services Building	OSHPD 1-In Service	5s			2	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-00446	Generator Switchgear Building	OSHPD 1-In Service	5			2	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-03283	Doctor's Sleep Building	OSHPD 1-In Service	4			2	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-03598	Medical Records Building Addition - Structurally connected to BLD-00443	OSHPD 1-Not an Independent Building	N/A			N/A	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05615	Emergency Department	OSHPD 1-In Service	5s			4s	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05616	Oxygen Storage	OSHPD 1-In Service	5s			4s	
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-05617	Mechanical Building - CUP	OSHPD 1-In Service	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
21 - Marin	10268	Kaiser Foundation Hospital - San Rafael	San Rafael	BLD-06848	Electrical Yard	OSHPD 1-Equipment Yard	N/A			2	
21 - Marin	10261	Kentfield Hospital	Kentfield	BLD-00440	Hospital Building	OSHPD 1-In Service	2	0.36		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00447	01 - Original Building & Additions (Redwood Pavilion)	OSHPD 1-In Service	2	1.55	1.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00448	02 - Additions & Alterations	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00449	03 - Cobalt Bomb Wing	OSHPD 1-In Service	2	0.15		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00450	Laboratory Addition & Remodel Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A			N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00451	04 - Medical Health Center (Mental Health Center) (Cypress Pavilion)	OSHPD 1R-Acute Psych Only	N/A		2.47	N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00452	05 - Elevated Pedestrian Bridge	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		14.44	N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00453	06 - West Wing (Cedar Pavilion)	OSHPD 1-In Service	3			2	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00455	1A - Additions & Alterations - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A			N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-00456	04A - Medical Records - Structurally connected to BLD-00451	OSHPD 1-Not an Independent Building	N/A			N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-03054	1C - East Canopy - Structurally connected to BLD-00447	OSHPD 1-Not an Independent Building	N/A			N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-03056	Ambulance Entry Canopy	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-03526	05A - Elevator	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		4.91	N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-06250	Hospital Replacement Building (Oak Pavilion)	OSHDP 1-In Service	5			4	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-06251	Hospital Replacement Building - Loading Dock	OSHDP 1-In Service	5			4	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-06252	Oxygen Tank Enclosure	OSHDP 1-Equipment Yard	N/A			2	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07233	Behavioral Health Emergency Generator	OSHDP 5-Proposed	N/A			N/A	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07619	Med Gas Building	OSHDP 1-In Service	5s			4s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07630	WT-01 Water Tank	OSHDP 1-Tanks	N/A			5	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07631	WWT-01 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07632	FT-02 Fuel Tank	OSHDP 1-Tanks	N/A			5	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07640	MV Disc-MD2	OSHDP 1-Proposed	N/A			5s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07670	Dining Addition	OSHDP 1-Proposed	5s			5s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07671	Connecting Canopy	OSHDP 1-Proposed	5s			4s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07672	Lobby / Main Entrance	OSHDP 1-Proposed	5s			4s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07673	Drop Off Canopy	OSHDP 1-Proposed	5s			4s	
21 - Marin	10273	Marinhealth Medical Center	Greenbrae	BLD-07674	Gift Shop	OSHDP 1-Proposed	5s			4s	
21 - Marin	17672	Novato Community Hospital	Novato	BLD-00457	Hospital	OSHDP 1-In Service	5			4	
21 - Marin	17672	Novato Community Hospital	Novato	BLD-07325	New Generator Yard	OSHDP 1-Under Construction	N/A			4s	
21 - Marin	17672	Novato Community Hospital	Novato	BLD-07326	Mechanical Yard	OSHDP 1-Under Construction	N/A			4s	
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-00458	Hospital Building	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-03808	Skilled Nursing Wing	OSHDP 2-Skilled Nursing Only	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-07703	John C. Fremont Replacement Hospital	OSHPD 1-Proposed	5s			5s	
22 - Mariposa	10287	John C. Fremont Healthcare District	Mariposa	BLD-07704	Drop-Off Canopy	OSHPD 1-Proposed	5s			5s	
23 - Mendocino	18198	Adventist Health Howard Memorial	Willits	BLD-05319	Main Building	OSHPD 1-In Service	5			4	
23 - Mendocino	18198	Adventist Health Howard Memorial	Willits	BLD-05320	Mechanical Yard	OSHPD 1-Equipment Yard	N/A			4	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-00469	Main Hospital	OSHPD 1-In Service	2	0.16		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-00470	Central Plant	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-00471	Emergency Addition - West	OSHPD 1-In Service	4			2	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-00472	X-Ray File Storage	OSHPD 1-In Service	5			4	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-02787	Respiratory Neurophysiology Lab	OSHPD 1-In Service	4			2	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-02788	Emergency Generator Shelter	OSHPD 1-In Service	4			4	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-03473	Emergency Addition - East	OSHPD 1-In Service	4			2	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-06731	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A			4	
23 - Mendocino	10301	Adventist Health Mendocino Coast	Fort Bragg	BLD-06732	Medical Air System Shed	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00305	Main Building, North Wing	OSHPD 1-In Service	4			4D-L1	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00306	OB Addition	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-00307	Central Plant	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-02959	Main Building, Central Wing	OSHPD 1-In Service	4			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-02960	Main Building, Ancillary	OSHPD 1-In Service	4			3	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-05704	Emergency Department Building	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06369	Support Building	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06370	Electrical Room	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06877	OB Porte Cochere	OSHPD 1-In Service	5			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06878	Main Entry Canopy	OSHPD 1-In Service	4			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06879	Entry Canopy	OSHPD 1-In Service	4			4	
23 - Mendocino	14560	Adventist Health Ukiah Valley	Ukiah	BLD-06955	East Patient Wing Expansion	OSHPD 1-In Service	5			4	
24 - Merced	10309	Memorial Hospital Los Banos	Los Banos	BLD-00029	Main Hospital	OSHPD 1-In Service	2	1	1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	Los Banos	BLD-00030	Mechanical Building	OSHPD 1-In Service	2	1.21	1.19	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
24 - Merced	10309	Memorial Hospital Los Banos	Los Banos	BLD-07016	Mechanical Canopy	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-03870	Hospital	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-03871	Power Plant	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05610	Radioactive Waste and Pathology Holding	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05611	Equipment Charging	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-05612	ER Entrance Bridge	OSHPD 1-In Service	5			4	
24 - Merced	10315	Mercy Medical Center	Merced	BLD-07020	Entry Canopy	OSHPD 1-In Service	5			4	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06279	Hospital - Building 100	OSHPD 1-In Service	5			5	Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06288	Entrance Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06784	Warnerview Skilled Nursing Facility	OSHPD 2-Skilled Nursing Only	N/A			N/A	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06895	Patient Room Expansion	OSHPD 1-In Service	5			5	Earthquake Resilient
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06896	Skilled Nursing Pedestrian Walkway	OSHPD 2-Skilled Nursing Only	N/A			N/A	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06897	Skilled Nursing Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-06898	Skilled Nursing Entrance Canopy	OSHPD 2-Skilled Nursing Only	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-07585	WWT-01 Waster Water Tank	OSHDP 1-Tanks	N/A			5	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-07586	WT-01 Water Tank	OSHDP 1-Tanks	N/A			5	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-07587	FT-01 Fuel Tank	OSHDP 1-Tanks	N/A			5	
25 - Modoc	18231	Modoc Medical Center	Alturas	BLD-07588	FT-02 Fuel Tank	OSHDP 1-Tanks	N/A			5	
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01621	Main Hospital	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01622	Pump House Building	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01623	Heating and Storage Building	OSHDP 1-In Service	2		0.52	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01624	Generator Building	OSHDP 1-In Service	2		0.36	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01625	South Wing Addition	OSHDP 1-In Service	5s			2	
25 - Modoc	10321	Surprise Valley Community Hospital	Cedarville	BLD-01626	Walk-in Box	OSHDP 1-In Service	5s			4	
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-00267	Main Hospital	OSHDP 1-In Service	4			2	
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-03697	New Wing	OSHDP 1-In Service	5			4	
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-03698	New Wing Connecting Corridor - North	OSHDP 1-In Service	5			4	
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-05561	New Wing Connecting Corridor - South	OSHDP 1-In Service	5			4	
26 - Mono	14304	Mammoth Hospital	Mammoth Lakes	BLD-06859	North Wing	OSHDP 1-Under Construction	5s			5s	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01629	A Phase I - 1960 Wing	OSHDP 1-In Service	4D			2	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01630	B Phase II - 1968 Wing - Structurally connected to BLD-01629	OSHDP 1-Not an Independent Building	N/A			N/A	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01631	C 1978 Addition	OSHDP 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-01633	E 1998 Cancer Center Addition	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-03714	Parking Structure	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05554	G Utility Service Building	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05555	H Cardiac EP Lab	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05556	J South Pavilion	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-05557	K Forest Pavilion	OSHPD 1-In Service	5			4	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-07228	Electrical Bunker	OSHPD 1-In Service	5			2	
27 - Monterey	10330	Community Hospital of the Monterey Peninsula	Monterey	BLD-07300	Switchgear Yard	OSHPD 1-Equipment Yard	N/A			4	
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-01634	Main Hospital	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03265	New Porte Cochere	OSHPD 1-In Service	5			4	
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03266	New Hospital	OSHPD 1-In Service	5			4	
27 - Monterey	10338	George L. Mee Memorial Hospital	King City	BLD-03328	Bottle Building	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02542	Extended Care Services (Bldg 100)	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02544	Food Service / Central Plant (Bldg 580) 580A	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-02545	Acute Care (Building 500)	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03827	Material Management (Bldg 600)	OSHPD 1-In Service	4			2	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03828	Inpatient Mental Health (Bldg 940)	OSHPD 1-In Service	4			2	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03829	Generator Building (Bldg 980)	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03862	Kitchen & Associated Fac (Bldg 600)	OSHPD 1-In Service	2		0.81	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03864	Canopy	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03865	Canopy	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03867	Canopy	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-03868	Canopy	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-05986	Pediatric / Surgery (BLD 580) 580B	OSHPD 1-In Service	5			4	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-07738	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
27 - Monterey	17353	Natividad Medical Center	Salinas	BLD-07739	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01635	Original Building	OSHPD 1-In Service	2	0.28		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01636	36 Bed Addition	OSHPD 1-In Service	2	0.35		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01638	Dietary Addition	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01639	Electrical and Mechanical Building	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01640	Central Sterile Supply	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01641	Cardiac Center North	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01642	Cardiac Center South	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01643	CCU Expansion	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01644	Outpatient Center	OSHPD 1-In Service	5			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01645	Cath Lab Expansion	OSHPD 1-In Service	5			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01646	Cath Lab Canopy	OSHPD 1-In Service	5			4	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01647	Cath Lab Stair Tower	OSHPD 1-In Service	5			4	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01648	Link	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-01649	Central Plant	OSHPD 1-In Service	5			4	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-03076	Administration Building	OSHPD 1-In Service	4			2	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-03455	Utility Tunnel	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-03456	Drop-off Canopy	OSHPD 1-In Service	5			4	
27 - Monterey	10348	Salinas Valley Health Medical Center	Salinas	BLD-05201	Rotary UPS	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01665	Smoking Porch Addition to Main Wing - Structurally connected to BLD-01666	OSHPD 1-Not an Independent Building	N/A			N/A	
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01666	Main Wing & Smoking Porch Addition	OSHPD 1-In Service	2		0.3	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01667	East Wing	OSHPD 1-In Service	2		0.31	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-01668	Ancillary Wing & (ICCU Add 5th Flr)	OSHPD 1-In Service	4			2	
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-03031	Generator Building	OSHPD 1-In Service	4			2	
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-03554	Health Center	OSHPD 1-In Service	2		1.13	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10366	Adventist Health St. Helena	St. Helena	BLD-05327	Chiller Plant	OSHPD 1-In Service	5s			4	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01650	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		7.94	N/A	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01651	West Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		2.3	N/A	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01652	West Tower	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01653	Conference Addition	OSHPD 1-In Service	3			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01654	Link Corridor	OSHPD 1-In Service	3			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01655	South Elevator Tower	OSHPD 1-In Service	4			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01656	South Nursing Wing	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01657	North Elevator Tower	OSHPD 1-In Service	4			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01658	North Nursing Wing	OSHPD 1-In Service	3			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01659	Maternity / Pediatrics	OSHPD 1-In Service	3			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01660	Admitting / Lobby	OSHPD 1-In Service	3			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01661	Radiology / Oncology Addition	OSHPD 1-In Service	4			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01663	Emergency Addition	OSHPD 1-In Service	5			2	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-01664	Emergency Canopy	OSHPD 1-In Service	5			4	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-02881	Canopy Addition	OSHPD 1-In Service	5			4	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-05309	North Acute Care Building	OSHPD 1-In Service	5			4	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-05323	North Acute Care Corridor	OSHPD 1-In Service	5			4	
28 - Napa	10362	Providence Queen Of The Valley Medical Center	Napa	BLD-05463	Women's Center	OSHPD 1-In Service	5			4	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01669	East Wing	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01670	West Wing	OSHPD 1-In Service	4			2	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01671	ICU Addition	OSHPD 1-In Service	4			2	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01673	West Wing Addition	OSHPD 1-In Service	4			2	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01674	Outpatient Center	OSHPD 1-In Service	4s			2	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-01675	West Wing Addition #2 - Structurally connected to BLD-01670	OSHPD 1-Not an Independent Building	N/A			N/A	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-03399	Entry Canopy West	OSHPD 1-In Service	5			4	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-03686	Central Plant	OSHPD 1-In Service	4			4	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-06080	Entry Canopy Center	OSHPD 1-In Service	5			4	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-06081	Entry Canopy East	OSHPD 1-In Service	5			4	
29 - Nevada	10375	Sierra Nevada Memorial Hospital	Grass Valley	BLD-07344	Pharmacy Addition	OSHPD 1-In Service	4s			2s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01676	1950 Building and 1966 Additions	OSHPD 1-In Service	2		0.44	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01677	1966 North Addition Building - Structurally connected to BLD-01676	OSHPD 1-Not an Independent Building	N/A			N/A	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01678	1978 Building	OSHPD 1-In Service	4			2	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01679	1990 Building	OSHPD 1-In Service	4			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-01680	1993 Building	OSHPD 1-In Service	4			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-02569	Med Gas Storage Building	OSHPD 1-In Service	4			2	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-03236	1986 Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-03897	Western Addition	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05249	2011 ED/SPD Addition	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05272	South Wing	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05273	South Wing Corridor	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05474	2002 Building	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05475	Generator Building	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05476	2008 Building	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05477	Central Plant	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05478	Modular Chiller Building	OSHPD 1-In Service	5			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05479	Chiller Building Cooling Tower	OSHPD 1-Not a Building Structure	N/A			4	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-05480	Skilled Nursing Facility Addition	OSHPD 2-Skilled Nursing Only	N/A			N/A	
29 - Nevada	10377	Tahoe Forest Hospital	Truckee	BLD-06666	Western Addition - Porte-Cochere	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01684	Central Plant	OSHPD 1-In Service	2		0.9	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01685	Main Hospital	OSHPD 1-In Service	2	0.36		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01692	Phase IV/North Wing - South	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01693	Phase IV East Entrance	OSHPD 1-In Service	4			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-01695	Main Entrance Building	OSHPD 1-In Service	5			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03658	Corridor No. 1	OSHPD 1-In Service	5			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03659	Porte Cochere	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03660	Corridor No. 2	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03661	Corridor No. 3	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03662	Corridor No. 4	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03663	Corridor No. 5	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03664	Arcade	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03665	Phase IV/North Wing - North	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03671	Phase IV East Entrance Addition North	OSHPD 1-In Service	3			2	
30 - Orange	10382	AHMC Anaheim Regional Medical Center	Anaheim	BLD-03672	Phase IV East Entrance Addition South	OSHPD 1-In Service	3			2	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01681	Original Building / Additions	OSHPD 1-In Service	2	0.39		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01682	ICU Addition	OSHPD 1-In Service	4			2	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-01683	OB/Gyn	OSHPD 1-In Service	4			4	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-06268	Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-06269	Trash Enclosure	OSHPD 1-Equipment Yard	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-07788	Pump House	OSHDP 1-Proposed	5s			5s	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-07789	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
30 - Orange	10381	Anaheim Community Hospital, LLC	Anaheim	BLD-07790	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00996	Psychiatric Treatment	OSHDP 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00997	Main Hospital Building	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00998	ICU / CCU Unit	OSHDP 1-In Service	4			2	
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-00999	ER Addition / Birthing Center	OSHDP 1-In Service	4			2	
30 - Orange	13061	Anaheim Global Medical Center	Anaheim	BLD-01000	Canopy Addition	OSHDP 1-In Service	4			2	
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02346	Main Building	OSHDP 1-In Service	2	0.22		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02347	Entry Pavilion	OSHDP 1-In Service	4s			2	
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02348	Mechanical Building	OSHDP 1-In Service	5			2	
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02349	ICU/Admin Addition	OSHDP 1-In Service	4			2	
30 - Orange	10400	Chapman Global Medical Center	Orange	BLD-02350	Surgery Addition	OSHDP 1-In Service	5s			2	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-06670	Main Hospital	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-06671	Central Utility Plant	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-06672	Entry Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07512	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07513	WT-02 Water Tank	OSHDP 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07514	WT-03 Water Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07515	FT-01 Fuel Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07516	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07517	WWT-02 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10036	City of Hope Orange County Cancer Specialty Hospital	Irvine	BLD-07518	WWT-03 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-02351	Original Hospital Building	OSHDP 1-In Service	2	0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-02352	Psychiatric Addition	OSHDP 1-In Service	4			2	
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03102	Radiographic and Fluoroscopy Addn	OSHDP 1-In Service	4			2	
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03417	Canopy 1	OSHDP 1-In Service	4			2	
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-03419	Canopy 3	OSHDP 1-In Service	4			2	
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-07142	Storage Building	OSHDP 1-Under Construction	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-07143	Utility Building	OSHDP 1-Under Construction	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10405	College Hospital Costa Mesa	Costa Mesa	BLD-07144	Utility Yard	OSHDP 1-Equipment Yard	N/A			2	
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	Tustin	BLD-06151	West Building	OSHDP 1-In Service	5			5	Earthquake Resilient
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	Tustin	BLD-06152	East Building	OSHDP 1-In Service	5			5	Earthquake Resilient
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	Tustin	BLD-06448	Oxygen Tank Enclosure	OSHDP 1-Equipment Yard	N/A			5	
30 - Orange	18226	Encompass Health Rehabilitation Hospital of Tustin	Tustin	BLD-07400	East Expansion	OSHDP 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-01029	Original Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-01030	Classroom Addition	OSHPD 1-In Service	4s			2	
30 - Orange	12573	Foothill Regional Medical Center	Tustin	BLD-02631	Mechanical Addition	OSHPD 1-In Service	4s			2	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02406	Patient Tower	OSHPD 1-In Service	4			3	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02407	Ancillary Building	OSHPD 1-In Service	4			3	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-02408	Mechanical Building	OSHPD 1-In Service	4			3	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-07590	Liquid Oxygen Tank Yard	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-07796	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-07797	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-07798	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
30 - Orange	10450	Garden Grove Hospital and Medical Center	Garden Grove	BLD-07799	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	17438	Healthbridge Children's Hospital-Orange	Orange	BLD-05189	Main Building	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-00283	D & T	OSHPD 1-In Service	4			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-00284	Nursing	OSHPD 1-In Service	4			2	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-05852	ER Entrance Canopy	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-05853	Emergency Department	OSHPD 1-In Service	5			5	Earthquake Resilient
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06285	Ambulance Bay Canopy	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06297	Trellis Wheel Chair Storage	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06480	Vending Kiosk	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06481	Wheelchair Storage	OSHPD 1-In Service	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06656	East Wing Addition	OSHPD 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06658	E-Generator Yard (E Generator Enclosure)	OSHPD 1-Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06660	Dock Receiving Enclosure (Basement Connecting Corridor)	OSHDP 1-Tunnels	5			4	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06661	Front Entrance Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06662	Front Entrance Expansion	OSHDP 1-Under Construction	5s			4s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06663	East Entrance Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06677	North-West Entrance Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06678	North Hospital - West Wing	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06680	North Hospital - East Wing	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06681	North-East Entrance Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06682	East Tunnel Connector	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06938	South-East Pedestrian Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-06939	South-West Pedestrian Canopy	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07116	Emergency Generator Enclosure #1	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07117	Emergency Generator Enclosure #2	OSHDP 1-Under Construction	5s			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07484	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07485	WT-02 Water Tank	OSHDP 1-Under Construction	N/A			5s	
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07486	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	16319	Hoag Hospital Irvine	Irvine	BLD-07487	WWT-02 Wastewater Tank	OSHDP 1- Under Construction	N/A			5s	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02360	Original Building	OSHDP 1-In Service	2	0.74		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02361	Four-Story Building - 1957	OSHDP 1-In Service	2	1.71		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02363	Old ICU - 1963	OSHDP 1-In Service	2	0.63		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02364	Old Radiation Therapy - 1975	OSHDP 1-In Service	4			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02366	Power Plant - Boilers and Chillers - Structurally connected to BLD-02369	OSHDP 1-Not an Independent Building	N/A			N/A	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02368	Inpatient Tower - 1974	OSHDP 1-In Service	2	0.48		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02369	Ancillary / Helistop / Power Plant	OSHDP 1-In Service	4D		0.03	2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02370	Helistop - 1974 - Structurally connected to BLD-02369	OSHDP 1-Not an Independent Building	N/A			N/A	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02371	Chemical Dependency - 1965	OSHDP 1-In Service	2	0.64		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02373	Cancer Center	OSHDP 1-In Service	3			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02374	MRI / MRI Addition	OSHDP 1-In Service	3			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02375	South Entrance	OSHDP 1-In Service	3			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02376	ER East Waiting Room Addition - Structurally connected to BLD-02369	OSHDP 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02377	MRI Addition - Structurally connected to BLD-02374	OSHPD 1-Not an Independent Building	N/A			N/A	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02378	Link Building	OSHPD 1-In Service	3			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-02379	Emergency Department Addition	OSHPD 1-In Service	5			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03098	Cancer Center - Link Tower	OSHPD 1-In Service	3			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03332	Power Plant - MUSS & ATS	OSHPD 1-In Service	4			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03333	Emergency Generator Building	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03415	Energy Treatment Building	OSHPD 1-In Service	4			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-03699	East Wing	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05442	Cogeneration Building	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05517	Cafe Building	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05518	Fire Pump Building	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05519	ECU Waiting Building	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05520	Original Building - North Portion	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05568	East Wing Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05900	ECU Waiting Walk-In Entry Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-05901	ECU Waiting Drop-Off Area Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-06281	Elevator Tower (for Inpatient Tower)	OSHPD 1-In Service	5			2	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-07102	Utility Tunnel	OSHPD 1-Tunnels	N/A			4s	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-07791	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-07792	Pump Vault	OSHPD 1-Proposed	5s			5s	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-07793	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10428	Hoag Memorial Hospital Presbyterian	Newport Beach	BLD-07794	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02387	Hospital Tower	OSHPD 1-In Service	2	0.36		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02388	Main Hospital	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02389	ICU/CCU Addition	OSHPD 1-In Service	4s			2	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02390	Emergency Expansion	OSHPD 1-In Service	3			2	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02916	CT Scan Addition	OSHPD 1-In Service	4			2	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-02917	X-Ray Addition	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-07746	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-07747	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-07748	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-07749	FT-01 Fuel Tank	OSHPD 1-Tanks	5			5	Earthquake Resilient
30 - Orange	10431	Huntington Beach Hospital	Huntington Beach	BLD-07750	FT-02 Fuel Tank	OSHPD 1-Proposed	5s			5s	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-05274	Hospital	OSHPD 1-In Service	5			4	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-05275	Central Utility Plant	OSHPD 1-In Service	5			4	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-06224	Walk-in Refrigerator	OSHPD 1-Not a Building Structure	N/A			4	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-06944	Fire Pump Building	OSHPD 1-In Service	5			4	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-07417	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-07418	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-07419	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-07598	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5	
30 - Orange	18178	Kaiser Foundation Hospital - Orange County - Anaheim	Anaheim	BLD-07599	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-03831	Main Building	OSHPD 1-In Service	5			4	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-03902	Central Plant	OSHPD 1-In Service	5			4	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-07408	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-07409	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-07410	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-07411	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	18152	Kaiser Foundation Hospital - Orange County - Irvine	Irvine	BLD-07412	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02353	Building I: Original Building	OSHPD 1-In Service	2	0.59		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02354	Building II	OSHPD 1-In Service	4			2	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02355	Building III	OSHPD 1-In Service	4			2	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02356	Building IV	OSHPD 1-In Service	4			2	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02357	Building V	OSHPD 1-In Service	4			2	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02358	Building VI	OSHPD 1-In Service	4			2	
30 - Orange	10407	Kindred Hospital - Santa Ana	Santa Ana	BLD-02359	Building VII	OSHPD 1-In Service	4			2	
30 - Orange	13068	Kindred Hospital Brea	Brea	BLD-02559	Main Building	OSHPD 1-In Service	3			2	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-01343	Patient Tower (Building I)	OSHPD 1-In Service	2	1.02	1.02	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03059	Entry/Lobby (Building II)	OSHPD 1-In Service	2	1.05	1.05	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03060	Critical Care (Building III)	OSHPD 1-In Service	2	1.05	1.05	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03061	Body Scanner Addition (Building IV)	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-03479	Entry Canopy	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07468	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07469	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07470	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07471	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07472	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10476	Kindred Hospital Westminster	Westminster	BLD-07473	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00982	Main Building	OSHPD 1-In Service	2	0.48		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00983	Perinatal Building Addition	OSHPD 1-In Service	4			4D-L1	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00984	Pool Building	OSHPD 1-In Service	4			4D-L1	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-00985	Service Building	OSHPD 1-In Service	4			2	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02758	Service Building	OSHPD 1-In Service	4s			2	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02759	Rehabilitation Department Expansion	OSHPD 1-In Service	4			4D-L1	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-02760	Patient Room Expansion	OSHPD 1-In Service	4			4D-L1	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-05516	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			2	
30 - Orange	13019	La Palma Intercommunity Hospital	La Palma	BLD-05782	Canopy	OSHPD 1-In Service	5			4	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00323	Original Building	OSHPD 1-In Service	3			2	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00324	South Addition	OSHPD 1-In Service	3			2	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-00325	Emergency Room Addition	OSHPD 1-In Service	3			2	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05472	Pedestrian Bridge	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05730	Patient Care Pavilion	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05731	Covered Walkway	OSHPD 1-In Service	4			4	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-05873	Emergency Room Addition #2	OSHPD 1- Under Construction	5s			5s	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-06027	LDR	OSHPD 1-In Service	3			2	
30 - Orange	15630	Memorialcare Orange Coast Medical Center	Fountain Valley	BLD-06231	LDR Canopy	OSHPD 1-In Service	3			4	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01042	Main Hospital	OSHPD 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01043	Women's Health Center	OSHPD 1-In Service	4			2	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01044	Central Plant - Steel Portion	OSHPD 1-In Service	2	0.74		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-01045	Central Plant - Concrete Portion	OSHPD 1-In Service	2	0.06		4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-02738	Critical Care Pavilion	OSHPD 1-In Service	5			4	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-03707	Central Plant Addition	OSHPD 1-In Service	4			2	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-05981	Utility Tunnel	OSHPD 1- Tunnels	N/A			2	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-05989	Main Hospital Canopy	OSHPD 1-In Service	5			4	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-06020	CCP Canopy	OSHPD 1-In Service	5			4	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-06024	WHC Canopy	OSHPD 1-In Service	5			4	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07141	Central Plant	OSHPD 1- Under Construction	5s			5s	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07477	FT-01 Fuel Tank	OSHPD 1- Under Construction	N/A			5s	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07478	WT-01 Water Tank	OSHPD 1- Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07479	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07480	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
30 - Orange	12755	Memorialcare Saddleback Medical Center	Laguna Hills	BLD-07481	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00295	Ancillary Building/ER Expansion	OSHPD 1-In Service	2	0.6		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00296	Elevator Tower	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00297	Nursing Tower	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00298	Administration	OSHPD 1-In Service	2	1.97	0.67	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00299	Shipping & Receiving	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00300	Mechanical Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00301	Radiation Therapy	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-00302	Support Services	OSHPD 1-In Service	5s			2	
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-05722	Entrance Canopy	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	18007	Orange County Global Medical Center	Santa Ana	BLD-06693	New Cooling Tower Yard	OSHPD 1-Under Construction	N/A			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00913	Pavilion - Building 1	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00914	Pavilion - Building 2	OSHPD 1-In Service	5			2	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00915	Pavilion - Building 3	OSHPD 1-In Service	4			2	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00916	Pavilion - Building 4	OSHPD 1-In Service	4			2	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00917	Pavilion - Building 5	OSHPD 1-In Service	5			2	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-00918	Hospital Tower	OSHPD 1-In Service	4			2	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-03184	Tower 2	OSHPD 1-In Service	5			4	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-03185	Linear Accelerator	OSHPD 1-In Service	5			4	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-03186	Perioperative Pediatric Pavilion	OSHPD 1-In Service	5			4	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-06715	Tower 2 Canopy	OSHPD 1-In Service	5			4	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-07234	Hospital Tower 3	OSHPD 1-Proposed	5s			5s	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-07235	Canopy	OSHPD 1-Proposed	5s			5s	
30 - Orange	12804	Providence Mission Hospital	Mission Viejo	BLD-07236	Lobby Infill	OSHPD 1-Proposed	5s			5s	
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02433	Original Building	OSHPD 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02434	Nursing Tower	OSHPD 1-In Service	2		0.31	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02435	Elevator Tower	OSHPD 1-In Service	2	0.13		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02436	Radiographic	OSHPD 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02437	Radiographic - South Addition	OSHPD 1-In Service	2	1.05	5.84	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02438	Administration Building	OSHDP 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02439	Mechanical / Central Plant	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10468	Providence Mission Hospital - Laguna Beach	Laguna Beach	BLD-02440	Linear Accelerator Suite (Treatment)	OSHDP 1-In Service	4			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02414	Main Building (A)	OSHDP 1-In Service	2		15.48	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02415	Central Plant	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02416	East/West Wing	OSHDP 1-In Service	2	0.59	13.47	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02417	South Tower	OSHDP 1-In Service	2	0.63		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02418	North Wing / Lobby	OSHDP 1-In Service	4			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02419	Main Hospital Building (B)	OSHDP 1-In Service	4			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02420	Main Hospital Building (C)	OSHDP 1-In Service	4			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02421	Regional Cancer Center	OSHDP 1-In Service	4			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02422	Emergency Department Expansion	OSHDP 1-In Service	5			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-02784	Generator Enclosure	OSHDP 1-In Service	5			2	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03013	ICU/CCU Addition	OSHDP 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03352	Patient Care Center/Plaza Tower	OSHDP 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03353	Facilities Services Building	OSHDP 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03354	PCC Lobby / Canopy	OSHDP 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03355	Underground Tunnel	OSHDP 1-Tunnels	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-03357	South Entry Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-06061	PCC West Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10457	Providence St. Joseph Hospital	Orange	BLD-06435	Emergency Entrance Canopy	OSHPD 1-In Service	5			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02424	Main Building / Canopies / Boiler Room	OSHPD 1-In Service	1	0.87	2.24	2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02425	West Building	OSHPD 1-In Service	1		17.89	2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02426	North Building	OSHPD 1-In Service	2	0.24		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02427	CT Scan Building	OSHPD 1-In Service	3			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02428	Outpatient/Admitting Building	OSHPD 1-In Service	3			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02429	Linear Accelerator - Structurally connected to BLD-02425	OSHPD 1-Not an Independent Building	N/A			N/A	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02431	Emergency Generator Enclosure	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02432	MRI and Surgery Building	OSHPD 1-In Service	3			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02832	E.R. Waiting/Canopy	OSHPD 1-In Service	3			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02833	Basement Expansion	OSHPD 1-In Service	1		8.14	2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-02834	Boiler Room Expansion / Chiller Rm	OSHPD 1-In Service	2	0.17		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-03190	Southwest Acute Care Bed Tower	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-03191	Central Utility Plant	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-03192	East Link	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-03193	West Link North	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-03194	Northwest Acute Care Bed Tower	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-05775	West Link South	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-05776	Trash Enclosure	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-05777	Medical Gas Enclosure	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-05778	Main Entrance Canopy	OSHPD 1-In Service	5			4	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-06581	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
30 - Orange	10458	Providence St. Jude Medical Center	Fullerton	BLD-07401	Trash Enclosure	OSHPD 1-In Service	1s			2	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-00271	CHOC North	OSHPD 1-In Service	3			3	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-00272	Research Building	OSHPD 1-In Service	3			3	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-00273	CHOC West	OSHPD 1-In Service	2		1.03	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-05243	Tower II	OSHPD 1-In Service	5			4	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-05335	CHOC Lobby	OSHPD 1-In Service	3s			2s	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-05672	Providence Tunnel	OSHPD 1-Tunnels	4			3	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-05720	La Veta Stairs	OSHPD 1-In Service	5			4	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-05721	Garage Bridge	OSHPD 1-In Service	5			4	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-07297	La Veta Stair Transition	OSHPD 1-In Service	5			4	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-07298	La Veta Bridge	OSHPD 1-In Service	5			4	
30 - Orange	14370	Rady Children's Hospital Orange County	Orange	BLD-07313	Garage Elevator Tower	OSHPD 1-In Service	5			4	
30 - Orange	13059	South Coast Global Medical Center	Santa Ana	BLD-00994	Main Hospital and Additions	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13059	South Coast Global Medical Center	Santa Ana	BLD-00995	Nursing Wing Addition	OSHPD 1-In Service	4			2	
30 - Orange	10062	UCI Health Rehabilitation Hospital	Irvine	BLD-06919	Rehab Hospital	OSHPD 1-Under Construction	5s			5s	
30 - Orange	10062	UCI Health Rehabilitation Hospital	Irvine	BLD-06920	Generator Enclosure / Exit Stair Room / Trash Enclosure	OSHPD 1-Under Construction	N/A			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-00926	Main Hospital/Additions	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-00927	Women & Children's Hosp.	OSHPD 1-In Service	4			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-00928	Dining Room Addition	OSHPD 1-In Service	4			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-00929	Conference Room Addition	OSHPD 1-In Service	4			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-00931	ER Addition	OSHPD 1-In Service	4			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-03497	Emergency Power Building	OSHPD 1-In Service	5			4	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-03498	Surgery Addition	OSHPD 1-Under Construction	5s			4s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-03770	ER Addition - Phase 2	OSHPD 1-In Service	4			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-03771	ER Addition - Phase 3	OSHPD 1-In Service	5			2	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-06644	Switchgear Building	OSHPD 1-In Service	4D			2s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07547	AHU Platform	OSHPD 1-Not a Building Structure	N/A			4	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07548	Entrance Canopy	OSHPD 1-In Service	5			4	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07714	Pump House #1	OSHPD 1-Proposed	5s			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07715	Pump House #2	OSHPD 1-Proposed	5s			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07716	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07717	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07718	WT-02 Water Tank (Non-potable)	OSHPD 1-Proposed	N/A			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07719	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			2s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07720	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	12834	UCI Health-Fountain Valley	Fountain Valley	BLD-07721	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	16234	UCI Health-Fountain Valley	Fountain Valley	BLD-05195	Living Care Center	OSHPD 1-In Service	3			2	
30 - Orange	16234	UCI Health-Fountain Valley	Fountain Valley	BLD-07723	Pump House	OSHPD 1-Proposed	5s			5s	
30 - Orange	16234	UCI Health-Fountain Valley	Fountain Valley	BLD-07724	WT-01 Water Tank	OSHPD 1-Proposed	5s			5s	
30 - Orange	16234	UCI Health-Fountain Valley	Fountain Valley	BLD-07725	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-02395	Main Hospital/ICU - CCU/Nuclear Med	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-02396	OB South/ER/Lab	OSHPD 1-In Service	3			2	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-02397	Women's Center	OSHPD 1-In Service	5			2	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-02398	Linear Accelerator	OSHPD 1-In Service	5			2	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-07557	Chiller Yard	OSHPD 1-Equipment Yard	N/A			4	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-07710	Pump House	OSHPD 1-Proposed	5s			5s	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-07711	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-07712	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10440	UCI Health-Los Alamitos	Los Alamitos	BLD-07713	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-02400	Medical Center Tower Building 1A	OSHPD 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-02401	Neuropsychiatric Center - West Wing	OSHPD 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-02402	Steam Plant Building 31	OSHPD 1-In Service	5			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-02403	Primary Electrical Facility Building 32	OSHPD 1-In Service	4			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-02404	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-03017	Neuropsychiatric Center - East Wing (Acute Center East)	OSHPD 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-03412	Douglas Hospital	OSHPD 1-In Service	5			4	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-03416	Link Building	OSHPD 1-In Service	5			4	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05584	Medical Gas / Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05587	Generator Switchgear	OSHPD 1-In Service	5s			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05588	Emergency Generator Housing	OSHPD 1-Equipment Yard	N/A			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05683	Neuropsychiatric Center - East Wing (Acute Center South)	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05769	Neuropsychiatric Center - East Wing (Acute Center North)	OSHDP 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05770	Neuropsychiatric Center - East Wing (Acute Center Walkway North)	OSHDP 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-05771	Neuropsychiatric Center - East Wing (Acute Center Walkway South)	OSHDP 1-In Service	3			2	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-06008	Ambulance Canopy	OSHDP 1-In Service	5			4	
30 - Orange	10446	UCI Health-Orange	Orange	BLD-06239	Chiller Plant	OSHDP 1-In Service	5			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-00156	Main Hospital & Addition	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-00157	Patient Room Addition	OSHDP 1-In Service	4			2	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-00158	OB Addition	OSHDP 1-In Service	4			2	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-00159	Classrooms & Additions	OSHDP 1-In Service	4	0.03		2	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-03742	GI Building Expansion	OSHDP 1-In Service	5			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-03743	GI Building Expansion Canopy	OSHDP 1-In Service	5			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-05701	Main Entry and Ambulance Canopy	OSHDP 1-In Service	5			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-05718	Free-Standing Mechanical Platform	OSHDP 1-Not a Building Structure	N/A			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07549	ED Expansion	OSHDP 1-In Service	5			2	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07550	ED Canopy	OSHDP 1-In Service	5			4	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07551	Mechanical Building	OSHDP 1-In Service	4			2	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07706	Pump House	OSHDP 1-Proposed	5s			5s	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07707	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07708	WT-02 Water Tank (Non-potable)	OSHDP 1-Proposed	N/A			5s	
30 - Orange	13077	UCI Health-Placentia Linda	Placentia	BLD-07709	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06720	Hospital	OSHDP 1-Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06721	Central Utility Plant	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06884	ED Canopy No 1	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06885	ED Canopy No 2	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06889	Utility Tunnel	OSHDP 1-Under Construction	5s			5s	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06911	Electrical Yard	OSHDP 1-Equipment Yard	N/A			5	
30 - Orange	10039	University of California Irvine Medical Center - Irvine	Irvine	BLD-06912	Main Switchgear	OSHDP 1-Not a Building Structure	N/A			5	
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02441	Main Hospital	OSHDP 1-In Service	2	1.06	1.08	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02675	Phase I - Tower Addition	OSHDP 1-In Service	3			2	
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-02886	Phase I - 1 Story Addition	OSHDP 1-In Service	3			2	
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-03118	Entry Canopy	OSHDP 1-In Service	3			2	
30 - Orange	10475	West Anaheim Medical Center	Anaheim	BLD-03559	Oxygen Tank Yard (Service Yard)	OSHDP 1-Equipment Yard	N/A			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00260	Hospital, Building 1	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00261	Hospital, Building 2	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00262	Hospital, Building 3	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00263	Hospital Tower	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00264	Hospital Tower North	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00265	Hospital Tower South	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-00266	Central Plant Building	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05230	Emergency Department/Radiology	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05723	Central Plant Addition	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05724	EVS Building	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05725	Women & Children's Link	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05726	Women & Children's Center	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-05727	Fire Pump Building	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06067	Entry Canopy	OSHDP 1-In Service	4			2	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06388	MRI Entry Canopy	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06786	Cart Wash and Compactor Canopy	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06832	Equipment Holding	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06856	Hospital Entry Canopy	OSHDP 1-Proposed	5s			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06857	Hospital Tower West	OSHDP 1-Under Construction	5s			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06858	ED Entry Canopy	OSHDP 1-Under Construction	5s			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06940	Switchgear and IT Building	OSHDP 1-Under Construction	5s			4s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06941	Generator Yard	OSHDP 1-Under Construction	N/A			4s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-06987	PRV Building	OSHDP 1-Under Construction	5s			4s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07124	Sanipak Canopy	OSHDP 1-In Service	5			4	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07434	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07435	WT-02 Water Tank	OSHDP 1-Under Construction	N/A			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07436	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07437	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07533	WT-03 Water Tank	OSHPD 1-Proposed	N/A			5s	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07534	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
31 - Placer	14214	Kaiser Foundation Hospital - Roseville	Roseville	BLD-07535	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01344	Original Hospital	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01345	Storage / Pharmacy Building	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01346	Dietary Addition	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01347	Emergency Addition	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01348	Medical Records Addition	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01349	Electrical Addition	OSHPD 1-In Service	5			4	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-01350	Boiler Addition	OSHPD 1-In Service	5			4	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-02979	West Electrical Room	OSHPD 1-In Service	4			4	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05552	Cath Lab Addition	OSHPD 1-In Service	5s			4s	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05553	MRI Addition	OSHPD 1-In Service	5s			4s	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05779	Patient Drop Off Canopy	OSHPD 1-In Service	5			4	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-05882	Emergency Generators Yard	OSHPD 1-Equipment Yard	N/A			4	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-07011	Addition #1	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-07012	Addition #2	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-07013	Addition #3	OSHPD 1-In Service	4			2	
31 - Placer	10494	Sutter Auburn Faith Hospital	Auburn	BLD-07014	Covered Walkway	OSHPD 1-In Service	4			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-00303	Main Hospital (General Hospital)	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-00304	Central Plant	OSHPD 1-In Service	5			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03248	Acute Rehabilitation - East - Structurally connected to BLD-03612	OSHPD 1-Not an Independent Building	N/A			N/A	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03249	Acute Rehabilitation - Pedestrian Walkway	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03580	General Hospital Pedestrian Walkway	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03581	Bed Tower South	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03582	Bed Tower North	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03583	Administration	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03584	MOB Pedestrian Walkway	OSHPD 1-In Service	5			2	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03585	Emergency Department Expansion	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03586	Bed Tower Expansion	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03587	Bed Tower Expansion Pedestrian Walkway	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03611	NICU	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03612	Acute Rehabilitation	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03613	Well Baby Nursery - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A			N/A	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-03614	ICU Expansion - Structurally connected to BLD-03581	OSHPD 1-Not an Independent Building	N/A			N/A	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06161	E.D. & Critical Care Expansion	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06753	Bed Tower Expansion - Walkway 2	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06754	Bed Tower Expansion - Walkway 3	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06758	Porte-Cochere	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-06759	Gas Cylinder Enclosure	OSHPD 1-In Service	5			4	
31 - Placer	17700	Sutter Roseville Medical Center	Roseville	BLD-07608	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A			5	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-01362	Main Hospital Building	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-01364	Boiler Plant Building	OSHDP 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-03655	SNF Addition	OSHDP 1-In Service	5			4	
32 - Plumas	10514	Eastern Plumas Hospital-Portola Campus	Portola	BLD-03656	Central Plant	OSHDP 1-In Service	5			4	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01351	Original Building	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01353	1976 Addition	OSHDP 1-In Service	4			2	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-01354	South Addition	OSHDP 1-In Service	4			2	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-06957	Skilled Nursing Facility	OSHDP 2-Skilled Nursing Only	N/A			N/A	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-07659	Lobby	OSHDP 2-Skilled Nursing Only	N/A			N/A	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-07660	Trash Enclosure	OSHDP 2-Skilled Nursing Only	N/A			N/A	
32 - Plumas	10512	Plumas District Hospital	Quincy	BLD-07661	Trash Enclosure	OSHDP 2-Skilled Nursing Only	N/A			N/A	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01355	Main Hospital Building	OSHDP 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01356	Pump Building	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01358	Entrance Addition - Structurally connected to BLD-01355	OSHDP 1-Not an Independent Building	N/A			N/A	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01359	Extended Care Addn.	OSHDP 1-In Service	4			2	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01360	Storage Addition	OSHDP 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-01361	Generator Building	OSHDP 1-In Service	5			4	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-03843	Boiler Room	OSHDP 1-In Service	2	0.06		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-06811	New Hospital	OSHDP 1-Under Construction	5s			5s	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-06812	New ED Canopy	OSHDP 1-Under Construction	5s			5s	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-06813	New Entrance Canopy	OSHDP 1-Under Construction	5s			5s	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-06814	New SNF	OSHDP 2-Under Construction	N/A			N/A	
32 - Plumas	10513	Seneca District Hospital	Chester	BLD-07110	New Ambulance Canopy	OSHDP 1-Under Construction	5s			5s	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01367	Original Hospital - Main	OSHDP 1-In Service	2	1.05	0.48	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01368	Ancillary - Main	OSHDP 1-In Service	4			2	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-01369	Surgery & Delivery - Main	OSHDP 1-In Service	3			2	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-02997	ED Addition	OSHDP 1-In Service	5			4	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-03594	Generator Building (Electrical Panel Room)	OSHDP 1-In Service	4			4	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05887	Bulk Medical Gas Yard	OSHDP 1-Equipment Yard	N/A			4	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05888	Emergency Generator	OSHDP 1-Equipment Yard	N/A			4	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05889	Switchgear Yard	OSHDP 1-Equipment Yard	N/A			4	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-05890	Modular MRI Building	OSHDP 3 - Local-Outpatient Only	N/A			N/A	
33 - Riverside	10529	Corona Regional Medical Center	Corona	BLD-06298	Porte Cochere	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01393	Main Hospital & Additions	OSHDP 1-In Service	2	0.38		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01395	Woman & Infants Hospital	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01396	North Wing	OSHDP 1-In Service	2	0.3		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01397	Central Plant	OSHDP 1-In Service	4			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01398	Shipping/Receiving	OSHDP 1-In Service	4			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01399	Surgery Wing	OSHDP 1-In Service	4			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01400	West Tower	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01401	Lobby	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01402	Admitting	OSHDP 1-In Service	4			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01403	Elevator Tower	OSHDP 1-In Service	4			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-01404	Dinah Shore Waiting Area	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-02932	East Tower	OSHDP 1-In Service	2	0.51		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03720	West Tower - Corridor 1	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03721	West Tower - Corridor 2	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03722	West Tower - Corridor 3	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03723	West Tower - Corridor 4	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03725	West Tower - Corridor 5	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03741	Medical Records Building	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03764	Elevator Tower - Corridor 1	OSHDP 1-In Service	3			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-03765	Elevator Tower - Corridor 2	OSHDP 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-06628	Equipment Yard	OSHDP 1-Equipment Yard	N/A			2	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07726	Pump House #1	OSHDP 1-Proposed	5s			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07727	Pump House #2	OSHDP 1-Proposed	5s			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07728	Pump House #3	OSHDP 1-Proposed	5s			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07729	WT-01 Water Tanks	OSHDP 1-Proposed	N/A			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07730	WT-02 Water Tanks	OSHDP 1-Proposed	N/A			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07731	WT-03 Water Tank	OSHDP 1-Proposed	N/A			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07732	WWT Wastewater Tanks	OSHDP 1-Proposed	N/A			5s	
33 - Riverside	10537	Desert Regional Medical Center	Palm Springs	BLD-07733	FT Fuel Tanks	OSHDP 1-Proposed	N/A			5s	
33 - Riverside	10554	Doctors Hospital Of Riverside	Riverside	BLD-01381	Original Hospital Building and 1961 Additions	OSHDP 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	Riverside	BLD-01382	1971 Tower	OSHDP 1-In Service	2	0.54		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10554	Doctors Hospital Of Riverside	Riverside	BLD-01383	Diagnostic & Treatment Wing & Addition	OSHDP 1-In Service	4			2	
33 - Riverside	10554	Doctors Hospital Of Riverside	Riverside	BLD-03344	Utility Plant Building	OSHDP 1-In Service	5			4	
33 - Riverside	10554	Doctors Hospital Of Riverside	Riverside	BLD-05783	Emergency Department Addition	OSHDP 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01056	North Addition	OSHDP 1-In Service	4			4D-L1	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01057	Eisenhower Wing (North) - Structurally connected to BLD-03004	OSHDP 1-Not an Independent Building	N/A	9.45	7.08	N/A	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01058	Gene Autry Wing	OSHDP 1-In Service	4			2	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01059	Surgery Expansion	OSHDP 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01060	Sinn Wing - Part A	OSHDP 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-01061	Birthing Center Bridge	OSHDP 1-In Service	3			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-02824	Engineering Department	OSHPD 1-In Service	2		0.64	4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03003	Eisenhower Wing (South) - Structurally connected to BLD-03004	OSHPD 1-Not an Independent Building	N/A	9.45	7.08	N/A	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03004	Eisenhower Wing (Center)	OSHPD 1-In Service	2	4.89	0.92	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03005	Sinn Wing - Part B (Amb. Canopy)	OSHPD 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03006	Sinn Wing - Part C	OSHPD 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03007	Sinn Wing - Part D	OSHPD 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03008	Sinn Wing - Part E	OSHPD 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03009	Sinn Wing - Part F	OSHPD 1-In Service	4			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03540	(CP) Central Plant	OSHPD 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03541	Annenberg Pavilion	OSHPD 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-03830	12 KV Switch Building	OSHPD 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-05500	Delivery Dock	OSHPD 1-In Service	2		0.21	4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-05647	ED / Renker Pavilion	OSHPD 1-In Service	5			4	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-06760	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A			2	
33 - Riverside	12662	Eisenhower Medical Center	Rancho Mirage	BLD-07376	Telecom Building	OSHPD 1-In Service	5			4	
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	Murrieta	BLD-05790	Rehabilitation Hospital	OSHPD 1-In Service	5			5	Earthquake Resilient
33 - Riverside	18213	Encompass Health Rehabilitation Hospital of Murrieta	Murrieta	BLD-06553	Admin	OSHPD 1-In Service	5			5	Earthquake Resilient
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01405	Pre 1980 Emergency - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01406	Tower I	OSHPD 1-In Service	2		1.2	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01407	1965 Mechanical Room - Structurally connected to BLD-01406	OSHPD 1-Not an Independent Building	N/A			N/A	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01408	1948 Addition	OSHPD 1-In Service	2		0.95	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01409	North Wing and Annex	OSHPD 1-In Service	2		1.12	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01410	Obstetrics I - Structurally connected to BLD-01409	OSHPD 1-Not an Independent Building	N/A			N/A	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01411	1965 NW Addition	OSHPD 1-In Service	2		1.06	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01412	Behavioral Health	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01413	Obstetrics II	OSHPD 1-In Service	4			2	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01414	Tower II Lower Levels - Structurally connected to BLD-01415	OSHPD 1-Not an Independent Building	N/A			N/A	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01415	Tower II Upper Levels	OSHPD 1-In Service	3			2	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01416	1980 Entrance - Structurally connected to BLD-01417	OSHPD 1-Not an Independent Building	N/A			N/A	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01417	Main Lobby and Entrance	OSHPD 1-In Service	3			2	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-01418	Area A	OSHPD 1-In Service	3			2	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-02857	Area B	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-02858	Area C - Structurally connected to BLD-02857	OSHPD 1-Not an Independent Building	N/A			N/A	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-05649	Emergency Department Addition	OSHPD 1-In Service	5			4	
33 - Riverside	10541	Hemet Global Medical Center	Hemet	BLD-06156	Canopy	OSHPD 1-In Service	4			2	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01370	Original Hospital Building	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01371	Central Plant	OSHPD 1-In Service	2	0.72		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01372	Central Plant Addition	OSHPD 1-In Service	4			2	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01373	North Wing/E.R. Expansion	OSHPD 1-In Service	4			2	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01374	West/South Wing	OSHPD 1-In Service	4			2	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-01375	ICU - MED / Surgery Addition	OSHPD 1-In Service	5			4	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-03525	Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-06500	MRI	OSHPD 1-Under Construction	5s			4s	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-06587	CT#2 Building	OSHPD 1-In Service	5			4	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-07734	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-07735	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-07736	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5s	
33 - Riverside	10545	John F. Kennedy Memorial Hospital	Indio	BLD-07737	Pump House	OSHPD 1-Proposed	5s			5s	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-00285	Patient Tower	OSHPD 1-In Service	4			2	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02918	Stair and Elevator Tower	OSHPD 1-In Service	4			2	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02919	Central Plant	OSHPD 1-In Service	3			2	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02920	Hospital Building	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-02921	Waiting Room Addition	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-05418	Bulk Oxygen Tank	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-05732	Emergency Department Expansion	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06545	Diagnostic and Treatment Addition	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06546	Energy Center (CUP)	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06547	Booster Pump House	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06548	Bulk Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06873	Entrance Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-06874	Drop Off Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-07461	WWT-01 Wastewater Tank	OSHPD 1-Tanks	N/A			5	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-07462	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-07463	WT-02 Water Tank	OSHPD 1-Tanks	N/A			5	
33 - Riverside	16325	Kaiser Foundation Hospital - Moreno Valley	Moreno Valley	BLD-07464	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-00274	Hospital Tower	OSHPD 1-In Service	3			2	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-00275	Plant Service Building	OSHPD 1-In Service	4			3	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05460	MRI Building	OSHPD 1-In Service	5			4	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05651	Switchgear Enclosure	OSHPD 1-Not a Building Structure	N/A			4	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05652	Generator Enclosure - Number 1	OSHPD 1-Not a Building Structure	N/A			4	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05653	Generator Enclosure - Number 2	OSHPD 1-Not a Building Structure	N/A			4	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-05654	Generator Enclosure - Number 3	OSHPD 1-Not a Building Structure	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06761	Bed Tower	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06762	Rotunda	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06763	North Canopy	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06764	South Canopy	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06868	Fire Pump Room	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06869	Tech Dock Building	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06890	Generator Enclosure - Number 4	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06891	Propane Tank and Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-06973	Hospital Tower Basement	OSHPD 1-In Service	4			2	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07455	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07456	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07457	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07458	WT-03 Water Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07596	WT-04 Water Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	16164	Kaiser Foundation Hospital - Riverside	Riverside	BLD-07597	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
33 - Riverside	13030	Kindred Hospital Riverside	Perris	BLD-00986	Main Hospital	OSHPD 1-In Service	2		0.24	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	13030	Kindred Hospital Riverside	Perris	BLD-03519	Storage	OSHPD 1-In Service	4s			2	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05595	Main Hospital Facility	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05596	Central Plant	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05800	Loading Dock Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05801	North Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05802	East Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05803	Emergency Department Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	18175	Loma Linda University Medical Center - Murrieta	Murrieta	BLD-05804	Entrance Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	16148	Menifee Global Medical Center	Sun City	BLD-00351	Hospital Building	OSHPD 1-In Service	4			2	
33 - Riverside	16148	Menifee Global Medical Center	Sun City	BLD-02897	Patient Tower	OSHPD 1-In Service	4			2	
33 - Riverside	16148	Menifee Global Medical Center	Sun City	BLD-02898	Stair and Elevator Tower	OSHPD 1-In Service	4			2	
33 - Riverside	16148	Menifee Global Medical Center	Sun City	BLD-02899	Central Plant	OSHPD 1-In Service	4			2	
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01376	Building A	OSHPD 1-In Service	2		0.03	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01377	Building B	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01378	Building C	OSHPD 1-In Service	4			2	
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01379	Building D	OSHPD 1-In Service	2		0.4	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10553	Palo Verde Hospital	Blythe	BLD-01380	Building E	OSHPD 1-In Service	2		0.02	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	Rancho Mirage	BLD-05443	Main Building	OSHPD 1-In Service	5s			4s	
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	Rancho Mirage	BLD-06095	Dining Addition	OSHPD 1-In Service	5s			4s	
33 - Riverside	18162	Rehabilitation Hospital Of Southern California	Rancho Mirage	BLD-06096	Rehab Addition	OSHPD 1-In Service	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01384	Building A (Main)	OSHPD 1-In Service	1		3.7	2	
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01385	Building B	OSHPD 1-In Service	2	1.69	0.5	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01386	Building C (Inpatient Building)	OSHPD 1-In Service	3			2	
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01387	Building D	OSHPD 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-01388	Old Radiology Building	OSHPD 1-In Service	2	0.15		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-03107	Emergency Generator Enclosure	OSHPD 1-In Service	4			4	
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-03421	Building G	OSHPD 1-In Service	5			4	
33 - Riverside	10556	Riverside Community Hospital	Riverside	BLD-07245	Building H	OSHPD 1-Proposed	5s			5s	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-02517	Main Building	OSHPD 1-In Service	3			2	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03488	Ancillary Building	OSHPD 1-In Service	3			2	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03489	Central Plant / Dining Building	OSHPD 1-In Service	3			2	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-03490	Generator Building	OSHPD 1-In Service	3			4	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-05814	Co-Gen Yard	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-05906	MRI Trailer	OSHPD 3 - Local-Outpatient Only	N/A			N/A	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-06352	Central Plant Yard	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-06830	Exterior Canopy 1	OSHPD 1-Under Construction	5s			4s	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-06831	Exterior Canopy 2	OSHPD 1-Under Construction	5s			4s	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-07403	Emergency Department Addition	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-07404	Wellness Center	OSHPD 5-Proposed	N/A			N/A	
33 - Riverside	15007	Riverside University Health System - Medical Center	Moreno Valley	BLD-07405	Ancillary Building Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-01389	Original Building-OB Addition-'64 Addition	OSHPD 1-In Service	2	0.59		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-01390	O.R. Addition	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-01391	Addition (1980)	OSHPD 1-In Service	4			2	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-01392	O.B. Addition	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-02947	Ambulance Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-02948	Entrance Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05235	ED / ICU	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05303	Central Plant	OSHPD 1-In Service	5			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-05425	Oxygen Tank and Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A			4	
33 - Riverside	10559	San Gorgonio Memorial Hospital	Banning	BLD-06816	Pedestrian Walkway Canopy	OSHPD 1-In Service	5			4	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-00331	Building A	OSHPD 1-In Service	3			2	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-00332	Building B & ER Addition	OSHPD 1-In Service	4			2	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-00334	Radiology Addition	OSHPD 1-In Service	4			2	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-00335	OR/Amb. Care Addn - Bldg D, North	OSHPD 1-In Service	5s			2	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-02980	OR/Amb. Care Addn - Bldg D, South	OSHPD 1-In Service	5s			2	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-05228	ER, ICU & Radiology Expansion - Building G	OSHPD 1-In Service	5s			4s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-05281	Bed Addition, Building "i"	OSHPD 1-In Service	5s			4s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-05282	ER, ICU & Radiology Expansion - Building F	OSHPD 1-In Service	5s			4s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-05284	ER, ICU & Radiology Expansion - Building H	OSHPD 1-In Service	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-05521	ER, ICU & Radiology Expansion - Building B1D	OSHPD 1-In Service	5s			4s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-06605	Replacement Hospital	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-06606	Central Plant	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-06776	Main Entry Canopy	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-06777	Loading Dock Canopy	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	15749	Southwest Healthcare Inland Valley Hospital	Wildomar	BLD-06807	Service Building	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	Murrieta	BLD-00290	Original Hospital Building & Conversions	OSHPD 1-In Service	4s			2	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	Murrieta	BLD-00291	Acute Care Addition	OSHPD 1-In Service	3s			2	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	Murrieta	BLD-05229	Women's Center and Emergency Room	OSHPD 1-In Service	5s			2	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	Murrieta	BLD-06770	Entry Canopy	OSHPD 1-Under Construction	5s			5s	
33 - Riverside	16681	Southwest Healthcare Rancho Springs Hospital	Murrieta	BLD-06828	Hospital and Women's Center Generator	OSHPD 1-Equipment Yard	N/A			4s	
33 - Riverside	18167	Temecula Valley Hospital	Temecula	BLD-05259	Main Hospital	OSHPD 1-In Service	5			4	
33 - Riverside	18167	Temecula Valley Hospital	Temecula	BLD-06130	D&T Expansion 2018	OSHPD 1-In Service	5			4	
33 - Riverside	18167	Temecula Valley Hospital	Temecula	BLD-07279	Drop Off Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-06522	CNU Medical Center	OSHPD 1-Proposed	5s			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-06523	Central Plant	OSHPD 1-Proposed	5s			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07308	Open Parking Garage (North)	OSHPD 1-Proposed	5s			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07309	Open Parking Garage (South)	OSHPD 1-Proposed	5s			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07523	WT-03 Water Tank	OSHPD 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07524	WT-04 Water Tank	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07525	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07526	WT-02 Water Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07527	FT-01 Fuel Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07528	FT-02 Fuel Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07529	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10027	California Northstate University Medical Center	Sacramento	BLD-07530	WWT-02 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01419	Hospital	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01420	Hospital Addition Tower	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01421	3 - Hospital Addition Clinic	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-01422	Camellia Building	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-03284	ATS Building	OSHDP 1-In Service	5			4	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-03557	Telephone Equipment Building	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-05469	Central Utility Building	OSHDP 1-In Service	5			4	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-05905	Camellia Utility Bridge	OSHDP 1-In Service	5			4	
34 - Sacramento	10604	Kaiser Foundation Hospital - Sacramento	Sacramento	BLD-06474	ED Expansion	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00319	Hospital, Building 1	OSHDP 1-In Service	4			2	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00320	Hospital, Building 2	OSHDP 1-In Service	4			2	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00321	Hospital Expansion	OSHDP 1-In Service	4			2	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-00322	Central Plant	OSHDP 1-In Service	4			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03502	Communications Building	OSHDP 1-In Service	4			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03503	ER / Radiology Expansion	OSHDP 1-In Service	5s			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03608	Central Utility Plant (Chiller Plant)	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-03609	Hospital Addition	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06109	ED Trauma Addition	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06128	Corridors	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06249	CUP Water Tank No. 2 (WT-01)	OSHDP 1-Tanks	N/A			5	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-06602	ED Expansion	OSHDP 1-In Service	5			4	
34 - Sacramento	15570	Kaiser Foundation Hospital - South Sacramento	Sacramento	BLD-07600	WWT-01 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-06442	Hospital	OSHDP 1-Under Construction	5s			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-06443	Energy Center	OSHDP 1-Under Construction	5s			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-06444	Entry Canopy	OSHDP 1-Under Construction	5s			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-06446	Ambulance Canopy	OSHDP 1-Under Construction	5s			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07266	Fire Pump House	OSHDP 1-Under Construction	5s			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07269	Oxygen Yard	OSHDP 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07501	WT-01 Water Tank	OSHDP 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07502	WT-02 Water Tank	OSHDP 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07503	WT-03 Water Tank	OSHDP 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07504	WWT-01 Wastewater Tank	OSHDP 1-Under Construction	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07505	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07506	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07507	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
34 - Sacramento	10022	Kaiser Foundation Hospital Sacramento	Sacramento	BLD-07508	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01423	South Wing / East Wing (South Wing)	OSHPD 1-In Service	2		0.26	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01424	East Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01425	Northeast Wing, Part A	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01426	Northeast Wing, Part B	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-01427	North Wing	OSHPD 1-In Service	4s			2	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03110	Northeast Wing, Part D	OSHPD 1-In Service	4			2	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03380	Heart Center	OSHPD 1-In Service	5			4	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-03381	Equipment Yard	OSHPD 1-Equipment Yard	N/A			2s	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-05211	2 Story Corridor Structure	OSHPD 1-In Service	3			2	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-05212	4 Story Corridor Structure - Structurally connected to BLD-01427	OSHPD 1-Not an Independent Building	N/A			N/A	
34 - Sacramento	10606	Mercy General Hospital	Sacramento	BLD-06125	Ambulance Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00078	South	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00079	West	OSHDP 1-In Service	4			2	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00080	East	OSHDP 1-In Service	4			2	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-00081	Central Plant	OSHDP 1-In Service	4			2	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-06990	Central Plant Addition	OSHDP 1-In Service	5s			4s	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-06991	Ambulance Canopy	OSHDP 1-In Service	5s			4s	
34 - Sacramento	16150	Mercy Hospital Of Folsom	Folsom	BLD-06992	Emergency Department	OSHDP 1-In Service	5s			4s	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01428	Original Hospital	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01429	Central Plant	OSHDP 1-In Service	4D			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01430	CCU/Telemetry	OSHDP 1-In Service	4			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01431	New Central Plant	OSHDP 1-In Service	5			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01432	New Hospital Wing	OSHDP 1-In Service	5			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-01433	Cath Lab Addition	OSHDP 1-In Service	4			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-03404	McAuley Tower	OSHDP 1-In Service	5			4	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-05784	McAuley Canopy	OSHDP 1-In Service	5			4	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-06461	Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-06988	McAuley Canopy - Low	OSHDP 1-In Service	5			4	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-06989	Lobby and Connecting Corridor	OSHDP 1-In Service	5			4	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-07284	Emergency Shower	OSHDP 1-In Service	5			2	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-07285	Vehicular Emergency Canopy	OSHDP 1-In Service	5			4	
34 - Sacramento	10607	Mercy San Juan Medical Center	Carmichael	BLD-07286	Emergency Entry	OSHDP 1-In Service	5			4	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00971	West Wing	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00972	East Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00973	Central Plant	OSHPD 1-In Service	4			2	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00974	ER Addition	OSHPD 1-In Service	4			2	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-00975	North Wing	OSHPD 1-In Service	5			2	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03216	ED Expansion	OSHPD 1-In Service	5			4	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03696	Medical Gas Building	OSHPD 1-In Service	4			2	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03705	East Wing Addition	OSHPD 1-In Service	5			3	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-03706	East Wing Canopy	OSHPD 1-In Service	5			2	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06308	ED Upper South Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06309	ED Lower South Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	13012	Methodist Hospital of Sacramento	Sacramento	BLD-06310	ED North Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	Sacramento	BLD-06365	Vibra Rehabilitation Hospital of Natomas	OSHPD 1-In Service	5			5	Earthquake Resilient
34 - Sacramento	11326	Sacramento Rehabilitation Hospital	Sacramento	BLD-06397	Main Entry Drop Off Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
34 - Sacramento	14506	Shriners Hospitals For Children Northern California	Sacramento	BLD-02530	Main Hospital	OSHPD 1-In Service	4s			2	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-01446	Main Hospital	OSHPD 1-In Service	4			2	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03264	Radiation Oncology Center - Structurally connected to BLD-05216	OSHPD 1-Not an Independent Building	N/A			N/A	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03622	Sutter Capital Pavilion	OSHPD 1-In Service	5			4	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-03629	Foot Bridge	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05216	Women's & Children's Center	OSHPD 1-In Service	5s			2	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05907	Sutter Capital Pavilion Utility Tunnel	OSHPD 1-Tunnels	N/A			4	
34 - Sacramento	10625	Sutter Medical Center, Sacramento	Sacramento	BLD-05908	Main Hospital Utility Tunnel	OSHPD 1-Tunnels	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	Sacramento	BLD-06469	UC Davis Rehabilitation Institute	OSHPD 1-In Service	5			5	Earthquake Resilient
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	Sacramento	BLD-06470	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A			5	
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	Sacramento	BLD-06664	Porte-Cochere	OSHPD 1-In Service	5			5	Earthquake Resilient
34 - Sacramento	10025	UC Davis Rehabilitation Hospital	Sacramento	BLD-07357	Trash Enclosure	OSHPD 1-In Service	5			5	Earthquake Resilient
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01434	North/South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		4.3	N/A	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01435	University Surgery Center - Structurally connected to BLD-01434	OSHPD 1-Not an Independent Building	N/A			N/A	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01436	East Wing (Tower)	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01437	East Wing (Radiology)	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01438	East Wing (Laundry)	OSHPD 1-In Service	4			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01439	University Tower	OSHPD 1-In Service	4			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01440	MRI	OSHPD 1-In Service	4			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01443	Emergency Room Expansion	OSHPD 1-In Service	4			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01444	Central Plant	OSHPD 1-In Service	5			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-01445	Davis Tower	OSHPD 1-In Service	5			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-02840	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-02841	Surgery and Emergency Services Pavilion	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-05815	CT Scan Building	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-06783	California Tower	OSHPD 1-Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-06825	Interim Ambulance Canopy	OSHPD 1-Proposed	5s			4s	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-06826	Interim Drop-off Canopy	OSHPD 1-Proposed	5s			4s	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07203	CUP Annex	OSHPD 1-Under Construction	5s			5s	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07261	Surgery and Emergency Services Pavilion - West	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07262	Loading Dock Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07263	Entry Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07264	Vestibule Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07265	Mechanical Room	OSHPD 1-In Service	5			2	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07281	Gas Bottle Storage	OSHPD 1-In Service	5			4	
34 - Sacramento	10619	University of California Davis Medical Center	Sacramento	BLD-07324	University Tower Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-03267	Main Building	OSHPD 1-In Service	5			4	
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05493	Entry Canopy	OSHPD 1-In Service	5			4	
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05494	Biowaste / Storage Building	OSHPD 1-In Service	5			4	
34 - Sacramento	10631	Vibra Hospital of Sacramento	Folsom	BLD-05495	Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01458	Original Hospital Building	OSHPD 1-In Service	2	0.28		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01459	ICU	OSHPD 1-In Service	4			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-01460	Conference	OSHPD 1-In Service	4			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03063	Emergency Room	OSHPD 1-In Service	4			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03064	Reception	OSHPD 1-In Service	3			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03065	Radiology	OSHPD 1-In Service	4			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03472	Entrance Canopy	OSHPD 1-In Service	3			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03761	Emergency Department Expansion	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-03820	Radiology Wing	OSHPD 1-In Service	5			2	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-05467	Women's Center	OSHPD 1-In Service	5			4	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-05874	William and Inez Mabie SNF	OSHPD 2-Skilled Nursing Only	N/A			N/A	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-07362	Entrance Canopy	OSHPD 1-In Service	5			4	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-07363	Connecting Corridor	OSHPD 1-In Service	5			4	
35 - San Benito	10640	Hazel Hawkins Memorial Hospital	Hollister	BLD-07763	Electrical Utility Building	OSHPD 1-In Service	4s			2s	
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00071	Diagnostic & Treatment Bldg.	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00072	Nursing Tower	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00073	Clinics Building	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00074	Mental Health Building	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00075	Central Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00076	MRI Building	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	17282	Arrowhead Regional Medical Center	Colton	BLD-00077	Loading Dock	OSHPD 1-In Service	3			5	
36 - San Bernardino	16877	Ballard Rehabilitation Hospital	San Bernardino	BLD-00293	Hospital	OSHPD 1-In Service	3			2	
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05294	Main Hospital Tower - North	OSHPD 1-In Service	5			4	
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05295	Main Hospital - South	OSHPD 1-In Service	5			4	
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05296	Porte-Cochere	OSHPD 1-In Service	5			4	
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05297	Entrance Canopy - East	OSHPD 1-In Service	5			4	
36 - San Bernardino	18197	Barstow Community Hospital	Barstow	BLD-05298	Entrance Canopy - West	OSHPD 1-In Service	5			4	
36 - San Bernardino	13035	Bear Valley Community Hospital	Big Bear Lake	BLD-00987	Main Hospital Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13035	Bear Valley Community Hospital	Big Bear Lake	BLD-00988	Mechanical Building	OSHPD 1-In Service	2	0.44		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01003	Building 1 (Main Core)	OSHPD 1-In Service	2	0.54		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01004	Building Two	OSHPD 1-In Service	3			2	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01005	Building Three	OSHPD 1-In Service	3			2	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01006	Building Four	OSHPD 1-In Service	3			2	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-01007	Building Five	OSHPD 1-In Service	3			2	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-07250	Main Entrance Canopy	OSHPD 1-In Service	3s			2s	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-07251	Ambulance Canopy	OSHPD 1-In Service	3s			2s	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-07252	Nuclear Medicine	OSHPD 1-In Service	3s			2s	
36 - San Bernardino	13072	Chino Valley Medical Center	Chino	BLD-07253	Storage	OSHPD 1-In Service	4s			2s	
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01471	Main Hospital, Wing A	OSHPD 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01472	Main Hospital, Wing B	OSHPD 1-In Service	2		0	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10684	Colorado River Medical Center	Needles	BLD-01473	Main Hospital, Wing C	OSHPD 1-In Service	2		0.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01846	Original Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	4.54		N/A	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01847	Storage Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	4.12		N/A	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01848	Physical Therapy	OSHPD 1-In Service	4			2	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01849	South Hospital	OSHPD 1-In Service	3s			2	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01850	North Hospital	OSHPD 1-In Service	3s			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01851	Wings 700/800/900	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01852	Utility/Central Plant 1/Service Buildings	OSHPD 1-In Service	2	1.2	1.2	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01853	Central Plant #2	OSHPD 1-In Service	4s			2	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-01854	Central Plant #3	OSHPD 1-In Service	4s			2	
36 - San Bernardino	10697	Community Hospital of San Bernardino	San Bernardino	BLD-03223	Telecom Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01046	Main Hospital Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01047	Birthing Center	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-01048	Emergency Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-02612	Main Hospital Entrance Canopy	OSHPD 1-In Service	4			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-02613	Emergency Room Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05640	Outpatient Surgery Waiting & Connecting Corridor	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05641	Cath Lab and Surgery Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-05642	65 Bed Acute Care Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-07204	ED Addition	OSHPD 1-Proposed	5s			5s	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-07602	CUP	OSHPD 1-Proposed	5s			5s	
36 - San Bernardino	12763	Desert Valley Hospital	Victorville	BLD-07606	Oxygen Yard	OSHPD 1-Proposed	N/A			5s	
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-00245	Acute Care Hospital Building	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-00246	Emergency Department Addition	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05124	Continuing Care Center	OSHPD 2-Skilled Nursing Only	N/A			N/A	
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05702	Perinatal Addition	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-05703	Pedestrian Walkway	OSHPD 1-In Service	5			5	Earthquake Resilient

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06062	Emergency Water Supply Pump Enclosure	OSHPD 1-Not a Building Structure	N/A			5	
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06105	Cooling Tower and Emergency Generator	OSHPD 1-Equipment Yard	N/A			5	
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06106	Emergency Ambulance Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06576	Electrical Building	OSHPD 1-Under Construction	5s			5s	
36 - San Bernardino	14100	Hi-Desert Medical Center	Joshua Tree	BLD-06577	Generator Enclosure	OSHPD 1-Under Construction	N/A			5s	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01494	Phase 2	OSHPD 1-In Service	2		0.62	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01495	Phase 1A3 - Structurally connected to BLD-01489	OSHPD 1-Not an Independent Building	N/A			N/A	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01496	Central Plant	OSHPD 1-In Service	4			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01498	Phase 4 Building	OSHPD 1-In Service	3			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01499	Phase 5 Building	OSHPD 1-In Service	3			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01500	MRI Addition	OSHPD 1-In Service	4			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-01501	Telecom Addition	OSHPD 1-In Service	4			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-03053	Parking Structure	OSHPD 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05250	Central Plant	OSHPD 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05251	Hospital Tower	OSHPD 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05512	Phase 3	OSHPD 1-In Service	2		0.52	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05564	Hospital Support Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05602	Hospital Drop-off Canopy	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05603	ED Drop-off Canopy	OSHDP 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05604	Loading Dock Storage	OSHDP 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05605	Central Plant Storage	OSHDP 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-05606	Pedestrian Tunnel	OSHDP 1-Tunnels	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-06933	MRI Addition #2	OSHDP 1-In Service	5			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-06981	Cooling Tower Yard	OSHDP 1-Equipment Yard	N/A			4	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07182	Phase 2 Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07183	Phase 5 Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07413	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07414	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07415	WT-02 Water Tank	OSHDP 1-Proposed	N/A			5s	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07416	WWT-02 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07444	FT-01 Fuel Tank	OSHDP 1-Tanks	N/A			5	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07445	FT-02 Fuel Tank	OSHDP 1-Tanks	N/A			5	
36 - San Bernardino	10670	Kaiser Foundation Hospital - Fontana	Fontana	BLD-07601	WT-03 Water Tank	OSHDP 1-Tanks	N/A			5s	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-05244	Main Hospital	OSHDP 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-05258	Central Utility Plant	OSHDP 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06958	Tech Dock Canopy 1	OSHDP 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06959	Tech Dock Canopy 2	OSHDP 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06960	Tech Dock Canopy 3	OSHDP 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06961	Tech Dock Canopy 4	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06962	E.D. Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06963	Medical Storage Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06964	CUP Expansion	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06965	IT Admin	OSHPD 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-06966	IT Plant	OSHPD 1-In Service	5			4	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-07420	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
36 - San Bernardino	17905	Kaiser Foundation Hospital - Ontario	Ontario	BLD-07421	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-01466	Building I	OSHPD 1-In Service	2	31.75	3.87	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-01467	Ambulance Canopy	OSHPD 1-In Service	4s			3	
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05842	Building III (Patient Wing 5)	OSHPD 1-In Service	2		0.75	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05843	Building IV (Support Services)	OSHPD 1-In Service	2		1.07	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05844	Building V (Patient Wing 6)	OSHPD 1-In Service	2		0.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10685	Kindred Hospital Ontario	Ontario	BLD-05845	Building VI (Patient Wing 7)	OSHPD 1-In Service	2		0.1	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	14102	Kindred Hospital Rancho	Rancho Cucamonga	BLD-03042	Original Building	OSHPD 1-In Service	5			2	
36 - San Bernardino	14102	Kindred Hospital Rancho	Rancho Cucamonga	BLD-03043	Generator Enclosure	OSHPD 1-Equipment Yard	N/A			2	
36 - San Bernardino	14102	Kindred Hospital Rancho	Rancho Cucamonga	BLD-07010	Drop Off Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	Redlands	BLD-07345	Loma Linda Rehabilitation Hospital	OSHPD 1-Proposed	5s			5s	
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	Redlands	BLD-07346	Porte-Cochere	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	Redlands	BLD-07347	Trash Enclosure	OSHDP 1-Proposed	5s			5s	
36 - San Bernardino	10101	Loma Linda Rehabilitation Hospital	Redlands	BLD-07348	Generator Yard	OSHDP 1-Proposed	N/A			5s	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01479	Main Hospital Tower - Area C	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		11.44	N/A	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01480	Main Hospital Tower - Area B	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01481	Emergency Room Expansion - 1976	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01482	Northeast Wing - Schuman Pavilion	OSHDP 1-In Service	4			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01483	South Wing Phase 2	OSHDP 1-In Service	3			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01484	Emergency Room Expansion - 1987 - Structurally connected to BLD-01481	OSHDP 1-Not an Independent Building	N/A			N/A	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01485	South Wing Phase I	OSHDP 1-In Service	3			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-01486	Co-Generation Plant	OSHDP 1-In Service	4			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-02961	Chiller Facility	OSHDP 1-In Service	4			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03021	South Wing Phase I	OSHDP 1-In Service	3			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03022	South Wing Phase I	OSHDP 1-In Service	3			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03023	Main Hospital Tower - Area A	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		14.07	N/A	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03024	South Wing Phase 2	OSHDP 1-In Service	3			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-03025	Original Plant	OSHDP 1-In Service	4D		7.34	4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05372	Utility Tunnel Expansion	OSHDP 1-Tunnels	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05373	Utility Tunnel	OSHDP 1-Tunnels	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05375	Edison Yard (Underground Vault)	OSHDP 1-In Service	N/A			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05482	Emergency Generator Fuel Tank	OSHDP 1-Equipment Yard	N/A			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05488	South Tower Fuel Tank	OSHDP 1-Equipment Yard	N/A			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05489	South Tower Bulk Medical Gas	OSHDP 1-Equipment Yard	N/A			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05490	Emergency Generator	OSHDP 1-In Service	5			2	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05592	South Wing Tunnel Phase 1	OSHDP 1-Tunnels	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-05878	New Replacement Hospital	OSHDP 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06022	Utility Tunnel – BLD 12B	OSHDP 1-Tunnels	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06028	Chiller Plant	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06032	CTP Generator Enclosure	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06068	Unimed Switchgear	OSHDP 1-Not a Building Structure	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06070	CTP Decontam Shower	OSHDP 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06071	CTP Loading Dock Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06072	CTP Entrance Canopy	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06073	CTP Galleria	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06074	CTP 7 & 8 Connector	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06075	CTP Grand Hallway Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06076	Schuman Addition	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06077	Schuman Bridge	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06395	Shop Canopy	OSHDP 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06406	Bulk Medical Gas	OSHDP 1-Equipment Yard	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06740	TES Generator	OSHDP 1-Under Construction	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06791	CTP Emergency Generator No. 1	OSHPD 1-Not a Building Structure	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06792	CTP Emergency Generator No. 2	OSHPD 1-Not a Building Structure	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06793	CTP Emergency Generator No. 3	OSHPD 1-Not a Building Structure	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06794	CTP Emergency Generator No. 4	OSHPD 1-Not a Building Structure	N/A			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-06839	P3 Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10677	Loma Linda University Medical Center	Loma Linda	BLD-07786	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5s	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01008	Hospital Ancillary	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01009	Nursing Wing	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01010	X-Ray Addition	OSHPD 1-In Service	4			2	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-01011	Storage Addition	OSHPD 1-In Service	4			2	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-02882	24 Bed Rehabilitation Hospital	OSHPD 1-In Service	5			4	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-03814	Telephone Building	OSHPD 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-05593	Mechanical Room	OSHPD 1-In Service	5			4	
36 - San Bernardino	13073	Loma Linda University Medical Center East Campus Hospital	Loma Linda	BLD-05793	24 Bed Rehabilitation Hospital - Covered Walkway	OSHPD 1-In Service	5			4	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	Redlands	BLD-05322	Heart and Surgical Hospital	OSHPD 1-In Service	5			4	
36 - San Bernardino	18161	Loma Linda University Surgical Hospital	Redlands	BLD-07186	Equipment Yard	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00963	Service Wing - Original Hospital	OSHPD 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00965	Service Wing - Dining Room Addition	OSHPD 1-In Service	5s			4D-L1		
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00966	Service Wing - Medical Records Addition	OSHPD 1-In Service	4			4D-L1		
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00967	North Wing - Original Hospital	OSHPD 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00968	North Wing - Labor & Delivery Addition	OSHPD 1-In Service	5			2		
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00969	East Wing - Original Hospital	OSHPD 1-In Service	2	0.2		4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-00970	Plant Services - Original Hospital	OSHPD 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-02737	Plant Services - Engineering Addition	OSHPD 1-In Service	4			4D-L1		
36 - San Bernardino	12992	Montclair Hospital Medical Center	Montclair	BLD-06936	Monochloramine Generating Station	OSHPD 1-Proposed	5s			4s		
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01474	Main Building	OSHPD 1-In Service	2		3.73	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01475	Radiology/Lab and ER Addition	OSHPD 1-In Service	5			2		
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01476	ER Addition - Structurally connected to BLD-01475	OSHPD 1-Not an Independent Building	N/A				N/A	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01477	Emergency Generator Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				N/A	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-01478	Oxygen Storage Bldg	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A				N/A	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-03687	Emergency Generator Bldg II	OSHPD 1-In Service	5			2		
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-05687	LOX Yard	OSHPD 1-Equipment Yard	N/A				4	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-06479	Skilled Nursing Building	OSHPD 1R-Skilled Nursing Only	N/A				N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-07304	Med/Surg and ED Addition	OSHDP 1-Proposed	5s			5s	
36 - San Bernardino	10681	Mountains Community Hospital	Lake Arrowhead	BLD-07305	Porte-Cochere	OSHDP 1-Proposed	5s			5s	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01821	Original Hospital & ER	OSHDP 1-In Service	2	0.53		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01822	Transitional Care-CCU/ICU	OSHDP 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01823	Emergency Addition - Structurally connected to BLD-01821	OSHDP 1-Not an Independent Building	N/A			N/A	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01824	CCU/ICU Addition - Structurally connected to BLD-01822	OSHDP 1-Not an Independent Building	N/A			N/A	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01825	Boiler Building	OSHDP 1-In Service	2	0.13		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01826	Chiller Building	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01827	Surgery Addition	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01828	West Addition	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01829	East Wing	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01830	Obstetrics/Prenatal/LDR Addition	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01831	Medical/Surgical	OSHDP 1-In Service	4			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-01832	New Hospital Building	OSHDP 1-In Service	5			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-02928	MRI Building	OSHDP 1-In Service	2		0.79	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06087	Filter Building	OSHDP 1-In Service	5			2	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06088	South Building Connector	OSHDP 1-In Service	5			3	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06089	South Building West Canopy	OSHDP 1-In Service	5			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06090	South Building South Canopy	OSHDP 1-In Service	5			3	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06230	Inpatient MRI Building	OSHDP 1-In Service	5			4	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06404	Generator Yard	OSHDP 1-Equipment Yard	N/A			4	
36 - San Bernardino	10695	Providence St. Mary Medical Center	Apple Valley	BLD-06405	Generator Distribution / Transfer Switch Building	OSHDP 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01801	Original Main Hospital	OSHDP 1-In Service	2		0.96	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01802	Part 1 Addition - Tower	OSHDP 1-In Service	2	0.3		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01803	Part 2 Addition - Surgery	OSHDP 1-In Service	2	0.2		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01804	Part 3 Addition - Admitting	OSHDP 1-In Service	2	0.27		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01806	Central Plant	OSHDP 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01807	Radiology Addition	OSHDP 1-In Service	2		0.17	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01808	Patient Tower	OSHDP 1-In Service	3			2	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01809	Central Supply	OSHDP 1-In Service	4			2	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01810	North Hallway	OSHDP 1-In Service	3			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01811	Radiotherapy Addition	OSHDP 1-In Service	5			2	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-01813	Emergency Building 2	OSHDP 1-In Service	4			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02812	Phase 2 Building Addition	OSHDP 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02813	1958 Radiology Building	OSHDP 1-In Service	2		0.77	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-02814	Electrical Utility Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-05892	Surgery Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-05904	Oxygen Farm	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06299	Gift Shop Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06327	North / South Utility Tunnel	OSHPD 1-Tunnels	N/A			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-06328	East / West Utility Tunnel	OSHPD 1-Tunnels	N/A			4	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-07474	Phase 3 Replacement Building	OSHPD 1-Proposed	5s			5s	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-07633	Pump House	OSHPD 1-Proposed	5s			5s	
36 - San Bernardino	10691	Redlands Community Hospital	Redlands	BLD-07634	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01833	Auditorium & Administration	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01834	Latimer Wing	OSHPD 1-In Service	2		1.16	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01835	Maternity - Structurally connected to BLD-01834	OSHPD 1-Not an Independent Building	N/A			N/A	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01836	Power Plant	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01837	Laundry Building	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01838	Main Building	OSHPD 1-In Service	2	0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01839	Increment II, Phase 1 - East	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01840	Increment II	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01841	Maternity Addition	OSHPD 1-In Service	5			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01842	Mental Health - South	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01843	Increment II - Phase 2 East & Middle	OSHPD 1-In Service	3			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-01845	NICU Addition	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03020	Increment II - Phase 2 West Section	OSHPD 1-In Service	3			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03542	Mental Health - North	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-03548	Increment II, Phase 1 - North	OSHPD 1-In Service	4			2	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-05253	Main Hospital Tower	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06154	New Oxygen Service Area	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06377	East Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06378	West Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06385	Central Plant	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06386	Emergency Drive Canopy	OSHPD 1-In Service	3			3	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06387	Emergency Walkway Canopy	OSHPD 1-In Service	3			3	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06604	Main Electrical Switchgear Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-06619	New Tower - Pedestrian Corridor	OSHPD 1-In Service	5			4	
36 - San Bernardino	10696	San Antonio Regional Hospital	Upland	BLD-07626	West Wing Corridor (formerly Latimer / Maternity)	OSHPD 1-Proposed	2s			2s	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01814	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		36.74	N/A	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01815	South Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	4.76		N/A	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01816	Emergency Building	OSHPD 1-In Service	3s			3	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01817	Central Tower	OSHPD 1-In Service	4D	4.22		2	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01818	North Tower	OSHPD 1-In Service	3			3	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01819	Service Building	OSHPD 1-In Service	4			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-01820	Ancillary Building	OSHPD 1-In Service	2	5.06	1.1	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-03363	Cooling Tower Yard	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-05639	IT Services Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06229	CoGen Plant	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06255	Loading Dock Canopy	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06259	CCU Med Air and Vacuum Canopy	OSHPD 1-In Service	5			4	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06260	Medical Gas Canopy	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	10694	St. Bernardine Medical Center	San Bernardino	BLD-06287	Conference Center	OSHPD 1-In Service	3			3	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-04912	Subacute	OSHPD 2-Skilled Nursing Only	N/A			N/A	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-05483	Acute Care Building No. 1	OSHPD 1-In Service	5			4	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-05959	Emergency Generator	OSHPD 1-Equipment Yard	N/A			4	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-06126	Medical Gas Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	18201	Totally Kids Rehabilitation Hospital	Loma Linda	BLD-06127	Lighthouse Bulk Medical Gas Building	OSHPD 1-In Service	5			4	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01855	Medical / Surgical / Surgery Add	OSHPD 1-In Service	3			2	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01856	Radiology/Surgery/L&D/Emergency	OSHPD 1-In Service	2	2.18	0.27	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01857	Equipment Shelter Pump House	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01858	Emergency Building - Structurally connected to BLD-01856	OSHPD 1-Not an Independent Building	N/A				N/A	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01859	Nursing Wing (BHU/PCU)	OSHPD 1-In Service	2	0.53			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01860	Cath Lab/ICU/Outpatient Surgery	OSHPD 1-In Service	4				2	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01861	Emergency Generator Room	OSHPD 1-In Service	4				2	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-01862	Urgent Care E.R. Expansion	OSHPD 1-In Service	3				2	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03131	O.B. Addition	OSHPD 1-Under Construction	N/A				N/A	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03132	Canopy Addition	OSHPD 1-In Service	3s				2	
36 - San Bernardino	10707	Victor Valley Global Medical Center	Victorville	BLD-03134	Helistop	OSHPD 1-In Service	5				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02098	Emergency Generator Building	OSHPD 1-In Service	4				4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02099	West Wing - West	OSHPD 1-In Service	2	0.12			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02100	North Wing	OSHPD 1-In Service	2	0.03			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02101	South Wing	OSHPD 1-In Service	2	0.09			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02102	Central Plant & Cooling Plant Expansion	OSHPD 1-In Service	4				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02103	East Wing	OSHPD 1-In Service	4				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02104	Physical Rehabilitation Unit	OSHPD 1-In Service	4				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02105	Meeting Room Addition	OSHPD 1-In Service	3				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02622	Main Entry	OSHPD 1-In Service	4				2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02829	Heart and Vascular Center	OSHPD 1-In Service	5				4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-02830	New Central Plant	OSHDP 1-In Service	5			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03678	Old Administration Building	OSHDP 1-In Service	2	0	0.01	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03683	Womens Health Center	OSHDP 1-In Service	3			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03685	East Wing Addition	OSHDP 1-In Service	4			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03767	West Wing - East	OSHDP 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-03768	West Wing - North	OSHDP 1-In Service	2	0.15	0.15	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05312	Mental Health Building	OSHDP 5-Acute Psych Only	N/A			N/A	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05336	ED/CCU and ACNU Building	OSHDP 1-In Service	5			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05368	Physical Rehabilitation Utility Vault	OSHDP 1-In Service	4s			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05510	MRI / Angio Addition	OSHDP 1-In Service	4			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05678	Utility Tunnel	OSHDP 1-Tunnels	N/A			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05764	Emergency Generator 1	OSHDP 1-Not a Building Structure	N/A			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-05765	Emergency Generator 2	OSHDP 1-Not a Building Structure	N/A			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-06787	Neuro ICU Addition	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-06788	PCU Addition	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-06867	Main Entry Canopy	OSHDP 1-In Service	4			2	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07007	South Loading Dock	OSHDP 1-In Service	4D			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07008	Utility Trellis	OSHDP 1-Not a Building Structure	N/A			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07070	Tunnel / Storage Room	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07071	ER Substation	OSHDP 1-In Service	5s			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07153	Oxygen Yard	OSHDP 1-Equipment Yard	N/A			4	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07685	WT-01 Water Tank	OSHDP 1-Tanks	N/A			5	
37 - San Diego	12322	Grossmont Hospital	La Mesa	BLD-07686	WWT-01 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-02943	Hospital	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-03552	Central Utility Plant	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-05690	Hospital Support Building	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06311	Main Entrance Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06312	Emergency Entry Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06313	Fire Pump Room	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06314	Tech Dock Canopy - Lower	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	18199	Kaiser Foundation Hospital - San Diego	San Diego	BLD-06315	Tech Dock Canopy - Upper	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-06531	Hospital Building	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-06532	Central Plant	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-06533	Entry Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-06534	ED Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-06536	Garden Canopy	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-07097	Tech Dock Canopy West	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-07098	Tech Dock Canopy East	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-07100	Bulk Oxygen Yard	OSHDP 1-Equipment Yard	N/A			5	
37 - San Diego	10028	Kaiser Foundation Hospital - San Marcos	San Marcos	BLD-07101	Bunker Fire Pump Rooms	OSHDP 1-In Service	5			5	Earthquake Resilient
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00198	Hospital Tower	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00199	Hospital Tower Addition	OSHDP 1-In Service	3			2	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00200	Clinic Tower Addition	OSHDP 1-In Service	3			2	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00201	Central Plant	OSHDP 1-In Service	3			2	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00202	Emergency Generator Building	OSHDP 1-In Service	4			2	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-00203	Cooling Tower	OSHDP 1-Not a Building Structure	N/A			2	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-03295	Med Gas Chain Link Fence Enclosure	OSHDP 1-In Service	5			4	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-07426	WWT-01 Wastewater Tank	OSHDP 1-Proposed	N/A			5s	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-07427	FT-01 Fuel Tank	OSHDP 1-Proposed	N/A			5s	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-07428	WT-01 Water Tank	OSHDP 1-Proposed	N/A			5s	
37 - San Diego	13111	Kaiser Foundation Hospital - Zion	San Diego	BLD-07429	WT-02 Water Tank	OSHDP 1-Proposed	N/A			5s	
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02106	Building I (Building A)	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02107	Building II (Building B)	OSHDP 1-In Service	2	0.67		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02108	Building III (Building C)	OSHDP 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02109	Building IV (Building D)	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-02110	Building V (Building E)	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12328	Kindred Hospital - San Diego	San Diego	BLD-07607	Exterior Blue Canopy	OSHDP 1-In Service	5s			4s	
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-05231	Hospital	OSHDP 1-In Service	5			4	
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-05232	Central Plant	OSHDP 1-In Service	5s			4	
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-07814	WWT Wastewater Tanks	OSHDP 1-Proposed	N/A			N/A	
37 - San Diego	18173	Palomar Medical Center	Escondido	BLD-07815	WT Water Tanks	OSHDP 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-00255	Patient Tower	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-00256	Ancillary Building (East)	OSHPD 1-In Service	4s			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-00257	Central Plant	OSHPD 1-In Service	4			4	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-00258	Angio / Cath Lab Addition	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-00259	Emergency Room Addition	OSHPD 1-In Service	5			4	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-02896	Co-Generation Building	OSHPD 1-In Service	4			4	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03240	Entrance Canopy	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03241	Pedestrian Link	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03588	Villa Pomerado	OSHPD 2-Skilled Nursing Only	N/A			N/A	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03589	Steam Plant	OSHPD 1-Equipment Yard	N/A			4	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03592	Patient Elevator Tower	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-03593	Lobby	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-06245	Ancillary Building (West)	OSHPD 1-In Service	4s			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-06246	Loading Dock/Electrical Room	OSHPD 1-In Service	4			2	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-06451	Power Conditioning UPS/ATS Building	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-06808	Covered Walkway	OSHPD 1-In Service	5			4	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-07812	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A			5s	
37 - San Diego	14190	Palomar Medical Center Poway	Poway	BLD-07813	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
37 - San Diego	18230	Palomar Rehabilitation Institute	Escondido	BLD-06258	Palomar Rehabilitation Institute	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02132	Main Tower	OSHPD 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02133	West Wing	OSHPD 1-In Service	2	0.54		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02134	East Wing	OSHPD 1-In Service	4			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02135	ER Expansion	OSHPD 1-In Service	4			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02136	Boiler Building	OSHPD 1-In Service	4			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02137	Pediatrics Wing	OSHPD 1-In Service	5s			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02138	Chiller Building	OSHPD 1-In Service	5s			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02139	Generator Building	OSHPD 1-In Service	5s			4	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02140	Medical Office Building	OSHPD 1-In Service	3s			2	
37 - San Diego	12348	Paradise Valley Hospital	National City	BLD-02141	Storage Building - BLD-06432 at 24384	OSHPD 1-Not an Independent Building	N/A	0.89		N/A	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02066	Dining Room - Original Hospital	OSHPD 1-In Service	2	0.16		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02070	2nd Dining Room - Original Hospital	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02071	Intensive Care Unit	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02072	Co-Generation Plant	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02073	Clinical Lab	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02076	Radiology Addition	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02079	Children's Way Pavilion (15A & 15B)	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02080	Children's Way Pavilion - Clock Tower	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02669	Surgical Unit	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02770	Gas Storage Building	OSHPD 1-Equipment Yard	N/A			4	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02772	Bridge to Acute Care Pavilion	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-02773	Emergency Generator Building	OSHPD 1-In Service	5			4	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03127	C Wing - Original Hospital	OSHPD 1-In Service	2	0.16		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03128	D Wing - Original Hospital	OSHPD 1-In Service	2	0.07		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03129	Bridge to Sharp Hospital - Structurally connected to BLD-03128	OSHPD 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03130	Trauma Room Addition	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03195	Intensive Care Unit	OSHPD 1-In Service	4			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03197	Passageway to NICU	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03198	Children's Way Pavilion - Bridge	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03647	Acute Care Pavilion	OSHPD 1-In Service	5			4	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-03896	Hahn Pavilion Loading Dock Canopy	OSHPD 1-In Service	3			3	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06800	ICU/ES Pavilion	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06801	Campus Connector	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06802	Central Utility Plant	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06803	Entry Canopy	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06804	Ambulance Canopy	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-06805	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A			4	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-07360	MBH Bridge	OSHPD 5-Proposed	N/A			N/A	
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-07361	Mental and Behavioral Health Building (MBH)	OSHPD 5-Proposed	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12285	Rady Children's Hospital San Diego	San Diego	BLD-07705	Electrical Doghouse	OSHPD 1- Under Construction	5s			5s	
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00250	Original Building - Phase I North Wing	OSHPD 1-In Service	4			2	
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00251	Original Building - Phase I South Wing	OSHPD 1-In Service	4			2	
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00253	Dining and Kitchen Addition	OSHPD 1-In Service	4			2	
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-00254	Storage & Maintenance Building	OSHPD 1-In Service	4			2	
37 - San Diego	14181	Scripps Green Hospital	La Jolla	BLD-02662	Heart, Lung, Vascular Center	OSHPD 1-In Service	3			2	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02085	Wood Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02086	Masonry Building	OSHPD 1-In Service	2	0.6		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02088	OSA Building	OSHPD 1-In Service	4			2	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02089	East Wing Addition - North	OSHPD 1-In Service	3			4D-L1	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02090	Emergency Room Addition	OSHPD 1-In Service	3			2	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02091	ICU Addition	OSHPD 1-In Service	3			2	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-02586	Loading Dock	OSHPD 1-In Service	3			4D-L1	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03553	Central Energy Plant Service Yard	OSHPD 1- Equipment Yard	N/A			5	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03673	East Wing Addition - South	OSHPD 1-In Service	3			4D-L1	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-03674	East Wing Addition - Center	OSHPD 1-In Service	3			4D-L1	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-05299	Critical Care Building	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-05301	Central Energy Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-06537	Acute Care Building	OSHPD 1- Under Construction	5s			5s	
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-06538	Entry Canopy	OSHPD 1- Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12309	Scripps Memorial Hospital - Encinitas	Encinitas	BLD-06539	Loading Dock	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01118	Building 1-3-4	OSHPD 1-In Service	2	0.57		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01119	Building 1-A	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01120	West Tower	OSHPD 1-In Service	2	0.23		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01121	Transition Tower (& 5A)	OSHPD 1-In Service	2	4.61	0.07	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01122	Addition to Women's Center - Structurally connected to BLD-01121	OSHPD 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01123	East Tower	OSHPD 1-In Service	2	0.14		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01124	Building 7	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01125	Service Building (8, 8A, 8B)	OSHPD 1-In Service	2	2.81		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01126	Co-Generation Plant	OSHPD 1-In Service	4			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01127	Building 10	OSHPD 1-In Service	3			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01128	Emergency Expansion	OSHPD 1-In Service	3			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-01129	Building 6A	OSHPD 1-In Service	2	0.44		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02583	Dining Area Addition	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02584	Mericos Building	OSHPD 1-In Service	3			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-02585	Outpatient Waiting Room	OSHPD 1-In Service	3			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03051	Building 10A	OSHPD 1-In Service	4			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03549	Scripps Clinic La Jolla Medical Office Building	OSHPD 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03550	Emergency Department Canopy	OSHPD 1-In Service	5			4	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-03551	Prebys Cardiovascular Institute Pedestrian Walkway	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-05266	Prebys Cardiovascular Institute	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-05267	Central Energy Plant	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-06436	New Tower	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-06747	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-06927	Pedestrian Tunnel	OSHPD 1-Proposed	5s			4s	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-07213	RA/Chem Storage	OSHPD 1-In Service	5			4	
37 - San Diego	12363	Scripps Memorial Hospital - La Jolla	La Jolla	BLD-07214	Bio Hazard Storage	OSHPD 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02114	Main Hospital Tower	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02115	Main Hospital Wing	OSHPD 1-In Service	2	0.13		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02116	ICU Building	OSHPD 1-In Service	2	0.18		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02119	ICU Addition	OSHPD 1-In Service	2	0.21		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02120	Elevator Tower	OSHPD 5-Acute Psych Only	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02121	Ambulatory Addition	OSHDP 1-In Service	3			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02122	Ambulatory Add - Elevator Tower	OSHDP 1-In Service	3			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02123	Ambulatory Addition	OSHDP 1-In Service	3			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02124	Ambulatory Addition - Structurally connected to BLD-02121	OSHDP 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02589	Mechanical Tunnel	OSHDP 1-Tunnels	N/A			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-02590	Clinic Building	OSHDP 5-Acute Psych Only	N/A			N/A	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03543	Central Energy Plant	OSHDP 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03545	Canopy 1	OSHDP 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03546	Canopy 2	OSHDP 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03547	Canopy 3	OSHDP 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03712	Ambulatory Add - Canopy	OSHDP 1-In Service	3			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-03713	Ambulatory Add - East Stair Add	OSHDP 1-In Service	3			2	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-05637	Emergency Department Addition	OSHDP 1-In Service	5			4	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-05638	Replacement Stair - Structurally connected to BLD-02119	OSHDP 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06492	Replacement Hospital	OSHDP 1-Proposed	5s			5s	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06493	New Canopy 1	OSHDP 1-Proposed	5s			5s	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06806	Pedestrian Access Bridge	OSHDP 1-Under Construction	5s			5s	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06853	Canopy 2	OSHDP 1-Proposed	5s			5s	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06854	Pedestrian Access Canopy	OSHDP 1-Proposed	5s			5s	
37 - San Diego	12339	Scripps Mercy Hospital	San Diego	BLD-06855	Canopy 3	OSHDP 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02055	Original Building	OSHPD 1-In Service	2	0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02056	Tower Addition	OSHPD 1-In Service	2	0.16		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02057	Emergency Room Addition	OSHPD 1-In Service	4			2	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02058	Hospital Expansion	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02060	Hospital Expansion - Emergency Dept	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-02061	Mechanical Building	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03044	Hospital Expansion - Lobby	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03045	Hospital Expansion - ICU	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03842	Connector Building - Structurally connected to BLD-02056	OSHPD 1-Not an Independent Building	N/A	0.14		N/A	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03874	Modular Cath Lab	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-03875	Cath Lab Canopy	OSHPD 1-In Service	5			4	
37 - San Diego	12268	Scripps Mercy Hospital Chula Vista	Chula Vista	BLD-07740	Bulk Medical Gas Yard	OSHPD 1-Equipment Yard	N/A			2s	
37 - San Diego	16703	Select Specialty Hospital - San Diego	San Diego	BLD-00292	Hospital and M.O.B.	OSHPD 1-In Service	3			2	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00227	East Tower - North Portion	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00228	East Tower - South Portion	OSHPD 1-In Service	2	0.56		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00229	West Tower - Lobby	OSHPD 1-In Service	5			2	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-00230	Cardiac Operating Room Addition	OSHPD 1-In Service	4			2	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02717	West Tower - Administrative Wing	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02718	Emergency Generator Building	OSHPD 1-In Service	5			4	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02719	West Tower - Tower	OSHPD 1-In Service	4			2	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-02828	Ocean View Tower	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05673	Entry Building	OSHPD 1-In Service	5			5	Earthquake Resilient
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05674	Chiller Plant	OSHPD 1-In Service	5			4	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-05969	Birch Patrick Convalescent Center	OSHPD 2-Skilled Nursing Only	N/A			N/A	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06011	Loading Dock Canopy	OSHPD 1-In Service	5			4	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06238	Bulk O2 Yard	OSHPD 1-Equipment Yard	N/A			4	
37 - San Diego	13336	Sharp Chula Vista Medical Center	Chula Vista	BLD-06394	Gas Bottle Storage	OSHPD 1-Not a Building Structure	N/A			4	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02081	Main Tower	OSHPD 1-In Service	4D	0.22		2	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02082	ICU Building (Emergency Department Building)	OSHPD 1-In Service	4D	0.07		2	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02083	Ancillary Building	OSHPD 1-In Service	4D	0.07		2	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-02827	Prospect Place Canopy	OSHPD 1-In Service	5			4	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03680	Morgue Building	OSHPD 1-In Service	4D	0.08		2	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03681	Long Term Care Building (Outpatient Pavilion Building)	OSHPD 1-In Service	4D	0.08		2	
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-03682	Sub Acute Care II Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12295	Sharp Coronado Hospital and Healthcare Center	Coronado	BLD-07669	Emergency Department Plaza Canopy	OSHPD 1-Proposed	5s			4s	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-03892	Mary Birch Womens Center	OSHPD 1-In Service	3			2	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-06769	Mary Birch Expansion	OSHPD 1-Proposed	5s			5s	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-06900	Loading Dock Canopy	OSHPD 1-Proposed	5s			4s	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-06903	Temporary Dietary Exit Canopy	OSHPD 1-Under Construction	5s			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
37 - San Diego	15454	Sharp Mary Birch Hospital For Women And Newborns	San Diego	BLD-07578	WWT-03 Wastewater Tank	OSHDP 1-Under Construction	N/A				5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01130	North Tower - East Building	OSHDP 1-In Service	2	0.05			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01131	North Tower - Central Building	OSHDP 1-In Service	2				2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01132	North Tower - West Building	OSHDP 1-In Service	2	0.16			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01133	Inter-Hospital Passageway	OSHDP 1-In Service	2				2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01134	South Tower	OSHDP 1-In Service	2	1.69	0.56		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01135	Rehabilitation Center	OSHDP 1-In Service	3				4D-L1	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01136	Emergency / Radiology	OSHDP 1-In Service	2	0.04			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01137	Dietary Building	OSHDP 1-In Service	2	0.06			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01138	Service Building	OSHDP 1-In Service	2	0.23			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01139	Long Term Care Building	OSHDP 1-In Service	2	0.76	0.76		4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01140	MRI Building	OSHDP 1-In Service	3				2	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-01142	New Central Plant	OSHDP 1-In Service	3				2	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-02835	New Acute Care Tower (Stephen Birch West Tower)	OSHDP 1-In Service	5				4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-02836	Stephen Birch East Tower	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03753	Corridor 1 - North	OSHDP 1-In Service	2		0.54	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03754	Corridor 1 - South	OSHDP 1-In Service	4			2	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03755	Corridor 2 - North	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03756	Corridor 2 - Middle	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03757	Corridor 2 - South	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-03758	Corridor 2 - Long Term Care	OSHDP 1-In Service	4			4D-L1	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05526	Passageway Link	OSHDP 1-In Service	2		4.2	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05527	Telephone Switch Building	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05534	Corridor 1 - North Segment B	OSHDP 1-In Service	4			2	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05535	Corridor 1 - North Segment C	OSHDP 1-In Service	4			2	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05540	Kitchen / Pharmacy Storage Building - Structurally connected to BLD-01136	OSHDP 1-Not an Independent Building	N/A		1.38	N/A	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05550	Outpatient Pavilion	OSHDP 3 - Local-Outpatient Only	N/A			N/A	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05551	Shop Building	OSHDP 1-In Service	2s			2s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05975	Emergency Canopy	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05976	Parking Structure Canopy	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05977	East Entrance Canopy	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05978	Main Front Canopy	OSHDP 1-In Service	5			4	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-05979	Lower Level SB Connector	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06596	Campus Connector (Center)	OSHPD 1-Under Construction	5s			4s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06755	New Central Energy Plant	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06756	ED Expansion	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06757	New Oxygen Yard	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06768	New Tower	OSHPD 1-Proposed	5s			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06810	Electrical Yard	OSHPD 1-Proposed	N/A			4s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06851	ED Canopy	OSHPD 1-Under Construction	5s			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06901	Campus Connector - North	OSHPD 1-Under Construction	5s			4s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-06902	Campus Connector - South	OSHPD 1-Under Construction	5s			4s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07571	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07573	FT-02 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07574	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07575	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07576	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12364	Sharp Memorial Hospital	San Diego	BLD-07577	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01143	Center Tower	OSHPD 1-In Service	2	0.57		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01144	North Wing	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01145	Center Complex - North	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01146	South Tower	OSHPD 1-In Service	2	0.71		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01147	Electrical Building	OSHPD 1-In Service	2		0.18	4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01148	1976 Center Complex Addition	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01149	Materials/Laboratory Building	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01150	1976 Radiology Addition	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01151	Emergency Room Addition	OSHPD 1-In Service	3			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01152	Administration Building	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01153	Pavilion Building Canopy	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01154	Pavilion Building	OSHPD 1-In Service	4			4D-L1	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-01155	Ancillary Building	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02868	South Tower Stair Shaft - Structurally connected to BLD-01146	OSHPD 1-Not an Independent Building	N/A		0.12	N/A	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02869	Electrical Building Addition	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02870	Emergency Room Addition Canopy	OSHPD 1-In Service	3			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02871	Perinatal Unit/Women's Center	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02872	Perinatal Unit/Women's Center Canopy 1	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02873	Perinatal Unit/Women's Center Canopy 2 - Structurally connected to BLD-02872	OSHPD 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02874	Perinatal Unit/Women's Center Canopy 3	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02875	Surgery Addition 1	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02876	Surgery Addition 2	OSHPD 1-In Service	3			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02877	Surgery Addition Canopy	OSHPD 1-In Service	3			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-02878	Central Plant	OSHPD 1-In Service	4			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-03766	Center Complex - South	OSHPD 1-In Service	3			2	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-05487	Behavioral Health Unit	OSHPD 5-Acute Psych Only	N/A			N/A	
37 - San Diego	12372	Tri-City Medical Center	Oceanside	BLD-06565	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-00935	Main Hospital	OSHPD 1-In Service	2	0.69		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-00938	Service Building	OSHPD 1-In Service	2	0.15		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-00939	Fire Pump Building	OSHPD 1-In Service	4			2	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-03050	East Equipment Yard - Structurally connected to BLD-00938	OSHPD 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-03453	ED Addition	OSHPD 1-In Service	5			4	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-06631	Emergency Generator	OSHPD 1-Equipment Yard	N/A			4	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-07193	Rehabilitation Hospital	OSHPD 1-In Service	4			2	
37 - San Diego	12872	UC San Diego Health - East Campus Medical Center	San Diego	BLD-07194	Connecting Bridge	OSHPD 1-In Service	4			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02142	Main Hospital Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02143	Ancillary & Support Services Facility	OSHPD 1-In Service	3			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02144	West Wing & Psychiatric Inpatient	OSHPD 5-Acute Psych Only	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02145	Central Plant - Structurally connected to BLD-03304	OSHDP 1-Not an Independent Building	N/A			N/A	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02146	Utility Line Bridge	OSHDP 1-In Service	2		0.71	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02147	Telecommunications	OSHDP 1-In Service	5			4	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-02148	Outpatient Clinic	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03304	Boiler House and Shops	OSHDP 1-In Service	4			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03853	OR Suite Expansion	OSHDP 1-In Service	4			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-03854	Delivery / Surgery Expansion	OSHDP 1-In Service	4			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05175	Utility Line Bridge - South	OSHDP 1-In Service	2		1.14	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05560	Chiller Building	OSHDP 1-In Service	5			2	
37 - San Diego	12359	UC San Diego Health Hillcrest - Hillcrest Medical Center	San Diego	BLD-05846	Emergency Generator Building	OSHDP 1-In Service	5			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-02561	Main Hospital	OSHDP 1-In Service	3			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-02846	Main Hospital	OSHDP 1-In Service	3			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05315	UCSD Sulpizio Family Cardiovascular Center	OSHDP 1-In Service	5			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05419	Central Plant	OSHDP 1-In Service	5			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05420	Bed Tower	OSHDP 1-In Service	5			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-05974	Emergency Preparedness Supplies Building	OSHDP 1-In Service	5			4	
37 - San Diego	11659	UC San Diego Health La Jolla - Jacobs Medical Center & Sulpizio Cardiovascular Center	La Jolla	BLD-07320	MRI Suite Expansion	OSHDP 1-Proposed	5s			4s	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01100	North Tower	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHDP

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01101	Link Building	OSHDP 1R-Acute Psych / SNF only	N/A		7.99	N/A	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01102	South Tower	OSHDP 1R-Acute Psych / SNF only	N/A		8.13	N/A	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01103	Rehabilitation Building	OSHDP 1R-Acute Psych / SNF only	N/A		0.18	N/A	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01104	Emergency Systems Additions	OSHDP 1-In Service	5			2	
38 - San Francisco	12416	California Pacific Medical Center - Davies Campus Hospital	San Francisco	BLD-01105	MER Building	OSHDP 1-In Service	3			2	
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	San Francisco	BLD-03810	New Hospital	OSHDP 1-In Service	5			4	
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	San Francisco	BLD-07628	WWT-01 Wastewater Tank	OSHDP 1-Tanks	N/A			5	
38 - San Francisco	18188	California Pacific Medical Center - Mission Bernal Campus	San Francisco	BLD-07629	WT-01 Water Tank	OSHDP 1-Tanks	N/A			5	
38 - San Francisco	18165	California Pacific Medical Center - Van Ness Campus	San Francisco	BLD-03801	New Acute Care Hospital	OSHDP 1-In Service	5			4	
38 - San Francisco	14621	Chinese Hospital	San Francisco	BLD-00316	Comprehensive Health Care Building	OSHDP 1-In Service	3			2	
38 - San Francisco	14621	Chinese Hospital	San Francisco	BLD-05688	Patient Tower	OSHDP 1-In Service	5s			4s	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01093	Main Hospital	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01094	East Wing	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01095	North Wing	OSHDP 1-In Service	4			2	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01096	MEE Building	OSHDP 1-In Service	4			2	
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-01097	Doctor's Sleep Annex	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12430	Kaiser Foundation Hospital - San Francisco	San Francisco	BLD-06935	Loading Dock Extension	OSHDP 1-In Service	4			3	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-03809	South Residence	OSHDP 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05918	North Residence	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05919	Pavilion Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-05920	Generator Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06623	Connecting Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06772	Knuckle Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06773	North Knuckle - SRB Connecting Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06774	South Knuckle - SRB Connecting Building	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06775	Loading Dock	OSHPD 1-In Service	5			4	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06781	Water Tank #1	OSHPD 1-Tanks	N/A			3s	
38 - San Francisco	12432	Laguna Honda Hospital & Rehabilitation Center	San Francisco	BLD-06782	Water Tank #2 (WT-02)	OSHPD 1-Under Construction	5s			4s	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01069	Main Hospital	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	14.47		N/A	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01070	M Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-01071	Service Building	OSHPD 1-In Service	5			2	
38 - San Francisco	12463	Priscilla Chan And Mark Zuckerberg San Francisco General Hospital And Trauma Center	San Francisco	BLD-03339	Replacement Hospital	OSHPD 1-In Service	5			4	
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	San Francisco	BLD-01072	Main Tower	OSHPD 1-In Service	2	1.18	0.64	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12460	UCSF Health - St. Mary's Hospital	San Francisco	BLD-01073	McAuley Wing	OSHPD 1-In Service	2	17.37	0.9	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health Saint Francis Hospital	San Francisco	BLD-01079	Main Tower	OSHPD 1-In Service	2	1.25	1.15	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12457	UCSF Health Saint Francis Hospital	San Francisco	BLD-01080	1958 Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
38 - San Francisco	12457	UCSF Health Saint Francis Hospital	San Francisco	BLD-01081	Pierotti Pavilion	OSHDP 1-In Service	3			2	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01012	Moffitt Hospital	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01013	Long Hospital	OSHDP 1-In Service	4			3	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01014	Emergency Entrance Structure	OSHDP 1-In Service	3			3	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-01016	Central Utilities Plant	OSHDP 1-In Service	4			3	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-06771	Helen Diller Hospital	OSHDP 1-Under Construction	5s			5s	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-06928	Oxygen Yard	OSHDP 1-Under Construction	N/A			4s	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-06994	Pump House	OSHDP 1-Under Construction	5s			4s	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-07135	Electrical Building	OSHDP 1-Under Construction	5s			4s	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-07377	Fire Suppression House	OSHDP 1-Under Construction	5s			4s	
38 - San Francisco	12476	UCSF Medical Center	San Francisco	BLD-07378	FT Fuel Tanks	OSHDP 1-Under Construction	5s			4s	
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	San Francisco	BLD-05445	UCSF Benioff Children's Hospital	OSHDP 1-In Service	5			5	Earthquake Resilient
38 - San Francisco	18181	UCSF Medical Center At Mission Bay	San Francisco	BLD-05523	Energy Center	OSHDP 1-In Service	5			5	Earthquake Resilient
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01082	Building A	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01083	Building B	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01084	Building D - Structurally connected to BLD-01083	OSHDP 1-Not an Independent Building	N/A			N/A	
38 - San Francisco	12443	UCSF Medical Center at Mount Zion	San Francisco	BLD-01085	Building R	OSHDP 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01876	Central (Main)/East Wing	OSHDP 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01877	West Wing	OSHDP 1-In Service	2	0.04		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01878	Central Plant	OSHDP 1-In Service	4s			4	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01879	North Wing	OSHDP 1-In Service	4			2	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-01880	Emergency Addition	OSHDP 1-In Service	4			2	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-02864	New Patient Tower	OSHDP 1-In Service	5			4	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-03624	New Central Plant	OSHDP 1-In Service	5			4	
39 - San Joaquin	10743	Adventist Health Lodi Memorial	Lodi	BLD-07232	New Elevator Tower	OSHDP 1-In Service	5			4	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01863	1987 Building - 87-A	OSHDP 1-In Service	4			2	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01864	1987 Building - 87-B	OSHDP 1-In Service	4			2	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01865	1975 Building - 75-A	OSHDP 1-In Service	4			2	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01866	1967 Building - 67-A	OSHDP 1-In Service	2	0.12		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01867	1964 Building - 64-A	OSHDP 1-In Service	2		0.26	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01868	1957 Building - 57-A - Structurally connected to BLD-01871	OSHDP 1-Not an Independent Building	N/A			N/A	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01869	Generator Building - Fuel Tank	OSHDP 1-Equipment Yard	N/A			2	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01870	Generator Building - Cooling Tower	OSHDP 1-Not a Building Structure	N/A			4s	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-01871	1932 Building - 32-A	OSHDP 1-In Service	2		0.97	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-03615	Generator Building	OSHPD 1-In Service	5s			2	
39 - San Joaquin	10729	Dameron Hospital	Stockton	BLD-05397	Generator Building - Bulk Oxygen	OSHPD 1-Equipment Yard	N/A			4s	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01881	Main Hospital & Additions	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01882	Outpatient/Administration	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01883	OR Addition/Meeting Room	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01884	East Patient Tower	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01885	Purchasing	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01886	Telephone Equipment Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01887	ER Addition	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01888	X-Ray Addition	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01889	Ultrasound/Storage	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01890	CT Scan	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01891	OB Addition	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01892	Mechanical Equip. Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01893	Entrance Canopy	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01894	OR Addition	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01895	LDR Addition	OSHPD 1-In Service	5			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01896	Mechanical Equip. Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-01897	Freezer - Structurally connected to BLD-01881	OSHPD 1-Not an Independent Building	N/A			N/A	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-07687	Pump House	OSHPD 1-Proposed	5s			5s	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-07688	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-07689	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-07690	FT-01 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
39 - San Joaquin	10745	Doctors Hospital of Manteca	Manteca	BLD-07692	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00065	East Wing	OSHPD 1-In Service	4			2	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00066	West Wing	OSHPD 1-In Service	4			2	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-00067	Tower	OSHPD 1-In Service	4			2	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07075	Emergency Department Expansion	OSHPD 1-Under Construction	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07273	Emergency Department Canopy A	OSHPD 1-Under Construction	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07274	Emergency Department Canopy B	OSHPD 1-Under Construction	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07275	Emergency Department Canopy C	OSHPD 1-Under Construction	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07276	Emergency Department Canopy D	OSHPD 1-Under Construction	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07277	MRI Canopy A	OSHPD 1-Proposed	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07278	MRI Canopy B	OSHPD 1-Proposed	5s			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07459	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
39 - San Joaquin	16324	Kaiser Foundation Hospital - Manteca	Manteca	BLD-07460	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01911	Main Hospital Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01912	Central Plant	OSHPD 1-In Service	5			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01913	OPD Building / Conference Center / Admin Wing	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		0.61	N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01914	OPD Emergency Generator Shed	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		2.97	N/A	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01915	Dietary Building	OSHDP 1-In Service	2		0.27	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-01917	A & B Wings	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		3.47	N/A	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03035	Loading Dock	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03171	Clinical Laboratory	OSHDP 1-In Service	5s			4s	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03172	Area F	OSHDP 1-In Service	5s			5s	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03726	Compacter / Sterilizer / Baler	OSHDP 1-In Service	3			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03727	Connecting Link - Part 1 - North	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03728	Connecting Link - Part 2 - North	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03729	Area D	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03730	Area E	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03731	Main Hospital Canopy	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03732	Connecting Link - Part 1 - West	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03733	Connecting Bridge - Part 1 - West	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03734	Connecting Bridge - Pylon	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03735	Connecting Link - Part 2 - West	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03736	Connecting Bridge - Part 2 - West	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03737	Connecting Bridge - Pylon 2	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10753	San Joaquin General Hospital	French Camp	BLD-03738	Connecting Link - Part 3 - West	OSHDP 1-In Service	4s			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01898	Main Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01899	North Wing	OSHDP 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01900	South Wing	OSHDP 1-In Service	2	0.18		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01901	West Wing	OSHDP 1-In Service	2	2.35	0.24	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01902	East Wing	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01903	Administrative Wing	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01904	Southeast Wing	OSHDP 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01905	Cafeteria	OSHDP 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01906	Heart Center	OSHDP 1-In Service	3			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01907	Outpatient Surgery Building	OSHDP 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01908	Cancer Center (Main Entrance)	OSHDP 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-01909	Hospital Main Entrance (Admitting)	OSHDP 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03367	Women & Children's Pavilion Building	OSHDP 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03369	LOX Yard	OSHDP 1-Equipment Yard	N/A			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03370	New Generator Building	OSHDP 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03371	Pedestrian Corridor	OSHDP 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03492	Elevator Addition	OSHDP 1-In Service	2	0.32		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03493	Kitchen Remodel 1	OSHDP 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03494	Kitchen Remodel 2	OSHPD 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03495	Material Management Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03496	Utility Plant	OSHPD 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-03575	Generator Enclosure for Women and Children's Pavilion Building	OSHPD 1-Equipment Yard	N/A			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07237	Ambulance Entry Canopy	OSHPD 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07238	Stair Tower	OSHPD 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07239	ED Lobby Canopy	OSHPD 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07240	Linear Accelerator Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07241	Arcade	OSHPD 1-In Service	3			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07242	OSB Canopy	OSHPD 1-In Service	3			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07243	Main Entrance Canopy	OSHPD 1-In Service	3			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07244	Canopy	OSHPD 1-In Service	5			4	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07343	North Tower	OSHPD 1-Proposed	5s			5s	
39 - San Joaquin	10750	St. Joseph's Medical Center of Stockton	Stockton	BLD-07653	Dietary Dock	OSHPD 1-Proposed	5s			4s	
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	Stockton	BLD-06280	Stockton Rehabilitation Hospital	OSHPD 1-In Service	5			5	Earthquake Resilient
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	Stockton	BLD-06282	LOX Tank	OSHPD 1-Equipment Yard	N/A			5	
39 - San Joaquin	18232	Stockton Regional Rehabilitation Hospital	Stockton	BLD-06319	Porte Cochere	OSHPD 1-In Service	5			5	Earthquake Resilient
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01918	Original Hospital Building / Additions	OSHPD 1-In Service	2	0.14		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01919	Building Block No. 2	OSHPD 1-In Service	2	0.11		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01920	1976 Alterations & Additions	OSHPD 1-In Service	4			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-01921	Two Story Addition West	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03046	Mechanical Building	OSHPD 1-In Service	4			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03075	Central Plant	OSHPD 1-In Service	5			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03200	North Canopy	OSHPD 1-In Service	4			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03345	Northwest Canopy	OSHPD 1-In Service	4			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03346	One Story Addition	OSHPD 1-In Service	4			2	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03347	Northeast Canopy	OSHPD 1-In Service	4			3	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03348	West Canopy	OSHPD 1-In Service	4			3	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03903	Ambulatory Care Entrance Corridor	OSHPD 1-In Service	5			4	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-03904	Ambulatory Care Addition	OSHPD 1-In Service	5			4	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-07761	Bulk Medical Gas Yard	OSHPD 1-Proposed	N/A			5s	
39 - San Joaquin	10757	Sutter Tracy Community Hospital	Tracy	BLD-07762	Storage Building	OSHPD 1-Proposed	5s			4s	
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	San Luis Obispo	BLD-00839	Main Hospital and Additions	OSHPD 1-In Service	2	0.37		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	San Luis Obispo	BLD-00840	Patient Tower	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	San Luis Obispo	BLD-00841	West Wing	OSHPD 1-In Service	3			2	
40 - San Luis Obispo	10778	Adventist Health Sierra Vista	San Luis Obispo	BLD-00842	E. R. Addition	OSHPD 1-In Service	4			2	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-00241	Main Hospital	OSHPD 1-In Service	4			2	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-00242	Radiology Addition/Cath Lab	OSHPD 1-In Service	4			2	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-00243	E.R. Room	OSHPD 1-In Service	4			2	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-00244	Administrative Addition	OSHPD 1-In Service	4			2	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-03458	Diagnostic & Treatment Expansion	OSHPD 1-In Service	5			4	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-03459	West Nurse Addition	OSHPD 1-In Service	5			4	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-03460	Support Service Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-03461	Patient Tower Addition	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-05966	Entry Canopy	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-05967	Main Entry Canopy	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	13999	Adventist Health Twin Cities	Templeton	BLD-06611	MEP Equipment Room	OSHDP 1-Proposed	5s			4s	
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	Arroyo Grande	BLD-07154	Dignity Health Central Coast Rehabilitation Hospital	OSHDP 1-Proposed	5s			5s	
40 - San Luis Obispo	10054	Dignity Health Central Coast Rehabilitation Hospital	Arroyo Grande	BLD-07155	Porte-Cochere	OSHDP 1-Proposed	5s			5s	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00955	Main Hospital	OSHDP 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00956	Cath Lab Addition	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-00957	Surgery Addition	OSHDP 1-In Service	4s			2	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-03600	Mechanical Building	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-05622	Electrical Room	OSHDP 1-In Service	5s			4	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06242	Emergency Department Addition	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06458	Patient Tower Addition	OSHDP 1-Proposed	5s			5s	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06630	Chapel	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06642	Generator Yard	OSHDP 1-Proposed	N/A			4s	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06675	Bell Tower	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06745	Ambulance Canopy	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	12964	French Hospital Medical Center	San Luis Obispo	BLD-06746	Patient Drop Off Canopy	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01922	Canopy	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01923	Kitchen Addition	OSHDP 1-In Service	5			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01924	Central Supply	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01925	Skilled Nursing	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01926	Corridor	OSHDP 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01927	Critical Care Unit	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01928	Corridor	OSHDP 1-In Service	3			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01929	Surgery, Emergency, Food Service	OSHDP 1-In Service	3			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01930	Canopy	OSHDP 1-In Service	3			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01931	Main Entrance	OSHDP 1-In Service	3			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01932	Storage and Service	OSHDP 1-In Service	4			2	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-01933	Nursing Unit, Admin, Laboratory	OSHDP 1-In Service	2	0.48		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-03310	Emergency Department Expansion	OSHDP 1-In Service	5			4	
40 - San Luis Obispo	10766	Marian Regional Medical Center, Arroyo Grande	Arroyo Grande	BLD-03312	Acute Rehab	OSHDP 1-In Service	5			4	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00846	1963 Tower	OSHDP 1-In Service	2	2.29	1.04	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00847	Front Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A	2.24		N/A	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00848	Area A & B	OSHDP 1-In Service	3			3	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00849	Area C	OSHDP 1-In Service	3			3	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00850	Area D	OSHDP 1-In Service	3			3	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00851	Center Pod	OSHDP 1-In Service	3			3	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00852	South Pod	OSHDP 1-In Service	3			3	
41 - San Mateo	10801	AHMC Seton Medical Center	Daly City	BLD-00853	Utilities Service Building	OSHDP 1-In Service	4			3	
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-03280	Central Plant	OSHDP 1-In Service	5			5	Earthquake Resilient
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-05277	Replacement Hospital	OSHDP 1-In Service	5			5	Earthquake Resilient
41 - San Mateo	18219	Kaiser Foundation Hospital - Redwood City	Redwood City	BLD-06356	Medical Office Building 2	OSHDP 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00177	Hospital - Building 1	OSHPD 1-In Service	2	0.45		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00178	Hospital - Building 2	OSHPD 1-In Service	2	0.45		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00179	Hospital Tower - Building 3	OSHPD 1-In Service	3			2	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00180	Hospital - Building 4	OSHPD 1-In Service	2	0.61		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00181	Hospital - Building 5	OSHPD 1-In Service	4D	0.61		3	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00182	Hospital - Building 6	OSHPD 1-In Service	2	0.45		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00183	Hospital - Building 7.1	OSHPD 1-In Service	3			2	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00184	Hospital - Building 8	OSHPD 1-In Service	3			2	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-00185	Hospital - Building 9	OSHPD 1-In Service	3			3	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03475	Hospital - Building 6 Canopy	OSHPD 1-In Service	2			4	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-03477	Hospital - Building 7.2 Exhaust Hood	OSHPD 1-In Service	4			3	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-06030	Chiller Canopy	OSHPD 1-In Service	5s			4s	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-07536	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-07537	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
41 - San Mateo	13086	Kaiser Foundation Hospital - South San Francisco	South San Francisco	BLD-07538	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5s	
41 - San Mateo	10804	Mills-Peninsula Medical Center	Burlingame	BLD-03217	New Hospital	OSHPD 1-In Service	5s			5s	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00856	Central Plant	OSHPD 1-In Service	5			4	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00857	Nursing Wing	OSHPD 1-In Service	5s			2	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00858	Nursing Wing Link	OSHPD 1-In Service	5			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-00859	North Addition	OSHPD 1-In Service	5			4	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-02636	Diagnostic and Treatment Center	OSHPD 1-In Service	5			4	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-03317	1958 Building - Structurally connected to BLD-00854	OSHPD 1-Not an Independent Building	N/A			N/A	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-07103	Soiled Storage Canopy	OSHPD 1-Under Construction	5s			4s	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-07104	Med Gas Storage Shed	OSHPD 1-Under Construction	5s			4s	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-07195	Central Plant Loading Dock Canopy	OSHPD 1-Under Construction	5s			4s	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-07451	WT-01 Water Tank	OSHPD 1-Tanks	N/A			5	
41 - San Mateo	10810	San Mateo Medical Center	San Mateo	BLD-07691	North Addition - South Side	OSHPD 1-In Service	5s			4	
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00860	Building 1	OSHPD 1-In Service	4D			3	
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00861	Building 2	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00862	Building 3	OSHPD 1-In Service	2	1.39		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00863	Building 4	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00864	Building 5	OSHPD 1-In Service	2		0.81	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00865	Building 6, 8, 9 and 10	OSHPD 1-In Service	2		1	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-00866	Building 7	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05198	Building 1A	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05233	Pavilion	OSHPD 1-In Service	5			4	
41 - San Mateo	10811	Sequoia Hospital	Redwood City	BLD-05234	Dining Room	OSHPD 1-In Service	5			4	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01022	Hospital Building	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01023	Locker Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-01024	Administration Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-02677	Breezeway Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	17662	Cottage Rehabilitation Hospital	Santa Barbara	BLD-02678	Office Infill Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-03218	East Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05365	Bulk Oxygen Storage	OSHPD 1-Equipment Yard	N/A			4	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05935	Lobby	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05936	West Building	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10831	Goleta Valley Cottage Hospital	Santa Barbara	BLD-05937	Porte Cochere	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10836	Lompoc Valley Medical Center	Lompoc	BLD-03028	Replacement Facility	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00878	Main Hospital	OSHPD 1-In Service	2	0.43		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00879	Surgery Addition	OSHPD 1-In Service	3			2	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00881	Central Plant II - 1993	OSHPD 1-In Service	5			2	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00882	ER/CCU/Radiology Addition	OSHPD 1-In Service	4			2	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-00883	Laboratory Addition	OSHPD 1-In Service	4s			2	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-03385	Mechanical / Electrical Room Addition	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-03386	New Hospital Expansion	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05455	New Hospital Expansion - Section J	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05456	New Hospital Expansion - Section K	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05457	New Hospital Expansion - Main Entry Canopy	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05458	New Hospital Expansion - Emergency Department Entry Canopy	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05459	New Hospital Expansion - Ambulance Entry Canopy	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05623	Breezeway	OSHPD 1-In Service	5s			4	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05994	Extended Care Center - Main Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05996	Extended Care Center - Colonnade	OSHPD 2-Skilled Nursing Only	N/A			N/A	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05997	Extended Care Center - Adult Day Care	OSHPD 2-Skilled Nursing Only	N/A			N/A	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-05998	Extended Care Center - Child Day Care	OSHPD 2-Skilled Nursing Only	N/A			N/A	
42 - Santa Barbara	10838	Marian Regional Medical Center	Santa Maria	BLD-06180	Extended Care Center - Day Care Connector	OSHPD 2-Skilled Nursing Only	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00901	South Wing (Building D) (Pueblo Pavilion)	OSHPD 1-In Service	2		0.93	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00902	East Wing (Building E) (Bath Pavilion)	OSHPD 1-In Service	2	0.58		3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00904	Surgery Wing (Building G)	OSHPD 1-In Service	4			3	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00905	Building H - Structurally connected to BLD-00902	OSHPD 1-Not an Independent Building	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00906	Centennial Wing (Building I) (Arlington Pavilion)	OSHPD 1-In Service	4			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-00907	Cancer Center (Building K)	OSHPD 1-In Service	5s			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05285	D & T Building (Junipero Pavilion)	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05286	D & T "B" - Structurally connected to BLD-05285	OSHDP 1-Not an Independent Building	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05287	Pavilion E (Wood-Claeysens Pavilion)	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05288	Pavilion F (Ridley-Tree Pavilion)	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05289	New Central Plant	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-05292	Medical Gas Yard	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06007	Knapp Building	OSHDP 3 - Local-Clinic - Local Jurisdiction	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06021	Link Building	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06402	Pavilion D (Compton Pavilion)	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06403	Treatment Pavilion (Arlington Pavilion)	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06447	Surgery Center of Santa Barbara	OSHDP 3 - Local-Proposed	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06748	Cottage Center For Advanced Imaging	OSHDP 3 - Local-Proposed	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06836	Cloister Garden	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06837	Main Lobby Canopy - High	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-06838	Main Lobby Canopy - Low	OSHDP 1-In Service	5			4	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-07033	Pediatric Medical Office Building	OSHDP 3 - Local-Proposed	N/A			N/A	
42 - Santa Barbara	10843	Santa Barbara Cottage Hospital	Santa Barbara	BLD-07114	Cottage Heart Center	OSHDP 3 - Local-Proposed	N/A			N/A	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-00896	Hospital Building	OSHDP 1-In Service	4D			4	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-00897	Emergency Services Building	OSHDP 1-In Service	4			4	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-03256	Patient Unit and Radiology Department	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05972	Emergency Entrance Porte Cochere (Entry Canopy)	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05973	Lobby Porte Cochere	OSHPD 1-In Service	5			4	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-05980	CT Scanner Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
42 - Santa Barbara	10848	Santa Ynez Valley Cottage Hospital	Solvang	BLD-07676	Imaging Addition	OSHPD 1-Proposed	5s			4s	
43 - Santa Clara	16713	Children's Healthcare Organization of Northern California - Pediatric Hospital	Campbell	BLD-03912	Main Building	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-02254	1 - Orchard Pavilion	OSHPD 1-In Service	3			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-02255	2 - Willow Pavilion	OSHPD 1-In Service	3			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-02262	10 - Central Plant	OSHPD 1-In Service	5			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-02264	13a - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-02265	14 - South Addition - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-03529	12 - Psychiatric Wings - Structurally connected to BLD-02263	OSHPD 1-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-03535	10 - Central Plant - Switchgear	OSHPD 1-In Service	5			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-03536	10 - Central Plant - Substation	OSHPD 1-In Service	5			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-03577	Slot Building	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-03578	New Main Hospital Building (West)	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05794	Behavioral Health Building	OSHPD 5-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05795	Behavioral Health Building - Entrance Canopy	OSHPD 5-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05797	Utility Tunnel (East-West)	OSHPD 1-Tunnels	N/A			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05962	New Main Hospital/Women's Hospital Connector	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05963	New Main Hospital SE Vestibule	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05964	New Main Hospital SE Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-05965	New Main Hospital SW Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-06083	New Main Hospital Building - East	OSHPD 1-In Service	5			4	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-06084	North-South Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-06085	New Main Hospital/Women's Hospital Tunnel	OSHPD 1-Tunnels	5s			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-06086	New Main Hospital / Willow Pavilion Tunnel	OSHPD 1-Tunnels	5			2	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-06570	New Canopy at Women's Hospital	OSHPD 1-Under Construction	5s			4s	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-07189	Wing J	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-07190	BHS Link	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10883	El Camino Health	Mountain View	BLD-07322	Bulk Gas - Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02243	Original Building / Outpatient	OSHPD 1-In Service	2	1.56	0.98	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02244	Generator Building	OSHPD 1-In Service	2	1.24	0.92	3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02245	Unit 2 Addition / CCU Building	OSHPD 1-In Service	2	0.91	0.91	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02246	Surgery / Medical Center	OSHPD 1-In Service	2			3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02247	Administration Building	OSHPD 1-In Service	2	0.22		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02248	ICU Building	OSHPD 1-In Service	2			3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02249	Emergency	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02250	Endoscopy	OSHPD 1-In Service	5			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02251	Entrance Canopy	OSHPD 1-In Service	5			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-02252	O.B. Gyn / Cancer Center	OSHPD 1-In Service	2	0.13		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03692	Rehabilitation Center	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03693	Emergency Generator Building	OSHPD 1-In Service	2	0.07		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03694	Rehab Center Addition 1	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03695	Rehab Center Addition 2	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03821	Back-of-house addition (freezer)	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03822	Back-of-house Facility	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03823	Ambulatory Surgery Holding	OSHPD 1-In Service	4			3	
43 - Santa Clara	10874	El Camino Hospital Los Gatos	Los Gatos	BLD-03824	Switch Gear Building	OSHPD 1-In Service	5			4	
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	Sunnyvale	BLD-07112	Rehabilitation Hospital	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	Sunnyvale	BLD-07113	Trash Enclosure	OSHPD 1-Under Construction	N/A			5s	
43 - Santa Clara	10042	El Camino Rehabilitation Hospital	Sunnyvale	BLD-07249	Emergency Generator Enclosure	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-02267	Main Building	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-02268	MRI Building	OSHPD 1-In Service	3			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03445	Women's & Children's Center	OSHPD 1-In Service	5			4	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03446	Connection	OSHPD 1-In Service	5			4	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03447	Central Plant	OSHPD 1-In Service	5			4	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-03448	Main Entrance Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-07291	New Main Hospital	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-07292	EMS Canopy	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-07293	ED Canopy	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10890	Good Samaritan Hospital	San Jose	BLD-07294	New Central Plant	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07126	Replacement Hospital	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07127	Energy Center	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07128	ED Canopy	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07129	Main Canopy	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07130	West Canopy	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07509	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07510	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
43 - Santa Clara	10044	Kaiser Foundation Hospital - San Jose	San Jose	BLD-07511	FT-01 Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	San Jose	BLD-00954	Hospital	OSHPD 1-In Service	2	0.59		3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	12952	Kaiser Foundation Hospital-San Jose	San Jose	BLD-03599	ED Expansion	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-03701	Hospital - Phase I	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-03702	Chiller Plant	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-05951	Sanipak Cover	OSHPD 1-Not a Building Structure	N/A			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07197	Hospital Phase IIA	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07198	Hospital Phase IIB	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07199	Hospital Phase IIC	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07200	Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07201	Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07202	Water Treatment Building	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07389	Vestibule #1	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07390	Vestibule #2	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07391	Side Canopy #1	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07392	Side Canopy #2	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07393	Main Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07741	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07742	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	17668	Kaiser Foundation Hospital-Santa Clara	Santa Clara	BLD-07743	WT-01 Water Tank	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-00286	L.S. Packard Children's Hospital	OSHPD 1-In Service	3			4	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-02867	LPCH Generator Yard	OSHPD 1-Equipment Yard	N/A			4s	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05369	New LPCH Expansion Building	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05370	New LPCH Loading Dock	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-05371	LPCH Tunnel	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-07532	LPCH Bike Cage	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-07644	Emergency Generator #1	OSHPD 1-Not a Building Structure	N/A			4s	
43 - Santa Clara	16477	Lucile Packard Children's Hospital Stanford	Palo Alto	BLD-07645	Emergency Generator #2	OSHPD 1-Not a Building Structure	N/A			4s	
43 - Santa Clara	10878	Mission Oaks Hospital	Los Gatos	BLD-02253	Main Building	OSHPD 1-In Service	3s			3	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02278	1953 Building	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		17.61	N/A	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02279	1953 Boiler House / Laundry	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		27.8	N/A	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02280	1969 Addition	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02281	Replacement Facility	OSHPD 1-In Service	4			2	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-02282	Replacement Boiler House	OSHPD 1-In Service	4			2	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03316	2005 Emergency Expansion	OSHPD 1-In Service	5			4	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03318	Linear Accelerator	OSHPD 1-In Service	4			2	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03319	Canopy 1	OSHPD 1-In Service	3			2	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-03320	Canopy 2	OSHPD 1-In Service	3			2	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-05675	2005 Emergency Expansion Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-06234	Bulk Medical Gas	OSHPD 1-Equipment Yard	N/A			4	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-07318	Medical Gas Canopy	OSHPD 1-Under Construction	5s			4s	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-07764	Pump House	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-07765	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10919	O'Connor Hospital	San Jose	BLD-07766	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02236	Main Tower and North Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02237	South Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02238	Obstetrics Wing	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02239	Emergency Department Building	OSHDP 1-In Service	4			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02240	Lab Building	OSHDP 1-In Service	3			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02241	Surgery Building	OSHDP 1-In Service	3			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02242	ICU/CCU Building	OSHDP 1-In Service	3			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-02958	7A Outpatient Surgery Center	OSHDP 1-In Service	4s			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03387	East Patient Wing	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03388	ICU Expansion	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03389	West Wing	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03391	Emergency Department Addition	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-03639	Central Plant	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06316	Bulk Oxygen Yard	OSHDP 1-Equipment Yard	N/A			2	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06396	West Wing Canopy	OSHDP 1-In Service	5			4	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06551	Connecting Corridor - Structurally connected to BLD-02241	OSHDP 1-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10856	Regional Medical Center of San Jose	San Jose	BLD-06980	ED Waiting Expansion	OSHDP 1-Under Construction	5s			4s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02546	Ancillary B (6043)	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02547	Old Main Hospital C West (6001)	OSHPD 1-In Service	1		20.67	2	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02548	Old Main Hospital C East (6001)	OSHPD 1-In Service	1		11.72	2	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02550	Rehabilitation Center Str B (6004)	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02552	Rehabilitation Center Str C (6004)	OSHPD 1-In Service	2	3.37		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02553	West Wing K Nursing (6006)	OSHPD 1-In Service	3			2	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02554	Main Hospital M (6009)	OSHPD 1-In Service	5			2	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02555	Energy Plant S1 - Boiler Room (6016)	OSHPD 1-In Service	4			4	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02556	Energy Plant S2 - Addition (6016)	OSHPD 1-In Service	4			4	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-02557	Mech/Elec Bldg U (6017)	OSHPD 1-In Service	5			4	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03654	M/E Chiller Addition (6017)	OSHPD 1-In Service	5			4	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03860	Services Bldg F (Unit 5) (6002)	OSHPD 1-In Service	2		31.65	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03861	Services Bldg S (Unit 4) (6002) - Structurally connected to BLD-03860	OSHPD 1-Not an Independent Building	N/A		15.1	N/A	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03869	Connecting Corridor (6002) - Structurally connected to BLD-03860	OSHPD 1-Not an Independent Building	N/A		7.35	N/A	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-03907	Rehabilitation Center Str A (6004)	OSHPD 1-In Service	2	0.59		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05256	Replacement Bed Building (Sobrato Pavilion) (6011)	OSHPD 1-In Service	5			4	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05306	Barbara Arons Pavilion (0914)	OSHPD 5-Acute Psych Only	N/A			N/A	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-05677	West Wing K Nursing (6006) Air Intake	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06589	Receiving and Support Center N (6008)	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06590	Receiving and Support Center Tunnel (6008)	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06702	Link Building	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06733	BHSC Building	OSHPD 5-Under Construction	N/A			N/A	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06734	BHSC Tunnel	OSHPD 5-Under Construction	N/A			N/A	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06833	ED Addition (6006)	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06834	ED Addition - North Side (6006)	OSHPD 1-Under Construction	5s			4s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06835	ED Addition - East Side (6006)	OSHPD 1-Under Construction	5s			4s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06850	Stair Tower #10	OSHPD 1-Under Construction	5s			4s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-06899	Subgrade Water Tank/Pump Enclosure (WT-01)	OSHPD 1-Tanks	4s			3s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07371	MRI Trailer Awning	OSHPD 1-Proposed	5s			4s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07558	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07559	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07560	WWT-03 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07561	WWT-04 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07562	WWT-05 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07563	WWT-06 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10935	Santa Clara Valley Medical Center	San Jose	BLD-07564	WWT-07 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02627	Hospital Building Area A	OSHPD 1-In Service	3			3	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02628	Hospital Building Area B/C	OSHPD 1-In Service	3			3	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-02629	Central Plant	OSHPD 1-In Service	3			3	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-06892	Above Ground Fuel Tank	OSHPD 1-Under Construction	N/A			5s	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-07332	Canopy	OSHPD 1-Proposed	5s			4s	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-07758	Mechanical Enclosure	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-07759	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-07760	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	17487	St. Louise Regional Hospital	Gilroy	BLD-07767	Emergency Generator	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10035	Stanford Health Care	Palo Alto	BLD-02865	New Stanford Hospital - Generator Building	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	Palo Alto	BLD-05260	New Stanford Hospital	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	Palo Alto	BLD-05880	New Stanford Hospital - Elevator / Stair Enclosure	OSHPD 1-In Service	5			5	Earthquake Resilient
43 - Santa Clara	10035	Stanford Health Care	Palo Alto	BLD-05881	New Stanford Hospital - Utility Tunnel	OSHPD 1-Tunnels	N/A			5	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02290	Edwards Building-Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		33.58	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02291	Lane Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		17.15	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02292	Alway Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		8.59	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02293	Grant Building - Med School	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A		10.13	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02294	Central Core	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02295	Central Core - East and West	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		28.15	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02296	Boswell Building	OSHDP 1R-No Gen Acute Care - OSHPD Bldg	N/A		18.25	N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02297	West Pavilion	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02298	East Pavilion	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02299	Phase 1 Central Core Expansion	OSHDP 1-In Service	3s			2	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02300	Nursing Pod D	OSHDP 1-In Service	4			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02301	Nursing Pod E	OSHDP 1-In Service	4			2	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02302	Nursing Pod F	OSHDP 1-In Service	4			3	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02303	Diagnostic Treatment Center	OSHDP 1-In Service	3s			2	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02304	Atrium	OSHDP 1-In Service	3s			3	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02305	F Pod Extension	OSHDP 1-In Service	3s			2	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02799	OSHDP Plant	OSHDP 1-In Service	5			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02800	OSHDP Electrical Equipment Yard	OSHDP 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02801	OSHDP Emergency Generator	OSHDP 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02802	OSHDP Cooling Towers	OSHDP 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02803	OSHDP Above Grade Fuel Tanks	OSHDP 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-02866	Modular Steam Plant	OSHDP 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03435	Utility Substation	OSHPD 1-Not a Building Structure	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03436	Emergency Generator	OSHPD 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03437	Utility Substation	OSHPD 1-Not a Building Structure	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-03805	Boiler Building - Office Portion - Structurally connected to BLD-02309	OSHPD 1-Not an Independent Building	N/A			N/A	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-05867	North Feed Steam Tunnel (OSHPD)	OSHPD 1-Tunnels	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-06567	Nursing Pod DX	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-06568	Nursing Pod EX	OSHPD 1-Under Construction	5s			5s	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-06849	Pediatric ED Canopy	OSHPD 1-In Service	5			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-06995	Breezeway Building	OSHPD 1-In Service	3			3	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-06996	Liquid Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07004	Waste Management Building	OSHPD 1-In Service	4			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07288	300P Fire Pump House	OSHPD 1-In Service	5			4	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07289	300P Emergency Generator Yard	OSHPD 1-Equipment Yard	N/A			4s	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07651	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07652	FT-02 Fuel Tank	OSHPD 1-Tanks	N/A			5	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07807	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10943	Stanford Health Care	Palo Alto	BLD-07808	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
43 - Santa Clara	10177	Sutter Medical Center, Santa Clara	Santa Clara	BLD-07683	Hospital	OSHPD 1-Proposed	5s			5s	
43 - Santa Clara	10177	Sutter Medical Center, Santa Clara	Santa Clara	BLD-07684	Central Plant	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02320	Main Hospital	OSHPD 1-In Service	2	0.35		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02321	Boiler House/Original Corridor	OSHPD 1-In Service	2	0.17		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02322	North Wing	OSHPD 1-In Service	3s			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02323	Original East Wing	OSHPD 1-In Service	4			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02324	Emergency Wing - Structurally connected to BLD-02323	OSHPD 1-Not an Independent Building	N/A			N/A	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-02325	Ancillary Building	OSHPD 1-In Service	4s			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-03373	Generator #3	OSHPD 1-Equipment Yard	N/A			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-03527	Emergency Parking Deck - Structurally connected to BLD-02320	OSHPD 1-Not an Independent Building	N/A			N/A	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07299	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07572	Canopy	OSHPD 1-In Service	4			2	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07772	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07773	WWT-02 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07774	WT-01 Water Tanks	OSHPD 1-Proposed	N/A			5s	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07775	FT-01 Fuel Tank	OSHPD 1-Tanks	N/A			5	
44 - Santa Cruz	10972	Dominican Hospital	Santa Cruz	BLD-07776	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	Santa Cruz	BLD-00240	Sutter Maternity	OSHPD 1-In Service	3			3	
44 - Santa Cruz	13901	Sutter Maternity & Surgery Center of Santa Cruz	Santa Cruz	BLD-05910	Connector Building	OSHPD 1-In Service	4			2	
44 - Santa Cruz	15019	Watsonville Community Hospital	Watsonville	BLD-00057	Main Hospital	OSHPD 1-In Service	5			4	
44 - Santa Cruz	15019	Watsonville Community Hospital	Watsonville	BLD-00058	Central Plant	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02327	Original Hospital	OSHPD 1-In Service	2		0.28	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02328	Long Term Beds Addition	OSHPD 1-In Service	4			2	
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02329	Surgery/O.B. Addition	OSHPD 1-In Service	4			2	
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-02332	Pharmacy and 12 Bed Addition	OSHPD 1-In Service	4			2	
45 - Shasta	11000	Mayers Memorial Hospital	Burney	BLD-05268	Skilled Nursing Building - Burney Campus	OSHPD 2-Skilled Nursing Only	N/A			N/A	
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-05334	Emergency Department Expansion	OSHPD 1-In Service	5			5	Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06253	Connector	OSHPD 1-In Service	5			5	Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06254	Drop-Off Canopy	OSHPD 1-In Service	5			5	Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06969	Water Tank	OSHPD 1-Tanks	5			5	Earthquake Resilient
45 - Shasta	11000	Mayers Memorial Hospital	Fall River Mills	BLD-06970	Water Tank Pump Enclosure	OSHPD 1-Not a Building Structure	N/A			5	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01502	Main Building	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01503	Pediatrics	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01504	East Wing	OSHPD 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01505	Radiology Addition	OSHPD 1-In Service	2	0.22		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01506	Central Wing	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01507	Doctor's Lounge - Structurally connected to BLD-01504	OSHPD 1-Not an Independent Building	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01508	Cafeteria Addition	OSHPD 1-In Service	4			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01509	Third Floor L & D Addition - Structurally connected to BLD-01502	OSHPD 1-Not an Independent Building	N/A			N/A	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01510	West Tower	OSHPD 1-In Service	4s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01511	Engineering Addition - Structurally connected to BLD-01502	OSHPD 1-Not an Independent Building	N/A			N/A	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01512	Pediatrics Addition	OSHPD 1-In Service	4s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01513	ER/ICU Addition	OSHPD 1-In Service	5			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01514	Radiology & Cafeteria Addition	OSHPD 1-In Service	4			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01515	Oncology Center Addition	OSHPD 1-In Service	5s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-01516	Generator Bunker	OSHPD 1-In Service	4			4	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03642	Corridor	OSHPD 1-In Service	3s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03643	Oncology Canopy	OSHPD 1-In Service	3s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-03644	Emergency Canopy	OSHPD 1-In Service	3s			2	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-05354	MRI Addition	OSHPD 1-In Service	5s			4s	
45 - Shasta	11002	Mercy Medical Center Redding	Redding	BLD-05618	Service Yard	OSHPD 1-Equipment Yard	N/A			2	
45 - Shasta	16679	Patients' Hospital of Redding	Redding	BLD-00289	Hospital Building	OSHPD 1-In Service	5			2	
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02340	East Wing	OSHPD 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02341	West Wing	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02342	Surgery/Radiology/ICU	OSHPD 1-In Service	4			2	
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02343	ER Expansion	OSHPD 1-In Service	5			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02344	Surgery/Cardiology/LDR	OSHPD 1-In Service	4			2	
45 - Shasta	11001	Shasta Regional Medical Center	Redding	BLD-02345	Expansion	OSHPD 1-In Service	4			2	
45 - Shasta	16620	Vibra Hospital Of Northern California	Redding	BLD-00064	N. Ca. Rehabilitaion Hosp. Building	OSHPD 1-In Service	4			2	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00082	Nursing Wing	OSHPD 1-In Service	5			4	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00083	D & T Wing	OSHPD 1-In Service	5			4	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-00084	Med. Gas Shed	OSHPD 1-In Service	5			4	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-07087	Emergency Department Waiting Room Addition	OSHPD 1-In Service	5			4	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-07093	Bulk O2 and Propane Yard	OSHPD 1-Under Construction	5s			4s	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-07156	Emergency Department Expansion	OSHPD 1-Under Construction	5s			5s	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-07157	Generator Yard	OSHPD 1-Under Construction	N/A			5s	
47 - Siskiyou	14900	Fairchild Medical Center	Yreka	BLD-07158	Patient Drop-Off Canopy	OSHPD 1-Under Construction	5s			4s	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00231	1973 Building	OSHPD 1-In Service	4			2	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00232	Administration Building - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A			N/A	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00233	Laboratory Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A			N/A	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00234	Radiology Addition - Structurally connected to BLD-00231	OSHPD 1-Not an Independent Building	N/A			N/A	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00235	Skilled Nursing Facility & Maintenance Shop	OSHPD 1-In Service	4			2	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-00236	Generator Enclosure	OSHPD 1-In Service	5s			2	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06101	Emergency Dept. Addition	OSHPD 1-In Service	5			4	
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06118	1973 Nursing Wing	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
47 - Siskiyou	13812	Mercy Medical Center Mt. Shasta	Mount Shasta	BLD-06321	OPS Addition	OSHPD 1-In Service	5			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00204	Central Plant East	OSHPD 1-In Service	4			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00205	Hospital Addition	OSHPD 1-In Service	3			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-00207	Central Plant West	OSHPD 1-In Service	2	0.08		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-02778	Central Plant	OSHPD 1-In Service	5			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-02779	Hospital Tower	OSHPD 1-In Service	5			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-03631	Central Plant East Storage / LOX	OSHPD 1-In Service	4			2	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-07215	Central Plant North-West	OSHPD 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-07216	Central Plant East Pathway	OSHPD 1-In Service	5			4	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-07423	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-07424	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	13142	Kaiser Foundation Hospital & Rehab Center - Vallejo	Vallejo	BLD-07425	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-03834	Hospital Building	OSHPD 1-In Service	5			4	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-03835	Central Utility Plant Phase 2	OSHPD 1-In Service	5			4	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-06842	Emergency Department Canopy	OSHPD 1-In Service	5			4	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07381	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07382	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07383	WWT-02 Wastewater Tank	OSHPD 1-Under Construction	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07384	WT-03 Water Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07385	WWT-03 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
48 - Solano	18164	Kaiser Foundation Hospital - Vacaville	Vacaville	BLD-07545	WT-01 Water Tank	Local-Tanks	N/A			5s	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01519	Central Plant	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01520	Phase 1 Replacement Building	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01521	Original Hospital Building A	OSHPD 1-In Service	4			2	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-01522	Emergency Room Addition	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02681	Med/Surg Addition	OSHPD 1-In Service	4s			2	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02682	Original Hospital Building B	OSHPD 1-In Service	4			2	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-02683	Original Hospital Building C	OSHPD 1-In Service	4			2	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-03029	Emergency Room Canopy	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-03030	Phase 1 Replacement Building Canopy	OSHPD 1-In Service	5s			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05345	Electrical Building	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05875	New North Wing	OSHPD 1-In Service	5			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-05876	Overhead Utility Support Structure	OSHPD 1-Not a Building Structure	N/A			4	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-06335	Laboratory Building	OSHPD 1-In Service	5			4s	
48 - Solano	11019	Northbay Medical Center	Fairfield	BLD-07340	Med Gas Storage Canopy	OSHPD 1-Proposed	5s			4s	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00340	Nursing Wing	OSHPD 1-In Service	3			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00341	Main Entrance	OSHPD 1-In Service	5			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00342	Ancillary Wing	OSHPD 1-In Service	3			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00343	Administration Wing	OSHPD 1-In Service	5			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00344	Central Plant	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00345	Cafeteria Wing	OSHDP 1-In Service	5			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-00347	Service Yard Canopy	OSHDP 1-In Service	3			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-05991	MRI Walkway	OSHDP 1-In Service	5			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-05993	Bulk Oxygen Tank	OSHDP 1-Equipment Yard	N/A			4	
48 - Solano	15807	NorthBay VacaValley Hospital	Vacaville	BLD-07675	ED / Lobby Addition	OSHDP 1-In Service	5s			4s	
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01019	Original Hospital	OSHDP 1-In Service	2		0.47	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01020	One Story Addition	OSHDP 1-In Service	4			2	
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-01021	Tower Addition	OSHDP 1-In Service	3s			2	
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-02969	Two Story Addition	OSHDP 1-In Service	4			2	
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-07017	Addition #1 (Chiller Building)	OSHDP 1-In Service	5			4	
48 - Solano	12525	Sutter Solano Medical Center	Vallejo	BLD-07018	Medical Gas Yard	OSHDP 1-Equipment Yard	N/A			5	
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-00919	Main Hospital Building	OSHDP 1-In Service	2			2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-00920	Entrance Addition	OSHDP 1-In Service	5			2	
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-00921	CT Scanner Addition	OSHDP 1-In Service	5s			2	
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-00922	Mechanical/Electrical Addition	OSHDP 1-In Service	5			2	
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-00923	Materials Management Addition	OSHDP 1-In Service	5s			2	
49 - Sonoma	12823	Healdsburg Hospital	Healdsburg	BLD-05449	ED Addition	OSHDP 1-In Service	5s			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00277	Hospital	OSHDP 1-In Service	3			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00278	Central Plant	OSHDP 1-In Service	4			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00279	Central Plant Addition	OSHDP 1-In Service	4			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-00280	Electrical Building	OSHDP 1-In Service	4			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02780	Hospital, South - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A			N/A	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02781	Hospital, North - Structurally connected to BLD-00277	OSHPD 1-Not an Independent Building	N/A			N/A	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02782	Canopy, South	OSHPD 1-In Service	3			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-02783	Canopy, North	OSHPD 1-In Service	3			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-03610	North Wing Expansion	OSHPD 1-In Service	5			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-03849	Generator Building	OSHPD 1-In Service	5			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-05699	Connecting Tunnel	OSHPD 1-In Service	5			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-05700	CUP / Boiler Room Expansion	OSHPD 1-In Service	5			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-06104	North Wing Expansion Canopy	OSHPD 1-In Service	5			4	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-07438	WWT-01 Wastewater Tank	OSHPD 1-Under Construction	N/A			5s	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-07439	WT-01 Water Tank	OSHPD 1-Under Construction	N/A			5s	
49 - Sonoma	16242	Kaiser Foundation Hospital - Santa Rosa	Santa Rosa	BLD-07440	WT-02 Water Tank	OSHPD 1-Under Construction	N/A			5s	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00311	Original Hospital - Southwest	OSHPD 1-In Service	3			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00312	Emergency Room Expansion	OSHPD 1-In Service	3			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00313	Power Plant Building	OSHPD 1-In Service	3			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00314	Switchgear Building	OSHPD 1-In Service	5			3	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-00315	Power Plant Addition	OSHPD 1-In Service	5			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02579	Original Hospital - Northeast	OSHPD 1-In Service	3			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02580	Original Hospital - Northwest	OSHPD 1-In Service	3			2	
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02581	Original Hospital - Southeast	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
49 - Sonoma	14568	Petaluma Valley Hospital	Petaluma	BLD-02757	Power Plant Addition	OSHPD 1-In Service	4			2	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01529	Original Hospital	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01530	Physical Therapy Addition	OSHPD 1-In Service	4			3	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01531	Psychiatric Addition	OSHPD 1-In Service	4			3	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-02755	Dietary Addition	OSHPD 1-In Service	4			3	
49 - Sonoma	11054	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-02756	Social Services Addition	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01533	West Pavilion - North Wing	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01534	West Pavilion - West Wing	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01535	Service Building	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01536	West Pavilion - Entry Lobby and Canopy (Entry Lobby)	OSHPD 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01537	Emergency Wing	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01538	Center East - West Link	OSHPD 1-In Service	3			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01539	Center East Wing	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01540	East Wing and East Wing Link	OSHPD 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-01543	Emergency Wing-Entrance Canopy	OSHPD 1-In Service	4			3	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-03203	ED Expansion	OSHPD 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-03205	Ambulance Drop Off Canopy	OSHPD 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-03206	ED Addition	OSHPD 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-03207	Surgery Building and Cath Lab Infill	OSHPD 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-03208	Observation #3	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06270	Oxygen Tank - Generator - Underground Fuel Tank	OSHDP 1-Equipment Yard	N/A			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06275	West Pavilion - Entry Lobby and Canopy (West Canopy)	OSHDP 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06276	West Pavilion - Entry Lobby and Canopy (East Canopy)	OSHDP 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06277	Main Entrance Canopy	OSHDP 1-In Service	5			4	
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06340	Water Treatment Structure	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11059	Providence Santa Rosa Memorial Hospital	Santa Rosa	BLD-06351	Bio-Hazard Holding	OSHDP 1-In Service	2			3	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01523	Hospital Building	OSHDP 1-In Service	3			2	
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01524	Entrance Canopy	OSHDP 1-In Service	3			2	
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01525	Emergency Canopy	OSHDP 1-In Service	3			2	
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01526	Mechanical Room	OSHDP 1-In Service	3			2	
49 - Sonoma	11052	Sonoma Specialty Hospital	Sebastopol	BLD-01527	Radiology Addition	OSHDP 1-In Service	4			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01544	West Wing	OSHDP 1-In Service	2	0.48		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01545	Central Wing	OSHDP 1-In Service	2		1.13	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-01546	East Wing North	OSHDP 1-In Service	4			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-02990	Central Wing Canopy	OSHDP 1-In Service	3s			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-02991	West Wing Canopy	OSHDP 1-In Service	3s			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03079	East Wing Center	OSHDP 1-In Service	3			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03080	East Wing South	OSHDP 1-In Service	4			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-03873	Chiller Building	OSHDP 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05409	East Wing Loading Dock Canopy	OSHPD 1-In Service	5s			2	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05410	ED / OR	OSHPD 1-In Service	5s			4s	
49 - Sonoma	11064	Sonoma Valley Hospital	Sonoma	BLD-05411	ED / OR Canopy	OSHPD 1-In Service	5s			4s	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05237	Hospital Building - West Wing	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05238	Hospital Building - Center Wing	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05239	Hospital Building - East Wing	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05240	Central Utility Plant	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05241	Water Treatment Building	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05242	Medical Gas Storage Building	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-05364	Utility Building	OSHPD 1-In Service	5			4	
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-06549	Expansion Wing	OSHPD 1-In Service	5			5	Earthquake Resilient
49 - Sonoma	18187	Sutter Santa Rosa Regional Hospital	Santa Rosa	BLD-07019	Medical Waste	OSHPD 1-In Service	5			4	
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-01551	Orig Hospital Bldg & Add - Bldg III	OSHPD 1-In Service	1		13.8	2	
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-01552	1978 Hospital Building - Bldg I	OSHPD 1-In Service	4			2	
50 - Stanislaus	11098	Central Valley Specialty Hospital	Modesto	BLD-03534	Building II	OSHPD 1-In Service	2		0.52	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01579	Main Hospital & Additions	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01580	South Tower	OSHPD 1-In Service	2	0.45		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01581	North Tower	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01582	Cath Lab	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01583	Lobby Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01584	Women & Children's Center	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01585	Central Mechanical Plant	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01586	West Tower	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01587	ER/Lab	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01588	Cardiology	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01589	Endoscopy	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01590	Endoscopy	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01591	Endoscopy	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01592	Pharmacy Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-01593	Dining Room Addition - Structurally connected to BLD-01579	OSHPD 1-Not an Independent Building	N/A			N/A	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-03405	ER/LAB Connecting Corridor	OSHPD 1-In Service	5			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-06179	Women & Children's Center - Steam Generator Room	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-06200	Entry Canopy	OSHPD 1-In Service	4			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-07074	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-07695	Pump House	OSHPD 1-Proposed	5s			5s	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-07696	WT Water Tanks	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-07697	WWT Wastewater Tanks	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11085	Doctors Medical Center	Modesto	BLD-07698	FT-02 Fuel Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01604	Main Building - East Wing	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01605	Main Building - West Wing	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01606	Mental Health Addition	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01607	Critical Care Addition	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01608	Diagnostic Imaging/ER Emergency	OSHPD 1-In Service	4			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01609	Nursing Unit Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01610	Engineering Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01611	Central Supply Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01612	Central Plant Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01613	O.R. / G.I. Addition	OSHPD 1-In Service	5			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01614	Walk-In Freezer	OSHPD 1-In Service	5			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01615	Dietary Addition	OSHPD 1-In Service	5			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01616	Surgery Addition	OSHPD 1-In Service	5			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01617	Utility Tunnel	OSHPD 1-Tunnels	N/A			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-01618	Exit Passage Way	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03229	Cardio Vascular Surgery Addition	OSHPD 1-In Service	5			4	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03230	ED Addition - North West Tower	OSHPD 1-In Service	5			4	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03231	Obstetrics Expansion	OSHPD 1-In Service	5			4	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03232	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			2	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03690	Exit Passage Way - Part II	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03691	Exit Passage Way - Part III	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-03813	Exit Passage Way - Part IV	OSHPD 1-In Service	2	0.07		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07191	North West Tower Canopy	OSHPD 1-In Service	5			4	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07677	Pump House	OSHPD 1-Proposed	5s			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07678	WT-01 Water Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07679	WT-02 Water Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07680	WT-03 Water Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07681	WT-04 Water Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07682	WWT-01 Wastewater Tank	OSHPD 1-Proposed	N/A			5s	
50 - Stanislaus	11090	Emanuel Medical Center	Turlock	BLD-07787	Entry Canopy	OSHPD 1-In Service	2s			2s	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05648	South Building	OSHPD 1-In Service	5			4	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05655	North Building	OSHPD 1-In Service	5			4	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05656	Emergency Generator Enclosure	OSHPD 1-Equipment Yard	N/A			4	
50 - Stanislaus	18204	Encompass Health Rehabilitation Hospital Of Modesto	Modesto	BLD-05657	Bulk Oxygen Enclosure	OSHPD 1-In Service	5			4	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05183	Main Building	OSHPD 1-In Service	5			4	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05184	Central Plant	OSHPD 1-In Service	5			4	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-05531	Central Utility Yard	OSHPD 1-Equipment Yard	N/A			4	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-07406	ED Canopy	OSHPD 1-In Service	5			4	
50 - Stanislaus	18151	Kaiser Foundation Hospital Modesto	Modesto	BLD-07638	Pump House	OSHPD 1-In Service	5s			4s	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01567	Connecting Corridor Infill	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01568	Physical Plant & Additions	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01569	G. I. Lab Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01570	Emergency/Ancillary Services	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01571	West Expansion	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01572	Same Day Surgery	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01573	Advanced Medical Diagnostic	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01574	Radiation Oncology Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01575	Original Hospital	OSHPD 1-In Service	2	0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01576	Obstetrics Expansion	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01577	Surgery/Emergency Expansion	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-01578	Dietary/Dining	OSHPD 1-In Service	4s			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03140	ER Expansion	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03225	North Tower	OSHPD 1-In Service	5			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03226	Central Plant Expansion	OSHPD 1-In Service	5			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03837	North Tower	OSHPD 1-In Service	5			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03838	Family Birthing Center Addition	OSHPD 1-In Service	5			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03839	Surgery/Emergency Expansion - East	OSHPD 1-In Service	4			4	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-03847	Original Hospital - South	OSHPD 1-In Service	2	0.24		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05405	Corridor and Elevator Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05406	Emergency/Ancillary Services Canopy	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05407	West Expansion - Labor and Delivery	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05408	West Expansion - Chapel	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-05417	GI Lab	OSHPD 1-In Service	4			2	
50 - Stanislaus	11111	Memorial Medical Center	Modesto	BLD-07627	Oxygen Tank Yard	OSHPD 1-Equipment Yard	N/A			4s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00193	Original Building	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00194	ICU Addition	OSHPD 1-In Service	4			2	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00195	Emergency Dept. Addition	OSHPD 1-In Service	5			4D-L1	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-00196	300 Wing Addition	OSHPD 1-In Service	5			4D-L1	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03243	Central Utility Plant	OSHPD 1-In Service	5			4	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03244	Replacement Hospital	OSHPD 1-In Service	5			4	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03245	Canopy #6	OSHPD 1-In Service	5			4	
50 - Stanislaus	13110	Oak Valley Hospital District	Oakdale	BLD-03246	Canopy #7	OSHPD 1-In Service	5			4	
50 - Stanislaus	17461	Stanislaus Surgical Hospital	Modesto	BLD-03242	Hospital Building	OSHPD 1-In Service	5			4	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	Yuba City	BLD-05179	Emergency Generator	OSHPD 1-Equipment Yard	N/A			4	
51 - Sutter	17724	Sutter Surgical Hospital - North Valley	Yuba City	BLD-05344	Hospital	OSHPD 1-In Service	5			4	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01560	Main Hospital - North Wing	OSHPD 1-In Service	4			2	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01561	Six Bed Addition - Structurally connected to BLD-02977	OSHPD 1-Not an Independent Building	N/A			N/A	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01562	Surgery Addition	OSHPD 1-In Service	4			2	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01563	Patient Rooms Addition	OSHPD 1-In Service	4			2	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01564	Medical Records Addition	OSHPD 1-In Service	4			2	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01565	Surgery Expansion - Structurally connected to BLD-01562	OSHPD 1-Not an Independent Building	N/A			N/A	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-01566	Administration Addition - Structurally connected to BLD-01560	OSHPD 1-Not an Independent Building	N/A			N/A	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-02977	Main Hospital - Southwest Wing	OSHPD 1-In Service	4			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-02978	Main Hospital - Southeast Wing	OSHPD 1-In Service	4			2	
52 - Tehama	11121	St. Elizabeth Community Hospital	Red Bluff	BLD-06031	Drop-off Canopy	OSHPD 1-In Service	5			4	
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02523	Main Hospital Building	OSHPD 1-In Service	2	0.02		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02524	SNF Building	OSHPD 2-Skilled Nursing Only	N/A			N/A	
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02525	Security Addition	OSHPD 1-In Service	2	10.49	0.86	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02526	16-Bed Addition	OSHPD 1-In Service	2	0.63		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02527	Lab and Radiology Addition	OSHPD 1-In Service	4			2	
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02528	Emergency Generator Building	OSHPD 1-In Service	2		0.98	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
53 - Trinity	11125	Trinity Hospital	Weaverville	BLD-02529	Connecting Corridor Addition	OSHPD 1R-Skilled Nursing Only	N/A		9.9	N/A	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00564	Original Structure & Additions	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00569	Fifth Addition: Radiology Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00570	Sixth Addition - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A			N/A	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00571	Sixth Add - 1.8	OSHPD 1-In Service	4			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-00572	Sixth Add - 1.9 - Structurally connected to BLD-00564	OSHPD 1-Not an Independent Building	N/A			N/A	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-02963	MRI Modular Building	OSHPD 3 - Local-Outpatient Only	N/A			N/A	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-03517	First Addition	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-03518	Second Addition	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05607	Tower 1	OSHPD 1-Under Construction	5s			5s	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05868	Generator Yard	OSHPD 1-Equipment Yard	N/A			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05869	Tower 1 Generator Yard	OSHPD 1-Under Construction	N/A			5s	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05870	Bulk Medical Gas and Water Tank Yard	OSHPD 1-Equipment Yard	N/A			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-05871	CT Scan Building	OSHPD 3 - Local-Outpatient Only	N/A			N/A	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06041	Sixth Add - 1.8 - Lobby	OSHPD 1-In Service	4			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06042	Sixth Add - 1.7 - North Restroom Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11145	Adventist Health Tulare	Tulare	BLD-06043	Sixth Add - 1.7 - South Restroom Addition	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01031	Original Building	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01032	1st. East Expansion	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01033	Cafeteria - Dining Unit	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01034	Special Services	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01035	Co-Gen. Building	OSHPD 1-In Service	3			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01036	Special Procedures	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01037	West Expansion	OSHPD 1-In Service	3			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-01038	East Expansion	OSHPD 1-In Service	3			2	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-02716	Cafeteria - Office Unit	OSHPD 1-In Service	4			2	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-03616	North Expansion	OSHPD 1-In Service	5			4	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-05583	Dietary Addition	OSHPD 1-In Service	5			4	
54 - Tulare	12601	Kaweah Health Medical Center	Visalia	BLD-06048	Emergency Department Addition	OSHPD 1-In Service	5			5s	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	Visalia	BLD-03749	Original Building - Part 1	OSHPD 1-In Service	5			2	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	Visalia	BLD-03750	Original Building - Part 3	OSHPD 1-In Service	5			2	
54 - Tulare	18179	Kaweah Health Medical Center D/P SNF	Visalia	BLD-03751	Original Building - Part 2	OSHPD 1-In Service	5			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00556	Original Building	OSHPD 1-In Service	2	0.01		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00557	Radiology Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00558	Emergency Addition #1	OSHPD 1-In Service	4			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00560	3 Story Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00561	4 Story Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00562	Emergency Addition #2	OSHPD 1-In Service	5			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-00563	Administration Addition #2	OSHPD 1-In Service	5			4	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-02696	Laboratory Addition	OSHPD 1-In Service	4			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-02697	Service Building	OSHPD 1-In Service	5			2	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-03239	Central Utility Plant	OSHPD 1-In Service	5			4	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-05569	Emergency Department Electrical Room Addition	OSHPD 1-In Service	5			4	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-06706	CT Building	OSHPD 1-In Service	3			3	
54 - Tulare	11140	Sierra View Medical Center	Porterville	BLD-06707	Cath Lab	OSHPD 1-In Service	5			4	
55 - Tuolumne	11151	Adventist Health Sonora	Sonora	BLD-03833	OB Unit 9	OSHPD 1-In Service	2	0		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
55 - Tuolumne	18163	Adventist Health Sonora	Sonora	BLD-05178	Main Building	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
55 - Tuolumne	18163	Adventist Health Sonora	Sonora	BLD-06910	O.R. – Admin. Addition	OSHPD 1-In Service	5			4	
55 - Tuolumne	18163	Adventist Health Sonora	Sonora	BLD-07654	Canopy	OSHPD 1-Proposed	5s			4s	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01246	Original Building	OSHPD 1-In Service	2		1.14	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01249	Main Hospital Building	OSHPD 1-In Service	3			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-01253	New Bridge/Elevator & Med. Gas Enclosure	OSHPD 1-In Service	4s			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-03335	North and South Patient Care Tower	OSHPD 1-In Service	5			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05217	Patient Care Tower Entrance	OSHPD 1-In Service	5			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05679	ED / Surgery Addition	OSHPD 1-In Service	5			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-05680	ED / Surgery Addition Entrance	OSHPD 1-In Service	5			4	
56 - Ventura	11177	Adventist Health Simi Valley	Simi Valley	BLD-07115	Central Utility Plant	OSHPD 1-Proposed	5s			5s	
56 - Ventura	11169	Community Memorial Hospital - Ojai	Ojai	BLD-00606	Hospital Building	OSHPD 1-In Service	2	0.14		3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11169	Community Memorial Hospital - Ojai	Ojai	BLD-02994	Nursing Wing	OSHPD 1-In Service	4			3	
56 - Ventura	11169	Community Memorial Hospital - Ojai	Ojai	BLD-02995	Laboratory Addition	OSHPD 1-In Service	4			3	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03167	New Ambulance Entry	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03168	New 6 Story Hospital Tower - West	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03169	New 6 Story Hospital Tower - East	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-03170	New 2 Story Hospital Tower	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05528	New ER Canopy	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05529	New Main Entry Canopy	OSHPD 1-In Service	5s			4s	
56 - Ventura	11159	Community Memorial Hospital - San Buenaventura	Ventura	BLD-05530	New 1 Story Pedestrian Walkway	OSHPD 1-In Service	5s			4s	
56 - Ventura	10040	Harvest Medical Complex	Santa Paula	BLD-06934	Hospital	OSHPD 1-Proposed	5s			5s	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00601	North Wing / Central Core	OSHPD 1-In Service	2	2.5	2.5	2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00602	South Wing	OSHPD 1-In Service	2	2.38		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00603	West Wing	OSHPD 1-In Service	3			2	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00604	New South Wing	OSHPD 1-In Service	3			2	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-00605	Emergency Generator Shed	OSHPD 1-In Service	4			4	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-02950	Emergency Department Addition	OSHPD 1-In Service	5			4	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-03108	ICU/CCU	OSHPD 1-In Service	5			4	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-03464	New Expansion	OSHPD 1-Under Construction	5s			4s	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-06341	Exit Discharge Area Expansion	OSHPD 1-In Service	5			4	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-06413	OR Expansion	OSHPD 1-In Service	5			4	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-07111	ED Waiting Room Expansion	OSHPD 1-Under Construction	5s			4s	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-07172	ED Entry Canopy	OSHPD 1-Under Construction	5s			4s	
56 - Ventura	11164	Los Robles Hospital & Medical Center	Thousand Oaks	BLD-07319	Dietary Expansion	OSHPD 1-Proposed	5s			5s	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02641	Building One	OSHPD 1-In Service	3s			2	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02642	Building Two - Dining/Kitchen	OSHPD 1-In Service	3s			2	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02643	Building Three	OSHPD 1-In Service	3s			2	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02644	Building Four - Gymnasium	OSHPD 1-In Service	4			2	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-02645	Building Five	OSHPD 1-In Service	3s			2	
56 - Ventura	16244	Los Robles Hospital & Medical Center - East Campus	Westlake Village	BLD-06012	Outpatient Canopy	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00607	Link Building 1	OSHPD 1-In Service	3			3	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00608	Hospital Building	OSHPD 1-In Service	3			3	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-00612	Canopy and Entrance Bridge	OSHPD 1-In Service	4s			3	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02614	Patient Tower	OSHPD 1-In Service	3			3	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02615	Link Building 2	OSHPD 1-In Service	4			3	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-02616	Central Plant	OSHPD 1-In Service	4			3	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-05872	MRI Building	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06160	Angiography Operating Suite Exterior Addition	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06174	New ED Expansion & Covered Entry	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06175	New Free-Standing Covered Walkway	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-06176	New Free-Standing Covered Entry	OSHPD 1-In Service	5			4	
56 - Ventura	11172	St Johns Regional Medical Center	Oxnard	BLD-07032	Canopy #1	OSHPD 1-In Service	4s			2s	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-00209	Main Hospital	OSHPD 1-In Service	1		26.04	2	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-00210	Central Plant/ Utilities Building	OSHPD 1-In Service	3			3	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-00211	Ancillary Building	OSHPD 1-In Service	3			3	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-00212	Ambulatory Surgery Center	OSHPD 1-In Service	3s			3	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-03257	Hospital Addition	OSHPD 1-In Service	5			4	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-03258	Chapel Addition	Adjacent Building - Local Jurisdiction- No Gen Acute Care - OSHPD Bldg	N/A			N/A	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-03845	Skilled Nursing Building	OSHPD 1-In Service	3			3	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-05209	ED Addition	OSHPD 1-In Service	5			4	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-06318	SNF Connection	OSHPD 1-In Service	5			4	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-06870	Recycle Enclosure	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-06871	Water Pump Yard	OSHDP 1-In Service	5			4	
56 - Ventura	13181	St. John's Hospital Camarillo	Camarillo	BLD-06872	Dietary Canopy	OSHDP 1-In Service	5			4	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	Thousand Oaks	BLD-05186	Main Building	OSHDP 1-In Service	5s			4s	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	Thousand Oaks	BLD-07180	Entry Canopy	OSHDP 1-In Service	5s			4s	
56 - Ventura	17669	Thousand Oaks Surgical Hosp., A Campus Of Los Robles Hosp. & Medical Ctr.	Thousand Oaks	BLD-07181	Porte-Cochere	OSHDP 1-In Service	5s			4s	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00594	Main Hospital Building - Bldg 305	OSHDP 1-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00595	Fainer Wing - Building 304	OSHDP 1-In Service	4			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00596	Administration Building - Bldg 306	OSHDP 1-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-00597	Mental Health Center - Building 399	OSHDP 1-In Service	5			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03341	Electrical Services Building 400	OSHDP 1-In Service	5			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03640	Administration Bldg Addition - #306	OSHDP 1-No Gen Acute Care - OSHPD Bldg	N/A			N/A	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-03641	Medical Lab / Kitchen - Bldg 401	OSHDP 1-In Service	5			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05572	Cafeteria Building - Building 403	OSHDP 1-In Service	2			4D-L1	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05660	Med Gas Enclosure - Building 307	OSHDP 1-Equipment Yard	N/A			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05661	Fainer Wing Cooling Tower Enclosure - Building 308	OSHDP 1-Equipment Yard	N/A			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05707	Hospital Replacement Wing	OSHDP 1-In Service	5			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-05729	Interim LOX Tank	OSHDP 1-Equipment Yard	N/A			4	
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-06225	Hospital Porte Cochere	OSHDP 1-In Service	4			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
56 - Ventura	11162	Ventura County Medical Center	Ventura	BLD-06227	Ambulance and ED Porte Cochere	OSHDP 1-In Service	4			4	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01241	Main Building / East & North Addition	OSHDP 1-In Service	2		0.91	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01242	East Addition - Structurally connected to BLD-01241	OSHDP 1-Not an Independent Building	N/A			N/A	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01243	North Addition - Structurally connected to BLD-01241	OSHDP 1-Not an Independent Building	N/A			N/A	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01244	E.R. Addition	OSHDP 1-In Service	5			3R	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-01245	Storage Building & Storage Addition	OSHDP 1-In Service	4			3	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02647	Generator Building	OSHDP 1-In Service	5			4	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02648	I.C.U. Addition	OSHDP 1-In Service	2		0.91	3R	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02724	Storage Addition - Structurally connected to BLD-01245	OSHDP 1-Not an Independent Building	N/A			N/A	
56 - Ventura	11175	Ventura County Medical Center - Santa Paula Hospital	Santa Paula	BLD-02929	Infectious Waste Sterilizer Bldg	OSHDP 1-In Service	5			3	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-01256	Main Hospital Building	OSHDP 1-In Service	4			2	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-01257	Central Plant	OSHDP 1-In Service	4			4	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-06114	Post Anesthesia Recovery Expansion	OSHDP 1-In Service	5			4	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-06528	Birth Department Expansion	OSHDP 1-In Service	5			4	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-06529	Emergency Department Expansion	OSHDP 1-In Service	5			4	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-06530	Ambulance Canopy	OSHDP 1-In Service	5			4	
57 - Yolo	17725	Sutter Davis Hospital	Davis	BLD-07307	MRI Canopy	OSHDP 1-In Service	5			4	
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01258	Building A	OSHDP 1-In Service	2	0.1		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice	
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01259	Building B	OSHPD 1-In Service	2	0.09		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01260	Building C	OSHPD 1-In Service	2	0.05		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01261	Building D	OSHPD 1-In Service	2	0.03		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01262	Building E, Ancillary Wing	OSHPD 1-In Service	4			2		
57 - Yolo	11198	Woodland Memorial Hospital	Woodland	BLD-01263	Lobby	OSHPD 1-In Service	4			2		
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01264	Patient Tower/Cath Lab/4th Floor	OSHPD 1-In Service	4			2		
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01265	Patient Tower Cath Lab - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A				N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01266	Patient Tower 4th Floor Buildout - Structurally connected to BLD-01264	OSHPD 1-Not an Independent Building	N/A				N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01267	Central Plant (1960 & 1988)	OSHPD 1-In Service	2	0.34		2	This building does not significantly jeopardize life, but may not be repairable or functional following an earthquake.	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01268	Central Plant CP-1 ('92 '98 & 2000)	OSHPD 1-In Service	4			2		
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01269	Central Plant CP-1 1998 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A				N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01270	Central Plant (1988) - Structurally connected to BLD-01267	OSHPD 1-Not an Independent Building	N/A				N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01271	Central Plant CP-1 2000 Addition - Structurally connected to BLD-01268	OSHPD 1-Not an Independent Building	N/A				N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01272	East Wing (1978)	OSHPD 1-In Service	4			2		

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail

SPC/NPC Ratings of Acute Care Hospital Buildings as of 3/4/2026

County Code	Facility Nbr	Facility Name	City	Building Nbr	Building Name	Building Status	SPC Rating *	2007 Hazus Score (%)	2010 Hazus Score (%)	HCAI NPC Rating *	AB 1882 Notice
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01273	West Wing (1960)	OSHPD 1R-No Gen Acute Care - OSHPD Bldg	N/A	2.56		N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01276	North Wing N-1 1980 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A			N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-01277	North Wing N-1 1986 Addition - Structurally connected to BLD-01275	OSHPD 1-Not an Independent Building	N/A			N/A	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-02785	New Patient Tower	OSHPD 1-In Service	5			4	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-03769	Registration Building	OSHPD 1-In Service	4			4	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-07207	North Entry Canopy	OSHPD 1-In Service	5			4	
58 - Yuba	11205	Adventist Health And Rideout	Marysville	BLD-07208	South Entry Canopy	OSHPD 1-In Service	5			4	

* 2s, 3s, 4s and 5s indicate SPC/NPC rating self-reported by the hospital and not verified by OSHPD

* 1s is a temporary rating assigned to seismically separate buildings created by retrofits

IND = HAZUS score cannot be determined as building is located on a fault and is equivalent to a HAZUS fail