

HEALTH FACILITY CHECKLIST

SECTION 1226 [OSHPD 3] CLINICS

1226.6 PRIMARY CARE CLINICS

Primary Care Clinics are Health Facilities licensed under Section 1200 of the California Health & Safety Code that provide services limited to those listed in California Building Code Section 1226.6. Outpatient clinical services of a hospital providing services, licensed under Section 1250 of the California Health & Safety Code, which are equivalent to a primary care clinic, shall also comply with California Building Code Section 1226.6 and be considered a primary care clinic. Primary care clinics are subject to the provisions of Section 1226 [OSHPD 3] CLINICS, of the California Building Code and all amendments to the California Building Standards Code (CBSC) under the banner [OSHPD 3]. OSHPD requirements apply to all facilities described above and are not dependent upon Occupancy Group designations.

While Examination Rooms are required in Primary Care Clinics, the provision of Treatment Rooms is optional and dependent upon the intended delivery of care. Examination Rooms are intended for diagnostic examinations, where Treatment Rooms are intended for clinical/interventional procedures and include appropriate size and finish requirements to accommodate treatment/procedures that do not require a restricted (sterile) environment but may use sterile instruments or equipment.

All new buildings and additions, alterations or repairs to existing buildings, and conversion of space to a clinic use within existing buildings, subject to Licensing and Certification, California Department of Public Health, shall comply with applicable provisions of the California Building Code (CBC), California Electrical Code (CEC), California Mechanical Code (CMC), California Plumbing Code (CPC), California Energy Code, California Green Building Standards Code and California Fire Code (Parts 2, 3, 4, 5, 6, 9, and 11 of Title 24). The enforcing agency for primary care clinics is the **local building department**. Note: Existing clinic facilities that have architectural conditions, such as room size or corridor width, that fail to meet the requirements of OSHPD-3 but were compliant at the time of their construction may be considered acceptable. Existing underground piping may remain as is if in serviceable condition.

EFFECTIVE USE OF THE CHECKLIST

The following checklist is intended to be used in the plan review of applications for health care facilities located in California. The checklist summarizes and references the applicable requirements from the Office of Statewide Health Planning and Development (OSHPD) as adopted and amended to the California Building Standards Code. Applicants should verify compliance of the plans submitted for building permit with all referenced requirements from OSHPD when completing this checklist. The checklist should be completed by the project architect or engineer based on the design actually reflected in the plans at the time of completion of the checklist.

This checklist only references OSHPD requirements associated with primary care clinics. Please note that other jurisdictions, regulations and codes have additional requirements which are not included in this checklist, such as: other applicable provisions of the CBSC and amendments enforced by the local authority having jurisdiction; regulations enforced by the local health department; CEQA, local ordinances and conditions of approval enforced by the local planning department; requirements of the local fire department; requirements and design standards of the local public works department; and any other agency that may have jurisdictional authority over an aspect of the

project. The applicant and design professional are encouraged to exercise appropriate due diligence that would be associated with embarking on any construction project.

If a clinical space is being reused under a new tenant/owner, existing non-OSHPD-3 architectural dimensional requirements that were compliant at the time of construction may remain as-is if the use does not change. Examples of this would be exam rooms size or corridor width. If these were compliant with the building code at the time they were constructed, and the use of the room or area is not changing, an increase in size or width would not be required.

If existing ceiling heights are greater than 7'-6" and it is infeasible to raise the ceiling, it may remain as is.

With the implementation of electronic records, the requirement for a dedicated space for storage and sorting of records may be shared with other workstations that may have other functions.

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6

Primary Care Clinic

- Clinic licensed by CDPH under CH&S Section 1200 or Section 1250

1226.6.1

Examination and treatment areas

1226.6.1.1

Examination rooms

1224.4.4.1.1

Space requirements

- 80 sf min clear floor area, exclusive of
- Fixed or wall-mounted cabinets, built-in shelves; and
- Alcoves with a dimension of less than 8', anterooms or vestibules
- 8' minimum clear dimension, clear of cabinets, etc.

11B-404.2.4

- *60" maneuvering clearance inside the room, perpendicular to the door
- *18" min clearance beyond latch side of the door

11B-805.4.1

- *36" wide clear space along at least one side of the exam table

11B-805.4.3

- *Clear turning space may be either:
 - 60" diameter circle; or
 - "T" shape within a 60" square w/ arms and base with 36" min width

1226.6.1.1

Required fixtures

1224.4.4.1.1

- Accommodation for written or electronic documentation
- Handwashing Station w/ following clearances:

11B-305.3

- *30" x 48" clear space centered on fixture

11B-306.2

- *9" high toe clearance under counter/fixture;
- 19" min depth;
- *29" high knee space under counter/fixture;

11B-306.3

- 8" min depth @ 29" high;
- 11" min depth @ 9" high, clearance reduction between 29" & 9" at 1:6

1224.4.11 & Table

Interior Finishes

1224.4.11

- Pin perforated, fine fissured, or lightly textured ceiling; washable walls; carpet permissible upon agency approval

1224.4.10

Ceiling height

- 8' minimum – see note in narrative
- Ceiling height shall accommodate ceiling-mounted equipment & fixtures
- * see accessibility requirements

Plumbing*:

- Handwashing fixture located in exam room, convenient for use by staff entering & leaving room 1224.14.1.6
CPC
Table 4-2
- Wrist/elbow blades are permitted 210.0 (1) a, i
- ABS & PVC drainage piping are not permitted 701.1-2(b)

Mechanical*:

- Ventilation: Neutral pressure balance at corridor CMC
Table 4-A
- Min 2 air changes/hr OSA
- Min 6 air changes/hr total
- (2) Filter banks 30% & 90% Table 4-B

Other OSHPD 3 requirements

- Space above a ceiling may not be utilized as an exhaust-air, or return-air plenum CMC
407.4.1.4
- Concealed building spaces/ independent construction within buildings may not be used as ducts or plenums
- Flexible ducts may not exceed 10 feet CMC
602.3.1
- Use of CPVC is not permitted for building water supply piping CPC 604.1
- OSHPD 3 disinfection procedures for potable water system is required CPC 609.9
- Secondary (redundant) water heater is required CPC 613.2
- Vent pipe termination 25' min from any air intake or vent shaft – 10' if previously licensed facility. CPC 906.2

Electrical*:

- General illumination: 50 fc @ 36" min CEC
517.22(A)(1)/
IESNA
CEC
- Metallic raceway or cable with metal sheath qualified as a ground conductor 517.13(A)
CEC
- Insulated copper grounding conductor 517.13(B)
CEC
- GFCI at receptacles <6' from sink 210.8(B)(5)

* Common requirements for all exam rooms

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

- 1226.6.1.2** **Treatment rooms** (when provided)
Space requirements
 - ___ 120 sf min clear floor area exclusive of
 - ___ Fixed or wall-mounted cabinets, built-in shelves; and
 - ___ Alcoves with a dimension of less than 10', anterooms or vestibules
 - ___ 10' minimum clear dimension, clear of cabinets, etc.
- 11B-404.2.4 ___ *60" maneuvering clearance inside the room, perpendicular to the door
- ___ *18" min clearance beyond latch side of the door
- 11B-805.4.1 ___ *36" wide clear space along both sides of the exam/treatment table
- 11B.805.4.3 ___ *Clear turning space may be either:
 - ___ 60" diameter circle; or
 - ___ "T" shape within a 60" square w/ arms and base with 36" min width
- 1226.6.1.2 Required fixtures
- 1224.4.4.1.2 ___ Examination light
- ___ Work Counter
- ___ Cabinets & medication storage
- ___ Handwashing Station w/ the following:
 - 11B-305.3 ___ *30" x 48" clear space centered on fixture
 - ___ *9" high toe clearance under counter/fixture;
 - 11B-306.2 ___ 19" min depth;
 - ___ *29" high knee space under counter/fixture;
 - 11B-306.3 ___ 8" min depth @ 29" high;
 - ___ 11" min depth @ 9" high, clearance reduction between 29" & 9" at 1:6
- Table 1224.4.11 Treatment Room Interior Finishes
- 1224.4.11.4.1.1 ___ Smooth and easily cleanable ceiling without perforations or fissures
- 1224.4.11.3.3 ___ Smooth washable walls able to withstand cleaning & chemicals
- 1224.4.11.1 ___ Smooth, waterproof and durable flooring; carpet prohibited
- 1224.4.10 Ceiling height
- 1224.5.2 ___ 8' minimum – see note in narrative.
- ___ Ceiling height shall accommodate ceiling-mounted equipment & fixtures
- * See accessibility requirements

- Plumbing*:
 - ___ Handwashing fixture located in treatment room 1224.14.1.6 CPC
 - ___ Wrist/elbow blades are not permitted Table 4-2 210.0 (1) a, i
 - ___ ABS & PVC drainage piping are not permitted 701.1-2(b)
- Mechanical*:
 - ___ Ventilation: Neutral pressure balance at corridor CMC Table 4-A
 - ___ Min 2 air changes/hr OSA
 - ___ Min 6 air changes/hr total
 - ___ (2) Filter banks 30% & 90% Table 4-B
- Other OSHPD 3 requirements
 - ___ Space above a ceiling may not be utilized as an exhaust-air, or return-air plenum CMC 407.4.1.4
 - ___ Concealed building spaces/ independent construction within buildings may not be used as ducts or plenums
 - ___ Flexible ducts may not exceed 10 feet CMC 602.3.1
 - ___ Use of CPVC is not permitted for building water supply piping CPC 604.1
 - ___ OSHPD 3 disinfection procedures for potable water system is required CPC 609.9
 - ___ Secondary (redundant) water heater is required CPC 613.2
 - ___ Vent pipe termination 25' min from any air intake or vent shaft – 10' if previously licensed facility. CPC 906.2
- Electrical*:
 - ___ General illumination: 50 fc@ 36" min CEC 517.22(A)(1)/ IESNA
 - ___ Metallic raceway or cable with metal sheath qualified as a ground conductor CEC 517.13(A)
 - ___ Insulated copper grounding conductor CEC 517.13(B)
 - ___ GFCI at receptacles <6' from sink CEC 210.8(B)(5)

* Common requirements for all exam rooms

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.2 Support areas for exam/treatment rms

Mechanical: CMC
 Table 4-A
 ___ Min 2 air changes/hr OSA
 ___ Min 4 air changes/hr total
 ___ (1) Filter bank 30%

- General
 1224.4.4.7.3 ___ 60" min corridor if treatment rms incl or
 ___ 44" min corridor if exam rms only
 1224.4.10 ___ 8' min ceiling height

1226.6.2.1 Administrative Center / Nurse Station

Plumbing: CPC
 Table 4-2
 ___ Handwashing fixture

- 11B-904.4 ___ Counter space
 ___ 28" min, 34" max, high work surface
 ___ 36" min wide x 34" max high assessable transaction top
 1226.4.13.1 ___ Storage space
 ___ Access to handwashing fixture
 ___ Reception/charting/communication

Lighting: IESNA
 ___ Task lighting as required

1226.6.2.2 Medication station

Plumbing: CPC
 Table 4-2
 ___ Handwashing fixture, and
 ___ Separate prep sink

- 1226.4.13.2.1 ___ Directly accessible form Nurse Sta.
 ___ Counter w/ handwashing station
 ___ Prep sink
 ___ Lockable refrigerator
 ___ Locked storage for controlled Rx

Or

Mechanical: CMC
 Table 4-A
 ___ Positive pressure
 ___ Min 2 air changes/hr OSA
 ___ Min 4 air changes/hr total
 ___ (1) Filter bank 30% Table 4-B

- 1226.4.13.2.2 ___ Self-contained dispensing unit
 ___ Located in the nurse station, **or**
 ___ Located in the clean utility room

Lighting: IESNA
 ___ Task lighting as required

Power:
 ___ Min: 1 receptacle

1226.6.2.3 Clean utility room

Plumbing: CPC
 Table 4-2
 ___ Handwashing fixture

- ___ Counter w/ handwashing station
 ___ Clean & sterile storage

Or

Mechanical: CMC
 Table 4-A
 ___ Positive pressure
 ___ Min 2 air changes/hr OSA
 ___ Min 6 air changes/hr total
 ___ Min 4 air changes if 100% OSA
 ___ (2) Filter bank 30% & 90% Table 4-B

- ___ Clean holding room

1226.6.2.4 Soiled workroom

Plumbing: CPC
 Table 4-2
 ___ Handwashing fixture
 ___ Clinical sink w/ bed-pan washing
 ___ Or utility sink

- 1226.4.13.4 ___ Counter w/ handwashing station
 ___ Flushing-rim clinical sink, or
 ___ Utility/service sink
 ___ Covered soiled linen area
 ___ Covered waste storage area

Or

Mechanical: CMC
 Table 4-A
 ___ Negative pressure
 ___ 100% exhaust
 ___ Min 2 air changes/hr OSA
 ___ Min 10 air changes/hr total
 ___ Min 4 air changes if 100% OSA Table 4-B
 ___ (1) Filter bank 30%

- ___ Soiled holding room
 ___ Covered soiled linen
 ___ Covered waste storage
 ___ Bed-pan washing at patient toilet

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.3 Support areas for patients

1226.6.3.1 Patient toilet room(s)

- Shall be provided separate from public use and be located for access from patient care areas without passing through publicly accessible areas, or
- May serve outpatient waiting rooms in clinics with a maximum of three exam &/or treatment rooms
- Each toilet room shall include the following:
 - Fully accessible water closet
 - Fully accessible lavatory
 - 7' min ceiling height
 - 5" min coved base for resilient floors

- Plumbing:
- Handwashing fixture located in patient toilet room, conventional spouts & controls acceptable, aerators are not permitted
 - Toilet may be equipped with bedpan washing device

CPC
Table 4-2

- Mechanical:
- Ventilation: 100% exhaust
 - 10 min air changes per hour

CMC
Table 4-A

- 1224.4.4.1** Doors must be equipped with hardware which will permit the door to swing outward

1226.6.3.2 Specimen and/or blood collection

- When provided:
- Space for a chair and work counter shall be provided for blood draw
 - Handwashing station is required
 - Use of the patient toilet room is permitted for specimen collection
 - Handwashing station is required
 - Lab pass-thru must be accessible

- Plumbing:
- Handwashing fixture

1226.6.4 General support services

1226.6.4.1 Garbage / medical waste / trash

- 1226.4.9.2 Lockable room or screened enclosure
- 25 sf minimum floor area
 - 4 foot minimum dimension
 - Concrete floor & curb w/ drain to sewer
 - Steam/hot water & cold water supplies

- Plumbing:
- Steam/hot water & cold water supplies

- Mechanical, if interior room:
- Ventilation: 100% exhaust
 - 10 min air changes per hour

Or

- 1226.4.9.3 Waste holding room
- 25 sf minimum floor area
 - 4 foot minimum dimension
 - Convenient access to exterior
 - 5" min coved base for resilient floors

- Mechanical:
- Ventilation: 100% exhaust
 - 10 min air changes per hour

1226.6.4.2 Housekeeping room

- 1224.4.15 Minimum floor area of 15 sf
- Service sink or
 - Floor receptor
 - Storage of supplies & housekeeping equipment

- Plumbing:
- Service sink

CPC
Table 4-2

- Mechanical:
- Negative pressure - 100% exhaust
 - 10 min air changes per hour

CMC
Table 4-A

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.5 Public and administrative areas

1226.6.5.1 Public area

1226.6.5.1.1 Reception

- 1226.4.16.1.1 Reception/information counter or desk shall be provided
 - 28" min, 34" max, high work surface
 - 36" min wide x 34" max high accessible transaction top

1226.5.1.2 Outpatient waiting room

- 1224.4.5 Provide seating area and space for wheelchairs, and have public corridor access to, or provision of:
 - Public toilet(s)
 - Separate accessible men's and women's toilet rooms, **Or**
 - Single toilet shared by both sexes if occupant load is 10 or fewer, **Or**
 - Served by patient toilet if clinic has 3 or fewer exam rooms
 - Accessible hi & low drinking fountain
- 11B.602 Telephone available to the public
 - 30"x48" clear floor space
 - Reach range per 11B.308
 - 29" min cord length
 - Volume control

1226.6.5.2 Administrative services

1226.6.5.2.1 Medical records storage

- Provide a health record service that includes:
- Accessible work area for sorting and recording paper or electronic media
 - Record storage area for paper or electronic media

1226.6.5.2.2 Equipment and supply storage

- General storage for office supplies and equipment

1226.6.6 Support areas for staff

1226.6.6.1 Staff toilet room(s) – provide as follows:

- CPC Male staff @ 1:1-15, **and**
- 422.3.1 Female staff @ 1:1-15, **Or**
- Table 4-2 Single toilet if less than 5 staff
- Separate from patients & visitors

Each toilet room shall contain:

- Handwashing fixture,
- Water closet, and
- Be fully accessible

Mechanical:

- Negative pressure
- 100% exhaust
- Min 2 air changes/hr OSA
- Min 10 air changes/hr total
- Min 10 air changes /100% OSA
- (1) Filter bank 30%

CMC
Table 4-A

Table 4-B

Plumbing:

- Handwashing fixture located in each staff toilet room, conventional spouts & controls acceptable, aerators are not permitted

CPC
Table 4-2

Mechanical:

- Ventilation: 100% exhaust
- 10 min air changes per hour

CMC
Table 4-A

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.6 Support areas for staff (continued)

1226.6.6.2 Storage for employees

- Provide storage for staff personal effects
- Locking drawers or cabinets
- Note: desk/workstation drawers or cabinets are acceptable
- Located convenient to individual workstations and shall be staff controlled

Supplemental (when provided)

1226.4.1.4 Airborne infection isolation exam room

- 1224.4.4.1.1
- Capacity – one exam table
 - Labeled “Airborne infection room”
 - Handwashing station
 - Gowning area & storage of clean and soiled materials located directly outside or inside the entry door
 - Doors – self-closing with latching devices
 - Sealed-tight to minimize air infiltration from the outside or other spaces
 - Floors
 - Perimeter walls
 - Ceilings
 - Doors
 - Penetrations
 - Seamless flooring with integral covered base
 - Smooth, easily cleanable ceiling without perforations or fissures
 - 8’ minimum ceiling height

Plumbing:	
<input type="checkbox"/> Handwashing fixture located in patient room, convenient for use by staff entering & leaving room	CPC Table 4-2
Mechanical:	
<input type="checkbox"/> Ventilation: Negative pressure	CMC
<input type="checkbox"/> 100% exhaust	Table 4-A
<input type="checkbox"/> Min 2 air changes/hr OSA	
<input type="checkbox"/> Min 12 air changes/hr total	
<input type="checkbox"/> Min 12 air changes /100% OSA	
<input type="checkbox"/> (2) Filter banks 30% & 90%	Table 4-B
Lighting:	
<input type="checkbox"/> General: 30 ft-candles @ 30” min	IESNA
<input type="checkbox"/> Task lighting	
Power:	
<input type="checkbox"/> Min of 1 receptacle at exam table	

1224.4.4.1.1.1 Airborne infection isolation exam room anteroom

- An anteroom is not required, however when provided it shall comply with the following:
- Space to don personal protective equipment before entering the patient room
- All doors shall have self-closing devices
- Provide storage of personal protective equipment (e.g. respirators, gowns, gloves) and clean equipment

Mechanical:	
<input type="checkbox"/> Ventilation: Positive pressure	CMC
<input type="checkbox"/> 100% exhaust	Table 4-A
<input type="checkbox"/> Min 2 air changes/hr OSA	
<input type="checkbox"/> Min 10 air changes/hr total	
<input type="checkbox"/> Min 10 air changes /100% OSA	
<input type="checkbox"/> (2) Filter banks 30% & 90%	Table 4-B

ADDITIONAL REQUIREMENTS FOR DENTAL SERVICES (when provided)

ARCHITECTURAL REQUIREMENTS		PLUMBING/MECHANICAL/ ELECTRICAL REQUIREMENTS	
1226.6.1	<u>Examination/Treatment area</u>		
1226.6.1.3	<u>Dental exam and treatment areas</u>		
1226.6.1.3.1	Space requirements – may be provided as a patient care station in an open treatment area	Plumbing*: ___ Handwashing fixture located in exam room, convenient for use by staff entering & leaving room	1224.14.1.6 CPC Table 4-2
	___ 80 sf min clear floor area, exclusive of Fixed or wall-mounted cabinets, built-in shelves; and	One handwashing fixture may be shared by two treatment stations in an open operatory/treatment area	1226.6.1.3.3
	___ Alcoves with a dimension of less than 8’, anterooms or vestibules	___ Wrist/elbow blades are permitted	210.0 (1) a, i
	___ 8’ minimum clear dimension, clear of cabinets, etc.	___ ABS & PVC drainage piping are not permitted	701.1-2(b)
11B-805.4.1	___ *36” wide clear space along full length of one side of the exam chair and at the head of the chair up to the cuspidor on the opposing side	Mechanical*: ___ Ventilation: Neutral pressure balance at corridor	CMC Table 4-A
1226.6.1.3.1		___ Min 2 air changes/hr OSA	
		___ Min 6 air changes/hr total	Table 4-B
11B-805.4.3	___ *Clear turning space within the room or open bay treatment area may be either: ___ 60” diameter circle; or ___ “T” shape within a 60” square w/ arms and base with 36” min width	___ (2) Filter banks 30% & 90%	
	Required fixtures	Other OSHPD 3 requirements	CMC
1226.6.1.1	___ Accommodation for written or electronic documentation	___ Space above a ceiling may not be utilized as an exhaust-air, or return-air plenum	407.4.1.4
1226.6.1.3.3	___ Handwashing Station - may be shared by two treatment stations in an open operatory/treatment area w/ following clearances:	___ Concealed building spaces/ independent construction within buildings may not be used as ducts or plenums	
11B-305.3	___ *30” x 48” clear space centered on fixture	___ Flexible ducts may not exceed 10 feet	CMC 602.3.1
	___ *9” high toe clearance under counter/fixture;	___ Use of CPVC is not permitted for building water supply piping	CPC 604.1
11B-306.2	___ 19” min depth;	___ OSHPD 3 disinfection procedures for potable water system is required	CPC 609.9 CPC 613.2
	___ *29” high knee space under counter/fixture;	___ Secondary (redundant) water heater is required	CPC 906.2
11B-306.3	___ 8” min depth @ 29” high;	___ Vent pipe termination 25’ min from any air intake or vent shaft - 10’ if previously licensed facility.	
	___ 11” min depth @ 9” high, clearance reduction between 29” & 9” at 1:6		
1224.4.11 & Table	___ Pin perforated, fine fissured, or lightly textured ceiling; washable walls; carpet permissible upon agency approval	Lighting*: ___ General: 30 ft-candles @ 30” min	IESNA
1224.4.11		___ Task illumination as required	
1224.4.10	Ceiling height	Power*: ___ Min of 1 receptacle at exam table	
	___ 8’ minimum - <u>see note in narrative</u>		
	___ Ceiling height shall accommodate ceiling-mounted equipment & fixtures		
	<i>* See accessibility requirements</i>		
		<i>* Common requirements for all dental exam and treatment rooms</i>	

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.1.3.2 Pediatric patients

___ At least one private consultation/
treatment room shall be provided when
pediatric patients are treated.

*See common requirements for all
exam rooms.

1226.6.1.3.4 Imaging

___ When imaging is provided the following
is required:
___ Space for a dental panoramic x-ray
system and printer; and
1226.5.5.2 ___ Shielding requirements; and
1224.18.1.1 ___ Alcove requirements

Mechanical:
___ Ventilation: Neutral pressure
balance at corridor *CMC*
Table 4-A
___ Min 2 air changes/hr OSA
___ Min 6 air changes/hr total
___ (2) Filter banks 30% & 90% *Table 4-B*

1226.6.1.4 Oral surgery

___ When provided, treatment areas for
procedures for which general
anesthesia is used on more than 5
patients at a time shall comply with the
requirements in Section 1226.8

Lighting:
___ General: 30 ft-candles @ 30" min *IESNA*

See requirements for Surgical Service
Space *CMC*
407.4.1.4

Support areas for dental exam rooms

1226.6.2.5 Consultation room

___ Dental facilities must provide a
consultation room for private
conferences with patients.
1224.2 ___ 70 sq. ft. minimum room with a door.
11B-306.2 ___ *60" maneuvering clearance inside
the room, perpendicular to the door
___ *18" min clearance beyond latch side
of the door
11B.306.3 ___ *Clear turning space may be either:
___ 60" diameter circle; or
___ "T" shape within a 60" square w/
arms and base with 36" min width

Mechanical:
___ Ventilation: Neutral pressure
balance at corridor *CMC*
Table 4-A
___ Min 2 air changes/hr OSA
___ Min 6 air changes/hr total
___ (2) Filter banks 30% & 90% *Table 4-B*

Lighting:
___ General: 30 ft-candles @ 30" min *IESNA*

1226.6.2.6 Sterilization facilities

___ When sterilization facilities are provided
the following is required:

1226.6.2.6.1 ___ Decontamination area:
___ Countertop (separated from clean
countertop by 4' minimum);
___ Instrument washing sink
(separated from clean area by 4'
minimum or 4' min high screen;
___ * Accessible handwashing fixture
separate from instrument sink;
___ Storage for supplies

1226.6.2.6.2 ___ Clean work area:
___ Countertop (separated from clean
countertop by 4' minimum);
___ Sterilization equipment, as
required for service provided;
___ * Accessible handwashing fixture
(may share with decontamination)
___ Storage for supplies

Mechanical - Decontamination:
___ Ventilation: Negative pressure
___ 100% exhaust *CMC*
Table 4-A
___ Min 2 air changes/hr OSA
___ Min 4 air changes/hr total
___ (2) Filter banks 30% & 90% *Table 4-B*

Mechanical – Clean work area:
___ Ventilation: Positive pressure
___ Min 2 air changes/hr OSA *CMC*
Table 4-A
___ Min 4 air changes/hr total
___ (2) Filter banks 30% & 90% *Table 4-B*

Plumbing:
___ Instrument washing sink
___ Handwashing fixture *CPC*
Table 4-2
___ Wrist/elbow blades are permitted
___ ABS & PVC drainage piping are
not permitted

Lighting:
___ General: 30 ft-candles @ 30" min *IESNA*
___ Task illumination as required

Power:
___ Min of 1 recept. at work counter

* See accessibility requirements

ARCHITECTURAL REQUIREMENTS

**PLUMBING/MECHANICAL/
ELECTRICAL REQUIREMENTS**

1226.6.2 Support areas for dental exam rooms

1226.6.2.7 Laboratory

___ Facilities for laboratory services shall be provided in dental facilities or through a contract arrangement with a laboratory service. When provided on site, the following is required:

- ___ Work area:
 - ___ Work counter;
 - ___ Laboratory sink;
 - ___ Tele/data service; and
 - ___ Electrical service

___ Handwashing Station w/ the following:

- 11B-305.3 ___ *30" x 48" clear space centered on fixture
- ___ *9" high toe clearance under counter/fixture;
- 11B-306.2 ___ 19" min depth;
- ___ *29" high knee space under counter/fixture;
- ___ 8" min depth @ 29" high;
- 11B.306.3 ___ 11" min depth @ 9" high, clearance reduction between 29" & 9" at 1:6

___ Storage for supplies

* See accessibility requirements

Plumbing:

- ___ Sink CPC
- ___ Handwashing fixture located in the laboratory, convenient for use by staff entering & leaving room Table 4-2
- ___ Wrist/elbow blades are permitted 210.0 (1) a, i
- ___ ABS & PVC drainage piping are not permitted 701.1-2(b)

Mechanical:

- ___ Ventilation: Negative pressure balance at corridor CMC
- ___ Min 2 air changes/hr OSA Table 4-A
- ___ Min 6 air changes/hr total
- ___ (2) Filter banks 30% & 90% Table 4-B

Lighting:

- ___ General: 30 ft-candles @ 30" min IESNA
- ___ Task illumination as required

Power:

- ___ Min of 1 receptacle at work counter