

DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

OFFICE USE ONLY APPLICATION FOR HCAI SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP-0152 **HCAI Special Seismic Certification Preapproval (OSP)** Type: New Renewal **Manufacturer Information** Manufacturer: IEA, LLC, an Engendren Corporation Subsidiary Manufacturer's Technical Representative: Rob Walsh Mailing Address: 9625 55th Street, Kenosha, WI 53144 Telephone: (262) 842-1414 Email: RWalsh@iearad.com **Product Information** Product Name: Emergency and Standby Power Systems Product Type: Remote Radiators Product Model Number: RCC10001S-AFC, RCC1002S-AFC, RCC1502S-AFC General Description: RCCs are stand-alone air cooling units used to cool hot turbocharger air prior to being introduced to the engine's combustion process. An RCC is used when the radiator cannot be mounted near the engine. Mounting Description: Custom Frame, Floor Mounted None Tested Seismic Enhancements: **Applicant Information** Applicant Company Name: Dynamic Certification Laboratories, LLC Contact Person: Kelly Laplace Mailing Address: 1315 Greg Street, Sparks, NV 89431

Email: kelly@shaketest.com





STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

Telephone: (775) 358-5085

Title: Business Manager

02/04/2022 OSP-0152 Page 1 of 8



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

"Hit i									
California Licensed Structural Engineer Re	esponsible for the Engineering and Test Report(s)								
Company Name: THE VMC GROUP									
Name: Kenneth Tarlow California License Number: S2851									
Mailing Address: 980 9th Street, 16th Floor, Sacra	amento, CA 95814								
Telephone: (832) 627-2214	Email: ken.tarlow@thevmcgroup.com								
Certification Method									
GR-63-Core X ICC-ES AC156	☐ IEEE 344 ☐ IEEE 693 ☐ NEBS 3								
Other (Please Specify):									
	EOR CODE CO.								
Testing Laboratory	Mp.								
Company Name: DYNAMIC CERTIFICATION LAE	BORATORY (DCL)								
Contact Person: Kelly Laplace									
Mailing Address: 1315 Greg St., Ste 109, Sparks N	NV 89431 - UT52								
Telephone: (775) 358-5085	Email: kelly@shaketest.com								
Minuses									
\C\\ DA	ATE: 02/04/2022								
	A Charles and a series and a se								



OSP-0152





02/04/2022



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

Seismic Parameters								
Design Basis of Equipment or Components (Fp/Wp) = 1.7								
SDS (Design spectral response acceleration at short period, g) = 2.26								
a _p (Amplification factor) =	2.5							
R _p (Response modification factor) =	6.0							
Ω_0 (System overstrength factor) =	2.0							
Ip (Importance factor) =	1.5							
z/h (Height ratio factor) =	1							
Natural frequencies (Hz) =	Natural frequencies (Hz) = See Attachment							
Overall dimensions and weight =	See Attachment							

HCAI Approval (For Office Use Only) - Approval Expires on 02/04/2028									
Date:	2/4/2022 OSP-0152	12							
Name:	Mohammad Karim	Title:	Supervisor, Health Facilities						
Special	Seismic Certification Valid Up to: SDS (g) = 2.26	z/h =	1						
Conditio	on of Approval (if applicable): DATE 02/04/2022								





02/04/2022 OSP-0152 Page 3 of 8

Table 1 - Special Seismic Certification

Certified Component Matrix

(()) DCL
DYNAMIC
CERTIFICATION
LABORATORIES,LLC

DCL Project No.: 77276-2101

Manufacturer: IEA Product Line: RCC

Product Construction: Steel structure with inlet and outlet pipes

Test Level: Sds = 2.26g, z/h = 1.0

Model	Dir	mensions (iı	n)	Approx.	Manufacturer	Frame Construction	Sds (g),	UUT
Model	Length	Width	Height	Weight (lb)	wanulacturer	Frame Construction	z/h=1.0	001
RCC1001-AFC ¹	30.5	26	64.9	350	IEA			Extrapolated
RCC1002S-AFC	78	22	50.7	690	IEA	Carbon steel	2.26	UUT-01
RCC1502S-AFC	66.4	36	81	1,100	IEA			UUT-02

1. RCC1001-AFC uses the same radiators as UUT-01 and the frame is of similar construction of UUT-02

BY: Mohammad Karim

DATE: 02/04/2022

Table 2 - Special Seismic Certification

Certified Subcomponent Matrix - Frame



DCL Project No.: 77276-2101

Product Line: RCC

Test Level: Sds = 2.26g, z/h = 1.0

Frame											
Model	Dimensions (in)			Approx.	Manufacturer	Construction Material	UUT				
Wiodei	Length	Width	Height	Weight (lb)	Manuacturer	Construction material	001				
Frame Assy RCC10 X2 1000KW	78.00	16.66	41.38	256	O/ IEA	Carbon steel	UUT-01				
Frame Assy RCC15 X2 2000KW	66.38	36.00	71.13	383	IEA	Carbon steer	UUT-02				

Table 3 - Special Seismic Certification

Certified Subcomponent Matrix - Housing

OSP-0152

DCL Project No.: 77276-2101

Product Line: RCC

Test Level: Sds = 2.26g, z/h = 1.0

DATE: 02/04/2022

BY: Mohammad Karim

Housing											
Model	Dimensions			Approx.	Manufacturer	Construction Material	UUT				
Wodei	Length	Width	Height	Weight (lb)	Walturacturei	Construction Material	001				
Housing RCC1001S	15.75	17.32	39.26	121	Professional Fabricators	Stainless Steel	UUT-01				
Housing Welded SS RCC15	18.88	20.32	44.00	205	Floressional Fabricators	Stairliess Steel	UUT-02				
				ADIFDIL							

Table 4 - Special Seismic Certification

Certified Subcomponent Matrix - Core

DYNAMIC CERTIFICATION LABORATORIES, LLC

DCL Project No.: 77276-2101

Product Line: RCC

Test Level: Sds = 2.26g, z/h = 1.0

Core											
Model	Dimensions			Approx.	Manufacturer	Construction Material	UUT				
Wiodei	Length	Width	Height	Weight (lb)	Manuacturer	Construction waterial	001				
Cool Sect RCC10 SX3 500 KW	15.75	14.75	22.13	48	O/ IEA	Aluminum	UUT-01				
Cool Sect RCC SX4 1.5	18.88	17.52	25.13	89	IEA	Aluminum	UUT-02				

Table 5 - Special Seismic Certification

Tested Units

OSP-0152

BY: Mohammad Karim

DCL Project No.: 77276-2101

Manufacturer: IEA
Product Line: RCC

DATE: 02/04/2022

Product Construction: Steel structure with inlet and outlet pipes

Test Level: Sds = 2.26g, z/h = 1.0

Model	Dimensions			Approx.	Manufacturer	Construction Material	шт
Wodel	Length	Width	Height	Weight (lb)	Manufacturer	Construction Material	UUT
RCC1002S-AFC	78.00	22.00	50.70	690 -	IEA	Carbon steel	UUT-01
RCC1502S-AFC	66.40	36.00	81.00	1100	IEA	Carbon Steel	UUT-02

UUT-01 UNIT UNDER TEST (UUT) Summary Sheet



DCL Project Number: 77276-2101

Manufacturer: IEA, LLC

Product Line: RCC

Model Number: RCC1002S-AFC

Product Construction Summary:

Steel structure with inlet and outlet pipes

Options / Component Summary:

Carbon steel frame, stainless steel housing, and aluminum core

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

UUT Properties												
Operating Weight	1	Dimensi	ons (inche	Lowest Natural Frequency (Hz)								
(lb)	Depth Width Height					Front-Back	Side-Side	Vertical				
690	78.04	22	22.0 0 5 0 - 0 1 50.7				9.5	>33				
	Seismic Test Parameters											
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig <mark>-H (g)</mark>	Aflx-V (g)	Arig-V (g)				
CBC 2019	ICC-ES AC1 <mark>5</mark> 6	2.26	1.0 ai	1.5	3.62	2.71	1.51	0.60				

Unit Mounting Description: Each radiator was mounted to the manufacturer-provided steel frame with twelve 3/8-inch Grade 8 bolts. The frame was mounted to the shake table using eight 1/2-inch Grade 8 bolts.



Overall view of UUT-01

UUT-02 UNIT UNDER TEST (UUT) Summary Sheet



DCL Project Number: 77276-2101

Manufacturer: IEA, LLC

Product Line: RCC

Model Number: RCC1502S-AFC

Product Construction Summary:

Steel structure with inlet and outlet pipes

Options / Component Summary:

Carbon steel frame, stainless steel housing, and aluminum core

Note: The UUT was operational before and after shaking and was full of operating content during the tests. The structural integrity of the component attachment system and force-resisting systems was maintained.

		(E)	UUT	Propertie	es	0,						
Operating Weight		Dimensi	ons (inches	Lowest Natural Frequency (Hz)								
(lb)	Depth	Wi	Width		Front-Back	Side-Side	Vertical					
1,100	66.4	36	36.0				4.7	27.4				
	Seismic Test Parameters											
Building Code	Test Criteria	Sds (g)	z/h	lp	Aflx-H (g)	Arig <mark>-H (g)</mark>	Aflx-V (g)	Arig-V (g)				
CBC 2019	ICC-ES AC156	2.26	1.0	1.5	3.62	2.71	1.51	0.60				

Unit Mounting Description: Each radiator was mounted to the manufacturer-provided steel frame with twelve 3/8-inch Grade 8 bolts. The frame was mounted to the shake table using six 5/8-inch Grade 8 bolts.



Overall view of UUT-02