

2019 Underground #2 Fuel Oil Storage for EPSS Reminder List

Applicable Codes and Standards

CBC 2019, CEC 2019, CMC 2019, CFC 2019, California Health & Safety Code
 NFPA 30 2018, NFPA 37 2015, NFPA 55 2016, NFPA 99 2018, NFPA 110 2016

I. Scope

- | | | |
|----|---|---|
| 1. | Emergency and standby power systems required by the California Building Code or the California Fire Code shall be installed in accordance with the California Building Code and NFPA 110. | CBC, Sec. 2702.1.3 |
| 2. | Prevention, control and mitigation of dangerous conditions related to storage, use, dispensing, mixing and handling of flammable and combustible liquids shall be in accordance with California Fire Code Chapter 50 and Chapter 57 and Sec. 603.3. | CFC Sec. 5701.1 & 5701.2 |
| 3. | Flammable and combustible liquids shall not be placed, stored or handled in any occupancy within the scope of California Code of Regulations, Title 19, Division 1 regulations, except as provided in the California Fire Code. | CCR, Title 19, Div. 1, §3.15 |
| 4. | Fuel oil storage and piping serving fuel oil fired heating equipment shall comply with California Fire Code Section 603.3, NFPA 31 2016 and NFPA 30 2018. | CFC Sec. 603.3 , CMC Sec. 1301.1 & CPC Sec. 1201.1 |

<u>CHK</u>	<u>N/A</u>	II. Generator Fuel Supply
-------------------	-------------------	----------------------------------

- | | | | |
|--------------------------|--------------------------|---|--|
| <input type="checkbox"/> | <input type="checkbox"/> | 1. Minimum fuel supply of 24 hrs. full-demand operation for acute care hospital. (Min 72 hrs. for NPC-5) | CEC 700-12(B)(2) Exc.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 2. Minimum fuel supply of 6 hrs. full-demand operation for SNF, Psych, ICF. | CEC 700-12(B)(2) Exc.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 3. Minimum fuel supply of 4 hrs. full-demand operation for ambulatory surgery clinics. | CEC 700-12(B)(2) Exc.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | 4. <i>Minimum fuel supply of 96 hours in seismic design category C, D, E, or F as determined in accordance with ASCE 7. This is not a CBC requirement. However, it may be required for CDPH, CMS or JCI approval.</i> | <i>NFPA 110-2010, Sec. 5.1.2</i> |
| <input type="checkbox"/> | <input type="checkbox"/> | 5. See OSHPD CAN 2-108 for temporary generator fuel supplies. | CBC, Sec. 108 |
| <input type="checkbox"/> | <input type="checkbox"/> | 6. Liquid fuel shall feed to engines by pumps only. | NFPA 37, Sec. 6.9 |
| <input type="checkbox"/> | <input type="checkbox"/> | 7. Fuel supply for exclusive use of EPSS or separate draw down. | NFPA 110, Sec. 5.5.1 & Sec. 5.5.1.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 8. Main fuel tank(s) shall be sized to accommodate 133% of the specific EPS class. | NFPA 110, Sec. 5.5.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | 9. Low-fuel sensing switch required for the main fuel supply tank(s) when less than the minimum fuel required for the specific EPS class remains in the tank(s). | NFPA 110, Sec. 5.5.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 10. Calculate full-demand generator fuel consumption. | NFPA 110, Sec. 7.9.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 11. Tanks shall be sized so that the fuel is consumed within the storage life, or provisions shall be made to remediate fuel that is stale or contaminated or to replace stale or contaminated fuel with clean fuel. | NFPA 110, Sec. 7.9.1.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | 12. Prior to being placed into service, tanks shall be tested in accordance with Section 21.5 of NFPA 30. | CFC, Sec. 5704.2.12.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 13. Low fuel annunciation at generator panel. | NFPA 110, Sec. 5.6.5.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 14. Low fuel annunciation at a remote location on-site or off-site. | NFPA 110, Sec. 5.6.6.2(1) |
| <input type="checkbox"/> | <input type="checkbox"/> | 15. Low fuel annunciation at a constantly monitored location. | NFPA 99, Sec. 6.7.1.2.15, 6.7.1.2.15.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 16. Low fuel annunciation at regular work station of operating personnel. | NFPA 99, Sec. 6.7.1.2.15, 6.7.1.2.15.2 |

CHK**N/A****III. Underground Tank Installation**

- | | | | |
|--------------------------|--------------------------|--|--|
| <input type="checkbox"/> | <input type="checkbox"/> | 1. CUPA (Certified Uniform Program Agency) review and approval required. | H & S Code, § 25280 et seq |
| <input type="checkbox"/> | <input type="checkbox"/> | 2. Located with respect to existing foundations and supports such that the loads carried by the latter cannot be transmitted to the tank. | CFC Sec. 5704.2.11.1(1) |
| <input type="checkbox"/> | <input type="checkbox"/> | 3. Tank location distance to wall of basement, pit, cellar or lot line not less than 3 ft.. | CFC Sec. 5704.2.11.1(2) |
| <input type="checkbox"/> | <input type="checkbox"/> | 4. Minimum distance of 1 ft. shell to shell between underground tanks. | CFC Sec. 5704.2.11.1(3) |
| <input type="checkbox"/> | <input type="checkbox"/> | 5. Tank, tank vent and tank filler locations in accordance with NFPA 55, Table 9.3.2. | NFPA 55, Sec. 9.3.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 6. Signs prohibiting open flames and smoking. | CFC, Sec. 5704.2.3.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 7. Set on a firm foundation and surrounded by at least 6 in. of noncorrosive inert material such as sand. | CFC Sec. 5704.2.11.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 8. Covered by 12 in. of backfill and 12 in. of clean earth or 12 in. of compacted backfill and 4" slab of reinforced concrete. | NFPA 30, Sec. 23.5.2.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 9. Where subject to traffic, at least 36 in. of backfill or 18 in. of compacted backfill and at least 6 in. of reinforced concrete or 18 in. of compacted backfill and 8 in. of asphaltic concrete. | NFPA 30, Sec. 23.5.2.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 10. When asphaltic or reinforced concrete is used for protection, it shall extend at least 12 in. beyond the tank in all directions. | NFPA 30, Sec. 23.5.2.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | 11. When the depth of cover is greater than the tank diameter or if the pressure at the bottom of the tank can exceed 10 psi, the manufacturer of the tank shall be consulted to determine if reinforcement of the tank is required. | NFPA 30, Sec. 23.5.3.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 12. Where the vertical length of the fill and vent pipes is such that when filled with liquid, the static head on the tank bottom can exceed 10 psi, the tank and its piping shall be hydrostatically tested using recognized engineering standards. | NFPA 30, Sec. 21.5.1.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 13. Fabrication & construction of tanks complies with NFPA 30. See NFPA 30, Sections 21, 22 & 23. | CFC Sec. 5704.2.7 |
| <input type="checkbox"/> | <input type="checkbox"/> | 14. Where a tank is located in an area where it is subject to buoyancy because of a rise in the water table, flooding or accumulation of water from fire suppression operations, uplift protection shall be provided in accordance with Sections 22.14 and 23.14 of NFPA 30. | CFC Sec. 5704.2.7.8 |
| <input type="checkbox"/> | <input type="checkbox"/> | 15. Fill pipes shall be equipped with a spill container and an overfill prevention system in accordance with NFPA 30. | CFC 5704.2.11.3 |
| <input type="checkbox"/> | <input type="checkbox"/> | 16. Provide an approved method of leak detection from any component of the system that is designed and installed in accordance with NFPA 30. | CFC Sec. 5704.2.11.4.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 17. Fill pipe and discharge lines shall enter only through the top of tank. | CFC Sec. 5704.2.7.5.5.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 18. Fill lines shall be sloped toward the tank. | CFC Sec. 5704.2.7.5.5.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 19. Fuel tanks supplied by pumps shall have (1) overflow line piped to source tank, (2) high level alarm and (3) high-level automatic shutoff. | NFPA 37, Sec. 6.5.4 |
| <input type="checkbox"/> | <input type="checkbox"/> | 20. Filling, emptying and vapor recovery connections shall be located outside buildings, away from sources of ignition not less than 5 ft. from building openings or lot lines of property that can be built upon & not more than 5 ft. above finished ground level.. | CFC Sec. 5704.2.7.5.2 & Sec. 5704.2.7.5.6 |
| <input type="checkbox"/> | <input type="checkbox"/> | 21. Prior to being placed in service, tanks shall be tested in accordance with NFPA 30, Sec. 21.5. An approved listing mark on tank is evidence of compliance. | CFC Sec. 5704.2.12.1 |
| <input type="checkbox"/> | <input type="checkbox"/> | 22. Before covering, tanks and connected piping shall be tested for tightness in the presence of the fire code official. | CFC Sec. 5704.2.12.2 |
| <input type="checkbox"/> | <input type="checkbox"/> | 23. Tanks and piping shall be protected by a cathodic protection system or constructed of approved or listed corrosion-resistant materials or systems. | NFPA 30, Sec. 23.3.5 |

CHK	N/A	IV. Generator Fuel Supply/Return Piping	
<input type="checkbox"/>	<input type="checkbox"/>	1. Provisions shall be made for pressure testing of piping.	CFC Sec. 5703.6.3
<input type="checkbox"/>	<input type="checkbox"/>	2. Protected from corrosion and galvanic action.	CFC Sec. 5703.6.5
<input type="checkbox"/>	<input type="checkbox"/>	3. Piping protected from damage by guard posts or other approved means.	CFC Sec. 5703.6.4
<input type="checkbox"/>	<input type="checkbox"/>	4. Supports protected by 2-hr fire rating, draining away or other approved means.	CFC Sec. 5703.6.8
<input type="checkbox"/>	<input type="checkbox"/>	5. Approved metallic or nonmetallic flex connectors permitted to protect the piping.	NFPA 37, Sec. 6.8.2.1
<input type="checkbox"/>	<input type="checkbox"/>	6. Valves shall be provided to control normal flow and shut off flow for breaks.	NFPA 37, Sec. 6.8.3
<input type="checkbox"/>	<input type="checkbox"/>	7. Fuel piping shall be of compatible metal to minimize electrolysis and be properly sized.	NFPA 110, Sec. 7.9.3
<input type="checkbox"/>	<input type="checkbox"/>	8. Galvanized fuel lines shall not be used.	NFPA 110, Sec. 7.9.3.1
<input type="checkbox"/>	<input type="checkbox"/>	9. Approved flexible fuel lines shall be used between the prime mover and the fuel piping.	NFPA 110, Sec. 7.9.3.2
<input type="checkbox"/>	<input type="checkbox"/>	10. Fuel line solenoids shall be battery powered.	NFPA 110, Sec. 7.9.9 & Sec. 5.6.3.2
<input type="checkbox"/>	<input type="checkbox"/>	11. EPS piping shall be designed to minimize damage from earthquakes.	NFPA 110, Sec. 7.11.5
<input type="checkbox"/>	<input type="checkbox"/>	12. Gravity return fuel lines between the day tank and main supply tank shall flow freely to the main tank.	NFPA 110, Sec. 7.9.4.2
<input type="checkbox"/>	<input type="checkbox"/>	13. Gravity feed to generator not permitted.	NFPA 37, Sec. 6.9
<input type="checkbox"/>	<input type="checkbox"/>	14. Spill control, drainage control & secondary containment not required for piping connected to systems. See ANSI/ASME B31.3	CFC Sec. 5703.6.2
<input type="checkbox"/>	<input type="checkbox"/>	15. Listed flexible joints required on underground liquid, vapor and vent piping at tank connections, connections at vent risers and where differential movement can occur.	CFC Sec. 5703.6.9
<input type="checkbox"/>	<input type="checkbox"/>	16. Listed flexible joints are not required for fiberglass-reinforced piping ≤ 4 in. in dia. and piping has a straight run of not less than 4 ft. on one side of a connection changing direction. The installation of nonmetallic piping shall be in accordance with the manufacturer's instructions.	CFC Sec. 5703.6.9.1

CHK	N/A	V. Underground Tank Venting	
<input type="checkbox"/>	<input type="checkbox"/>	1. Vent for normal venting shall vent to exterior not less than 12 ft. above grade level..	CFC Sec. 5704.2.7.3.3
<input type="checkbox"/>	<input type="checkbox"/>	2. Vent pipes shall terminate at least 5 ft from building openings, lot lines from property that can be built upon and at least 15 ft from powered ventilation air intake devices.	CFC Sec. 5704.2.7.3.3 & NFPA 30, Sec. 27.8.2.2
<input type="checkbox"/>	<input type="checkbox"/>	3. Vent pipe outlets shall be located and directed vertically or horizontally so that vapors will not accumulate or travel to an unsafe location, enter building openings, or be trapped under eaves or other obstructions.	CFC Sec. 5704.2.7.3.3 & NFPA 30, Sec. 27.8.2.2
<input type="checkbox"/>	<input type="checkbox"/>	4. Vent pipes and vapor return piping shall be installed without sags or traps in which liquid can collect. Vent piping shall drain back to tank.	CFC Sec. 5704.2.7.3.4 & NFPA 30, Sec. 27.8.2.9
<input type="checkbox"/>	<input type="checkbox"/>	5. Vent outlets and devices shall be protected to minimize the possibility of blockage from weather, dirt, or insect nests.	NFPA 30, Sec. 27.8.2.4
<input type="checkbox"/>	<input type="checkbox"/>	6. Vent piping shall not be manifolded unless otherwise required. When vent piping is manifolded, piping shall be sized to prevent excessive pressure when tanks are filled simultaneously.	CFC Sec. 5704.2.7.3.5 & NFPA 30, Sec. 27.8.2.12
<input type="checkbox"/>	<input type="checkbox"/>	7. Vent pipes shall be permitted to be fitted with return bends, coarse screens, or other devices to minimize ingress of foreign material.	NFPA 30, Sec. 27.8.2.78
<input type="checkbox"/>	<input type="checkbox"/>	8. Vent piping protected from physical damage by guard posts or other approved means.	CFC Sec. 5703.6.4
<input type="checkbox"/>	<input type="checkbox"/>	9. Normal vent piping shall not be used for any other purpose.	CFC Sec. 5704.2.7.3.1
<input type="checkbox"/>	<input type="checkbox"/>	10. The tank end of the vent pipe shall enter the tank through the top.	NFPA 30, Sec. 27.8.2.11

NOTE

Compliance with all items on this list does not necessarily assure compliance with all provisions of the applicable codes and standards. This reminder list should be used only by persons with a comprehensive knowledge of the applicable codes and standards.

OSHDP Policy Intent Notices and Code Application Notices.

<https://oshpd.ca.gov/construction-finance/codes-and-regulations/#cans-pins-faqs>

OSHDP Project Review Status

<https://esp.oshpd.ca.gov/CitizenAccess/>

OSHDP Public Use Forms

<https://oshpd.ca.gov/construction-finance/resources/forms-applications-reminder-lists/#ProjectForms>